

ORDINANCE NO. 303

AN ORDINANCE SETTING STANDARDS OF INSTALLATION OF FIRE HYDRANTS.

THE CITY OF BROOKINGS ORDAINS AS FOLLOWS:

Section 1:

Spacing of fire hydrants:

(A) Industrial areas: One or more fire hydrants shall be placed at each street intersection depending on the needed fire flow with an intermediate fire hydrant being placed so that the fire hydrants are no more than 300 feet apart and so located that all buildings in a complex can be reached by a comparatively short hose line from more than one fire hydrant. The above spacing shall be the same for large individual buildings of industrial, mercantile, nature, or multiple unit residential structures.

(B) For single family residential areas, there shall be a fire hydrant located at each street intersection with intermediate hydrants spaced so they are no more than 500 feet apart.


Section 2:

Fire hydrants required shall be tested and inspected prior to any framing construction being commenced on structures which may demand a high fire flow.


Section 3:

Upon the contractor's completion of all work and prior to acceptance of the fire hydrants by the City, an inspection will be required.

Passed by the Council and signed by the Mayor this 15th day of August, 1978.


MAYOR

ATTEST:


CITY RECORDER