

RESOLUTION NO. 1592

A RESOLUTION EXEMPTING SANITARY SEWER LIFT STATION PUMP ASSEMBLIES FROM THE REQUIREMENTS OF TMC 2.24.050(A) AND SPECIFYING THE USE OF "FLYGT" BRAND PUMP ASSEMBLIES IN FUTURE SANITARY SEWER LIFT STATIONS


THE TROUTDALE CITY COUNCIL FINDS AS FOLLOWS:

1. The City of Troutdale currently owns and operates eight sanitary sewer pumping stations. Currently, four of those pump stations are outfitted with "Flygt" brand pump assemblies.
2. Uniformity in pump assemblies among all of the City's sanitary sewer pump stations will allow City maintenance personnel to standardize spare parts, tools, and other materials used in the operation and maintenance of the stations.
3. Uniformity in pump assemblies among all of the City's sanitary sewer pump stations will provide for greater focus and depth of knowledge by City personnel and will minimize learning curves for future personnel in operation and maintenance of these stations.
4. Standardization of spare parts, tools and materials along with focused expertise will result in increased efficiency in maintenance and operation that will result in long term cost benefits for the City.
5. Reliability of sanitary sewer pumping equipment is paramount. It is critical that sanitary sewer facilities utilize quality equipment with a record of proven reliability.
6. Experience of City staff has shown that Flygt brand pump assemblies provide the best combination of reliability, performance and value in the sanitary sewer pumping applications needed by the City.
7. Flygt brand pump assemblies are highly regarded for quality and value within the sanitary sewer operations industry at large.
8. Flygt is locally represented with spare parts and maintenance technicians readily available in the Portland metropolitan area.

NOW THEREFORE BE IT RESOLVED BY THE COUNCIL OF THE CITY OF TROUTDALE

That all future contracts for the construction, reconstruction, upgrade, or rehabilitation of sanitary sewer pump stations which include the installation or replacement of pump assemblies will specify the use of Flygt brand pump assemblies.

YEAS: 6
NAYS: 0
ABSTAINED: 0


Paul Thalhofer, Mayor
Dated: 4-11-02


Debbie Stickney, City Recorder

Adopted: April 9, 2002