

555 CHETCO

REQUEST FOR INSPECTION
Brookings Building Department 41-13-5CB

Date 8/25/95 Time _____

Type of Inspection Final

Time Desired Wed Aug 23

Owner Don Kirk
Contractor _____

Project Address 5³⁷~~50~~ Chetco

Remarks Temporary Occupancy

Valid for no more than 30 days

INSPECTOR'S REPORT

Approved
 Not Approved

Date 8/25/95

Remarks Temporary Occupancy

Need: Handrail on all stairs
with 2 risers or more. Windows
on west end replace with wire
glass assembly

By Ray Alexander