


**8/13/1973**

**OREGON  
ENVIRONMENTAL QUALITY  
COMMISSION MEETING  
MATERIALS**




**State of Oregon  
Department of  
Environmental  
Quality**

This file is digitized in **black and white** using Optical Character Recognition (OCR) in a standard PDF format.

Standard PDF Creates PDF files to be printed to desktop printers or digital copiers, published on a CD, or sent to client as publishing proof. This set of options uses compression and downsampling to keep the file size down. However, it also embeds subsets of all (allowed) fonts used in the file, converts all colors to sRGB, and prints to a medium resolution. Window font subsets are not embedded by default. PDF files created with this settings file can be opened in Acrobat and Reader versions 6.0 and later.

NOTE FOR THE FILE: This was the only agenda item for the meeting.

The meeting was a public hearing on PGE's Harborton facility, and this was brought to the Commission as a special item because of the urgency of the matter.



## ENVIRONMENTAL QUALITY COMMISSION

1234 S.W. MORRISON STREET • PORTLAND, ORE. 97205 • Telephone (503) 229-5696

TOM McCALL  
GOVERNOR

B. A. McPHILLIPS  
Chairman, McMinnville

GRACE S. PHINNEY  
Corvallis

PAUL E. BRAGDON  
Portland

MORRIS K. CROTHERS  
Salem

ARNOLD M. COGAN  
Portland

DIARMUID F. O'SCANNLAIN  
Director

### MEMORANDUM

To: Environmental Quality Commission  
From: Director  
Subject: Unified Sewerage Agency of Washington County  
Allocation of Connections

The Department has evaluated the proposal submitted by the Unified Sewerage Agency and concludes that the proposed program is a reasonable alternative to the monthly quota system originally proposed by the Department in Medford on July 26, 1973. The USA proposal will permit allocation of 2/3 of the remaining treatment plant capacity during the next year. Allocation of connections beyond that point will be subject to reevaluation of remaining plant capacity.

### Director's Recommendations

It is recommended that connection quotas be established as follows for the period ending August 1, 1974:

	<u>Single family unit equivalents</u> <u>not to exceed:</u>
Aloha Plant	1,200
Metzger Plant	600
Tigard Plant	200
Sherwood Plant	100 Until irrigation farm is complete

Commitment of connections within these quotas shall be subject to the following conditions:

1. If any treatment plant fails to perform in compliance with permit limits, commitment of additional connections to such plant may be terminated until compliance is restored.

2. In addition to monthly plant performance monitoring reports required by permit conditions, a report shall be submitted at the end of each calendar month containing the following information for each plant:

Number of single family unit equivalents served.

Number of SFU equivalents committed during the month including a listing identifying individual commitments.

Total number of SFU equivalents committed but not yet served.

It is further recommended that the Department be authorized to establish and implement quotas for the Tualatin and King City plants to insure that such plants do not become overloaded and continue to perform in compliance with permit limits.



DIARMUID F. O'SCANNLAIN

HLS:ak

August 9, 1973