


NOTE: DIRECT TAP MAY BE MADE TO ALL SIZES OF DUCTILE IRON MAIN FOR 1" SERVICES. ALL OTHER SERVICE CONNECTIONS SHALL BE MADE USING A SERVICE SADDLE AT THE MAIN. TRAFFIC RATED METER BOX AND COVER REQUIRED IN AREAS SUBJECT TO VEHICLE TRAFFIC.



## LAKE GROVE WATER DISTRICT WATER SYSTEM STANDARDS

MAY, 2019

## 1"Ø MINIMUM SERVICE CONNECTION

LG 4