



- NOTES:**
1. REDUCED PRESSURE BACKFLOW ASSEMBLY SHALL BE INSTALLED IN A LOCATION APPROVED BY THE DISTRICT
 2. REDUCED PRESSURE BACKFLOW ASSEMBLY SHALL BE INSTALLED HORIZONTAL AND PLUMB.
 3. ALL CLEARANCES APPLY TO OUTSIDE, IN-BUILDING, AND VAULT INSTALLATIONS.
 4. TO BE INSULATED AND/OR HAVE A HEAT SOURCE TO KEEP ENCLOSURE AT 40°F (NFPA 13-4-5.4.1.1).
 5. ENCLOSURE SHALL INCLUDE A BORE SIGHTED DRAIN TO DAYLIGHT CAPABLE OF DRAINING A FULL RELIEF VALVE DISCHARGE SEE DETAIL 557.
 6. 4" 3/4"-0" COMPACTED GRAVEL LEVELING COURSE
 7. A BILCO DOOR OR OTHER APPROVED ACCESS SHALL BE PROVIDED.
 8. ALL ASSEMBLIES 2 1/2" AND LARGER SHALL BE FLANGED
 9. ALL STRUCTURES TO COMPLY WITH LOCAL BUILDING CODES.
 10. OPENINGS IN BOTTOM OF VAULT TO BE PRE-FORMED KNOCKOUTS
 11. DETECTOR METER TO READ IN CUBIC FEET