



UTILITY VAULT 675-WA-730 WITH SYRACUSE CHD-11AL OR BILCO JD-3AL DOOR AND A LADDER MEETING OSHA REQUIREMENTS. EXTERIOR TO BE SEALED WITH CRYSTAL SEAL OR APPROVED EQUAL. PROVIDE DRAINAGE VIA GRAVITY OR PUMP.

- ① 4" DUCTILE IRON BYPASS
- ② 4"x4" TEE
- ③ 4" GATE VALVE
- ④ 4" SENSOR SINGLE REGISTER COMPOUND METER