

ADDENDUM NO. 1
TO THE CONTRACT DOCUMENTS
for the construction of
WATER PIPELINE MATERIALS AND APPURTENANCES
FOR THE DOG RIVER PIPELINE REPLACEMENT PROJECT
(Contract No. 2022-002)

Date: January 18, 2022
Project No.: D3504800

To All Planholders and/or Prospective Bidders:

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for the construction of the Water Pipeline Materials and Appurtenances for the Dog River Pipeline Replacement Project dated January 2022 as fully and completely as if the same were fully set forth therein:

A. PART 2, CONTRACTING REQUIREMENTS

1. Section 00 52 63, Agreement Form. Page 3, Paragraph 5.2.2. **DELETE** the following text:

“(or within a period 15 days prior to)”.

B. PART 3, SPECIFICATIONS

1. Section 33 05 01.10, High-Density Polyethylene (HDPE) Pressure Pipe and Fittings. Page 4, Article 2.01 Materials, Paragraph A. Pipe and Fittings, Subparagraph 8. **DELETE** in its entirety and **REPLACE** with the following:

“8. Pipe Segment Length:
a. Minimum 50 feet.
b. Maximum 55 feet.”

All Bidders shall acknowledge receipt and acceptance of this Addendum No. 1 in the Bid Form or by submitting the Addendum with the bid package. Bid Forms submitted without acknowledgment or without this Addendum will be considered in nonconformance.

Jacobs



Brady Fuller, Project Manager

Appended hereto and NOT part of Addendum No. 1:

- A. Bidder Questions and Buyer Answers as of
January 18, 2022

END OF ADDENDUM

WATER PIPELINE MATERIALS AND APPURTENANCES
 FOR THE DOG RIVER PIPELINE REPLACEMENT PROJECT
 (Contract No. 2022-002)

Bidder Questions and Buyer Answers as of January 18, 2022.

No.	Bidder Question	Buyer Answer
1	Order Cancellation, as opposed to the contract language in Article 11, 11.01 on page 17, would the buyer be willing to sign the required non-cancellable PO required from the manufacturer?	No.
2	Part 2 Contract forms, Section 5. Contract Times 5.2.1.1 "Seller to Submit shop drawings and samples" What samples would be required to have approved?	Samples, (if any) are specified in the Specifications. No samples are anticipated in this Contract.
3	Part 2 Contract forms, Section 5. Contract Times 5.2.2 "Date for Delivery of goods" The term "delivered by" is used in each milestone date. Can the seller assume that we can deliver before any of those dates? What is the earliest you would expect pipe for delivery? I see the maximum number of loads in 1 day is 6. Is there any possibility of increasing that?	See Addendum 1, which modifies the delivery timing. Intent is to allow delivery as soon as possible from Supplier. Regarding maximum number of loads per day, no changes to Specification are anticipated due to limits on Buyer's ability to unload.
4	Would 53' pieces of the 30" pipe be Ok as opposed to the 50' as stated in the documents.	See Addendum 1, which modifies allowable pipe segment length.
5	The option for fittings is much better in IPS sizes is there an option to change this project from DIPS to IPS?	No. Ductile Iron Pipe Size (DIPS) fittings and DIPS pipe are specified due to project hydraulic design criteria.
6		
7		
8		
9		

