



PUBLIC HEALTH DIVISION
Drinking Water Services

Kate Brown, Governor

Oregon
Health
Authority

800 NE Oregon Street, #640
Portland, OR 97232-2162
Phone: 971-673-0191
Fax: 971-673-0694
www.healthoregon.org/DWP

March 17, 2016

Jennifer Cline
Public Works Director
City of Molalla
117 N Molalla Avenue
Molalla, OR 97038

Re: **Molalla Avenue Improvements (PR#29-2016)**
City of Molalla (PWS ID#00534)
Conditional Approval

Dear Jennifer:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Molalla Avenue Waterline Improvements for City of Molalla. On February 29, 2016, our office received a set of plans and specifications as well as a plan review fee of \$3,300.

The project includes installation of 10" PVC waterline along S. Molalla Avenue as well as assorted appurtenances.

The plans are approved with the following conditions:

- Distribution piping must be carefully bedded, fully supported in material free from rocks.
- The distance between tracer lead access locations must not be more than 1,000 feet.
- Disinfection of the waterline should be completed according to AWWA C651.
- Any sewer and water line crossings must conform to OAR 333-061-0050(9)(b). Note that any zone conflicts represented in Figure 1 in that rule other than zone 1 conflicts must be approved by OHA/DWS.

Until we receive verification that the conditions have been met and final approval has been issued, the project is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted

plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #29-2016 and can be emailed to me at Carrie.L.Gentry@state.or.us or mailed to:

Attn: Carrie Gentry
OHA-Oregon Drinking Water Services
PO Box 14450
Portland, OR 97293-0450

If you have any questions, please feel free to call me at (971) 673-0191.

Sincerely,



Carrie Gentry, PE
Regional Engineer
Drinking Water Services

cc: ✓ Pete Farrelly, PE, OHA/DWS
Daphne Marcyan, PE, Murray, Smith & Associates, Inc.