



# **Metals Emissions Test Report**

---

PCC Structurals, Inc.  
Large Parts Campus  
Baghouse 9203  
5001 SE Johnson Creek Blvd.  
Milwaukie, Oregon 97222  
Project No. M232604B Rev.1  
June 27 and 30, 2023



## Metals Emissions Test Report

PCC Structurals, Inc.  
Large Parts Campus  
Baghouse 9203  
**5001 SE Johnson Creek Blvd.**  
Milwaukie, Oregon 97222  
June 27 and 30, 2023

**Report Submittal Date**  
September 29, 2023  
**Report Resubmittal Date**  
December 20, 2023

© Copyright 2023  
All rights reserved in  
Mostardi Platt

**Project No. M232604B Rev.1**

---

## TABLE OF CONTENTS

1.0 EXECUTIVE SUMMARY .....	1
2.0 PROCESS DESCRIPTION .....	2
2.1 Project Contact Information .....	2
3.0 OVERVIEW OF TEST RESULTS .....	2
3.1 9203 Baghouse System Run 1 .....	3
3.2 9203 Baghouse System Run 1 .....	4
3.3 9203 Baghouse System Run 2 .....	5
3.4 9203 Baghouse System Run 2 .....	6
4.0 TEST METHODOLOGY .....	7
4.1 Method 1 Sample and Velocity Traverse Determination .....	7
4.2 Method 2 Volumetric Flow Rate Determination .....	7
4.3 Method 29 Metals Determination .....	7
4.4 Method 0061 Cr <sup>+6</sup> Determination .....	8
5.0 TEST RESULT SUMMARIES .....	9
5.1 Baghouse Inlet Method 29 Summaries .....	9
5.1.1 Inlet West Method 29 Summaries .....	9
5.1.2 Inlet Center Method 29 Summaries .....	12
5.1.3 Inlet East Method 29 Summaries .....	15
5.2 Baghouse Inlet Method 0061 Summaries .....	18
5.2.1 Inlet West Method 0061 Summary .....	18
5.2.2 Inlet Center Method 0061 Summary .....	19
5.2.3 Inlet East Method 0061 Summary .....	20
5.3 Baghouse Outlet Method 29 Summaries .....	21
5.3.1 Outlet West Method 29 Summaries .....	21
5.3.2 Outlet East Method 29 Summaries .....	24
5.4 Baghouse Outlet Method 0061 Summaries .....	27
5.4.1 Outlet West Method 0061 Summary .....	27
5.4.2 Outlet East Method 0061 Summary .....	28
5.5 Baghouse Outlet Volumetric Flow Rate Summaries .....	29
6.0 CERTIFICATION.....	30
APPENDICES	
Appendix A - Test Section Diagrams .....	32
Appendix B - Sample Train Diagrams .....	35
Appendix C - Calculation Nomenclature and Formulas .....	39
Appendix D - Reference Method Test Data .....	47
Appendix E - Plant Operating Data .....	113
Appendix F - Field Data Sheets.....	115
Appendix G - Calibration Data.....	176
Appendix H - Laboratory Sample Analysis.....	250

## 1.0 EXECUTIVE SUMMARY

Mostardi Platt conducted an emissions test program for PCC Structural, Inc. (PCC) at their Large Parts Campus (LPC) facility located at 5001 SE Johnson Creek Blvd. in Milwaukie, Oregon. Testing was performed to demonstrate removal efficiencies across each baghouse system as well as mass emission rates of several metals, including hexavalent chrome ( $\text{Cr}^{+6}$ ), from the baghouse inlet and HEPA exhaust outlet.

Inlet samples were collected utilizing a flexible sampling line connection between the filter and impingers and Teflon coated stainless steel nozzles were utilized.

Any references in the field data sheets and lab results to "north" test locations correlate to "west" test locations, while references to "south" test locations correlate to "east" test locations.

The test locations, test dates, and test parameters are summarized below.

TEST INFORMATION		
Test Locations	Test Dates	Test Parameters
9203 Baghouse Inlet Ducts (3)		Aluminum (Al), Arsenic (As), Antimony (Sb), Barium (Ba), Beryllium (Be), Cadmium (Cd), Chromium (Cr), Cobalt (Co), Copper (Cu), Lead (Pb), Manganese (Mn), Mercury (Hg), Nickel (Ni), Phosphorus (P), Selenium (Se), Silver (Ag), Thallium (Tl), Vanadium (V), Zinc (Zn), and Hexavalent Chromium ( $\text{Cr}^{+6}$ )
9203 Baghouse Outlet Ducts (6)	June 27 and 30, 2023	

## 2.0 PROCESS DESCRIPTION

Baghouse/HEPA 9203 (BH9203) controls emissions from cutting activities related to the cleaning process.

### 2.1 Project Contact Information

Location	Address	Contact
Test Consultant	Maul Foster & Alongi, Inc. 6 Centerpointe Drive, Suite 360 Lake Oswego, OR 97035	Mr. Brian Eagle Senior Consultant 971.713.3571 <a href="mailto:beagle@maulfoster.com">beagle@maulfoster.com</a>
Test Facility	PCC Structural, Inc. 5001 SE Johnson Creek Blvd. Milwaukie, OR 97222	Mr. Brandon Hadzinsky Division Environmental Affairs 503.724.3036 <a href="mailto:Brandon.hadzinsky@pccstructural.com">Brandon.hadzinsky@pccstructural.com</a>
Test Company Representative	Mostardi Platt 888 Industrial Drive Elmhurst, IL 60126	Mr. Eric Ehlers VP, Field Operations (630) 699-7690 <a href="mailto:eehlers@mp-mail.com">eehlers@mp-mail.com</a>

The test crew consisted of Messrs. C. Trezak, K. Addison, N. Colangelo, M. Sather, V. Vang, J. Meade, C. Rock, M. Dolatowski, P. Pradhan, J. Jiminez, F. Diaz, and E. Ehlers of Mostardi Platt.

Mr. Thomas Rhodes of the Oregon Department of Environmental Quality (ODEQ) observed a portion of the test program.

## 3.0 OVERVIEW OF TEST RESULTS

Selected results of the test program are summarized below. A complete summary of emission test results follows the narrative portion of this report. Operating data was provided by PCC and is found in Appendix E.

On Friday, June 30th, emissions tests on 9203 were stopped prior to the assumed end time as it was discovered that plant operations had ceased. Once this was discovered, sampling trains were shut off and post-test leak checks and recoveries were performed. Consequently, all the sample points were not sampled.

ADL means both fractions of the sample analyses were above the detection limit. DLL means that one of the fractions of the sample analyses were below the detection limit. BDL means both fractions of the sample analyses were below the detection limit.

The filters that were used for the test program had Aluminum and Phosphorus contents exceeding levels specified in Section 7.2.1 of Method 29, and as a result, the Method 29 blank corrections likely overestimate calculated emissions of these constituents. This is particularly true for aluminum - in some instances the blank correction calculated using the methodology outlined in Section 12.6.3 of Method 29 was almost 20 times lower than the Aluminum content of the filter blank. Therefore, the reported emission rates should not be considered valid.

### 3.1 9203 Baghouse System Run 1

Measured Parameter	Emission Rate Inlet East lb/hr	Emission Rate Inlet West lb/hr	Emission Rate Inlet Center lb/hr	Emission Rate Total Inlet lb/hr	Emission Rate Total Outlet East, lb/hr	Emission Rate Total Outlet West, lb/hr	Emission Rate Total Outlet lb/hr	Removal Efficiency %
Al	7.62E-03	6.73E-03	7.45E-03	2.18E-02	4.15E-03	3.69E-03	7.84E-03	64.04%
Sb	ND	ND	ND	ND	ND	ND	ND	N/A
As	≤4.20E-05 <sup>a</sup>	ND	ND	ND	ND	ND	ND	N/A
Ba	3.95E-04	1.89E-04	5.04E-04	1.088E-03	9.16E-05	3.57E-05	1.273E-04	88.33%
Be	ND	ND	ND	ND	ND	ND	ND	N/A
Cd	5.67E-05	1.50E-05	2.74E-05	9.91E-05	1.32E-05	8.07E-06	2.09E-05	78.46%
Cr	2.46E-02	8.08E-03	7.05E-03	3.98E-02	6.61E-05	1.04E-04	1.70E-04	99.57%
Co	4.08E-04	1.87E-03	1.30E-03	3.58E-03	≤4.96E-06 <sup>a</sup>	≤3.73E-06 <sup>b</sup>	≤8.69E-06 <sup>b</sup>	N/A
Cu	2.74E-03	3.03E-03	3.89E-03	9.65E-03	3.57E-04	7.52E-05	4.28E-04	95.52%
Pb	≤1.55E-05 <sup>a</sup>	≤2.78E-05 <sup>a</sup>	3.27E-05	≤7.60E-05 <sup>a</sup>	≤2.49E-05 <sup>a</sup>	≤3.48E-05 <sup>a</sup>	≤5.97E-05 <sup>a</sup>	N/A
Mn	4.71E-04	2.48E-04	1.11E-03	1.83E-03	5.23E-05	1.02E-03	1.08E-03	41.12%
Hg	≤4.29E-06 <sup>a</sup>	≤5.94E-06 <sup>a</sup>	≤4.08E-06 <sup>a</sup>	≤1.43E-05 <sup>a</sup>	≤5.12E-06 <sup>a</sup>	≤3.34E-05 <sup>a</sup>	≤3.86E-05 <sup>a</sup>	N/A
Ni	7.58E-02	5.85E-02	4.62E-02	1.80E-01	1.26E-04	6.70E-04	7.96E-04	99.56%
P	1.07E-03	1.04E-03	1.49E-03	3.60E-03	7.03E-04	6.32E-04	1.335E-03	62.92%
Se	ND	1.14E-04	ND	ND	≤9.42E-05 <sup>a</sup>	ND	ND	N/A
Ag	3.77E-05	1.75E-05	5.96E-05	1.15E-04	≤1.85E-05 <sup>b</sup>	≤1.49E-05 <sup>b</sup>	≤3.34E-05 <sup>b</sup>	N/A
Tl	ND	ND	ND	ND	ND	ND	ND	N/A
V	5.21E-05	2.52E-05	2.73E-05	1.05E-04	≤6.70E-06 <sup>a</sup>	≤4.60E-06 <sup>a</sup>	≤1.10E-05 <sup>a</sup>	N/A
Zn	1.71E-03	1.32E-03	6.26E-03	9.29E-03	≤6.36E-04 <sup>a</sup>	3.67E-04	≤1.00E-03 <sup>a</sup>	N/A
Cr <sup>+6</sup>	4.51E-04	7.00E-06	1.93E-03	2.39E-03	4.40E-05	2.20E-05	6.60E-05	97.24%

ND - Non detect. Analyte below detection limit at both the inlet and outlet

N/A – No control efficiency was calculated.

<sup>a</sup> – Value based on data qualified as DLL in the lab report

<sup>b</sup> – Analyte below detection at outlet, but measurable at inlet. Value shown is detection limit.

### 3.2 9203 Baghouse System Run 1

Measured Parameter	Emission Factor Total Inlet lb/ton metal processed	Emission Factor Total Outlet lb/ton metal processed
Al	1.97E-02	7.08E-03
Sb	ND	ND
As	ND	ND
Ba	9.84E-04	1.15E-04
Be	ND	ND
Cd	8.95E-05	1.93E-05
Cr	3.59E-02	1.54E-04
Co	5.57E-03	≤7.87E-06 <sup>b</sup>
Cu	8.72E-03	3.91E-04
Pb	≤6.87E-05 <sup>a</sup>	≤5.41E-05 <sup>a</sup>
Mn	1.65E-03	9.72E-04
Hg	≤1.29E-05 <sup>a</sup>	≤3.49E-05 <sup>a</sup>
Ni	1.63E-01	7.22E-04
P	3.26E-03	1.207E-03
Se	ND	ND
Ag	1.04E-04	≤3.02E-05 <sup>b</sup>
Tl	ND	ND
V	9.45E-05	≤1.02E-05 <sup>a</sup>
Zn	8.40E-03	≤9.10E-04 <sup>a</sup>
Cr <sup>+6</sup>	2.13E-03	5.97E-05

ND – Non detect. Analyte below detection limit at both the inlet and outlet

N/A – No control efficiency was calculated.

<sup>a</sup> – Value based on data qualified as DLL in the lab report

<sup>b</sup> – Analyte below detection at outlet, but measurable at inlet. Value shown is detection limit.

### 3.3 9203 Baghouse System Run 2

Measured Parameter	Emission Rate Inlet East lb/hr	Emission Rate Inlet West lb/hr	Emission Rate Inlet Center lb/hr	Emission Rate Total Inlet lb/hr	Emission Rate Total Outlet East, lb/hr	Emission Rate Total Outlet West, lb/hr	Emission Rate Total Outlet lb/hr	Removal Efficiency %
Al	1.17E-02	7.17E-03	8.89E-03	2.769E-02	4.15E-03	3.45E-03	7.60E-03	72.55%
Sb	≤1.69E-05 <sup>a</sup>	ND	ND	ND	≤3.62E-05 <sup>a</sup>	ND	ND	N/A
As	ND	ND	ND	ND	ND	ND	ND	N/A
Ba	1.12E-04	5.80E-05	7.90E-05	2.49E-04	≤2.70E-05 <sup>a</sup>	≤1.79E-05 <sup>a</sup>	≤4.49E-05 <sup>a</sup>	N/A
Be	ND	ND	ND	ND	ND	ND	ND	N/A
Cd	7.04E-05	5.55E-06	1.17E-05	8.76E-05	3.60E-06	4.56E-06	8.16E-06	90.69%
Cr	5.05E-02	1.21E-02	1.36E-02	7.62E-02	7.56E-04	2.68E-04	1.02E-03	98.66%
Co	5.66E-04	2.95E-03	4.44E-04	3.96E-03	3.00E-04	1.27E-04	4.27E-04	89.20%
Cu	7.04E-03	3.73E-03	7.79E-03	1.86E-02	2.18E-03	≤4.00E-05 <sup>a</sup>	≤2.22E-03 <sup>a</sup>	N/A
Pb	2.02E-05	1.76E-05	≤1.87E-05 <sup>a</sup>	≤5.65E-05 <sup>a</sup>	≤1.90E-05 <sup>a</sup>	≤1.45E-05 <sup>a</sup>	≤3.35E-05 <sup>a</sup>	N/A
Mn	2.80E-03	4.32E-04	1.28E-03	4.51E-03	2.14E-03	3.81E-04	2.53E-03	44.03%
Hg	≤5.52E-06 <sup>a</sup>	≤5.11E-06 <sup>a</sup>	≤8.56E-06 <sup>a</sup>	≤1.92E-05 <sup>a</sup>	≤1.30E-05 <sup>a</sup>	≤1.67E-05 <sup>a</sup>	≤2.98E-05 <sup>a</sup>	N/A
Ni	2.11E-01	9.47E-02	7.86E-02	3.84E-01	1.95E-03	8.87E-04	2.83E-03	99.26%
P	1.36E-03	1.08E-03	1.18E-03	3.62E-03	7.70E-04	6.05E-04	1.375E-03	70.16%
Se	ND	ND	ND	ND	≤7.29E-05 <sup>a</sup>	ND	ND	N/A
Ag	≤3.01E-05 <sup>a</sup>	1.16E-05	2.58E-05	≤6.75E-05 <sup>a</sup>	≤1.77E-05 <sup>b</sup>	≤1.41E-05 <sup>b</sup>	≤3.18E-05 <sup>b</sup>	N/A
Tl	ND	ND	ND	ND	ND	ND	ND	N/A
V	7.27E-05	2.09E-05	4.05E-05	1.34E-04	≤5.81E-06 <sup>a</sup>	≤3.98E-06 <sup>a</sup>	≤9.79E-06 <sup>a</sup>	N/A
Zn	3.06E-03	1.52E-03	1.84E-03	6.42E-03	≤5.71E-04 <sup>a</sup>	2.15E-04	≤7.86E-04 <sup>a</sup>	N/A
Cr <sup>+6</sup>	2.68E-04	3.20E-05	9.46E-04	1.24E-03	5.70E-05	9.80E-05	1.55E-04	87.50%

ND – Non detect. Analyte below detection limit at both the inlet and outlet

N/A – No control efficiency was calculated.

<sup>a</sup> – Value based on data qualified as DLL in the lab report

<sup>b</sup> – Analyte below detection at outlet, but measurable at inlet. Value shown is detection limit.

### 3.4 9203 Baghouse System Run 2

Measured Parameter	Emission Factor Total Inlet lb/ton metal processed	Emission Factor Total Outlet lb/ton metal processed
Al	2.195E-02	6.37E-03
Sb	ND	ND
As	ND	ND
Ba	1.968E-04	≤3.76E-05 <sup>b</sup>
Be	ND	ND
Cd	6.89E-05	6.83E-06
Cr	5.93E-02	8.58E-04
Co	3.16E-03	3.58E-04
Cu	1.46E-02	≤1.86E-03 <sup>a</sup>
Pb	≤4.47E-05 <sup>a</sup>	≤2.81E-05 <sup>a</sup>
Mn	3.55E-03	2.12E-03
Hg	≤1.52E-05 <sup>a</sup>	≤2.49E-05 <sup>a</sup>
Ni	3.03E-01	2.37E-03
P	2.869E-03	1.152E-03
Se	ND	ND
Ag	≤5.32E-05 <sup>a</sup>	≤2.66E-05 <sup>b</sup>
Tl	ND	ND
V	1.06E-04	≤8.20E-06 <sup>a</sup>
Zn	5.07E-03	≤6.59E-04 <sup>a</sup>
Cr <sup>+6</sup>	1.04E-03	1.30E-04

ND – Non detect. Analyte below detection limit at both the inlet and outlet

N/A – No control efficiency was calculated.

<sup>a</sup> – Value based on data qualified as DLL in the lab report

<sup>b</sup> – Analyte below detection at outlet, but measurable at inlet. Value shown is detection limit.

## 4.0 TEST METHODOLOGY

Emission testing was conducted following the United States Environmental Protection Agency (USEPA) methods specified in 40CFR60 and 40CFR63, Appendix A in addition the Mostardi Platt Quality Manual. Schematics of the test section diagrams and sampling trains used are included in Appendix A and B respectively. Calculation nomenclature are included in Appendix C. Laboratory analysis for each test run are included in Appendix H. The computerized reference method test data is included in Appendix D.

The following methodologies were used during the test program:

### 4.1 Method 1 Sample and Velocity Traverse Determination

Test measurement points were selected in accordance with Method 1, 40 CFR, Part 60, Appendix A. The characteristics of each measurement location is summarized in the table below. A null-point pitot traverse was performed prior to testing to ensure the absence of cyclonic flow.

*Sample Point Selection*

Test Location	Stack Diameter	Upstream Distance	Downstream Distance	Test Parameters	Number of Sampling Points
BH9203 Inlets (3)	36"	>0.5	>2.0	Cr <sup>+6</sup> and Metals	24
BH9203 Outlets (2)	34"	>0.5	>2.0	Cr <sup>+6</sup> and Metals	24

### 4.2 Method 2 Volumetric Flow Rate Determination

Gas velocity was measured following Method 2, 40 CFR, Part 60, Appendix A, for purposes of calculating gas volumetric flow rate and emission rates on a lb/hr and lb/ton basis metal processed. An S-type pitot tube, as a component of the isokinetic sampling train, differential pressure gauge, thermocouple, and temperature readout were used to determine gas velocity at each sample point. Additionally, the four outlet stacks that were not sampled for metals or hexavalent chrome were continuously monitored utilizing pitot tubes placed at a representative sample point and recorded on a data logger. Flow data for these four stacks is appended to this test report. All of the equipment used was calibrated in accordance with the specifications of the Method. Calibration data is presented in Appendix G of this report.

### 4.3 Method 29 Metals Determination

Metals concentrations and emission rates were determined in accordance with Method 29.

Impingers one and two were loaded with 100 mL each of 5% HNO<sub>3</sub>/10% H<sub>2</sub>O<sub>2</sub>. The third impinger remained empty. The fourth and fifth impinger were loaded with 100mL of 10% H<sub>2</sub>SO<sub>4</sub>/5% KMnO<sub>4</sub>. The sixth impinger was filled with silica gel. The impingers were weighed prior to and after each test run in order to determine moisture content of the stack gas. Impingers were recovered as proscribed in the method, with 0.1N HNO<sub>3</sub> used on impingers 1 and 2, 0.1N HNO<sub>3</sub> also used on impinger three (in a separate sample container), and 10% H<sub>2</sub>SO<sub>4</sub>/5% KMnO<sub>4</sub>, DI water, and 8N HCl for impingers four and five.

The filter media were Whatman quartz microfiber filters exhibiting a 99.97% efficiency on 0.3-micron DOP smoke particles in accordance with ASTM Standard Method D-2986-71.

Sample analysis was conducted by ChesterNet Labs for particle bound metals from the nozzle, probe, and filter catch, and analyzed for vapor phase metals from the impinger catch.

#### **4.4 Method 0061 Cr<sup>+6</sup> Determination**

Hexavalent chromium (Cr<sup>+6</sup>) concentrations were determined in accordance with SW-846 Method 0061. The sample was extracted isokinetically from the gas stream and passed through a 0.5N potassium hydroxide (KOH) solution, which was also recirculated through the first impinger to the sample nozzle. The sample train consisted of a glass nozzle, and five impingers. The first three impingers contained the KOH solution (150mL in impinger one, approximately 75mL each in impingers two and three, the fourth impinger remained empty, and the fifth impinger contained silica gel to absorb any remaining moisture). The pH of the first impinger was checked and verified to be greater than 8.5. A post-test nitrogen purge was performed on the impinger train for thirty minutes at 10 liters/minute. Once this purge was complete, samples were filtered and recovered utilizing deionized water and stored in Nalgene sample containers.

# 5.0 TEST RESULT SUMMARIES

## 5.1 Baghouse Inlet Method 29 Summaries

### 5.1.1 Inlet West Method 29 Summaries

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet West  
 Test Method: 29

Source Condition	Batch Process		
	Date	6/27/23	6/30/23
Start Time	5:15	5:25	
End Time	13:42	13:40	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	69.2	72.7	71.0
Flue Gas Moisture, percent by volume	1.0%	1.3%	1.2%
Average Flue Pressure, in. Hg	29.71	29.78	29.75
Gas Sample Volume, dscf	409.320	409.619	409.470
Average Gas Velocity, ft/sec	66.522	70.225	68.374
Gas Volumetric Flow Rate, acfm	28,213	29,783	28,998
Gas Volumetric Flow Rate, dscfm	27,678	28,985	28,332
Gas Volumetric Flow Rate, scfm	27,949	29,382	28,666
Isokinetic Variance	99.9	99.6	99.8
Sample Duration, hours	8.00	7.67	
Tons of metal processed	8.853	9.550	9.202
<b>Aluminum (Al) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	752.21	765.89	759.05
ppb	57.81	58.82	58.32
ug/dscm	64.90	66.03	65.47
ug/dscf	1.84E+00	1.87E+00	1.85E+00
lb/hr	6.73E-03	7.17E-03	6.95E-03
lb/ton metal processed	6.08E-03	5.76E-03	5.92E-03
<b>Antimony (Sb) Emissions</b>			
Detection Limit Qualifier	BDL	BDL	
ug of sample collected	≤ 1.63	≤ 1.55	≤ 1.59
ppb	≤ 0.03	≤ 0.03	≤ 0.03
ug/dscm	≤ 0.14	≤ 0.13	≤ 0.14
ug/dscf	≤ 3.96E-03	≤ 3.68E-03	≤ 3.82E-03
lb/hr	≤ 1.46E-05	≤ 1.45E-05	≤ 1.45E-05
lb/ton metal processed	≤ 1.32E-05	≤ 1.17E-05	≤ 1.24E-05
<b>Arsenic (As) Emissions</b>			
Detection Limit Qualifier	BDL	BDL	
ug of sample collected	≤ 3.60	≤ 3.50	≤ 3.55
ppb	≤ 0.10	≤ 0.10	≤ 0.10
ug/dscm	≤ 0.31	≤ 0.30	≤ 0.31
ug/dscf	≤ 8.78E-03	≤ 8.50E-03	≤ 8.64E-03
lb/hr	≤ 3.22E-05	≤ 3.27E-05	≤ 3.25E-05
lb/ton metal processed	≤ 2.91E-05	≤ 2.63E-05	≤ 2.77E-05
<b>Barium (Ba) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	21.10	6.20	13.65
ppb	0.32	0.09	0.21
ug/dscm	1.82	0.53	1.18
ug/dscf	5.15E-02	1.50E-02	3.33E-02
lb/hr	1.89E-04	5.80E-05	1.23E-04
lb/ton metal processed	1.71E-04	4.66E-05	1.09E-04
<b>Beryllium (Be) Emissions</b>			
Detection Limit Qualifier	BDL	BDL	
ug of sample collected	≤ 0.08	≤ 0.08	≤ 0.08
ppb	≤ 0.02	≤ 0.02	≤ 0.02
ug/dscm	≤ 0.01	≤ 0.01	≤ 0.01
ug/dscf	≤ 2.83E-04	≤ 2.83E-04	≤ 2.83E-04
lb/hr	≤ 7.25E-07	≤ 7.30E-07	≤ 7.27E-07
lb/ton metal processed	≤ 6.55E-07	≤ 5.86E-07	≤ 6.21E-07
<b>Cadmium (Cd) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	1.67	0.59	1.13
ppb	0.03	0.01	0.02
ug/dscm	0.14	0.05	0.10
ug/dscf	3.96E-03	1.42E-03	2.69E-03
lb/hr	1.50E-05	5.55E-06	1.03E-05
lb/ton metal processed	1.35E-05	4.46E-06	8.99E-06

**Client:** PCC Structural, Inc.  
**Facility:** Large Parts Campus Facility - Milwaukie, OR  
**Test Location:** BH9203 Inlet West  
**Test Method:** 29

Source Condition	Batch Process		
Date	6/27/23	6/30/23	
Start Time	5:15	5:25	
End Time	13:42	13:40	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	69.2	72.7	71.0
Flue Gas Moisture, percent by volume	1.0%	1.3%	1.2%
Average Flue Pressure, in. Hg	29.71	29.78	29.75
Gas Sample Volume, dscf	409.320	409.619	409.470
Average Gas Velocity, ft/sec	66.522	70.225	68.374
Gas Volumetric Flow Rate, acfm	28,213	29,783	28,998
Gas Volumetric Flow Rate, dscfm	27,678	28,985	28,332
Gas Volumetric Flow Rate, scfm	27,949	29,382	28,666
Isokinetic Variance	99.9	99.6	99.8
Sample Duration, hours	8.00	7.67	
Tons of metal processed	8.853	9.550	9.202
<b>Chromium (Cr) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	903.17	1,293.00	1,098.08
ppb	36.02	51.52	43.77
ug/dscm	77.92	111.47	94.70
ug/dscf	2.21E+00	3.16E+00	2.68E+00
lb/hr	8.08E-03	1.21E-02	1.01E-02
lb/ton metal processed	7.30E-03	9.72E-03	8.51E-03
<b>Cobalt (Co) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	208.57	314.66	261.61
ppb	7.34	11.06	9.20
ug/dscm	17.99	27.13	22.56
ug/dscf	5.09E-01	7.68E-01	6.39E-01
lb/hr	1.87E-03	2.95E-03	2.41E-03
lb/ton metal processed	1.69E-03	2.37E-03	2.03E-03
<b>Copper (Cu) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	338.20	398.99	368.60
ppb	11.04	13.01	12.02
ug/dscm	29.18	34.40	31.79
ug/dscf	8.26E-01	9.74E-01	9.00E-01
lb/hr	3.03E-03	3.73E-03	3.38E-03
lb/ton metal processed	2.73E-03	3.00E-03	2.87E-03
<b>Lead (Pb) Emissions</b>			
Detection Limit Qualifier	DLL	ADL	
ug of sample collected	≤ 3.11	1.88	≤ 2.49
ppb	≤ 0.03	0.02	≤ 0.03
ug/dscm	≤ 0.27	0.16	≤ 0.22
ug/dscf	≤ 7.65E-03	4.53E-03	≤ 6.09E-03
lb/hr	≤ 2.78E-05	1.76E-05	≤ 2.27E-05
lb/ton metal processed	≤ 2.51E-05	1.41E-05	≤ 1.96E-05
<b>Manganese (Mn) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	27.77	46.17	36.97
ppb	1.05	1.74	1.39
ug/dscm	2.40	3.98	3.19
ug/dscf	6.80E-02	1.13E-01	9.03E-02
lb/hr	2.48E-04	4.32E-04	3.40E-04
lb/ton metal processed	2.24E-04	3.47E-04	2.86E-04
<b>Mercury (Hg) Emissions</b>			
Detection Limit Qualifier	DLL	DLL	
ug of sample collected	≤ 0.66	≤ 0.55	≤ 0.60
ppb	≤ 0.01	≤ 0.01	≤ 0.01
ug/dscm	≤ 0.06	≤ 0.05	≤ 0.06
ug/dscf	≤ 1.70E-03	≤ 1.42E-03	≤ 1.56E-03
lb/hr	≤ 5.94E-06	≤ 5.11E-06	≤ 5.52E-06
lb/ton metal processed	≤ 5.37E-06	≤ 4.10E-06	≤ 4.73E-06

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet West  
 Test Method: 29

Source Condition		Batch Process	
Date	6/27/23	6/30/23	
Start Time	5:15	5:25	
End Time	13:42	13:40	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	69.2	72.7	71.0
Flue Gas Moisture, percent by volume	1.0%	1.3%	1.2%
Average Flue Pressure, in. Hg	29.71	29.78	29.75
Gas Sample Volume, dscf	409.320	409.619	409.470
Average Gas Velocity, ft/sec	66.522	70.225	68.374
Gas Volumetric Flow Rate, acfm	28,213	29,783	28,998
Gas Volumetric Flow Rate, dscfm	27,678	28,985	28,332
Gas Volumetric Flow Rate, scfm	27,949	29,382	28,666
Isokinetic Variance	99.9	99.6	99.8
Sample Duration, hours	8.00	7.67	
Tons of metal processed	8.853	9.550	9.202
<b>Nickel (Ni) Emissions</b>			
Detection Limit Qualifier	<b>ADL</b>	<b>ADL</b>	
ug of sample collected	6,536.42	10,113.20	8,324.81
ppb	230.94	357.06	294.00
ug/dscm	563.94	871.89	717.92
ug/dscf	1.60E+01	2.47E+01	2.03E+01
lb/hr	5.85E-02	9.47E-02	7.66E-02
Ib/ton metal processed	5.28E-02	7.60E-02	6.44E-02
<b>Phosphorus (P) Emissions</b>			
Detection Limit Qualifier	<b>ADL</b>	<b>ADL</b>	
ug of sample collected	116.75	115.75	116.25
ppb	7.82	7.74	7.78
ug/dscm	10.07	9.98	10.03
ug/dscf	2.85E-01	2.83E-01	2.84E-01
lb/hr	1.04E-03	1.08E-03	1.06E-03
Ib/ton metal processed	9.44E-04	8.70E-04	9.07E-04
<b>Selenium (Se) Emissions</b>			
Detection Limit Qualifier	<b>ADL</b>	<b>BDL</b>	
ug of sample collected	12.75	≤ 2.57	≤ 7.66
ppb	0.34	≤ 0.07	≤ 0.20
ug/dscm	1.10	≤ 0.22	≤ 0.66
ug/dscf	3.11E-02	≤ 6.23E-03	≤ 1.87E-02
lb/hr	1.14E-04	≤ 2.41E-05	≤ 6.90E-05
Ib/ton metal processed	1.03E-04	≤ 1.93E-05	≤ 6.12E-05
<b>Silver (Ag) Emissions</b>			
Detection Limit Qualifier	<b>ADL</b>	<b>ADL</b>	
ug of sample collected	1.95	1.24	1.59
ppb	0.02	0.01	0.02
ug/dscm	0.17	0.11	0.14
ug/dscf	4.81E-03	3.11E-03	3.96E-03
lb/hr	1.75E-05	1.16E-05	1.45E-05
Ib/ton metal processed	1.58E-05	9.29E-06	1.25E-05
<b>Thallium (Tl) Emissions</b>			
Detection Limit Qualifier	<b>BDL</b>	<b>BDL</b>	
ug of sample collected	≤ 1.67	≤ 1.48	≤ 1.58
ppb	≤ 0.02	≤ 0.02	≤ 0.02
ug/dscm	≤ 0.14	≤ 0.13	≤ 0.14
ug/dscf	≤ 3.96E-03	≤ 3.68E-03	≤ 3.82E-03
lb/hr	≤ 1.49E-05	≤ 1.39E-05	≤ 1.44E-05
Ib/ton metal processed	≤ 1.35E-05	≤ 1.11E-05	≤ 1.23E-05
<b>Vanadium (V) Emissions</b>			
Detection Limit Qualifier	<b>ADL</b>	<b>ADL</b>	
ug of sample collected	2.81	2.23	2.52
ppb	0.11	0.09	0.10
ug/dscm	0.24	0.19	0.22
ug/dscf	6.80E-03	5.38E-03	6.09E-03
lb/hr	2.52E-05	2.09E-05	2.30E-05
Ib/ton metal processed	2.27E-05	1.68E-05	1.97E-05
<b>Zinc (Zn) Emissions</b>			
Detection Limit Qualifier	<b>ADL</b>	<b>ADL</b>	
ug of sample collected	147.78	161.98	154.88
ppb	4.69	5.13	4.91
ug/dscm	12.75	13.96	13.36
ug/dscf	3.61E-01	3.95E-01	3.78E-01
lb/hr	1.32E-03	1.52E-03	1.42E-03
Ib/ton metal processed	1.19E-03	1.22E-03	1.21E-03

## 5.1.2 Inlet Center Method 29 Summaries

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet Center  
 Test Method: 29

Source Condition	Batch Process		
	Date	6/27/23	6/30/23
Start Time	5:15	5:25	
End Time	13:50	13:30	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	68.5	71.5	70.0
Flue Gas Moisture, percent by volume	0.7%	1.2%	1.0%
Average Flue Pressure, in. Hg	29.70	29.71	29.71
Gas Sample Volume, dscf	391.296	388.108	389.702
Average Gas Velocity, ft/sec	67.316	70.942	69.129
Gas Volumetric Flow Rate, acfm	28,550	30,088	29,319
Gas Volumetric Flow Rate, dscfm	28,113	29,333	28,723
Gas Volumetric Flow Rate, scfm	28,309	29,680	28,995
Isokinetic Variance	97.9	99.3	98.6
Sample Duration, hours	8.00	7.50	
Tons of metal processed	8.853	9.550	9.202
<b>Aluminum (Al) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	784.32	889.68	837.00
ppb	63.06	72.12	67.59
ug/dscm	70.79	80.95	75.87
ug/dscf	2.00E+00	2.29E+00	2.15E+00
lb/hr	7.45E-03	8.89E-03	8.17E-03
lb/ton metal processed	6.74E-03	6.99E-03	6.86E-03
<b>Antimony (Sb) Emissions</b>			
Detection Limit Qualifier	BDL	BDL	
ug of sample collected	≤ 1.45	≤ 1.58	≤ 1.51
ppb	≤ 0.03	≤ 0.03	≤ 0.03
ug/dscm	≤ 0.13	≤ 0.14	≤ 0.14
ug/dscf	≤ 3.68E-03	≤ 3.96E-03	≤ 3.82E-03
lb/hr	≤ 1.38E-05	≤ 1.58E-05	≤ 1.48E-05
lb/ton metal processed	≤ 1.25E-05	≤ 1.24E-05	≤ 1.24E-05
<b>Arsenic (As) Emissions</b>			
Detection Limit Qualifier	BDL	BDL	
ug of sample collected	≤ 3.29	≤ 3.51	≤ 3.40
ppb	≤ 0.10	≤ 0.10	≤ 0.10
ug/dscm	≤ 0.30	≤ 0.32	≤ 0.31
ug/dscf	≤ 8.50E-03	≤ 9.06E-03	≤ 8.78E-03
lb/hr	≤ 3.13E-05	≤ 3.51E-05	≤ 3.32E-05
lb/ton metal processed	≤ 2.83E-05	≤ 2.76E-05	≤ 2.79E-05
<b>Barium (Ba) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	53.06	7.90	30.48
ppb	0.84	0.13	0.48
ug/dscm	4.79	0.72	2.76
ug/dscf	1.36E-01	2.04E-02	7.80E-02
lb/hr	5.04E-04	7.90E-05	2.92E-04
lb/ton metal processed	4.56E-04	6.20E-05	2.59E-04
<b>Beryllium (Be) Emissions</b>			
Detection Limit Qualifier	BDL	BDL	
ug of sample collected	≤ 0.07	≤ 0.08	≤ 0.08
ppb	≤ 0.02	≤ 0.02	≤ 0.02
ug/dscm	≤ 0.01	≤ 0.01	≤ 0.01
ug/dscf	≤ 2.83E-04	≤ 2.83E-04	≤ 2.83E-04
lb/hr	≤ 6.94E-07	≤ 7.90E-07	≤ 7.42E-07
lb/ton metal processed	≤ 6.27E-07	≤ 6.20E-07	≤ 6.24E-07
<b>Cadmium (Cd) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	2.88	1.17	2.03
ppb	0.06	0.02	0.04
ug/dscm	0.26	0.11	0.19
ug/dscf	7.36E-03	3.11E-03	5.24E-03
lb/hr	2.74E-05	1.17E-05	1.95E-05
lb/ton metal processed	2.47E-05	9.19E-06	1.70E-05

**Client:** PCC Structural, Inc.  
**Facility:** Large Parts Campus Facility - Milwaukie, OR  
**Test Location:** BH9203 Inlet Center  
**Test Method:** 29

Source Condition	Batch Process		
Date	6/27/23	6/30/23	
Start Time	5:15	5:25	
End Time	13:50	13:30	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	68.5	71.5	70.0
Flue Gas Moisture, percent by volume	0.7%	1.2%	1.0%
Average Flue Pressure, in. Hg	29.70	29.71	29.71
Gas Sample Volume, dscf	391.296	388.108	389.702
Average Gas Velocity, ft/sec	67.316	70.942	69.129
Gas Volumetric Flow Rate, acfm	28,550	30,088	29,319
Gas Volumetric Flow Rate, dscfm	28,113	29,333	28,723
Gas Volumetric Flow Rate, scfm	28,309	29,680	28,995
Isokinetic Variance	97.9	99.3	98.6
Sample Duration, hours	8.00	7.50	
Tons of metal processed	8.853	9.550	9.202
<b>Chromium (Cr) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	741.97	1,360.90	1,051.43
ppb	30.95	57.24	44.09
ug/dscm	66.96	123.83	95.40
ug/dscf	1.90E+00	3.51E+00	2.70E+00
lb/hr	7.05E-03	1.36E-02	1.03E-02
lb/ton metal processed	6.37E-03	1.07E-02	8.53E-03
<b>Cobalt (Co) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	137.00	44.42	90.71
ppb	5.04	1.65	3.35
ug/dscm	12.36	4.04	8.20
ug/dscf	3.50E-01	1.14E-01	2.32E-01
lb/hr	1.30E-03	4.44E-04	8.73E-04
lb/ton metal processed	1.18E-03	3.49E-04	7.63E-04
<b>Copper (Cu) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	409.10	779.37	594.24
ppb	13.96	26.82	20.39
ug/dscm	36.92	70.92	53.92
ug/dscf	1.05E+00	2.01E+00	1.53E+00
lb/hr	3.89E-03	7.79E-03	5.84E-03
lb/ton metal processed	3.51E-03	6.12E-03	4.82E-03
<b>Lead (Pb) Emissions</b>			
Detection Limit Qualifier	ADL	DLL	
ug of sample collected	3.44	≤ 1.87	≤ 2.66
ppb	0.04	≤ 0.02	≤ 0.03
ug/dscm	0.31	≤ 0.17	≤ 0.24
ug/dscf	8.78E-03	≤ 4.81E-03	≤ 6.80E-03
lb/hr	3.27E-05	≤ 1.87E-05	≤ 2.57E-05
lb/ton metal processed	2.95E-05	≤ 1.47E-05	≤ 2.21E-05
<b>Manganese (Mn) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	116.57	128.17	122.37
ppb	4.60	5.10	4.85
ug/dscm	10.52	11.66	11.09
ug/dscf	2.98E-01	3.30E-01	3.14E-01
lb/hr	1.11E-03	1.28E-03	1.19E-03
lb/ton metal processed	1.00E-03	1.01E-03	1.00E-03
<b>Mercury (Hg) Emissions</b>			
Detection Limit Qualifier	DLL	DLL	
ug of sample collected	≤ 0.43	≤ 0.86	≤ 0.64
ppb	≤ 0.01	≤ 0.01	≤ 0.01
ug/dscm	≤ 0.04	≤ 0.08	≤ 0.06
ug/dscf	≤ 1.13E-03	≤ 2.27E-03	≤ 1.70E-03
lb/hr	≤ 4.08E-06	≤ 8.56E-06	≤ 6.32E-06
lb/ton metal processed	≤ 3.69E-06	≤ 6.72E-06	≤ 5.20E-06

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet Center  
 Test Method: 29

Source Condition	Batch Process		
	Date	6/27/23	6/30/23
Start Time	5:15	5:25	
End Time	13:50	13:30	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	68.5	71.5	70.0
Flue Gas Moisture, percent by volume	0.7%	1.2%	1.0%
Average Flue Pressure, in. Hg	29.70	29.71	29.71
Gas Sample Volume, dscf	391.296	388.108	389.702
Average Gas Velocity, ft/sec	67.316	70.942	69.129
Gas Volumetric Flow Rate, acfm	28.550	30.088	29.319
Gas Volumetric Flow Rate, dscfm	28,113	29,333	28,723
Gas Volumetric Flow Rate, scfm	28,309	29,680	28,995
Isokinetic Variance	97.9	99.3	98.6
Sample Duration, hours	8.00	7.50	
Tons of metal processed	8.853	9.550	9.202
<b>Nickel (Ni) Emissions</b>			
Detection Limit Qualifier	<b>ADL</b>	<b>ADL</b>	
ug of sample collected	4,859.42	7,859.52	6,359.47
ppb	179.60	292.87	236.23
ug/dscm	438.57	715.15	576.86
ug/dscf	1.24E+01	2.03E+01	1.63E+01
lb/hr	4.62E-02	7.86E-02	6.24E-02
Ib/ton metal processed	4.17E-02	6.17E-02	5.17E-02
<b>Phosphorus (P) Emissions</b>			
Detection Limit Qualifier	<b>ADL</b>	<b>ADL</b>	
ug of sample collected	156.82	118.35	137.59
ppb	10.98	8.36	9.67
ug/dscm	14.15	10.77	12.46
ug/dscf	4.01E-01	3.05E-01	3.53E-01
lb/hr	1.49E-03	1.18E-03	1.34E-03
Ib/ton metal processed	1.35E-03	9.29E-04	1.14E-03
<b>Selenium (Se) Emissions</b>			
Detection Limit Qualifier	<b>BDL</b>	<b>BDL</b>	
ug of sample collected	≤ 2.20	≤ 2.66	≤ 2.43
ppb	≤ 0.06	≤ 0.07	≤ 0.07
ug/dscm	≤ 0.20	≤ 0.24	≤ 0.22
ug/dscf	≤ 5.66E-03	≤ 6.80E-03	≤ 6.23E-03
lb/hr	≤ 2.09E-05	≤ 2.66E-05	≤ 2.38E-05
Ib/ton metal processed	≤ 1.89E-05	≤ 2.09E-05	≤ 1.99E-05
<b>Silver (Ag) Emissions</b>			
Detection Limit Qualifier	<b>ADL</b>	<b>ADL</b>	
ug of sample collected	6.28	2.58	4.43
ppb	0.07	0.03	0.05
ug/dscm	0.57	0.23	0.40
ug/dscf	1.61E-02	6.51E-03	1.13E-02
lb/hr	5.96E-05	2.58E-05	4.27E-05
Ib/ton metal processed	5.39E-05	2.03E-05	3.71E-05
<b>Thallium (Tl) Emissions</b>			
Detection Limit Qualifier	<b>BDL</b>	<b>BDL</b>	
ug of sample collected	≤ 1.23	≤ 1.54	≤ 1.39
ppb	≤ 0.01	≤ 0.02	≤ 0.01
ug/dscm	≤ 0.11	≤ 0.14	≤ 0.13
ug/dscf	≤ 3.11E-03	≤ 3.96E-03	≤ 3.54E-03
lb/hr	≤ 1.17E-05	≤ 1.54E-05	≤ 1.35E-05
Ib/ton metal processed	≤ 1.06E-05	≤ 1.21E-05	≤ 1.13E-05
<b>Vanadium (V) Emissions</b>			
Detection Limit Qualifier	<b>ADL</b>	<b>ADL</b>	
ug of sample collected	2.88	4.05	3.47
ppb	0.12	0.17	0.15
ug/dscm	0.26	0.37	0.32
ug/dscf	7.36E-03	1.05E-02	8.92E-03
lb/hr	2.73E-05	4.05E-05	3.39E-05
Ib/ton metal processed	2.47E-05	3.18E-05	2.83E-05
<b>Zinc (Zn) Emissions</b>			
Detection Limit Qualifier	<b>ADL</b>	<b>ADL</b>	
ug of sample collected	658.98	184.11	421.55
ppb	21.86	6.16	14.01
ug/dscm	59.47	16.75	38.11
ug/dscf	1.68E+00	4.74E-01	1.08E+00
lb/hr	6.26E-03	1.84E-03	4.05E-03
Ib/ton metal processed	5.66E-03	1.45E-03	3.55E-03

### 5.1.3 Inlet East Method 29 Summaries

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet East  
 Test Method: 29

Source Condition	Batch Process		
	Date	6/27/23	6/30/23
Start Time	5:15	5:25	
End Time	13:30	13:30	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	70.7	73.4	72.1
Flue Gas Moisture, percent by volume	0.9%	1.5%	1.2%
Average Flue Pressure, in. Hg	29.70	29.78	29.74
Gas Sample Volume, dscf	359.466	316.259	337.863
Average Gas Velocity, ft/sec	61.064	60.004	60.534
Gas Volumetric Flow Rate, acfm	25,898	25,449	25,674
Gas Volumetric Flow Rate, dscfm	25,354	24,691	25,023
Gas Volumetric Flow Rate, scfm	25,575	25,071	25,323
Isokinetic Variance	102.8	99.1	101.0
Sample Duration, hours	8.00	7.50	
Tons of metal processed	8.853	9.550	9.202
<b>Aluminum (Al) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	816.62	1134.49	975.56
ppb	71.47	112.85	92.16
ug/dscm	80.23	126.68	103.46
ug/dscf	2.27E+00	3.59E+00	2.93E+00
lb/hr	7.62E-03	1.17E-02	9.67E-03
lb/ton metal processed	6.88E-03	9.20E-03	8.04E-03
<b>Antimony (Sb) Emissions</b>			
Detection Limit Qualifier	BDL	DLL	
ug of sample collected	≤ 1.51	≤ 1.64	≤ 1.57
ppb	≤ 0.03	≤ 0.04	≤ 0.03
ug/dscm	≤ 0.15	≤ 0.18	≤ 0.17
ug/dscf	≤ 4.25E-03	≤ 5.10E-03	≤ 4.67E-03
lb/hr	≤ 1.41E-05	≤ 1.69E-05	≤ 1.55E-05
lb/ton metal processed	≤ 1.27E-05	≤ 1.33E-05	≤ 1.30E-05
<b>Arsenic (As) Emissions</b>			
Detection Limit Qualifier	DLL	BDL	
ug of sample collected	≤ 4.50	≤ 3.28	≤ 3.89
ppb	≤ 0.14	≤ 0.12	≤ 0.13
ug/dscm	≤ 0.44	≤ 0.37	≤ 0.41
ug/dscf	≤ 1.25E-02	≤ 1.05E-02	≤ 1.15E-02
lb/hr	≤ 4.20E-05	≤ 3.39E-05	≤ 3.79E-05
lb/ton metal processed	≤ 3.79E-05	≤ 2.66E-05	≤ 3.23E-05
<b>Barium (Ba) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	42.39	10.88	26.64
ppb	0.73	0.21	0.47
ug/dscm	4.16	1.21	2.69
ug/dscf	1.18E-01	3.43E-02	7.60E-02
lb/hr	3.95E-04	1.12E-04	2.54E-04
lb/ton metal processed	3.57E-04	8.82E-05	2.23E-04
<b>Beryllium (Be) Emissions</b>			
Detection Limit Qualifier	BDL	BDL	
ug of sample collected	≤ 0.08	≤ 0.07	≤ 0.07
ppb	≤ 0.02	≤ 0.02	≤ 0.02
ug/dscm	≤ 0.01	≤ 0.01	≤ 0.01
ug/dscf	≤ 2.83E-04	≤ 2.83E-04	≤ 2.83E-04
lb/hr	≤ 7.00E-07	≤ 7.44E-07	≤ 7.22E-07
lb/ton metal processed	≤ 6.32E-07	≤ 5.84E-07	≤ 6.08E-07
<b>Cadmium (Cd) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	6.08	6.81	6.45
ppb	0.13	0.16	0.15
ug/dscm	0.60	0.76	0.68
ug/dscf	1.70E-02	2.15E-02	1.93E-02
lb/hr	5.67E-05	7.04E-05	6.35E-05
lb/ton metal processed	5.13E-05	5.53E-05	5.33E-05

**Client:** PCC Structural, Inc.  
**Facility:** Large Parts Campus Facility - Milwaukie, OR  
**Test Location:** BH9203 Inlet East  
**Test Method:** 29

Source Condition	Batch Process		
Date	6/27/23	6/30/23	
Start Time	5:15	5:25	
End Time	13:30	13:30	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	70.7	73.4	72.1
Flue Gas Moisture, percent by volume	0.9%	1.5%	1.2%
Average Flue Pressure, in. Hg	29.70	29.78	29.74
Gas Sample Volume, dscf	359.466	316.259	337.863
Average Gas Velocity, ft/sec	61.064	60.004	60.534
Gas Volumetric Flow Rate, acfm	25,898	25,449	25,674
Gas Volumetric Flow Rate, dscfm	25,354	24,691	25,023
Gas Volumetric Flow Rate, scfm	25,575	25,071	25,323
Isokinetic Variance	102.8	99.1	101.0
Sample Duration, hours	8.00	7.50	
Tons of metal processed	8.853	9.550	9.202
<b>Chromium (Cr) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	2,639.82	4,891.94	3,765.88
ppb	119.87	252.48	186.17
ug/dscm	259.34	546.25	402.80
ug/dscf	7.34E+00	1.55E+01	1.14E+01
lb/hr	2.46E-02	5.05E-02	3.76E-02
lb/ton metal processed	2.23E-02	3.97E-02	3.10E-02
<b>Cobalt (Co) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	43.78	54.84	49.31
ppb	1.75	2.50	2.13
ug/dscm	4.30	6.12	5.21
ug/dscf	1.22E-01	1.73E-01	1.48E-01
lb/hr	4.08E-04	5.66E-04	4.87E-04
lb/ton metal processed	3.69E-04	4.45E-04	4.07E-04
<b>Copper (Cu) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	293.23	681.99	487.61
ppb	10.90	28.80	19.85
ug/dscm	28.81	76.15	52.48
ug/dscf	8.16E-01	2.16E+00	1.49E+00
lb/hr	2.74E-03	7.04E-03	4.89E-03
lb/ton metal processed	2.47E-03	5.53E-03	4.00E-03
<b>Lead (Pb) Emissions</b>			
Detection Limit Qualifier	DLL	ADL	
ug of sample collected	≤ 1.67	1.96	≤ 1.81
ppb	≤ 0.02	0.03	≤ 0.02
ug/dscm	≤ 0.16	0.22	≤ 0.19
ug/dscf	≤ 4.53E-03	6.23E-03	≤ 5.38E-03
lb/hr	≤ 1.55E-05	2.02E-05	≤ 1.79E-05
lb/ton metal processed	≤ 1.40E-05	1.59E-05	≤ 1.50E-05
<b>Manganese (Mn) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	50.47	270.97	160.72
ppb	2.17	13.24	7.70
ug/dscm	4.96	30.26	17.61
ug/dscf	1.40E-01	8.57E-01	4.99E-01
lb/hr	4.71E-04	2.80E-03	1.63E-03
lb/ton metal processed	4.25E-04	2.20E-03	1.31E-03
<b>Mercury (Hg) Emissions</b>			
Detection Limit Qualifier	DLL	DLL	
ug of sample collected	≤ 0.46	≤ 0.53	≤ 0.50
ppb	≤ 0.01	≤ 0.01	≤ 0.01
ug/dscm	≤ 0.05	≤ 0.06	≤ 0.06
ug/dscf	≤ 1.42E-03	≤ 1.70E-03	≤ 1.56E-03
lb/hr	≤ 4.29E-06	≤ 5.52E-06	≤ 4.91E-06
lb/ton metal processed	≤ 3.88E-06	≤ 4.33E-06	≤ 4.11E-06

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet East  
 Test Method: 29

Source Condition	Batch Process		
	Date	6/27/23	6/30/23
	Start Time	5:15	5:25
	End Time	13:30	13:30
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	70.7	73.4	72.1
Flue Gas Moisture, percent by volume	0.9%	1.5%	1.2%
Average Flue Pressure, in. Hg	29.70	29.78	29.74
Gas Sample Volume, dscf	359,466	316,259	337,863
Average Gas Velocity, ft/sec	61.064	60.004	60.534
Gas Volumetric Flow Rate, acfm	25,898	25,449	25,674
Gas Volumetric Flow Rate, dscfm	25,354	24,691	25,023
Gas Volumetric Flow Rate, scfm	25,575	25,071	25,323
Isokinetic Variance	102.8	99.1	101.0
Sample Duration, hours	8.00	7.50	
Tons of metal processed	8,853	9,550	9,202
<b>Nickel (Ni) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	8,119.83	20,414.22	14,267.03
ppb	326.68	933.51	630.09
ug/dscm	797.71	2279.53	1538.62
ug/dscf	2.26E+01	6.45E+01	4.36E+01
lb/hr	7.58E-02	2.11E-01	1.43E-01
lb/ton metal processed	6.85E-02	1.66E-01	1.17E-01
<b>Phosphorus (P) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	114.55	131.54	123.05
ppb	8.73	11.40	10.07
ug/dscm	11.25	14.69	12.97
ug/dscf	3.19E-01	4.16E-01	3.67E-01
lb/hr	1.07E-03	1.36E-03	1.21E-03
lb/ton metal processed	9.66E-04	1.07E-03	1.02E-03
<b>Selenium (Se) Emissions</b>			
Detection Limit Qualifier	BDL	BDL	
ug of sample collected	≤ 2.40	≤ 2.18	≤ 2.29
ppb	≤ 0.07	≤ 0.07	≤ 0.07
ug/dscm	≤ 0.24	≤ 0.24	≤ 0.24
ug/dscf	≤ 6.80E-03	≤ 6.80E-03	≤ 6.80E-03
lb/hr	≤ 2.24E-05	≤ 2.25E-05	≤ 2.25E-05
lb/ton metal processed	≤ 2.02E-05	≤ 1.77E-05	≤ 1.90E-05
<b>Silver (Ag) Emissions</b>			
Detection Limit Qualifier	ADL	DLL	
ug of sample collected	4.04	≤ 2.91	≤ 3.48
ppb	0.05	≤ 0.04	≤ 0.04
ug/dscm	0.40	≤ 0.33	≤ 0.37
ug/dscf	1.13E-02	≤ 9.34E-03	≤ 1.03E-02
lb/hr	3.77E-05	≤ 3.01E-05	≤ 3.39E-05
lb/ton metal processed	3.41E-05	≤ 2.36E-05	≤ 2.88E-05
<b>Thallium (Tl) Emissions</b>			
Detection Limit Qualifier	BDL	BDL	
ug of sample collected	≤ 1.37	≤ 1.22	≤ 1.30
ppb	≤ 0.02	≤ 0.02	≤ 0.02
ug/dscm	≤ 0.13	≤ 0.14	≤ 0.14
ug/dscf	≤ 3.68E-03	≤ 3.96E-03	≤ 3.82E-03
lb/hr	≤ 1.28E-05	≤ 1.26E-05	≤ 1.27E-05
lb/ton metal processed	≤ 1.16E-05	≤ 9.89E-06	≤ 1.07E-05
<b>Vanadium (V) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	5.59	7.04	6.31
ppb	0.26	0.37	0.32
ug/dscm	0.55	0.79	0.67
ug/dscf	1.56E-02	2.24E-02	1.90E-02
lb/hr	5.21E-05	7.27E-05	6.24E-05
lb/ton metal processed	4.71E-05	5.71E-05	5.21E-05
<b>Zinc (Zn) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	182.88	296.48	239.68
ppb	6.61	12.17	9.39
ug/dscm	17.97	33.11	25.54
ug/dscf	5.09E-01	9.38E-01	7.23E-01
lb/hr	1.71E-03	3.06E-03	2.38E-03
lb/ton metal processed	1.54E-03	2.40E-03	1.97E-03

## 5.2 Baghouse Inlet Method 0061 Summaries

### 5.2.1 Inlet West Method 0061 Summary

**Client:** PCC Structural, Inc.  
**Facility:** Large Parts Campus Facility - Milwaukie, OR  
**Test Location:** BH9203 Inlet West  
**Test Method:** 0061

Source Condition	Batch Process		
	Date	6/27/23	6/30/23
Start Time	5:15	5:25	
End Time	13:42	13:30	
	Run 1	Run 2	Average
Stack Conditions			
Average Gas Temperature, °F	65.6	68.8	67.2
Flue Gas Moisture, percent by volume	1.0%	1.3%	1.2%
Average Flue Pressure, in. Hg	29.70	29.78	29.74
Gas Sample Volume, dscf	378.716	388.962	383.839
Average Gas Velocity, ft/sec	64.690	71.185	67.938
Gas Volumetric Flow Rate, acfm	27,436	30,191	28,814
Gas Volumetric Flow Rate, dscfm	27,084	29,613	28,349
Gas Volumetric Flow Rate, scfm	27,358	30,003	28,681
Isokinetic Variance	99.3	101.8	100.6
Tons of metal processed	8.853	9.550	9.227
Hexavalent Chromium (Cr+6) Emissions			
Detection Limit Qualifier	ADL	ADL	ADL
ug of sample collected	82.30	99.20	90.75
ppb	3.55	4.16	3.86
ug/dscm	7.67E+00	9.01E+00	8.34E+00
ug/dscf	2.17E-01	2.55E-01	2.36E-01
lb/hr	7.79E-04	9.99E-04	8.89E-04
lb/ton metal processed	7.04E-04	8.37E-04	0.00077

## 5.2.2 Inlet Center Method 0061 Summary

**Client:** PCC Structural, Inc.  
**Facility:** Large Parts Campus Facility - Milwaukie, OR  
**Test Location:** BH9203 Inlet Center  
**Test Method:** 0061

Source Condition	Batch Process		
	Date	6/27/23	6/27/23
Start Time	5:15	5:25	
End Time	13:50	13:30	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	68.8	71.5	70.2
Flue Gas Moisture, percent by volume	0.7%	1.2%	1.0%
Average Flue Pressure, in. Hg	29.70	29.71	29.71
Gas Sample Volume, dscf	406.203	352.050	379.127
Average Gas Velocity, ft/sec	69.435	64.794	67.115
Gas Volumetric Flow Rate, acfm	29,448	27,480	28,464
Gas Volumetric Flow Rate, dscfm	28,980	26,785	27,883
Gas Volumetric Flow Rate, scfm	29,185	27,110	28,148
Isokinetic Variance	95.6	97.8	96.7
Tons of metal processed	8.853	9.550	9.202
<b>Hexavalent Chromium (Cr+6) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	204.00	94.00	149.00
ppb	8.20	4.36	6.28
ug/dscm	1.77E+01	9.43E+00	1.36E+01
ug/dscf	5.02E-01	2.67E-01	3.85E-01
lb/hr	1.93E-03	9.46E-04	1.44E-03
lb/ton metal processed	1.74E-03	7.92E-04	1.27E-03

### 5.2.3 Inlet East Method 0061 Summary

**Client:** PCC Structural, Inc.  
**Facility:** Large Parts Campus Facility - Milwaukie, OR  
**Test Location:** BH9203 Inlet East  
**Test Method:** 0061

Source Condition	Batch Process		
	Date	6/27/23	6/30/23
Start Time	5:15	5:25	
End Time	13:20	14:00	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	70.1	72.2	71.2
Flue Gas Moisture, percent by volume	0.9%	1.5%	1.2%
Average Flue Pressure, in. Hg	29.70	29.78	29.74
Gas Sample Volume, dscf	360.840	325.578	343.209
Average Gas Velocity, ft/sec	60.266	59.985	60.126
Gas Volumetric Flow Rate, acfm	25,560	25,441	25,501
Gas Volumetric Flow Rate, dscfm	25,042	24,743	24,893
Gas Volumetric Flow Rate, scfm	25,269	25,120	25,195
Isokinetic Variance	102.4	93.5	98.0
Tons of metal processed	8.853	9.550	9.227
<b>Hexavalent Chromium (Cr+6) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	49.10	26.70	37.90
ppb	2.22	1.34	1.78
ug/dscm	4.81E+00	2.90E+00	3.86E+00
ug/dscf	1.36E-01	8.21E-02	1.09E-01
lb/hr	4.51E-04	2.68E-04	3.60E-04
Ib/ton metal processed	4.08E-04	2.25E-04	3.16E-04

## 5.3 Baghouse Outlet Method 29 Summaries<sup>1</sup>

### 5.3.1 Outlet West Method 29 Summaries

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Outlet West  
 Test Method: 29

Source Condition	Batch Process		
	Date	6/27/23	6/30/23
	Start Time	5:15	5:25
End Time	13:33	13:35	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	73.7	77.2	75.5
Flue Gas Moisture, percent by volume	0.7%	1.0%	0.9%
Average Flue Pressure, in. Hg	30.01	30.01	30.01
Gas Sample Volume, dscf	412.857	423.437	418.147
Average Gas Velocity, ft/sec	57.331	59.234	58.283
Gas Volumetric Flow Rate, acfm	21,683	22,403	22,043
Gas Volumetric Flow Rate, dscfm	21,374	21,855	21,615
Gas Volumetric Flow Rate, scfm	21,514	22,084	21,799
Isokinetic Variance	100.7	101.0	100.9
Sample Duration, hours	8.00	8.00	
Tons of metal processed	8.853	9.550	9.202
<b>Aluminum (Al) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	538.75	505.59	522.17
ppb	41.05	37.56	39.31
ug/dscm	46.08	42.17	44.13
ug/dscf	1.30E+00	1.19E+00	1.25E+00
lb/hr	3.69E-03	3.45E-03	3.57E-03
Ib/ton metal processed	3.33E-03	2.89E-03	3.11E-03
<b>Antimony (Sb) Emissions</b>			
Detection Limit Qualifier	BDL	BDL	
ug of sample collected	≤ 1.46	≤ 1.47	≤ 1.47
ppb	≤ 0.03	≤ 0.02	≤ 0.02
ug/dscm	≤ 0.13	≤ 0.12	≤ 0.13
ug/dscf	≤ 3.68E-03	≤ 3.40E-03	≤ 3.54E-03
lb/hr	≤ 1.00E-05	≤ 1.00E-05	≤ 1.00E-05
Ib/ton metal processed	≤ 9.06E-06	≤ 8.42E-06	≤ 8.74E-06
<b>Arsenic (As) Emissions</b>			
Detection Limit Qualifier	BDL	BDL	
ug of sample collected	≤ 3.31	≤ 3.33	≤ 3.32
ppb	≤ 0.09	≤ 0.09	≤ 0.09
ug/dscm	≤ 0.28	≤ 0.28	≤ 0.28
ug/dscf	≤ 7.93E-03	≤ 7.93E-03	≤ 7.93E-03
lb/hr	≤ 2.27E-05	≤ 2.27E-05	≤ 2.27E-05
Ib/ton metal processed	≤ 2.05E-05	≤ 1.90E-05	≤ 1.98E-05
<b>Barium (Ba) Emissions</b>			
Detection Limit Qualifier	ADL	DLL	
ug of sample collected	5.22	≤ 2.62	≤ 3.92
ppb	0.08	≤ 0.04	≤ 0.06
ug/dscm	0.45	≤ 0.22	≤ 0.34
ug/dscf	1.27E-02	≤ 6.23E-03	≤ 9.49E-03
lb/hr	3.57E-05	≤ 1.79E-05	≤ 2.68E-05
Ib/ton metal processed	3.23E-05	≤ 1.50E-05	≤ 2.36E-05
<b>Beryllium (Be) Emissions</b>			
Detection Limit Qualifier	BDL	BDL	
ug of sample collected	≤ 0.07	≤ 0.07	≤ 0.07
ppb	≤ 0.02	≤ 0.02	≤ 0.02
ug/dscm	≤ 0.01	≤ 0.01	≤ 0.01
ug/dscf	≤ 2.83E-04	≤ 2.83E-04	≤ 2.83E-04
lb/hr	≤ 5.00E-07	≤ 5.05E-07	≤ 5.03E-07
Ib/ton metal processed	≤ 4.52E-07	≤ 4.23E-07	≤ 4.37E-07
<b>Cadmium (Cd) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	0.40	0.24	0.32
ppb	0.01	0.00	0.01
ug/dscm	0.03	0.02	0.03
ug/dscf	8.50E-04	5.66E-04	7.08E-04
lb/hr	2.71E-06	1.62E-06	2.17E-06
Ib/ton metal processed	2.45E-06	1.36E-06	1.91E-06

<sup>1</sup> Includes actual emissions from the sources tested, does not include total lb/hr as summed in Section 3.8

**Client:** PCC Structural, Inc.  
**Facility:** Large Parts Campus Facility - Milwaukie, OR  
**Test Location:** BH9203 Outlet West  
**Test Method:** 29

Source Condition	Batch Process		
Date	6/27/23	6/30/23	
Start Time	5:15	5:25	
End Time	13:33	13:35	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	73.7	77.2	75.5
Flue Gas Moisture, percent by volume	0.7%	1.0%	0.9%
Average Flue Pressure, in. Hg	30.01	30.01	30.01
Gas Sample Volume, dscf	412.857	423.437	418.147
Average Gas Velocity, ft/sec	57.331	59.234	58.283
Gas Volumetric Flow Rate, acfm	21,683	22,403	22,043
Gas Volumetric Flow Rate, dscfm	21,374	21,855	21,615
Gas Volumetric Flow Rate, scfm	21,514	22,084	21,799
Isokinetic Variance	100.7	101.0	100.9
Sample Duration, hours	8.00	8.00	
Tons of metal processed	8.853	9.550	9.202
<b>Chromium (Cr) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	5.08	13.99	9.53
ppb	0.20	0.54	0.37
ug/dscm	0.43	1.17	0.80
ug/dscf	1.22E-02	3.31E-02	2.27E-02
lb/hr	3.48E-05	9.55E-05	6.51E-05
lb/ton metal processed	3.14E-05	8.00E-05	5.57E-05
<b>Cobalt (Co) Emissions</b>			
Detection Limit Qualifier	BDL	ADL	
ug of sample collected	≤ 0.18	6.62	≤ 3.40
ppb	≤ 0.01	0.23	≤ 0.12
ug/dscm	≤ 0.02	0.55	≤ 0.29
ug/dscf	≤ 5.66E-04	1.56E-02	≤ 8.07E-03
lb/hr	≤ 1.25E-06	4.52E-05	≤ 2.32E-05
lb/ton metal processed	≤ 1.13E-06	3.79E-05	≤ 1.95E-05
<b>Copper (Cu) Emissions</b>			
Detection Limit Qualifier	ADL	DLL	
ug of sample collected	3.69	≤ 2.09	≤ 2.89
ppb	0.12	≤ 0.07	≤ 0.09
ug/dscm	0.32	≤ 0.17	≤ 0.25
ug/dscf	9.06E-03	≤ 4.81E-03	≤ 6.94E-03
lb/hr	2.53E-05	≤ 1.43E-05	≤ 1.98E-05
lb/ton metal processed	2.28E-05	≤ 1.20E-05	≤ 1.74E-05
<b>Lead (Pb) Emissions</b>			
Detection Limit Qualifier	DLL	DLL	
ug of sample collected	≤ 1.71	≤ 0.76	≤ 1.23
ppb	≤ 0.02	≤ 0.01	≤ 0.01
ug/dscm	≤ 0.15	≤ 0.06	≤ 0.11
ug/dscf	≤ 4.25E-03	≤ 1.70E-03	≤ 2.97E-03
lb/hr	≤ 1.17E-05	≤ 5.18E-06	≤ 8.44E-06
lb/ton metal processed	≤ 1.06E-05	≤ 4.34E-06	≤ 7.45E-06
<b>Manganese (Mn) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	49.97	19.91	34.94
ppb	1.87	0.73	1.30
ug/dscm	4.27	1.66	2.97
ug/dscf	1.21E-01	4.70E-02	8.40E-02
lb/hr	3.42E-04	1.36E-04	2.39E-04
lb/ton metal processed	3.09E-04	1.14E-04	2.12E-04
<b>Mercury (Hg) Emissions</b>			
Detection Limit Qualifier	DLL	DLL	
ug of sample collected	≤ 1.64	≤ 0.87	≤ 1.26
ppb	≤ 0.02	≤ 0.01	≤ 0.01
ug/dscm	≤ 0.14	≤ 0.07	≤ 0.11
ug/dscf	≤ 3.96E-03	≤ 1.98E-03	≤ 2.97E-03
lb/hr	≤ 1.12E-05	≤ 5.97E-06	≤ 8.59E-06
lb/ton metal processed	≤ 1.01E-05	≤ 5.00E-06	≤ 7.57E-06

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Outlet West  
 Test Method: 29

Source Condition		Batch Process		
Date	6/27/23	6/30/23		
Start Time	5:15	5:25		
End Time	13:33	13:35		
	Run 1	Run 2	Average	
<b>Stack Conditions</b>				
Average Gas Temperature, °F	73.7	77.2	75.5	
Flue Gas Moisture, percent by volume	0.7%	1.0%	0.9%	
Average Flue Pressure, in. Hg	30.01	30.01	30.01	
Gas Sample Volume, dscf	412.857	423.437	418.147	
Average Gas Velocity, ft/sec	57.331	59.234	58.283	
Gas Volumetric Flow Rate, acfm	21,683	22,403	22,043	
Gas Volumetric Flow Rate, dscfm	21,374	21,855	21,615	
Gas Volumetric Flow Rate, scfm	21,514	22,084	21,799	
Isokinetic Variance	100.7	101.0	100.9	
Sample Duration, hours	8.00	8.00	8.00	
Tons of metal processed	8.853	9.550	9.202	
<b>Nickel (Ni) Emissions</b>				
Detection Limit Qualifier	ADL	ADL		
ug of sample collected	32.86	46.31	39.59	
ppb	1.15	1.58	1.37	
ug/dscm	2.81	3.86	3.34	
ug/dscf	7.96E-02	1.09E-01	9.44E-02	
lb/hr	2.25E-04	3.16E-04	2.71E-04	
Ib/ton metal processed	2.03E-04	2.65E-04	2.34E-04	
<b>Phosphorus (P) Emissions</b>				
Detection Limit Qualifier	ADL	ADL		
ug of sample collected	92.35	88.68	90.52	
ppb	6.13	5.74	5.94	
ug/dscm	7.90	7.40	7.65	
ug/dscf	2.24E-01	2.10E-01	2.17E-01	
lb/hr	6.32E-04	6.05E-04	6.19E-04	
Ib/ton metal processed	5.71E-04	5.07E-04	5.39E-04	
<b>Selenium (Se) Emissions</b>				
Detection Limit Qualifier	BDL	BDL		
ug of sample collected	≤ 2.24	≤ 2.27	≤ 2.26	
ppb	≤ 0.06	≤ 0.06	≤ 0.06	
ug/dscm	≤ 0.19	≤ 0.19	≤ 0.19	
ug/dscf	≤ 5.38E-03	≤ 5.38E-03	≤ 5.38E-03	
lb/hr	≤ 1.53E-05	≤ 1.55E-05	≤ 1.54E-05	
Ib/ton metal processed	≤ 1.39E-05	≤ 1.30E-05	≤ 1.34E-05	
<b>Silver (Ag) Emissions</b>				
Detection Limit Qualifier	BDL	BDL		
ug of sample collected	≤ 0.73	≤ 0.74	≤ 0.73	
ppb	≤ 0.01	≤ 0.01	≤ 0.01	
ug/dscm	≤ 0.06	≤ 0.06	≤ 0.06	
ug/dscf	≤ 1.70E-03	≤ 1.70E-03	≤ 1.70E-03	
lb/hr	≤ 5.01E-06	≤ 5.02E-06	≤ 5.02E-06	
Ib/ton metal processed	≤ 4.53E-06	≤ 4.21E-06	≤ 4.37E-06	
<b>Thallium (Tl) Emissions</b>				
Detection Limit Qualifier	BDL	BDL		
ug of sample collected	≤ 1.26	≤ 1.28	≤ 1.27	
ppb	≤ 0.01	≤ 0.01	≤ 0.01	
ug/dscm	≤ 0.11	≤ 0.11	≤ 0.11	
ug/dscf	≤ 3.11E-03	≤ 3.11E-03	≤ 3.11E-03	
lb/hr	≤ 8.63E-06	≤ 8.74E-06	≤ 8.68E-06	
Ib/ton metal processed	≤ 7.80E-06	≤ 7.32E-06	≤ 7.56E-06	
<b>Vanadium (V) Emissions</b>				
Detection Limit Qualifier	DLL	DLL		
ug of sample collected	≤ 0.23	≤ 0.21	≤ 0.22	
ppb	≤ 0.01	≤ 0.01	≤ 0.01	
ug/dscm	≤ 0.02	≤ 0.02	≤ 0.02	
ug/dscf	≤ 5.66E-04	≤ 5.66E-04	≤ 5.66E-04	
lb/hr	≤ 1.55E-06	≤ 1.42E-06	≤ 1.48E-06	
Ib/ton metal processed	≤ 1.40E-06	≤ 1.19E-06	≤ 1.29E-06	
<b>Zinc (Zn) Emissions</b>				
Detection Limit Qualifier	ADL	ADL		
ug of sample collected	18.08	11.24	14.66	
ppb	0.57	0.35	0.46	
ug/dscm	1.55	0.94	1.25	
ug/dscf	4.39E-02	2.66E-02	3.53E-02	
lb/hr	1.24E-04	7.67E-05	1.00E-04	
Ib/ton metal processed	1.12E-04	6.43E-05	8.81E-05	

### 5.3.2 Outlet East Method 29 Summaries

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Outlet East  
 Test Method: 29

Source Condition	Batch Process		
	Date	6/27/23	6/30/23
Start Time	5:15	5:25	
End Time	18:05	13:35	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	76.3	77.6	77.0
Flue Gas Moisture, percent by volume	0.9%	0.9%	0.9%
Average Flue Pressure, in. Hg	30.01	30.01	30.01
Gas Sample Volume, dscf	360.728	355.670	358.199
Average Gas Velocity, ft/sec	58.266	57.947	58.107
Gas Volumetric Flow Rate, acfm	22,037	21,916	21,977
Gas Volumetric Flow Rate, dscfm	21,565	21,401	21,483
Gas Volumetric Flow Rate, scfm	21,757	21,586	21,672
Isokinetic Variance	100.8	100.1	100.5
Sample Duration, hours	8.00	8.00	
Tons of metal processed	8.853	9.550	9.202
<b>Aluminum Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	524.65	521.27	522.96
ppb	45.76	46.11	45.93
ug/dscm	51.36	51.76	51.56
ug/dscf	1.45E+00	1.47E+00	1.46E+00
lb/hr	4.15E-03	4.15E-03	4.15E-03
lb/ton metal processed	3.75E-03	3.48E-03	3.61E-03
<b>Antimony (Sb) Emissions</b>			
Detection Limit Qualifier	BDL	DLL	
ug of sample collected	≤ 1.57	≤ 1.54	≤ 1.56
ppb	≤ 0.03	≤ 0.03	≤ 0.03
ug/dscm	≤ 0.15	≤ 0.15	≤ 0.15
ug/dscf	≤ 4.25E-03	≤ 4.25E-03	≤ 4.25E-03
lb/hr	≤ 1.24E-05	≤ 1.23E-05	≤ 1.23E-05
lb/ton metal processed	≤ 1.12E-05	≤ 1.03E-05	≤ 1.08E-05
<b>Arsenic (As) Emissions</b>			
Detection Limit Qualifier	BDL	BDL	
ug of sample collected	≤ 3.50	≤ 3.38	≤ 3.44
ppb	≤ 0.11	≤ 0.11	≤ 0.11
ug/dscm	≤ 0.34	≤ 0.34	≤ 0.34
ug/dscf	≤ 9.63E-03	≤ 9.63E-03	≤ 9.63E-03
lb/hr	≤ 2.77E-05	≤ 2.69E-05	≤ 2.73E-05
lb/ton metal processed	≤ 2.50E-05	≤ 2.25E-05	≤ 2.38E-05
<b>Barium (Ba) Emissions</b>			
Detection Limit Qualifier	ADL	DLL	
ug of sample collected	11.58	≤ 3.39	≤ 7.49
ppb	0.20	≤ 0.06	≤ 0.13
ug/dscm	1.13	≤ 0.34	≤ 0.74
ug/dscf	3.20E-02	≤ 9.63E-03	≤ 2.08E-02
lb/hr	9.16E-05	≤ 2.70E-05	≤ 5.93E-05
lb/ton metal processed	8.27E-05	≤ 2.26E-05	≤ 5.27E-05
<b>Beryllium (Be) Emissions</b>			
Detection Limit Qualifier	BDL	BDL	
ug of sample collected	≤ 0.08	≤ 0.08	≤ 0.08
ppb	≤ 0.02	≤ 0.02	≤ 0.02
ug/dscm	≤ 0.01	≤ 0.01	≤ 0.01
ug/dscf	≤ 2.83E-04	≤ 2.83E-04	≤ 2.83E-04
lb/hr	≤ 6.25E-07	≤ 5.97E-07	≤ 6.11E-07
lb/ton metal processed	≤ 5.65E-07	≤ 5.00E-07	≤ 5.32E-07
<b>Cadmium (Cd) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	0.56	0.15	0.36
ppb	0.01	0.00	0.01
ug/dscm	0.06	0.02	0.04
ug/dscf	1.70E-03	5.66E-04	1.13E-03
lb/hr	4.45E-06	1.22E-06	2.83E-06
lb/ton metal processed	4.02E-06	1.02E-06	2.52E-06

**Client:** PCC Structural, Inc.  
**Facility:** Large Parts Campus Facility - Milwaukie, OR  
**Test Location:** BH9203 Outlet East  
**Test Method:** 29

Source Condition	Batch Process		
Date	6/27/23	6/30/23	
Start Time	5:15	5:25	
End Time	18:05	13:35	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	76.3	77.6	77.0
Flue Gas Moisture, percent by volume	0.9%	0.9%	0.9%
Average Flue Pressure, in. Hg	30.01	30.01	30.01
Gas Sample Volume, dscf	360.728	355.670	358.199
Average Gas Velocity, ft/sec	58.266	57.947	58.107
Gas Volumetric Flow Rate, acfm	22,037	21,916	21,977
Gas Volumetric Flow Rate, dscfm	21,565	21,401	21,483
Gas Volumetric Flow Rate, scfm	21,757	21,586	21,672
Isokinetic Variance	100.8	100.1	100.5
Sample Duration, hours	8.00	8.00	
Tons of metal processed	8.853	9.550	9.202
<b>Chromium (Cr) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	2.82	32.17	17.49
ppb	0.13	1.48	0.80
ug/dscm	0.28	3.19	1.74
ug/dscf	7.93E-03	9.03E-02	4.91E-02
lb/hr	2.23E-05	2.56E-04	1.39E-04
lb/ton metal processed	2.01E-05	2.14E-04	1.17E-04
<b>Cobalt (Co) Emissions</b>			
Detection Limit Qualifier	DLL	ADL	
ug of sample collected	≤ 0.21	12.77	≤ 6.49
ppb	≤ 0.01	0.52	≤ 0.26
ug/dscm	≤ 0.02	1.27	≤ 0.65
ug/dscf	≤ 5.66E-04	3.60E-02	≤ 1.83E-02
lb/hr	≤ 1.67E-06	1.02E-04	≤ 5.17E-05
lb/ton metal processed	≤ 1.51E-06	8.52E-05	≤ 4.33E-05
<b>Copper (Cu) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	15.18	92.50	53.84
ppb	0.56	3.47	2.02
ug/dscm	1.49	9.18	5.34
ug/dscf	4.22E-02	2.60E-01	1.51E-01
lb/hr	1.20E-04	7.36E-04	4.28E-04
lb/ton metal processed	1.08E-04	6.17E-04	3.63E-04
<b>Lead (Pb) Emissions</b>			
Detection Limit Qualifier	DLL	DLL	
ug of sample collected	≤ 1.06	≤ 0.81	≤ 0.93
ppb	≤ 0.01	≤ 0.01	≤ 0.01
ug/dscm	≤ 0.10	≤ 0.08	≤ 0.09
ug/dscf	≤ 2.83E-03	≤ 2.27E-03	≤ 2.55E-03
lb/hr	≤ 8.37E-06	≤ 6.43E-06	≤ 7.40E-06
lb/ton metal processed	≤ 7.57E-06	≤ 5.39E-06	≤ 6.48E-06
<b>Manganese (Mn) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	2.23	91.16	46.69
ppb	0.10	3.96	2.03
ug/dscm	0.22	9.05	4.64
ug/dscf	6.23E-03	2.56E-01	1.31E-01
lb/hr	1.76E-05	7.26E-04	3.72E-04
lb/ton metal processed	1.59E-05	6.08E-04	3.12E-04
<b>Mercury (Hg) Emissions</b>			
Detection Limit Qualifier	DLL	DLL	
ug of sample collected	≤ 0.22	≤ 0.55	≤ 0.39
ppb	≤ 0.00	≤ 0.01	≤ 0.01
ug/dscm	≤ 0.02	≤ 0.05	≤ 0.04
ug/dscf	≤ 5.66E-04	≤ 1.42E-03	≤ 9.91E-04
lb/hr	≤ 1.72E-06	≤ 4.40E-06	≤ 3.06E-06
lb/ton metal processed	≤ 1.56E-06	≤ 3.69E-06	≤ 2.62E-06

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Outlet East  
 Test Method: 29

Source Condition	Batch Process		
	Date	6/27/23	6/30/23
	Start Time	5:15	5:25
	End Time	18:05	13:35
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	76.3	77.6	77.0
Flue Gas Moisture, percent by volume	0.9%	0.9%	0.9%
Average Flue Pressure, in. Hg	30.01	30.01	30.01
Gas Sample Volume, dscf	360.728	355.670	358.199
Average Gas Velocity, ft/sec	58.266	57.947	58.107
Gas Volumetric Flow Rate, acfm	22,037	21,916	21,977
Gas Volumetric Flow Rate, dscfm	21,565	21,401	21,483
Gas Volumetric Flow Rate, scfm	21,757	21,586	21,672
Isokinetic Variance	100.8	100.1	100.5
Sample Duration, hours	8.00	8.00	
Tons of metal processed	8.853	9.550	9.202
<b>Nickel (Ni) Emissions</b>			
Detection Limit Qualifier	<b>ADL</b>	<b>ADL</b>	
ug of sample collected	5.36	82.83	44.10
ppb	0.22	3.37	1.79
ug/dscm	0.53	8.22	4.38
ug/dscf	1.50E-02	2.33E-01	1.24E-01
lb/hr	4.24E-05	6.59E-04	3.51E-04
Ib/ton metal processed	3.83E-05	5.52E-04	2.95E-04
<b>Phosphorus (P) Emissions</b>			
Detection Limit Qualifier	<b>ADL</b>	<b>ADL</b>	
ug of sample collected	88.95	96.72	92.84
ppb	6.76	7.45	7.11
ug/dscm	8.71	9.60	9.16
ug/dscf	2.47E-01	2.72E-01	2.59E-01
lb/hr	7.03E-04	7.70E-04	7.37E-04
Ib/ton metal processed	6.36E-04	6.45E-04	6.40E-04
<b>Selenium (Se) Emissions</b>			
Detection Limit Qualifier	<b>DLL</b>	<b>DLL</b>	
ug of sample collected	≤ 4.01	≤ 3.10	≤ 3.56
ppb	≤ 0.12	≤ 0.09	≤ 0.11
ug/dscm	≤ 0.39	≤ 0.31	≤ 0.35
ug/dscf	≤ 1.10E-02	≤ 8.78E-03	≤ 9.91E-03
lb/hr	≤ 3.17E-05	≤ 2.47E-05	≤ 2.82E-05
Ib/ton metal processed	≤ 2.87E-05	≤ 2.07E-05	≤ 2.47E-05
<b>Silver (Ag) Emissions</b>			
Detection Limit Qualifier	<b>BDL</b>	<b>BDL</b>	
ug of sample collected	≤ 0.79	≤ 0.75	≤ 0.77
ppb	≤ 0.01	≤ 0.01	≤ 0.01
ug/dscm	≤ 0.08	≤ 0.07	≤ 0.08
ug/dscf	≤ 2.27E-03	≤ 1.98E-03	≤ 2.12E-03
lb/hr	≤ 6.22E-06	≤ 5.99E-06	≤ 6.10E-06
Ib/ton metal processed	≤ 5.62E-06	≤ 5.01E-06	≤ 5.32E-06
<b>Thallium (Tl) Emissions</b>			
Detection Limit Qualifier	<b>BDL</b>	<b>BDL</b>	
ug of sample collected	≤ 1.53	≤ 1.36	≤ 1.45
ppb	≤ 0.02	≤ 0.02	≤ 0.02
ug/dscm	≤ 0.15	≤ 0.14	≤ 0.15
ug/dscf	≤ 4.25E-03	≤ 3.96E-03	≤ 4.11E-03
lb/hr	≤ 1.21E-05	≤ 1.08E-05	≤ 1.15E-05
Ib/ton metal processed	≤ 1.09E-05	≤ 9.07E-06	≤ 1.00E-05
<b>Vanadium (V) Emissions</b>			
Detection Limit Qualifier	<b>DLL</b>	<b>DLL</b>	
ug of sample collected	≤ 0.29	≤ 0.25	≤ 0.27
ppb	≤ 0.01	≤ 0.01	≤ 0.01
ug/dscm	≤ 0.03	≤ 0.02	≤ 0.03
ug/dscf	≤ 8.50E-04	≤ 5.66E-04	≤ 7.08E-04
lb/hr	≤ 2.25E-06	≤ 1.97E-06	≤ 2.11E-06
Ib/ton metal processed	≤ 2.04E-06	≤ 1.65E-06	≤ 1.84E-06
<b>Zinc (Zn) Emissions</b>			
Detection Limit Qualifier	<b>DLL</b>	<b>DLL</b>	
ug of sample collected	≤ 27.08	≤ 24.28	≤ 25.68
ppb	≤ 0.98	≤ 0.89	≤ 0.93
ug/dscm	≤ 2.65	≤ 2.41	≤ 2.53
ug/dscf	≤ 7.50E-02	≤ 6.82E-02	≤ 7.16E-02
lb/hr	≤ 2.14E-04	≤ 1.93E-04	≤ 2.04E-04
Ib/ton metal processed	≤ 1.94E-04	≤ 1.62E-04	≤ 1.78E-04

## 5.4 Baghouse Outlet Method 0061 Summaries

### 5.4.1 Outlet West Method 0061 Summary

**Client:** PCC Structural, Inc.  
**Facility:** Large Parts Campus Facility - Milwaukie, OR  
**Test Location:** BH9203 Outlet West  
**Test Method:** 0061

Source Condition	Batch Process		
	Date	6/27/23	6/30/23
Start Time	5:15	5:25	
End Time	13:33	13:25	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
<b>Average Gas Temperature, °F</b>	73.6	80.2	76.9
<b>Flue Gas Moisture, percent by volume</b>	0.7%	1.0%	0.9%
<b>Average Flue Pressure, in. Hg</b>	30.01	30.01	30.01
<b>Gas Sample Volume, dscf</b>	357.472	379.700	368.586
<b>Average Gas Velocity, ft/sec</b>	54.703	55.084	54.894
<b>Gas Volumetric Flow Rate, acfm</b>	20,689	20,833	20,761
<b>Gas Volumetric Flow Rate, dscfm</b>	20,387	20,218	20,303
<b>Gas Volumetric Flow Rate, scfm</b>	20,531	20,422	20,477
<b>Isokinetic Variance</b>	98.6	98.8	98.7
<b>Tons of metal processed</b>	8.853	9.550	9.202
<b>Hexavalent Chromium (Cr+6) Emissions</b>			
<b>Detection Limit Qualifier</b>	ADL	ADL	
<b>ug of sample collected</b>	0.94	4.61	2.78
<b>ppb</b>	0.04	0.20	0.12
<b>ug/dscm</b>	9.00E-02	4.30E-01	2.60E-01
<b>ug/dscf</b>	2.55E-03	1.22E-02	7.36E-03
<b>lb/hr</b>	7.00E-06	3.20E-05	1.95E-05
<b>lb/ton metal processed</b>	6.33E-06	2.68E-05	1.66E-05

## 5.4.2 Outlet East Method 0061 Summary

**Client:** PCC Structural, Inc.  
**Facility:** Large Parts Campus Facility - Milwaukie, OR  
**Test Location:** BH9203 Outlet East  
**Test Method:** 0061

Source Condition	Batch Process		
	Date	6/27/23	6/30/23
Start Time	5:15	5:25	
End Time	13:33	13:25	
	Run 1	Run 2	Average
<b>Stack Conditions</b>			
Average Gas Temperature, °F	76.4	77.9	77.2
Flue Gas Moisture, percent by volume	0.9%	0.9%	0.9%
Average Flue Pressure, in. Hg	30.01	30.01	30.01
Gas Sample Volume, dscf	382.895	334.654	358.775
Average Gas Velocity, ft/sec	56.087	55.972	56.030
Gas Volumetric Flow Rate, acfm	21,213	21,169	21,191
Gas Volumetric Flow Rate, dscfm	20,753	20,652	20,703
Gas Volumetric Flow Rate, scfm	20,941	20,839	20,890
Isokinetic Variance	100.8	98.6	99.7
Tons of metal processed	8.853	9.550	9.202
<b>Hexavalent Chromium (Cr+6) Emissions</b>			
Detection Limit Qualifier	ADL	ADL	
ug of sample collected	1.97	2.29	2.13
ppb	0.08	0.11	0.10
ug/dscm	1.80E-01	2.40E-01	2.10E-01
ug/dscf	5.10E-03	6.80E-03	5.95E-03
lb/hr	1.40E-05	1.90E-05	1.65E-05
lb/ton metals processed	1.27E-05	1.59E-05	1.43E-05

## 5.5 Baghouse Outlet Volumetric Flow Rate Summaries

**PCC Structural, Inc.**  
**Large Parts Campus Facility**  
**9203 Volumetric Flow Rate Summary**

Test Location	Test Method	Date	Start Time	End Time	Square Root Dp	ACFM	DSCFM			
Southwest Outlet Stack	2	6/27/2023	5:15:00	13:33:00	1.006	21,424	21,027			
Central (west) Outlet Stack	29				1.018	21,683	21,374			
Northwest Outlet Stack	2				1.005	21,192	21,192			
<b>Average - West Stacks</b>					1.010	21,433	21,198			
<b>Summation - West Stacks</b>						64,299	63,593			
Test Location	Test Method	Date	Start Time	End Time	Square Root Dp	ACFM	DSCFM			
Southeast Outlet Stack	2	6/27/2023	5:15:00	13:33:00	1.000	21,202	20,985			
Central (east) Outlet Stack	29				1.032	22,664	22,178			
Northeast Outlet Stack	2				0.994	21,033	20,920			
<b>Average - East Stacks</b>					1.009	21,633	21,361			
<b>Summation - East Stacks</b>						64,899	64,083			

Test Location	Test Method	Date	Start Time	End Time	Square Root Dp	ACFM	DSCFM			
Southwest Outlet Stack	2	6/30/2023	5:36:00	13:35:00	1.080	22,958	22,588			
Central (west) Outlet Stack	29				1.048	22,403	21,855			
Northwest Outlet Stack	2				0.808	17,222	16,874			
<b>Average - West Stacks</b>					0.979	20,861	20,439			
<b>Summation - West Stacks</b>						62,583	61,317			
Test Location	Test Method	Date	Start Time	End Time	Square Root Dp	ACFM	DSCFM			
Southeast Outlet Stack	2	6/30/2023	5:36:00	13:35:00	0.936	20,043	19,462			
Central (east) Outlet Stack	29				1.025	22,539	22,009			
Northeast Outlet Stack	2				1.036	21,962	21,762			
<b>Average - East Stacks</b>					0.999	21,515	21,078			
<b>Summation - East Stacks</b>						64,544	63,233			

## 6.0 CERTIFICATION

Mostardi Platt is pleased to have been of service to PCC Structural, Inc. If you have any questions regarding this test report, please do not hesitate to contact us at 630-993-2100.

As the program manager, I hereby certify that this test report represents a true and accurate summary of emissions test results and the methodologies employed to obtain those results. The test program was performed in accordance with the test methods and the Mostardi Platt Quality Manual, as applicable.

MOSTARDI PLATT

  
\_\_\_\_\_  
Eric L. Ehlers

Program Manager

  
\_\_\_\_\_  
Jeffrey M. Crivlare


Quality Assurance

---

## APPENDICES

## **Appendix A - Test Section Diagrams**

## EQUAL AREA TRAVERSE FOR ROUND DUCTS



Project: PCC Structural, Inc.

Large Parts Campus

Milwaukie, Oregon

Unit: BH9203 Inlets (3 total, identical dimensions)

Stack Diameter: 3.0 Feet

Stack Area: 7.069 Square Feet



No. Points Across Diameter: 12

No. of Ports: 2

Port Length: 4.0 inches

## EQUAL AREA TRAVERSE FOR ROUND DUCTS

(PM and preliminary flows)



Project: PCC Structural, Inc.

Large Parts Campus

Milwaukie, Oregon

Unit: BH9203 Outlets (6 total, identical dimensions)

Stack Diameter: 2.833 Feet

Stack Area: 6.305 Square Feet


No. Points Across Diameter: 12

No. of Ports: 2


Port Length: 4.0 inches

## **Appendix B - Sample Train Diagrams**


## USEPA Method 2 – Type S Pitot Tube Manometer Assembly



## USEPA Method 29- Metals Sample Train Diagram



## Method 0061- Hexavalent Chromium Sampling Train



## **Appendix C - Calculation Nomenclature and Formulas**

Client: PCC Structural, Inc.  
 Plant: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet Center  
 Run: 1  
 Date: 6/27/2023

### Moisture Calculations

$$V_{wc}(\text{std}) = \frac{(V_f - V_i) * P_w * R * T_{std}}{P_{std} * M_w} = 0.04707 (V_f - V_i)$$

$$V_{wsq}(\text{std}) = \frac{(W_f - W_i) * P_w * R * T_{std}}{P_{std} * M_w} = 0.04715 (V_f - V_i)$$

$$V_m(\text{std}) = \frac{\Delta H}{17.64 * V_m * Y * \frac{P_{bar} + 13.6}{T_m}}$$

$$B_{ws} = \frac{V_{wc}(\text{std}) + V_{wsq}(\text{std})}{V_{wc}(\text{std}) + V_{wsq}(\text{std}) + V_m(\text{std})}$$

$$\begin{aligned} V_f &= 100.0 \\ V_i &= 0.0 \end{aligned}$$

$$\begin{aligned} W_f &= 30 \\ W_i &= 0.0 \end{aligned}$$

$$V_{wc}(\text{std}) = 4.71$$

$$V_{wsq}(\text{std}) = 1.41$$

$$\begin{aligned} V_m &= 407.912 \\ P_{bar} &= 29.97 \\ T_m &= 531 \end{aligned}$$

$$\begin{aligned} Y &= 0.994 \\ \Delta H &= 1.833 \end{aligned}$$

$$V_m(\text{std}) = 406.203$$

$$B_{ws} = 0.007$$

# MOSTARDI PLATT

## Volumetric Flow Nomenclature

A = Cross-sectional area of stack or duct, ft<sup>2</sup>

B<sub>ws</sub> = Water vapor in gas stream, proportion by volume

C<sub>p</sub> = Pitot tube coefficient, dimensionless

M<sub>d</sub> = Dry molecular weight of gas, lb/lb-mole

M<sub>s</sub> = Molecular weight of gas, wet basis, lb/lb-mole

M<sub>w</sub> = Molecular weight of water, 18.0 lb/lb-mole

P<sub>bar</sub> = Barometric pressure at testing site, in. Hg

P<sub>g</sub> = Static pressure of gas, in. Hg (in. H<sub>2</sub>O/13.6)

P<sub>s</sub> = Absolute pressure of gas, in. Hg = P<sub>bar</sub> + P<sub>g</sub>

P<sub>std</sub> = Standard absolute pressure, 29.92 in. Hg

Q<sub>acf m</sub> = Actual volumetric gas flow rate, acfm

Q<sub>sd</sub> = Dry volumetric gas flow rate corrected to standard conditions, dscf/hr

R = Ideal gas constant, 21.85 in. Hg-ft<sup>3</sup>/°R-lb-mole

T<sub>s</sub> = Absolute gas temperature, °R

T<sub>std</sub> = Standard absolute temperature, 528°R

v<sub>s</sub> = Gas velocity, ft/sec

V<sub>w(std)</sub> = Volume of water vapor in gas sample, corrected to standard conditions, scf

Y = Dry gas meter calibration factor

Δp = Velocity head of gas, in. H<sub>2</sub>O

K<sub>1</sub> = 17.647 °R/in. Hg

%EA = Percent excess air

%CO<sub>2</sub> = Percent carbon dioxide by volume, dry basis

%O<sub>2</sub> = Percent oxygen by volume, dry basis

%N<sub>2</sub> = Percent nitrogen by volume, dry basis

0.264 = Ratio of O<sub>2</sub> to N<sub>2</sub> in air, v/v

0.28 = Molecular weight of N<sub>2</sub> or CO, divided by 100

0.32 = Molecular weight of O<sub>2</sub> divided by 100

0.44 = Molecular weight of CO<sub>2</sub> divided by 100

13.6 = Specific gravity of mercury (Hg)

# MOSTARDI PLATT

## Volumetric Air Flow Calculations

$$Vm (std) = 17.647 \times Vm \times \left[ \frac{\left( P_{bar} + \left[ \frac{DH}{13.6} \right] \right)}{(460 + Tm)} \right] \times Y$$

$$Vw (std) = 0.0471 \times Vlc$$

$$Bws = \left[ \frac{Vw (std)}{Vw (std) + Vm (std)} \right]$$

$$Md = (0.44 \times \%CO_2) + (0.32 \times \%O_2) + [0.28 \times (100 - \%CO_2 - \%O_2)]$$

$$Ms = Md \times (1 - Bws) + (18 \times Bws)$$

$$Vs = \sqrt{\frac{(Ts + 460)}{Ms \times Ps}} \times \sqrt{DP} \times Cp \times 85.49$$

$$Acfm = Vs \times \text{Area (of stack or duct)} \times 60$$

$$Scfm = Acfm \times 17.647 \times \left[ \frac{Ps}{(460 + Ts)} \right]$$

$$Scfh = Scfm \times 60 \frac{min}{hr}$$

$$Dscfm = Scfm \times (1 - Bws)$$

# MOSTARDI PLATT

## Isokinetic Nomenclature

- A = Cross-sectional area of stack or duct, square feet  
A<sub>n</sub> = Cross-sectional area of nozzle, square feet  
B<sub>ws</sub> = Water vapor in gas stream, by volume  
C<sub>a</sub> = Acetone blank residue concentration, g/g  
C<sub>acf</sub> = Concentration of particulate matter in gas stream at actual conditions, gr/acfm  
C<sub>p</sub> = Pitot tube coefficient  
C<sub>s</sub> = Concentration of particulate matter in gas stream, dry basis, corrected to standard conditions, gr/dscf  
IKV = Isokinetic sampling variance, must be 90.0 % ≤ IKV ≤ 110.0%  
M<sub>d</sub> = Dry molecular weight of gas, lb/lb-mole  
M<sub>s</sub> = Molecular weight of gas, wet basis, lb/lb-mole  
M<sub>w</sub> = Molecular weight of water, 18.0 lb/lb-mole  
m<sub>a</sub> = Mass of residue of acetone after evaporation, grams  
P<sub>bar</sub> = Barometric pressure at testing site, inches mercury  
P<sub>g</sub> = Static pressure of gas, inches mercury (inches water/13.6)  
P<sub>s</sub> = Absolute pressure of gas, inches mercury = P<sub>bar</sub> + P<sub>g</sub>  
P<sub>std</sub> = Standard absolute pressure, 29.92 inches mercury  
Q<sub>acf</sub> = Actual volumetric gas flow rate, acfm  
Q<sub>sd</sub> = Dry volumetric gas flow rate corrected to standard conditions, dscfh  
R = Ideal gas constant, 21.85 inches mercury cubic foot/°R-lb-mole  
T<sub>m</sub> = Dry gas meter temperature, °R  
T<sub>s</sub> = Gas temperature, °R  
T<sub>std</sub> = Absolute temperature, 528°R  
V<sub>a</sub> = Volume of acetone blank, ml  
V<sub>aw</sub> = Volume of acetone used in wash, ml  
W<sub>a</sub> = Weight of residue in acetone wash, grams  
m<sub>n</sub> = Total amount of particulate matter collected, grams  
V<sub>1c</sub> = Total volume of liquid collected in impingers and silica gel, ml  
V<sub>m</sub> = Volume of gas sample as measured by dry gas meter, dcf  
V<sub>m(std)</sub> = Volume of gas sample measured by dry gas meter, corrected to standard conditions, dscf  
v<sub>s</sub> = Gas velocity, ft/sec  
V<sub>w(std)</sub> = Volume of water vapor in gas sample, corrected to standard conditions, scf  
Y = Dry gas meter calibration factor  
ΔH = Average pressure differential across the orifice meter, inches water  
Δp = Velocity head of gas, inches water  
ρ<sub>a</sub> = Density of acetone, 0.7855 g/ml (average)  
ρ<sub>w</sub> = Density of water, 0.002201 lb/ml  
θ = Total sampling time, minutes  
K<sub>1</sub> = 17.647 °R/in. Hg  
K<sub>2</sub> = 0.04707 ft<sup>3</sup>/ml  
K<sub>4</sub> = 0.09450/100 = 0.000945  
K<sub>p</sub> = 
$$85.49 \frac{\text{ft}}{\text{sec}} \left[ \frac{(\text{lb/lb - mole})(\text{in. Hg})}{(\text{°R})(\text{in. H}_2\text{O})} \right]^{1/2}$$
  
Pitot tube constant,  
%EA = Percent excess air  
%CO<sub>2</sub> = Percent carbon dioxide by volume, dry basis  
%O<sub>2</sub> = Percent oxygen by volume, dry basis  
%CO = Percent carbon monoxide by volume, dry basis  
%N<sub>2</sub> = Percent nitrogen by volume, dry basis  
0.264 = Ratio of O<sub>2</sub> to N<sub>2</sub> in air, v/v  
28 = Molecular weight of N<sub>2</sub> or CO  
32 = Molecular weight of O<sub>2</sub>  
44 = Molecular weight of CO<sub>2</sub>  
13.6 = Specific gravity of mercury (Hg)

# MOSTARDI PLATT

## Isokinetic Calculation Formulas

$$1. \quad V_{w(\text{std})} = V_{lc} \left( \frac{\rho_w}{M_w} \right) \left( \frac{RT_{\text{std}}}{P_{\text{std}}} \right) = K_2 V_{lc}$$

$$2. \quad V_{m(\text{std})} = V_m Y \left( \frac{T_{\text{std}}}{T_m} \right) \left( \frac{(P_{\text{bar}} + (\frac{\Delta H}{13.6}))}{P_{\text{std}}} \right) = K_1 V_m Y \frac{(P_{\text{bar}} + (\frac{\Delta H}{13.6}))}{T_m}$$

$$3. \quad B_{ws} = \frac{V_{w(\text{std})}}{(V_{m(\text{std})} + V_{w(\text{std})})}$$

$$4. \quad M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$$

$$5. \quad M_s = M_d (1 - B_{ws}) + 18.0(B_{ws})$$

$$6. \quad C_a = \frac{m_a}{V_a \rho_a}$$

$$7. \quad W_a = C_a V_{aw} \rho_a$$

$$8. \quad C_{acf} = 15.43 K_i \left( \frac{m_n P_s}{V_{w(\text{std})} + V_{m(\text{std})} T_s} \right)$$

$$9. \quad C_s = (15.43 \text{ grains/gram}) (m_n / V_{m(\text{std})})$$

$$10. \quad v_s = K_p C_p \sqrt{\frac{\Delta P T_s}{P_s M_s}}$$

$$11. \quad Q_{acf} = v_s A (60 \text{ sec/min})$$

$$12. \quad Q_{sd} = (3600 \text{ sec/hr}) (1 - B_{ws}) v_s \left( \frac{T_{\text{std}} P_s}{T_s P_{\text{std}}} \right) A$$

$$13. \quad E \text{ (emission rate, lbs/hr)} = Q_{std} (C_s / 7000 \text{ grains/lb})$$

$$14. \quad IKV = \frac{T_s V_{m(\text{std})} P_{\text{std}}}{T_{\text{std}} v_s \theta A_n P_s 60 (1 - B_{ws})} = K_4 \frac{T_s V_{m(\text{std})}}{P_s v_s A_n \theta (1 - B_{ws})}$$

$$15. \quad \%EA = \left( \frac{\%O_2 - (0.5 \%CO)}{0.264 \%N_2 - (\%O_2 - 0.5 \%CO)} \right) \times 100$$

# MOSTARDI PLATT

## Moisture Calculations

$$V_{wc(std)} = \frac{(V_f - V_i)\rho_w RT_{std}}{P_{std}M_w} = 0.04707(V_f - V_i)$$

$$V_{wsg(std)} = \frac{(W_f - W_i)\rho_w RT_{std}}{P_{std}M_w} = 0.04715(W_f - W_i)$$

$$V_{m(std)} = 17.64 V_m Y \frac{P_{bar} + \frac{\Delta H}{13.6}}{T_m}$$

$$B_{ws} = \frac{V_{wc(std)} + V_{wsg(std)}}{V_{wc(std)} + V_{wsg(std)} + V_{m(std)}}$$

Where:

$B_{ws}$  = Water vapor in gas stream, proportion by volume

$M_w$  = Molecular weight of water, 18.015 lb/lb-mole

$P_{bar}$  = Barometric pressure at the testing site, in. Hg

$P_{std}$  = Standard absolute pressure, 29.92 in. Hg

$R$  = Ideal gas constant, 0.048137 (in. Hg)(ft<sup>3</sup>)/(g-mole)(°R) = [21.8348(in. Hg)(ft<sup>3</sup>)/(lb-mole)(°R)]/453.592 g-mole/lb-mole

$T_m$  = Absolute average dry gas meter temperature, °R

$T_{std}$  = Standard absolute temperature, 528 °R

$V_f$  = Final volume of condenser water, ml

$V_i$  = Initial volume of condenser water, ml

$V_m$  = Dry gas volume measured by dry gas meter, dcf

$V_{m(std)}$  = Dry gas volume measured by dry gas meter, corrected to standard conditions, scf

$V_{wc(std)}$  = Volume of condensed water vapor, corrected to standard conditions, scf

$V_{wsg(std)}$  = Volume of water vapor collected in silica gel, corrected to standard conditions, scf

$W_f$  = Final weight of silica gel, g

$W_i$  = Initial weight of silica gel, g

$Y$  = Dry gas meter calibration factor

$\Delta H$  = Average pressure exerted on dry gas meter outlet by gas sample bag, in. H<sub>2</sub>O

$\rho_w$  = Density of water, 0.9982 g/ml

13.6 = Specific gravity of mercury (Hg)

17.64 =  $T_{std}/P_{std}$

0.04707 = ft<sup>3</sup>/ml                  0.04715 = ft<sup>3</sup>/g

# MOSTARDI PLATT

## Trace Metal (Including Mercury) Sample Calculations

### Concentration

$$\frac{\mu g}{m^3} = \frac{\mu g \text{ of trace metal}}{dscf \text{ volume sampled} \times 0.02832 \frac{m^3}{ft^3}}$$

### Emission Rate

$$\frac{\mu g \text{ of sample} \times \frac{1 \times 10^{-6} \text{ grams}}{\mu g}}{453.6 \text{ gr/lb}} = \text{lbs of trace metal}$$

$$\frac{\text{lbs of trace metal}}{V_m(\text{std})\text{sample}} \times dscfm \times 60 \frac{\text{min}}{\text{hr}} = \text{lbs of trace metal/hr}$$

## **Appendix D - Reference Method Test Data**

<b>Client:</b>	PCC Structural, Inc.	
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	
<b>Test Location:</b>	BH9203 Inlet West	
<b>Project #:</b>	M232604	
<b>Test Method:</b>	29	
<b>Test Engineer:</b>	JXJ	
<b>Test Technician:</b>	PPP	
	<b>Run 1</b>	<b>Run 2</b>
<b>Temp ID:</b>	CM43	CM43
<b>Meter ID:</b>	CM43	CM43
<b>Pitot ID:</b>	312	312
<b>Nozzle Diameter (Inches):</b>	0.200	0.200
<b>Meter Calibration Date:</b>	6/21/2023	6/21/2023
<b>Meter Calibration Factor (Y):</b>	0.992	0.992
<b>Meter Orifice Setting (Delta H):</b>	1.810	1.810
<b>Pitot Tube Coefficient:</b>	0.840	
<b>Probe Length (Feet):</b>	4.0	
<b>Probe Liner Material:</b>	Glass	
<b>Sample Plane:</b>	Horizontal	
<b>Port Length (Inches):</b>	4.00	
<b>Port Size (Diameter, Inches):</b>	4.00	
<b>Port Type:</b>	Nipple	
<b>Duct Shape:</b>	Circular	
<b>Diameter (Feet):</b>	3	
<b>Duct Area (Square Feet):</b>	7.069	
<b>Upstream Distance (Feet):</b>	22.0	
<b>Downstream Distance (Feet):</b>	28.0	
<b>Number of Ports Sampled:</b>	2	
<b>Number of Points per Port:</b>	12	
<b>Minutes per Point:</b>	20.0	
<b>Minutes per Reading:</b>	10.0	
<b>Total Number of Traverse Points:</b>	24	
<b>Test Length (Minutes):</b>	480	
<b>Train Type:</b>	Hot Box	
<b>Source Condition:</b>	Batch Process	
<b>Moisture Balance ID:</b>	S10-35	
<b># of Runs</b>	2	

## Run 1 - Method 29

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet West

Date: 6/27/23  
 Start Time: 5:15  
 End Time: 13:42

Source Condition: Batch Process

DRY GAS METER CONDITIONS			STACK CONDITIONS		
ΔH:	2.38	in. H <sub>2</sub> O	Static Pressure	-4.00	in. H <sub>2</sub> O
Meter Temperature, T <sub>m</sub> :	78.5	°F	Flue Pressure (Ps):	29.71	in. Hg. abs.
Sqrt ΔP:	1.180	in. H <sub>2</sub> O			
Stack Temperature, T <sub>s</sub> :	69.2	°F			
Meter Volume, V <sub>m</sub> :	417.289	ft <sup>3</sup>	Gas Weight dry, M <sub>d</sub> :	29.000	lb/lb mole
Meter Volume, V <sub>mstd</sub> :	409.320	dscf	Gas Weight wet, M <sub>s</sub> :	28.893	lb/lb mole
Meter Volume, V <sub>wstd</sub> :	4.008	wscf	Excess Air:	%	
Isokinetic Variance:	99.9	%l	Gas Velocity, V <sub>s</sub> :	66.522	fps
Test Length:	480.00	in mins.	Volumetric Flow:	28,213	acfm
Nozzle Diameter:	0.200	in inches	Volumetric Flow:	27,678	dscfm
Barometric Pressure:	30.00	in Hg	Volumetric Flow:	27,949	scfm

## MOISTURE DETERMINATION

Initial Impinger Content:	3414.2	ml	Silica Initial Wt.	810.9	grams
Final Impinger Content:	3448.6	ml	Silica Final Wt.	861.6	grams
Impinger Difference:	34.4	ml	Silica Difference:	50.7	grams
Total Water Gain:	85.1		Moisture, Bws:	0.010	Supersaturation Value, Bws: 0.024

Port-Point No.	Clock Time	Velocity Head Δp in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Temp			Meter Temp		Probe Temp °F	Filter Exit Temp °F	Impinger Exit Temp °F
					Meter Vol.	Temp °F	Inlet °F	Outlet °F	Temp °F			
1-1	5:15:00	0.51	0.84	7.983	65	57	57	251	260	50		
1-1	5:25:00	0.52	0.85	13.047	65	58	58	255	259	48		
1-2	5:35:00	1.50	2.50	18.170	64	60	60	248	260	50		
1-2	5:45:00	1.70	2.80	26.913	64	62	62	255	248	50		
1-3	5:55:00	1.40	2.30	36.257	64	62	62	250	251	48		
1-3	6:05:00	1.30	2.20	44.736	64	63	63	249	251	49		
1-4	6:15:00	1.20	2.00	52.923	63	64	64	249	257	51		
1-4	6:25:00	1.20	2.00	60.811	64	65	65	246	252	51		
1-5	6:35:00	1.10	1.80	68.706	64	66	66	250	249	52		
1-5	6:45:00	1.20	2.00	76.280	65	67	67	251	247	52		
1-6	6:55:00	1.20	2.00	84.198	66	67	67	250	260	52		
1-6	7:05:00	1.20	2.00	92.108	65	68	68	244	248	53		
1-7	7:15:00	1.20	2.00	100.041	66	69	69	254	258	54		
1-7	7:25:00	1.30	2.20	107.981	66	69	69	248	255	55		
1-8	7:35:00	1.10	1.80	116.246	66	70	70	247	258	55		
1-8	7:45:00	1.20	2.00	123.863	66	71	71	247	257	55		
1-9	7:55:00	1.10	1.85	131.833	65	71	71	261	255	55		
1-9	8:05:00	1.10	1.85	139.471	65	72	72	256	257	54		
1-10	8:15:00	1.10	1.86	147.124	65	73	73	251	260	55		
1-10	8:25:00	1.10	1.86	154.791	65	73	73	250	250	55		
1-11	8:35:00	1.10	1.86	162.458	67	74	74	245	260	55		
1-11	8:45:00	1.10	1.86	170.125	67	74	74	241	261	56		
1-12	8:55:00	1.20	2.00	177.792	67	75	75	249	253	57		
1-12	9:05:00	1.10	1.86	185.815	68	77	77	255	247	57		
	9:15:00			193.518								
2-1	9:42:00	1.30	2.20	194.815	70	82	82	253	251	59		
2-1	9:52:00	1.30	2.20	203.251	70	82	82	248	257	60		
2-2	10:02:00	1.70	2.90	211.686	69	82	82	249	259	59		
2-2	10:12:00	1.80	3.00	221.342	69	82	82	251	247	58		
2-3	10:22:00	1.70	2.90	231.278	71	83	83	255	258	57		
2-3	10:32:00	1.80	3.00	240.933	71	84	84	252	247	58		
2-4	10:42:00	1.70	2.90	250.887	71	85	85	249	247	57		
2-4	10:52:00	1.60	2.70	260.577	71	87	87	263	255	58		
2-5	11:02:00	1.70	2.90	270.013	72	87	87	258	259	61		
2-5	11:12:00	1.70	2.90	279.731	73	87	87	247	246	62		
2-6	11:22:00	1.80	3.00	289.439	73	88	88	243	255	63		
2-6	11:32:00	1.70	2.90	299.447	72	89	89	253	259	58		
2-7	11:42:00	1.70	2.90	309.200	72	90	90	256	259	49		
2-7	11:52:00	1.70	2.90	318.970	73	91	91	251	247	49		
2-8	12:02:00	1.70	2.90	328.749	74	91	91	249	251	50		
2-8	12:12:00	1.60	2.70	338.228	76	92	92	249	259	50		
2-9	12:22:00	1.70	2.90	347.997	76	92	92	250	247	50		
2-9	12:32:00	1.70	2.90	357.767	76	93	93	255	256	51		
2-10	12:42:00	1.80	3.00	367.554	75	95	95	257	258	53		
2-10	12:52:00	1.80	3.00	377.670	76	95	95	255	250	54		
2-11	13:02:00	1.70	2.90	387.778	76	96	96	248	248	49		
2-11	13:12:00	1.60	2.70	397.324	76	96	96	255	258	49		
2-12	13:22:00	1.60	2.70	406.871	76	96	96	250	250	53		
2-12	13:32:00	1.70	2.90	416.711	76	97	97	256	260	54		
	13:42:00			426.569								

Total 8:00:00 417.289 78.5 78.5

Average 2.38 69.2 78.5

Min 0.84 63.0 57.0

Max 3.00 76.0 97.0

### Impinger Weight Sheet - Run 1

Client:	PCC Structural, Inc.	Scale Calibration Check Date:	6/27/2023
Facility:	Large Parts Campus Facility - Milwaukie, OR		
Test Location:	BH9203 Inlet West		
Project #:	M232604		
Date:	6/27/2023		
Test Method:	29		
Weighed/Measured By:	CST		
Balance ID:	S10-35		
		<u>Certified Weight, grams</u>	<u>Result, grams</u>
		250	250.0
		500	500.1
		750	750.1

IMPIINGER CONTENTS	FINAL		INITIAL		GAIN	
	MLS / GRAMS		MLS / GRAMS		MLS / GRAMS	
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	608.3		603.6		4.7	
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	780.9		777.6		3.3	
Empty	658.6		657.0		1.6	
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	620.6		625.7		-5.1	
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	780.2		750.3		29.9	
Silica Gel	861.6		810.9		50.7	

<u>3,448.6</u>	<u>3,414.2</u>	<u>34.4</u>
Liquid Final	Liquid Initial	Liquid Gain
<u>861.6</u>	<u>810.9</u>	<u>50.7</u>
Silica Final	Silica Initial	Silica Gain

## Run 2 - Method 29

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet West

Date: 6/30/23  
 Start Time: 5:25  
 End Time: 13:40

Source Condition: Batch Process

DRY GAS METER CONDITIONS			STACK CONDITIONS		
ΔH:	2.58	in. H <sub>2</sub> O	Static Pressure	-3.70	in. H <sub>2</sub> O
Meter Temperature, T <sub>m</sub> :	78.5	°F	Flue Pressure (Ps):	29.78	in. Hg. abs.
Sqrt ΔP:	1.242	in. H <sub>2</sub> O			
Stack Temperature, T <sub>s</sub> :	72.7	°F			
Meter Volume, V <sub>m</sub> :	416.647	ft <sup>3</sup>			
Meter Volume, V <sub>mstd</sub> :	409.619	dscf	Gas Weight dry, Md:	29.000	lb/lb mole
Meter Volume, V <sub>wstd</sub> :	5.605	wscf	Gas Weight wet, Ms:	28.852	lb/lb mole
Isokinetic Variance:	99.6	%l	Excess Air:	%	
Test Length:	460.00	in mins.	Gas Velocity, V <sub>s</sub> :	70.225	fps
Nozzle Diameter:	0.200	in inches	Volumetric Flow:	29,783	acfm
Barometric Pressure:	30.05	in Hg	Volumetric Flow:	28,985	dscfm
			Volumetric Flow:	29,382	scfm

## MOISTURE DETERMINATION

Initial Impinger Content:	3632.5	ml	Silica Initial Wt.	807.3	grams
Final Impinger Content:	3687.2	ml	Silica Final Wt.	871.6	grams
Impinger Difference:	54.7	ml	Silica Difference:	64.3	grams
Total Water Gain:	119.0		Moisture, Bws:	0.013	Supersaturation Value, Bws: 0.027

Port-Point No.	Clock Time	Velocity	Orifice	Actual	Stack	Meter Temp		Probe	Filter	Impinger
		Head Ap in. H <sub>2</sub> O	ΔH in. H <sub>2</sub> O	Meter Vol. ft <sup>3</sup>	Temp °F	Inlet °F	Outlet °F	Temp °F	Exit Temp °F	Exit Temp °F
1-1	5:25:00	1.60	2.60	36,474	68	59	59	245	247	54
1-1	5:35:00	1.60	2.60	45,405	68	60	60	250	252	56
1-2	5:45:00	1.40	2.30	54,355	66	61	61	258	250	56
1-2	5:55:00	1.50	2.50	62,755	67	64	64	252	246	56
1-3	6:05:00	1.50	2.50	71,495	67	64	64	252	245	54
1-3	6:15:00	1.50	2.50	80,236	67	66	66	245	257	53
1-4	6:25:00	1.40	2.30	89,010	67	67	67	244	246	53
1-4	6:35:00	1.40	2.30	97,495	67	67	67	243	247	53
1-5	6:45:00	1.50	2.50	105,982	68	69	69	254	254	54
1-5	6:55:00	1.60	2.70	114,800	67	70	70	253	248	54
1-6	7:05:00	1.50	2.50	123,925	67	70	70	257	255	54
1-6	7:15:00	1.40	2.30	132,762	68	71	71	248	252	55
1-7	7:25:00	1.50	2.50	141,310	68	71	71	242	253	55
1-7	7:35:00	1.60	2.70	150,160	68	72	72	251	254	56
1-8	7:45:00	1.60	2.70	159,310	68	72	72	256	246	56
1-8	7:55:00	1.60	2.70	168,465	68	73	73	249	247	56
1-9	8:05:00	1.60	2.70	177,635	68	73	73	261	258	57
1-9	8:15:00	1.50	2.50	186,805	68	73	73	260	246	57
1-10	8:25:00	1.60	2.70	195,690	68	74	74	259	249	56
1-10	8:35:00	1.50	2.50	204,875	68	74	74	254	252	56
1-11	8:45:00	1.50	2.50	213,777	69	75	75	263	256	56
1-11	8:55:00	1.50	2.50	222,675	69	76	76	249	247	56
1-12	9:05:00	1.40	2.30	231,601	70	76	76	252	251	56
1-12	9:15:00	1.50	2.50	240,210	72	77	77	250	258	57
	9:25:00			249,120						
2-1	10:00:00	1.50	2.50	249,120	73	80	80	250	252	58
2-1	10:10:00	1.60	2.70	258,075	73	81	81	245	248	59
2-2	10:20:00	1.60	2.70	267,340	74	84	84	261	249	56
2-2	10:30:00	1.50	2.50	276,650	74	85	85	246	248	55
2-3	10:40:00	1.60	2.70	285,680	74	86	86	254	250	54
2-3	10:50:00	1.50	2.50	295,020	75	87	87	247	254	57
2-4	11:00:00	1.50	2.50	304,075	77	88	88	250	247	57
2-4	11:10:00	1.60	2.70	313,125	76	87	87	257	247	56
2-5	11:20:00	1.70	2.90	322,465	77	87	87	250	257	57
2-5	11:30:00	1.50	2.50	332,100	77	88	88	245	248	53
2-6	11:40:00	1.60	2.70	341,145	77	89	89	249	249	53
2-6	11:50:00	1.50	2.50	350,505	79	88	88	245	247	54
2-7	12:00:00	1.50	2.50	359,545	80	89	89	246	248	55
2-7	12:10:00	1.70	2.90	368,586	79	89	89	264	255	55
2-8	12:20:00	1.50	2.50	378,225	80	89	89	257	249	55
2-8	12:30:00	1.50	2.50	387,270	81	89	89	253	257	55
2-9	12:40:00	1.50	2.50	396,305	82	90	90	255	249	57
2-9	12:50:00	1.60	2.70	405,347	80	91	91	257	249	58
2-10	13:00:00	1.70	2.90	414,725	81	92	92	261	250	57
2-10	13:10:00	1.60	2.70	424,395	81	92	92	262	255	57
2-11	13:20:00	1.70	2.90	433,777	81	92	92	260	253	58
2-11	13:30:00	1.70	2.90	443,450	81	92	92	250	250	59
	13:40:00			453,121						

Total 7:40:00 416,647 78.5 78.5  
 Average 2.58 72.7 78.5  
 Min 2.30 66.0 59.0  
 Max 2.90 82.0 92.0

## Impinger Weight Sheet - Run 2

Client:	PCC Structural, Inc.	Scale Calibration Check Date:	6/30/2023
Facility:	Large Parts Campus Facility - Milwaukee, OR		
Test Location:	BH9203 Inlet West		
Project #:	M232604	Certified Weight, grams	Result, grams
Date:	6/30/2023	250	250.0
Test Method:	29	500	500.1
Weighed/Measured By:	CST	750	750.1
Balance ID:	S10-35		

IMPINGER CONTENTS	FINAL		INITIAL		GAIN	
	MLS / GRAMS		MLS / GRAMS		MLS / GRAMS	
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	780.6		735.2		45.4	
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	765.8		764.2		1.6	
Empty	661.2		655.5		5.7	
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	741.3		739.3		2.0	
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	738.3		738.3		0.0	
Silica Gel	871.6		807.3		64.3	

<u>3,687.2</u>	<u>3,632.5</u>	<u>54.7</u>
Liquid Final	Liquid Initial	Liquid Gain
<u>871.6</u>	<u>807.3</u>	<u>64.3</u>
Silica Final	Silica Initial	Silica Gain

<b>Client:</b>	PCC Structural, Inc.	
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	
<b>Test Location:</b>	BH9203 Inlet Center	
<b>Project #:</b>	M232604	
<b>Test Method:</b>	29	
<b>Test Engineer:</b>	EE	
<b>Test Technician:</b>	MTD	
	<b>Run 1</b>	<b>Run 2</b>
<b>Temp ID:</b>	CM7	CM7
<b>Meter ID:</b>	CM7	CM7
<b>Pitot ID:</b>	288	288
<b>Nozzle Diameter (Inches):</b>	0.196	0.196
<b>Meter Calibration Date:</b>	6/16/2023	6/16/2023
<b>Meter Calibration Factor (Y):</b>	0.988	0.988
<b>Meter Orifice Setting (Delta H):</b>	1.533	1.533
<b>Pitot Tube Coefficient:</b>	0.840	
<b>Probe Length (Feet):</b>	4.0	
<b>Probe Liner Material:</b>	Glass	
<b>Sample Plane:</b>	Other	
<b>Port Length (Inches):</b>	4.00	
<b>Port Size (Diameter, Inches):</b>	4.00	
<b>Port Type:</b>	Nipple	
<b>Duct Shape:</b>	Circular	
<b>Diameter (Feet):</b>	3	
<b>Duct Area (Square Feet):</b>	7.069	
<b>Upstream Distance (Feet):</b>	18.0	
<b>Downstream Distance (Feet):</b>	32.0	
<b>Number of Ports Sampled:</b>	2	
<b>Number of Points per Port:</b>	12	
<b>Minutes per Point:</b>	20.0	
<b>Minutes per Reading:</b>	10.0	
<b>Total Number of Traverse Points:</b>	24	
<b>Test Length (Minutes):</b>	480	
<b>Train Type:</b>	Hot Box	
<b>Source Condition:</b>	Batch Process	
<b>Moisture Balance ID:</b>	S10-35	
<b># of Runs</b>	2	

## Run 1 - Method 29

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet Center

Date: 6/27/23  
 Start Time: 5:15  
 End Time: 13:50

Source Condition: Batch Process

DRY GAS METER CONDITIONS			STACK CONDITIONS		
Meter Temperature, Tm:	75.5	°F	Static Pressure	-3.70	in. H <sub>2</sub> O
Sqr ΔP:	1.195	in. H <sub>2</sub> O	Flue Pressure (Ps):	29.70	in. Hg. abs.
Stack Temperature, Ts:	68.5	°F			
Meter Volume, Vmstd:	399.167	ft <sup>3</sup>	Gas Weight dry, Md:	29.000	lb/lb mole
Meter Volume, Vwstd:	391.296	dscf	Gas Weight wet, Ms:	28.924	lb/lb mole
Isokinetic Variance:	2.718	wscf			
Isokinetic Variance:	97.9	%	Gas Velocity, Vs:	67.316	fps
Test Length:	480.00	in mins.	Volumetric Flow:	28,550	acfm
Nozzle Diameter:	0.196	in inches	Volumetric Flow:	28,113	dscfm
Barometric Pressure:	29.97	in Hg	Volumetric Flow:	28,309	scfm

## MOISTURE DETERMINATION

Initial Impinger Content:	3640.5	ml	Silica Initial Wt.	816.1	grams
Final Impinger Content:	3642.8	ml	Silica Final Wt.	871.5	grams
Impinger Difference:	2.3	ml	Silica Difference:	55.4	grams
Total Water Gain:	57.7		Moisture, Bws:	0.007	Supersaturation Value, Bws: 0.024

Port-Point No.	Clock Time	Velocity Head Ap in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Meter Temp			Probe Temp °F	Filter Exit Temp °F	Impinger Exit Temp °F
					Temp °F	Inlet °F	Outlet °F			
1-1	5:15:00	1.60	3.00	460.34	63	58	55	257	250	54
1-1	5:25:00	1.60	2.10	470.60	65	58	54	241	250	61
1-2	5:35:00	1.40	1.80	479.97	61	63	57	253	250	62
1-2	5:45:00	1.40	1.80	488.00	61	65	57	236	250	49
1-3	5:55:00	1.50	1.90	496.51	63	66	58	231	250	49
1-3	6:05:00	1.50	1.90	504.510	63	66	59	251	250	50
1-4	6:15:00	1.50	1.90	511.910	63	66	59	240	250	47
1-4	6:25:00	1.50	1.90	521.000	63	67	60	241	250	47
1-5	6:35:00	1.50	1.90	529.220	63	67	61	255	250	54
1-5	6:45:00	1.50	1.90	536.054	64	67	60	264	250	46
1-6	6:55:00	1.50	1.90	545.345	63	67	61	250	250	45
1-6	7:05:00	1.50	1.90	555.420	64	69	62	243	251	47
1-7	7:15:00	1.60	2.10	565.098	64	70	62	262	250	47
1-7	7:25:00	1.50	1.90	571.640	64	72	64	241	250	49
1-8	7:35:00	1.50	1.90	579.900	64	72	64	247	250	49
1-8	7:45:00	1.40	1.80	587.620	64	77	64	260	250	48
1-9	7:55:00	1.50	1.90	596.900	64	71	65	259	250	47
1-9	8:05:00	1.50	1.90	604.220	64	75	65	235	250	47
1-10	8:15:00	1.60	2.06	614.090	65	75	66	248	250	46
1-10	8:25:00	1.60	2.06	621.240	65	74	67	238	250	47
1-11	8:35:00	1.50	1.90	630.460	65	74	67	260	250	47
1-11	8:45:00	1.40	1.80	637.790	66	76	68	244	250	48
1-12	8:55:00	1.50	1.90	646.410	67	75	69	259	250	50
1-12	9:05:00	1.50	1.90	655.230	67	76	70	255	249	53
	9:15:00			663.220						
2-1	9:50:00	1.30	1.70	663.375	68	78	73	247	248	59
2-1	10:00:00	1.30	1.70	670.750	67	78	72	241	252	51
2-2	10:10:00	1.20	1.60	678.420	67	78	72	251	251	51
2-2	10:20:00	1.20	1.60	686.340	69	80	74	258	248	47
2-3	10:30:00	1.80	2.40	695.360	70	81	76	230	251	46
2-3	10:40:00	1.80	2.40	703.630	71	84	78	253	250	47
2-4	10:50:00	1.40	1.80	712.280	72	83	78	249	250	45
2-4	11:00:00	1.40	1.80	721.780	73	84	79	239	251	49
2-5	11:10:00	1.50	2.00	730.190	72	85	80	238	251	47
2-5	11:20:00	1.40	1.80	739.040	73	85	80	243	250	48
2-6	11:30:00	1.30	1.70	747.980	74	94	81	247	250	49
2-6	11:40:00	1.30	1.70	755.440	72	85	82	249	249	50
2-7	11:50:00	1.30	1.70	763.050	72	87	82	245	250	48
2-7	12:00:00	1.30	1.70	771.020	73	88	87	236	250	47
2-8	12:10:00	1.40	1.80	778.440	74	88	83	251	250	50
2-8	12:20:00	1.30	1.70	786.180	75	89	85	260	251	51
2-9	12:30:00	1.30	1.70	794.350	76	90	86	260	251	50
2-9	12:40:00	1.30	1.70	802.310	76	89	86	253	251	55
2-10	12:50:00	1.30	1.70	810.980	76	94	98	271	250	54
2-10	13:00:00	1.30	1.70	819.160	76	97	89	235	250	54
2-11	13:10:00	1.30	1.70	827.640	76	97	90	268	251	54
2-11	13:20:00	1.40	1.80	835.660	76	96	91	263	250	53
2-12	13:30:00	1.30	1.70	843.550	80	96	91	248	249	53
2-12	13:40:00	1.20	1.60	851.740	77	97	91	246	252	54
	13:50:00			859.665						

Total 8:00:00 399.167 78.5 72.5

Average 1.87 68.5 75.5  
 Min 1.60 61.0 54.0  
 Max 3.00 80.0 98.0

### Impinger Weight Sheet - Run 1

Client:	PCC Structural, Inc.	Scale Calibration Check Date:	6/27/2023
Facility:	Large Parts Campus Facility - Milwaukee, OR		
Test Location:	BH9203 Inlet Center		
Project #:	M232604	Scale Calibration Check (see QS-6.05C for procedure)	
Date:	6/27/2023	must be within $\pm 0.5\text{g}$ of certified mass	
Test Method:	29	Certified Weight, grams	Result, grams
Weighed/Measured By:	CST	250	250.0
Balance ID:	S10-35	500	500.1
		750	750.1

IMPINGER CONTENTS	FINAL		INITIAL		GAIN	
	MLS / GRAMS		MLS / GRAMS		MLS / GRAMS	
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	770.0		752.2		17.8	
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	744.5		741.2		3.3	
Empty	653.2		653.5		-0.3	
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	746.4		756.6		-10.2	
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	728.7		737.0		-8.3	
Silica Gel	871.5		816.1		55.4	
	3,642.8		3,640.5		2.3	
	Liquid Final		Liquid Initial		Liquid Gain	
	871.5		816.1		55.4	
	Silica Final		Silica Initial		Silica Gain	

## Run 2 - Method 29

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet Center

Date: 6/30/23  
 Start Time: 5:25  
 End Time: 13:30

Source Condition: Batch Process

DRY GAS METER CONDITIONS			STACK CONDITIONS		
ΔH:	2.18	In. H <sub>2</sub> O	Static Pressure	-3.50	in. H <sub>2</sub> O
Meter Temperature, T <sub>m</sub> :	76.1	°F	Flue Pressure (Ps):	29.71	in. Hg. abs.
Sqrt ΔP:	1.255	In. H <sub>2</sub> O			
Stack Temperature, T <sub>s</sub> :	71.5	°F			
Meter Volume, V <sub>m</sub> :	396.055	ft <sup>3</sup>			
Meter Volume, V <sub>mstd</sub> :	388.108	dscf	Gas Weight dry, Md:	29.000	lb/lb mole
Meter Volume, V <sub>wstd</sub> :	4.602	wscf	Gas Weight wet, Ms:	28.871	lb/lb mole
Isokinetic Variance:	101.5	%l			
Test Length:	440.00	in mins.	Gas Velocity, V <sub>s</sub> :	70.942	fps
Nozzle Diameter:	0.196	in inches	Volumetric Flow:	30,088	acfm
Barometric Pressure:	29.97	in Hg	Volumetric Flow:	29,333	dscfm
			Volumetric Flow:	29,680	scfm

## MOISTURE DETERMINATION

Initial Impinger Content:	3635.5	ml	Silica Initial Wt.	839.1	grams
Final Impinger Content:	3671.9	ml	Silica Final Wt.	900.4	grams
Impinger Difference:	36.4	ml	Silica Difference:	61.3	grams
Total Water Gain:	97.7		Moisture, Bws:	0.012	Supersaturation Value, Bws: 0.026

Port-Point No.	Clock Time	Velocity Head Δp in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Meter Temp			Probe Temp °F	Filter Exit Temp °F	Impinger Exit Temp °F
					Temp °F	Inlet °F	Outlet °F			
1-1	5:25:00	1.50	2.10	62.145	66	57	57	254	249	45
1-1	5:35:00	1.70	2.40	69.000	65	60	56	253	251	53
1-2	5:45:00	1.60	2.20	77.630	64	64	57	250	250	54
1-2	5:55:00	1.60	2.20	86.730	64	67	58	245	250	55
1-3	6:05:00	1.60	2.20	96.330	65	69	59	258	250	55
1-3	6:15:00	1.60	2.20	106.550	65	67	60	249	250	56
1-4	6:25:00	1.60	2.20	116.340	64	68	60	262	251	56
1-4	6:35:00	1.60	2.20	125.960	65	70	62	255	250	57
1-5	6:45:00	1.50	2.10	134.990	67	70	62	260	251	56
1-5	6:55:00	1.60	2.20	144.340	66	70	63	256	249	56
1-6	7:05:00	1.60	2.20	152.360	66	71	64	249	251	57
1-6	7:15:00	1.60	2.20	160.350	67	71	65	250	251	57
1-7	7:25:00	1.60	2.20	168.680	67	72	66	242	251	58
1-7	7:35:00	1.50	2.10	177.550	66	72	71	258	251	59
1-8	7:45:00	1.50	2.10	186.340	68	73	67	249	250	60
1-8	7:55:00	1.50	2.10	194.120	67	74	67	249	250	61
1-9	8:05:00	1.60	2.20	202.720	67	74	67	262	251	62
1-9	8:15:00	1.60	2.20	214.520	67	74	68	252	250	59
1-10	8:25:00	1.60	2.20	220.330	67	75	68	245	249	59
1-10	8:35:00	1.60	2.20	229.540	67	74	68	256	250	52
1-11	8:45:00	1.50	2.10	238.780	69	76	70	245	250	54
1-11	8:55:00	1.60	2.20	247.730	68	77	70	245	249	53
1-12	9:05:00	1.60	2.20	255.890	70	77	71	244	252	54
1-12	9:15:00	1.60	2.20	265.240	71	77	71	250	250	54
	9:25:00			275.660						
2-1	10:00:00	1.50	2.10	275.660	73	72	69	241	250	56
2-1	10:10:00	1.50	2.10	284.600	73	77	71	249	250	53
2-2	10:20:00	1.50	2.10	293.200	75	79	73	248	249	52
2-2	10:30:00	1.50	2.10	302.900	75	81	74	263	252	49
2-3	10:40:00	1.50	2.10	310.300	75	82	76	239	251	51
2-3	10:50:00	1.60	2.20	319.100	74	84	78	254	249	50
2-4	11:00:00	1.60	2.20	327.600	75	86	79	252	250	51
2-4	11:10:00	1.60	2.20	336.600	75	86	81	244	250	52
2-5	11:20:00	1.60	2.20	345.000	77	87	82	245	250	50
2-5	11:30:00	1.70	2.40	353.700	77	88	84	235	252	46
2-6	11:40:00	1.70	2.40	362.300	78	89	85	250	249	47
2-6	11:50:00	1.60	2.20	371.200	78	91	86	263	250	47
2-7	12:00:00	1.60	2.20	380.400	77	92	87	249	249	48
2-7	12:10:00	1.60	2.20	390.700	78	91	88	238	249	48
2-8	12:20:00	1.60	2.20	401.400	78	91	89	248	252	47
2-8	12:30:00	1.60	2.20	412.300	80	92	90	246	248	50
2-9	12:40:00	1.60	2.20	421.500	80	93	90	250	250	50
2-9	12:50:00	1.60	2.20	430.600	80	96	91	227	250	51
2-10	13:00:00	1.50	2.10	438.300	81	97	92	251	252	51
2-10	13:10:00	1.50	2.10	445.900	81	98	93	246	251	52
2-11	13:20:00	1.50	2.10	451.200	81	98	94	255	248	54
	13:30:00			458.200						

Total 7:30:00 396.055 78.9 73.3

Average 2.18 71.5 76.1  
 Min 2.10 64.0 56.0  
 Max 2.40 81.0 98.0

## **Impinger Weight Sheet - Run 2**

Client:	PCC Structural, Inc.	Scale Calibration Check Date:	6/30/2023
Facility:	Large Parts Campus Facility - Milwaukie, OR		
Test Location:	BH9203 Inlet Center		
Project #:	M232604		
Date:	6/30/2023	Certified Weight, grams	Result, grams
Test Method:	29	250	250.0
Weighed/Measured By:	CST	500	500.1
Balance ID:	S10-35	750	750.1

IMPINGER	FINAL	INITIAL	GAIN
CONTENTS	MLS / GRAMS	MLS / GRAMS	MLS / GRAMS
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	776.1	754.7	21.4
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	760.0	746.3	13.7
Empty	630.0	624.4	5.6
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	763.7	769.2	-5.5
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	742.1	740.9	1.2
Silica Gel	900.4	839.1	61.3
<hr/>			
3,671.9		3,635.5	36.4
<hr/> Liquid Final		<hr/> Liquid Initial	<hr/> Liquid Gain
<hr/>			
900.4		839.1	61.3
<hr/> Silica Final		<hr/> Silica Initial	<hr/> Silica Gain

<b>Client:</b>	PCC Structural, Inc.	
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	
<b>Test Location:</b>	BH9203 Inlet East	
<b>Project #:</b>	M232604	
<b>Test Method:</b>	29	
<b>Test Engineer:</b>	NCC	
<b>Test Technician:</b>	PPP	
	<b>Run 1</b>	<b>Run 2</b>
<b>Temp ID:</b>	CM8	CM8
<b>Meter ID:</b>	CM8	CM8
<b>Pitot ID:</b>	290	290
<b>Nozzle Diameter (Inches):</b>	0.193	0.193
<b>Meter Calibration Date:</b>	6/6/2023	6/6/2023
<b>Meter Calibration Factor (Y):</b>	0.984	0.984
<b>Meter Orifice Setting (Delta H):</b>	1.860	1.860
<b>Pitot Tube Coefficient:</b>	0.840	
<b>Probe Length (Feet):</b>	4.0	
<b>Probe Liner Material:</b>	Glass	
<b>Sample Plane:</b>	Vertical	
<b>Port Length (Inches):</b>	4.00	
<b>Port Size (Diameter, Inches):</b>	4.00	
<b>Port Type:</b>	Nipple	
<b>Duct Shape:</b>	Circular	
<b>Diameter (Feet):</b>	3	
<b>Duct Area (Square Feet):</b>	7.069	
<b>Upstream Distance (Feet):</b>	14.0	
<b>Downstream Distance (Feet):</b>	36.0	
<b>Number of Ports Sampled:</b>	2	
<b>Number of Points per Port:</b>	12	
<b>Minutes per Point:</b>	20.0	
<b>Minutes per Reading:</b>	10.0	
<b>Total Number of Traverse Points:</b>	24	
<b>Test Length (Minutes):</b>	480	
<b>Train Type:</b>	Hot Box	
<b>Source Condition:</b>	Batch Process	
<b>Moisture Balance ID:</b>	S10-35	
<b># of Runs</b>	2	

## Run 1 - Method 29

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet East  
 Source Condition: Batch Process

Date: 6/27/23  
 Start Time: 5:15  
 End Time: 13:20

DRY GAS METER CONDITIONS			STACK CONDITIONS		
ΔH:	1.78	in. H <sub>2</sub> O	Static Pressure	-3.70	in. H <sub>2</sub> O
Meter Temperature, T <sub>m</sub> :	69.4	°F	Flue Pressure (Ps):	29.70	in. Hg. abs.
Sqrt ΔP:	1.081	in. H <sub>2</sub> O			
Stack Temperature, T <sub>s</sub> :	70.7	°F			
Meter Volume, V <sub>mstd</sub> :	364.061	ft <sup>3</sup>	Gas Weight dry, M <sub>d</sub> :	29.000	lb/lb mole
Meter Volume, V <sub>wstd</sub> :	359.466	dscf	Gas Weight wet, M <sub>s</sub> :	28.905	lb/lb mole
Nozzle Diameter:	3.127	wscf	Excess Air:	%	
Isokinetic Variance:	102.8	%l	Gas Velocity, V <sub>s</sub> :	61.064	fps
Test Length:	480.00	in mins.	Volumetric Flow:	25,898	acfm
Barometric Pressure:	29.97	in Hg	Volumetric Flow:	25,354	dscfm
			Volumetric Flow:	25,575	scfm

## MOISTURE DETERMINATION

Initial Impinger Content:	3639.4	ml	Silica Initial Wt.	837.2	grams
Final Impinger Content:	3654.3	ml	Silica Final Wt.	888.7	grams
Impinger Difference:	14.9	ml	Silica Difference:	51.5	grams
Total Water Gain:	66.4		Moisture, Bws:	0.009	Supersaturation Value, Bws: 0.026

Port-Point No.	Clock Time	Velocity Head Δp in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Meter Temp			Probe Temp °F	Filter Exit Temp °F	Impinger Exit Temp °F
					Temp °F	Inlet °F	Outlet °F			
1-1	5:15:00	1.30	2.00	74,482	65	57	57	251	254	57
1-1	5:25:00	1.30	2.00	82,300	65	57	57	251	254	54
1-2	5:35:00	1.30	2.00	90,050	65	58	58	250	254	52
1-2	5:45:00	1.30	2.00	97,840	64	58	58	251	254	51
1-3	5:55:00	1.10	1.70	105,540	65	59	59	251	254	52
1-3	6:05:00	1.10	1.70	112,700	65	60	60	251	254	51
1-4	6:15:00	1.10	1.70	119,820	66	61	61	251	254	52
1-4	6:25:00	1.10	1.70	126,930	65	61	61	251	254	52
1-5	6:35:00	1.10	1.70	134,090	65	62	62	251	254	53
1-5	6:45:00	1.10	1.70	141,230	65	63	63	250	254	53
1-6	6:55:00	1.00	1.50	148,350	66	63	63	251	254	54
1-6	7:05:00	1.00	1.50	155,160	66	64	64	251	254	53
1-7	7:15:00	1.10	1.70	161,950	66	64	64	251	254	53
1-7	7:25:00	1.10	1.70	169,090	66	64	64	251	254	53
1-8	7:35:00	1.10	1.70	176,230	67	65	65	251	254	54
1-8	7:45:00	1.10	1.70	183,370	67	65	65	251	254	55
1-9	7:55:00	1.20	1.80	190,510	66	66	66	251	254	53
1-9	8:05:00	1.10	1.70	197,940	66	67	67	252	254	52
1-10	8:15:00	1.10	1.70	205,460	66	67	67	251	254	53
1-10	8:25:00	1.20	1.80	213,670	67	68	68	252	254	54
1-11	8:35:00	1.20	1.80	220,740	67	68	68	251	254	53
1-11	8:45:00	1.20	1.80	226,470	68	69	69	251	254	55
1-12	8:55:00	1.10	1.70	233,100	69	69	69	251	254	56
1-12	9:05:00	1.10	1.70	240,320	70	71	71	251	254	58
	9:15:00			249,037						
2-1	9:30:00	1.20	1.80	249,644	70	70	70	231	254	61
2-1	9:40:00	1.20	1.80	258,520	71	70	70	231	254	61
2-2	9:50:00	1.20	1.80	262,170	71	70	70	231	254	61
2-2	10:00:00	1.20	1.80	269,310	71	71	71	250	254	62
2-3	10:10:00	1.20	1.80	275,520	71	71	71	251	254	57
2-3	10:20:00	1.20	1.80	286,220	73	71	71	245	254	57
2-4	10:30:00	1.20	1.80	293,620	74	71	71	251	254	56
2-4	10:40:00	1.20	1.80	303,390	74	71	71	250	254	58
2-5	10:50:00	1.20	1.80	310,630	74	71	71	251	254	59
2-5	11:00:00	1.30	2.00	319,250	74	71	71	250	254	57
2-6	11:10:00	1.30	2.00	328,140	75	71	71	251	254	57
2-6	11:20:00	1.30	2.00	333,710	76	71	71	250	254	58
2-7	11:30:00	1.10	1.70	342,340	76	71	71	251	254	55
2-7	11:40:00	1.20	1.80	350,370	74	71	71	251	254	55
2-8	11:50:00	1.10	1.70	358,980	75	72	72	250	254	53
2-8	12:00:00	1.10	1.70	368,130	76	74	74	251	254	54
2-9	12:10:00	1.20	1.80	377,420	78	75	75	250	254	50
2-9	12:20:00	1.20	1.80	386,640	77	78	78	251	254	50
2-10	12:30:00	1.20	1.80	395,760	79	80	80	252	254	50
2-10	12:40:00	1.20	1.80	405,150	79	82	82	251	254	50
2-11	12:50:00	1.20	1.80	412,740	79	85	85	252	254	50
2-11	13:00:00	1.20	1.80	420,660	80	87	87	251	254	50
2-12	13:10:00	1.20	1.80	427,270	80	89	89	252	254	52
2-12	13:20:00	1.20	1.80	434,280	80	91	91	251	254	51

Total ##### 364,061 69.4 69.4  
 Average 1.78 70.7 69.4  
 Min 1.50 64.0 57.0  
 Max 2.00 80.0 91.0

### Impinger Weight Sheet - Run 1

Client:	PCC Structural, Inc.	Scale Calibration Check Date:	6/27/2023
Facility:	Large Parts Campus Facility - Milwaukie, OR	<u>Scale Calibration Check (see QS-6.05C for procedure)</u>	
Test Location:	BH9203 Inlet East	must be within $\pm 0.5\text{g}$ of certified mass	
Project #:	M232604	<u>Certified Weight, grams</u>	<u>Result, grams</u>
Date:	6/27/2023	250	250.0
Test Method:	29		
Weighed/Measured By:	CST	500	500.1
Balance ID:	S10-35	750	750.1

IMPINGER	FINAL	INITIAL	GAIN
CONTENTS	MLS / GRAMS	MLS / GRAMS	MLS / GRAMS
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	732.7	720.3	12.4
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	794.0	779.6	14.4
Empty	625.5	623.2	2.3
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	768.0	779.1	-11.1
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	734.1	737.2	-3.1
Silica Gel	888.7	837.2	51.5

<u>3,654.3</u>	<u>3,639.4</u>	<u>14.9</u>
<u>Liquid Final</u>	<u>Liquid Initial</u>	<u>Liquid Gain</u>
<u>888.7</u>	<u>837.2</u>	<u>51.5</u>
<u>Silica Final</u>	<u>Silica Initial</u>	<u>Silica Gain</u>

## Run 2 - Method 29

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet East  
 Source Condition: Batch Process

DRY GAS METER CONDITIONS			STACK CONDITIONS		
ΔH:	1.66	In. H <sub>2</sub> O	Static Pressure	-3.70	in. H <sub>2</sub> O
Meter Temperature, Tm:	73.8	°F	Flue Pressure (Ps):	29.78	in. Hg. abs.
Sqrt ΔP:	1.060	In. H <sub>2</sub> O			
Stack Temperature, Ts:	73.4	°F			
Meter Volume, Vm:	322.247	ft <sup>3</sup>			
Meter Volume, Vmstd:	316.259	dscf	Gas Weight dry, Md:	29.000	lb/lb mole
Meter Volume, Vwstd:	4.870	wscf	Gas Weight wet, Ms:	28.833	lb/lb mole
Isokinetic Variance:	101.3	%	Excess Air:		%
Test Length:	440.00	in mins.	Gas Velocity, Vs:	60.004	fps
Nozzle Diameter:	0.193	in inches	Volumetric Flow:	25.449	acfm
Barometric Pressure:	30.05	in Hg	Volumetric Flow:	24.691	dscfm
			Volumetric Flow:	25.071	scfm

## MOISTURE DETERMINATION

Initial Impinger Content:	3705.5	ml	Silica Initial Wt.	802.1	grams
Final Impinger Content:	3742.2	ml	Silica Final Wt.	868.8	grams
Impinger Difference:	36.7	ml	Silica Difference:	66.7	grams
Total Water Gain:	103.4		Moisture, Bws:	0.015	
			Supersaturation Value, Bws:	0.028	

Port- Point No.	Clock Time	Velocity Head Δp in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Temp °F	Inlet °F	Meter Temp °F	Outlet °F	Probe Temp °F	Filter Exit Temp °F	Impinger Exit Temp °F
1-1	5:25:00	1.50	2.20	40.542	67	60	60	251	254	54	
1-1	5:35:00	1.50	2.20	48.120	68	61	61	250	254	55	
1-2	5:45:00	1.30	1.90	56.580	68	62	62	251	254	60	
1-2	5:55:00	1.20	1.80	65.580	67	62	62	250	254	66	
1-3	6:05:00	1.20	1.80	72.730	66	63	63	250	254	58	
1-3	6:15:00	1.20	1.80	80.220	67	64	64	251	254	58	
1-4	6:25:00	1.10	1.60	87.590	67	64	64	251	254	56	
1-4	6:35:00	1.10	1.60	94.020	68	65	65	251	254	59	
1-5	6:45:00	1.10	1.60	101.220	67	64	64	251	254	58	
1-5	6:55:00	1.10	1.60	108.780	69	67	67	249	254	61	
1-6	7:05:00	1.10	1.60	115.830	67	67	67	251	254	59	
1-6	7:15:00	1.10	1.60	123.750	67	68	68	251	254	60	
1-7	7:25:00	1.00	1.50	130.610	68	69	69	251	254	62	
1-7	7:35:00	1.10	1.60	136.490	68	69	69	250	254	60	
1-8	7:45:00	1.10	1.60	144.830	68	70	70	250	254	61	
1-8	7:55:00	1.20	1.80	151.610	69	70	70	251	254	59	
1-9	8:05:00	1.10	1.60	159.340	69	70	70	249	254	59	
1-9	8:15:00	0.95	1.40	166.220	71	71	71	251	254	60	
1-10	8:25:00	1.00	1.50	172.640	70	71	71	251	254	58	
1-10	8:35:00	1.00	1.50	179.850	70	72	72	251	254	59	
1-11	8:45:00	1.10	1.60	186.220	71	72	72	251	254	57	
1-11	8:55:00	1.00	1.50	193.040	71	73	73	251	254	59	
1-12	9:05:00	0.95	1.40	200.070	71	73	73	249	254	58	
1-12	9:15:00	1.00	1.50	206.870	72	74	74	250	254	61	
	9:25:00			213.521							
2-1	10:00:00	1.20	1.80	213.522	74	72	72	250	254	61	
2-1	10:10:00	1.10	1.60	220.450	74	72	72	250	254	61	
2-2	10:20:00	1.10	1.60	228.910	74	73	73	251	254	57	
2-2	10:30:00	1.10	1.60	236.010	75	73	73	249	254	57	
2-3	10:40:00	1.00	1.50	242.750	75	74	74	252	254	55	
2-3	10:50:00	1.10	1.60	249.690	75	75	75	251	254	58	
2-4	11:00:00	1.20	1.80	256.990	77	75	75	250	254	58	
2-4	11:10:00	1.10	1.60	264.560	78	76	76	250	254	60	
2-5	11:20:00	1.30	1.90	271.520	80	77	77	252	254	56	
2-5	11:30:00	1.20	1.80	277.750	79	77	77	250	254	53	
2-6	11:40:00	1.10	1.60	285.630	81	78	78	251	254	51	
2-6	11:50:00	1.10	1.60	292.540	80	79	79	251	254	51	
2-7	12:00:00	1.00	1.50	299.790	80	81	81	247	254	52	
2-7	12:10:00	1.10	1.60	307.540	81	83	83	251	254	54	
2-8	12:20:00	1.20	1.80	315.720	81	85	85	251	254	53	
2-8	12:30:00	1.10	1.60	322.410	81	88	88	249	254	56	
2-9	12:40:00	1.10	1.60	329.310	82	89	89	251	254	55	
2-9	12:50:00	1.10	1.60	336.510	82	91	91	251	254	57	
2-10	13:00:00	1.10	1.60	343.780	82	93	93	252	254	56	
2-10	13:10:00	1.10	1.60	350.490	83	95	95	252	254	59	
2-11	13:20:00	1.30	1.90	356.520	83	96	96	250	254	57	
2-11	13:30:00			362.790							

Total	#####	322.247	73.8	73.8
Average		1.66	73.4	73.8
Min		1.40	66.0	60.0
Max		2.20	83.0	96.0

## Impinger Weight Sheet - Run 2

Client:	PCC Structural, Inc.	Scale Calibration Check Date:	6/30/2023
Facility:	Large Parts Campus Facility - Milwaukie, OR	<u>Scale Calibration Check (see QS-6.05C for procedure)</u>	
Test Location:	BH9203 Inlet East	must be within $\pm 0.5\text{g}$ of certified mass	
Project #:	M232604	<u>Certified Weight, grams</u>	<u>Result, grams</u>
Date:	6/30/2023	250	250.0
Test Method:	29		
Weighed/Measured By:	CST	500	500.1
Balance ID:	S10-35		
		750	750.1

IMPIINGER CONTENTS	FINAL		INITIAL		GAIN	
	MLS / GRAMS		MLS / GRAMS		MLS / GRAMS	
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	779.2		752.7		26.5	
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	764.3		752.1		12.2	
Empty	657.7		657.2		0.5	
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	776.9		782.1		-5.2	
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	764.1		761.4		2.7	
Silica Gel	868.8		802.1		66.7	

<u>3,742.2</u>	<u>3,705.5</u>	<u>36.7</u>
Liquid Final	Liquid Initial	Liquid Gain
<u>868.8</u>	<u>802.1</u>	<u>66.7</u>
Silica Final	Silica Initial	Silica Gain

<b>Client:</b>	PCC Structural, Inc.	
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	
<b>Test Location:</b>	BH9203 Inlet West	
<b>Project #:</b>	M232604	
<b>Test Method:</b>	0061	
<b>Test Engineer:</b>	JXJ	
<b>Test Technician:</b>	PPP	
	<b>Run 1</b>	<b>Run 2</b>
<b>Temp ID:</b>	CM39	CM39
<b>Meter ID:</b>	CM39	CM39
<b>Pitot ID:</b>	316	316
<b>Nozzle Diameter (Inches):</b>	0.195	0.195
<b>Meter Calibration Date:</b>	6/20/2023	6/20/2023
<b>Meter Calibration Factor (Y):</b>	1.010	1.010
<b>Meter Orifice Setting (Delta H):</b>	1.924	1.924
<b>Pitot Tube Coefficient:</b>	0.840	
<b>Probe Length (Feet):</b>	4.0	
<b>Probe Liner Material:</b>	Glass	
<b>Sample Plane:</b>	Horizontal	
<b>Port Length (Inches):</b>	4.00	
<b>Port Size (Diameter, Inches):</b>	4.00	
<b>Port Type:</b>	Nipple	
<b>Duct Shape:</b>	Circular	
<b>Diameter (Feet):</b>	3	
<b>Duct Area (Square Feet):</b>	7.069	
<b>Upstream Distance (Feet):</b>	22.0	
<b>Downstream Distance (Feet):</b>	28.0	
<b>Number of Ports Sampled:</b>	2	
<b>Number of Points per Port:</b>	12	
<b>Minutes per Point:</b>	20.0	
<b>Minutes per Reading:</b>	10.0	
<b>Total Number of Traverse Points:</b>	24	
<b>Test Length (Minutes):</b>	480	
<b>Train Type:</b>	Hot Box	
<b>Source Condition:</b>	Batch Process	
<b># of Runs</b>	2	

## Run 1 - Method 0061

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet West  
 Source Condition: Batch Process

Date: 6/27/23  
 Start Time: 5:15  
 End Time: 13:42

DRY GAS METER CONDITIONS			STACK CONDITIONS		
Meter Temperature, Tm:	74.0	in. H <sub>2</sub> O	Static Pressure	-3.70	in. H <sub>2</sub> O
Sqrt AP:	1.151	in. H <sub>2</sub> O	Flue Pressure (Ps):	29.70	in. Hg. abs.
Stack Temperature, Ts:	65.6	°F			
Meter Volume, Vm:	376.631	ft <sup>3</sup>			
Meter Volume, Vmstd:	378.716	dscf	Gas Weight dry, Md:	29.000	lb/lb mole
Meter Volume, Vwstd:	0.000	wscf	Gas Weight wet, Ms:	28.890	lb/lb mole
Isokinetic Variance:	99.3	%l			
Test Length:	480.00	in mins.	Gas Velocity, Vs:	64.690	fps
Nozzle Diameter:	0.195	in inches	Volumetric Flow:	27,436	acfm
Barometric Pressure:	29.97	in Hg	Volumetric Flow:	27,084	dscfm
			Volumetric Flow:	27,358	scfm

Moisture, Bws: 0.010 Supersaturation Value, Bws: 0.021

Port- Point No.	Clock Time	Velocity Head Δp in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Temp °F	Meter Temp Inlet °F	Meter Temp Outlet °F	Impinger Exit Temp °F
1-1	5:15:00	1.50	2.35	8,005	60	52	52	50
1-1	5:25:00	1.60	2.50	16,058	60	53	53	50
1-2	5:35:00	1.30	2.05	24,391	59	54	54	52
1-2	5:45:00	1.30	2.05	31,924	60	55	55	51
1-3	5:55:00	1.60	2.50	39,465	59	56	56	53
1-3	6:05:00	1.50	2.37	47,855	59	56	56	52
1-4	6:15:00	1.40	2.22	55,979	59	57	57	54
1-4	6:25:00	1.40	2.22	63,842	60	57	57	50
1-5	6:35:00	1.50	2.40	71,698	61	59	59	52
1-5	6:45:00	1.50	2.40	79,853	61	59	59	53
1-6	6:55:00	1.30	2.10	88,008	61	60	60	54
1-6	7:05:00	1.30	2.10	95,615	60	61	61	51
1-7	7:15:00	1.40	2.20	103,244	62	61	61	53
1-7	7:25:00	1.30	2.10	111,145	62	63	63	52
1-8	7:35:00	1.20	1.90	118,788	62	64	64	52
1-8	7:45:00	1.40	2.20	126,146	62	65	65	57
1-9	7:55:00	1.30	2.10	134,108	61	65	65	55
1-9	8:05:00	1.30	2.10	141,787	60	65	65	55
1-10	8:15:00	1.20	1.90	149,475	61	67	67	56
1-10	8:25:00	1.30	2.10	156,881	61	67	67	55
1-11	8:35:00	1.40	2.20	164,590	63	69	69	54
1-11	8:45:00	1.30	2.10	172,605	63	70	70	56
1-12	8:55:00	1.40	2.30	180,343	64	71	71	55
1-12	9:05:00	1.30	2.10	188,381	65	74	74	56
	9:15:00			196,163				
2-1	9:42:00	1.40	2.30	197,361	65	81	81	54
2-1	9:52:00	1.40	2.30	205,542	64	81	81	55
2-2	10:02:00	1.40	2.30	213,731	63	81	81	54
2-2	10:12:00	1.30	2.10	221,928	66	81	81	55
2-3	10:22:00	1.40	2.30	229,804	67	81	81	56
2-3	10:32:00	1.20	1.90	237,970	68	82	82	55
2-4	10:42:00	1.30	2.10	245,537	69	83	83	57
2-4	10:52:00	1.20	1.90	253,420	68	84	84	57
2-5	11:02:00	1.20	1.90	261,014	69	85	85	56
2-5	11:12:00	1.10	1.80	268,616	70	85	85	56
2-6	11:22:00	1.50	2.50	275,887	70	86	86	56
2-6	11:32:00	1.40	2.30	284,393	70	86	86	56
2-7	11:42:00	1.20	1.90	292,611	70	87	87	56
2-7	11:52:00	1.20	1.90	300,233	70	87	87	56
2-8	12:02:00	1.30	2.10	307,855	72	88	88	57
2-8	12:12:00	1.30	2.10	315,788	73	88	88	54
2-9	12:22:00	1.30	2.10	323,713	73	88	88	54
2-9	12:32:00	1.20	1.90	331,639	73	88	88	53
2-10	12:42:00	1.30	2.10	339,253	73	88	88	53
2-10	12:52:00	1.30	2.10	347,179	74	92	92	39
2-11	13:02:00	1.20	1.90	355,155	75	92	92	63
2-11	13:12:00	1.20	1.90	362,811	75	92	92	63
2-12	13:22:00	1.20	1.90	370,466	73	92	92	63
2-12	13:32:00	1.20	1.90	378,137	73	94	94	64
	13:42:00			385,834				

Total 8:00:00 376,631 74.0 74.0

Average 2.13 65.6 74.0  
 Min 1.80 59.0 52.0  
 Max 2.50 75.0 94.0

## Run 2 - Method 0061

**Client:** PCC Structural, Inc.  
**Facility:** Large Parts Campus Facility - Milwaukie, OR  
**Test Location:** BH9203 Inlet West  
**Source Condition:** Batch Process

**Date:** 6/30/23  
**Start Time:** 5:25  
**End Time:** 13:40

## DRY GAS METER CONDITIONS

	$\Delta H$ :	2.55	in. H <sub>2</sub> O		Stack Pressure	-3.70	in. H <sub>2</sub> O
Meter Temperature, T <sub>m</sub> :	72.7	°F			Flue Pressure (Ps):	29.78	in. Hg. abs.
Sqr $\Delta P$ :	1.264	in. H <sub>2</sub> O					
Stack Temperature, T <sub>s</sub> :	69.0	°F					
Meter Volume, V <sub>m</sub> :	392.915	ft <sup>3</sup>					
Meter Volume, V <sub>mstd</sub> :	397.537	dscf			Gas Weight dry, M <sub>d</sub> :	29.000	lb/lb mole
Meter Volume, V <sub>wstd</sub> :	0.000	wscf			Gas Weight wet, M <sub>s</sub> :	28.857	lb/lb mole
Isokinetic Variance:	99.5	%I					
Test Length:	460.00	in mins.			Gas Velocity, V <sub>s</sub> :	71.200	fps
Nozzle Diameter:	0.195	in inches			Volumetric Flow:	30,197	acfmin
Barometric Pressure:	30.05	in Hg			Volumetric Flow:	29,608	dscfm
					Volumetric Flow:	29,998	scfm

Moisture, Bws: 0.013 Supersaturation Value, Bws: 0.024

Port- Point No.	Clock Time	Velocity Head Δp in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Temp °F	Meter Temp Inlet °F	Meter Temp Outlet °F	Impinger Exit Temp °F
1-1	5:25:00	1.70	2.70	59.025	62	57	57	52
1-1	5:35:00	1.70	2.70	67.640	62	61	61	61
1-2	5:45:00	1.60	2.60	76.315	61	64	64	66
1-2	5:55:00	1.60	2.60	84.790	61	64	64	64
1-3	6:05:00	1.50	2.40	93.262	61	64	64	61
1-3	6:15:00	1.60	2.50	101.468	62	64	64	60
1-4	6:25:00	1.50	2.40	109.935	62	65	65	59
1-4	6:35:00	1.50	2.40	118.150	63	67	67	61
1-5	6:45:00	1.70	2.70	126.390	63	66	66	59
1-5	6:55:00	1.60	2.60	135.140	63	66	66	59
1-6	7:05:00	1.50	2.40	143.627	62	66	66	59
1-6	7:15:00	1.50	2.40	151.856	63	65	65	59
1-7	7:25:00	1.50	2.40	160.065	63	65	65	60
1-7	7:35:00	1.60	2.60	168.267	64	65	65	59
1-8	7:45:00	1.60	2.50	176.735	64	65	65	59
1-8	7:55:00	1.60	2.50	185.200	64	65	65	59
1-9	8:05:00	1.70	2.70	193.670	64	66	66	59
1-9	8:15:00	1.60	2.50	202.415	64	66	66	58
1-10	8:25:00	1.60	2.50	210.895	64	67	67	59
1-10	8:35:00	1.50	2.40	219.395	65	67	67	59
1-11	8:45:00	1.50	2.40	227.615	65	67	67	60
1-11	8:55:00	1.60	2.50	235.835	65	67	67	60
1-12	9:05:00	1.50	2.40	244.325	66	67	67	60
1-12	9:15:00	1.50	2.40	252.540	68	68	68	58
	9:25:00			260.755				
2-1	10:00:00	1.70	2.70	260.755	69	76	76	58
2-1	10:10:00	1.70	2.70	269.625	70	75	75	58
2-2	10:20:00	1.70	2.70	278.470	70	75	75	59
2-2	10:30:00	1.70	2.70	287.310	71	75	75	59
2-3	10:40:00	1.60	2.60	296.145	72	76	76	59
2-3	10:50:00	1.50	2.40	304.725	72	76	76	60
2-4	11:00:00	1.60	2.60	313.030	74	77	77	60
2-4	11:10:00	1.70	2.70	321.610	74	77	77	57
2-5	11:20:00	1.60	2.50	330.450	75	77	77	56
2-5	11:30:00	1.60	2.60	339.025	75	80	80	51
2-6	11:40:00	1.60	2.60	347.645	75	80	80	50
2-6	11:50:00	1.50	2.40	356.260	76	81	81	50
2-7	12:00:00	1.60	2.60	364.610	76	82	82	51
2-7	12:10:00	1.70	2.70	373.251	77	83	83	50
2-8	12:20:00	1.60	2.60	382.170	77	83	83	50
2-8	12:30:00	1.50	2.40	390.818	79	84	84	48
2-9	12:40:00	1.50	2.40	399.195	79	85	85	48
2-9	12:50:00	1.70	2.70	407.588	78	86	86	48
2-10	13:00:00	1.70	2.70	416.545	79	87	87	48
2-10	13:10:00	1.70	2.70	425.510	78	88	88	49
2-11	13:20:00	1.60	2.60	434.501	78	88	88	49
2-11	13:30:00	1.60	2.60	443.220	78	88	88	50
	13:40:00			451.940				

Total 7:40:00 392.915 72.7 72.7

Average	2.55	69.0	72.7
Min	2.40	61.0	57.0
Max	2.70	79.0	88.0

<b>Client:</b>	PCC Structural, Inc.	
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	
<b>Test Location:</b>	BH9203 Inlet Center	
<b>Project #:</b>	M232604	
<b>Test Method:</b>	0061	
<b>Test Engineer:</b>	EE	
<b>Test Technician:</b>	PPP	
	<b>Run 1</b>	<b>Run 2</b>
<b>Temp ID:</b>	CM11	CM11
<b>Meter ID:</b>	CM11	CM11
<b>Pitot ID:</b>	289	289
<b>Nozzle Diameter (Inches):</b>	0.199	0.199
<b>Meter Calibration Date:</b>	6/20/2023	6/20/2023
<b>Meter Calibration Factor (Y):</b>	0.994	0.994
<b>Meter Orifice Setting (Delta H):</b>	1.833	1.833
<b>Pitot Tube Coefficient:</b>	0.840	
<b>Probe Length (Feet):</b>	4.0	
<b>Probe Liner Material:</b>	Glass	
<b>Sample Plane:</b>	Other	
<b>Port Length (Inches):</b>	4.00	
<b>Port Size (Diameter, Inches):</b>	4.00	
<b>Port Type:</b>	Nipple	
<b>Duct Shape:</b>	Circular	
<b>Diameter (Feet):</b>	3	
<b>Duct Area (Square Feet):</b>	7.069	
<b>Upstream Diameters:</b>	1.0	
<b>Downstream Diameters:</b>	8.0	
<b>Number of Ports Sampled:</b>	2	
<b>Number of Points per Port:</b>	12	
<b>Minutes per Point:</b>	20.0	
<b>Minutes per Reading:</b>	10.0	
<b>Total Number of Traverse Points:</b>	24	
<b>Test Length (Minutes):</b>	480	
<b>Train Type:</b>	Hot Box	
<b>Source Condition:</b>	Batch Process	
<b># of Runs</b>	2	

## Run 1 - Method 0061

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet Center  
 Source Condition: Batch Process

Date: 6/27/23  
 Start Time: 5:15  
 End Time: 13:50

## DRY GAS METER CONDITIONS

	ΔH:	2.47	in. H <sub>2</sub> O			Stack Conditions		
Meter Temperature, T <sub>m</sub> :	71.1	°F				Static Pressure	-3.70	in. H <sub>2</sub> O
Sqrt AP:	1.232	in. H <sub>2</sub> O				Flue Pressure (Ps):	29.70	in. Hg. abs.
Stack Temperature, T <sub>s</sub> :	68.8	°F						
Meter Volume, V <sub>m</sub> :	407.912	ft <sup>3</sup>						
Meter Volume, V <sub>mstd</sub> :	406.203	dscf				Gas Weight dry, M <sub>d</sub> :	29.000	lb/lb mole
Meter Volume, V <sub>wstd</sub> :	0.000	wscf				Gas Weight wet, M <sub>w</sub> :	28.923	lb/lb mole
Isokinetic Variance:	95.6	%l						
Test Length:	480.00	in mins.				Gas Velocity, V <sub>s</sub> :	69.435	fps
Nozzle Diameter:	0.199	in inches				Volumetric Flow:	29,448	acf m
Barometric Pressure:	29.97	in Hg				Volumetric Flow:	28,980	dscfm
						Volumetric Flow:	29,185	scfm

Moisture, Bws: 0.007 Supersaturation Value, Bws: 0.024

Port- Point No.	Clock Time	Velocity Head Δp in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Temp °F	Meter Temp Inlet °F	Meter Temp Outlet °F	Impinger Exit Temp °F
1-1	5:15:00	1.60	2.50	621.033	63	56	54	58
1-1	5:25:00	1.40	2.30	629.300	65	63	56	58
1-2	5:35:00	1.20	2.00	638.100	62	59	56	58
1-2	5:45:00	1.20	2.00	646.100	61	65	57	55
1-3	5:55:00	1.30	2.10	654.200	63	66	58	54
1-3	6:05:00	1.30	2.10	661.600	63	66	58	51
1-4	6:15:00	1.30	2.10	669.500	64	61	67	51
1-4	6:25:00	1.40	2.30	677.310	64	61	58	51
1-5	6:35:00	1.40	2.30	685.530	65	61	58	52
1-5	6:45:00	1.40	2.30	693.032	65	61	58	51
1-6	6:55:00	1.40	2.30	701.555	64	61	58	52
1-6	7:05:00	1.50	2.50	710.539	64	62	59	52
1-7	7:15:00	1.50	2.50	720.135	65	62	60	53
1-7	7:25:00	1.40	2.30	727.860	65	63	60	52
1-8	7:35:00	1.40	2.30	735.000	64	64	61	53
1-8	7:45:00	1.40	2.30	743.550	64	64	62	52
1-9	7:55:00	1.30	2.10	751.980	64	64	62	53
1-9	8:05:00	1.40	2.30	760.370	65	64	62	53
1-10	8:15:00	1.50	2.50	769.240	66	63	63	53
1-10	8:25:00	1.50	2.50	776.860	65	66	64	52
1-11	8:35:00	1.50	2.50	782.560	66	66	64	52
1-11	8:45:00	1.50	2.50	793.830	67	67	64	53
1-12	8:55:00	1.40	2.30	802.160	67	68	65	52
1-12	9:05:00	1.50	2.50	810.330	67	68	66	53
	9:15:00			817.880				
2-1	9:50:00	1.60	2.60	818.025	68	70	69	57
2-1	10:00:00	1.50	2.40	826.520	61	70	69	59
2-2	10:10:00	1.60	2.60	836.230	69	70	69	61
2-2	10:20:00	1.50	2.40	845.000	69	70	69	59
2-3	10:30:00	1.70	2.70	854.100	70	71	69	60
2-3	10:40:00	2.00	3.20	862.670	72	72	70	62
2-4	10:50:00	1.60	2.60	870.990	72	72	70	63
2-4	11:00:00	1.40	1.80	879.290	73	84	79	64
2-5	11:10:00	1.60	2.60	887.950	73	73	73	60
2-5	11:20:00	1.60	2.60	896.230	73	75	74	55
2-6	11:30:00	1.60	2.70	905.160	73	76	75	55
2-6	11:40:00	1.70	2.70	913.650	73	78	76	55
2-7	11:50:00	1.70	2.70	922.370	72	80	78	54
2-7	12:00:00	1.70	2.70	931.550	74	83	80	55
2-8	12:10:00	1.60	2.60	940.090	74	84	82	56
2-8	12:20:00	1.60	2.60	948.900	75	85	83	56
2-9	12:30:00	1.70	2.70	968.540	76	90	87	56
2-9	12:40:00	1.70	2.70	977.950	77	90	87	56
2-10	12:50:00	1.80	2.90	985.000	77	92	89	55
2-10	13:00:00	1.80	2.90	985.000	77	92	89	56
2-11	13:10:00	1.80	2.90	994.180	76	93	90	56
2-11	13:20:00	1.50	2.40	1003.190	77	94	91	56
2-12	13:30:00	1.60	2.60	1011.560	77	94	92	56
2-12	13:40:00	1.50	2.40	1020.740	77	95	93	56
	13:50:00			1029.090				

Total 8:00:00 407.912 72.4 69.9

Average	2.47	68.8	71.1
Min	1.80	61.0	54.0
Max	3.20	77.0	95.0

**Run 2 - Method 0061**

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Inlet Center**

**Source Condition: Batch Process**

**Date:** 6/30/23  
**Start Time:** 5:25  
**End Time:** 13:30

DRY GAS METER CONDITIONS			STACK CONDITIONS		
Meter Temperature, Tm:	74.9	in. H <sub>2</sub> O	Static Pressure	-3.50	in. H <sub>2</sub> O
Sqrt AP:	1.146	in. H <sub>2</sub> O	Flue Pressure (Ps):	29.71	in. Hg. abs.
Stack Temperature, Ts:	71.5	°F			
Meter Volume, Vm:	356.224	ft <sup>3</sup>			
Meter Volume, Vmstd:	352.050	dscf	Gas Weight dry, Md:	29.000	lb/lb mole
Meter Volume, Vwstd:	0.000	wscf	Gas Weight wet, Ms:	28.868	lb/lb mole
Isokinetic Variance:	97.8	%l			
Test Length:	440.00	in mins.	Gas Velocity, Vs:	64.794	fps
Nozzle Diameter:	0.199	in inches	Volumetric Flow:	27,480	acfm
Barometric Pressure:	29.97	in Hg	Volumetric Flow:	26,785	dscfm
			Volumetric Flow:	27,110	scfm

Moisture, Bws: 0.012 Supersaturation Value, Bws: 0.026

Port- Point No.	Clock Time	Velocity Head Δp in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Temp °F	Meter Temp Inlet °F	Meter Temp Outlet °F	Impinger Exit Temp °F
1-1	5:25:00	1.30	2.20	31.956	68	60	58	58
1-1	5:35:00	1.20	2.00	40.230	68	62	58	58
1-2	5:45:00	1.00	1.70	48.410	67	65	60	58
1-2	5:55:00	1.10	1.90	55.440	66	65	60	55
1-3	6:05:00	1.10	1.90	62.970	67	66	61	54
1-3	6:15:00	1.10	1.90	70.580	67	67	60	51
1-4	6:25:00	1.10	1.90	77.670	67	67	61	51
1-4	6:35:00	1.10	1.90	85.430	68	68	62	51
1-5	6:45:00	1.10	1.90	92.570	69	69	62	52
1-5	6:55:00	1.10	1.90	99.750	68	69	64	51
1-6	7:05:00	1.10	1.90	107.460	68	70	64	52
1-6	7:15:00	1.10	1.90	115.480	69	70	65	52
1-7	7:25:00	1.10	1.90	122.820	67	70	65	53
1-7	7:35:00	1.10	1.90	130.830	68	70	66	52
1-8	7:45:00	1.10	1.90	138.140	68	72	66	53
1-8	7:55:00	1.10	1.90	145.530	68	71	67	52
1-9	8:05:00	1.10	1.90	153.540	68	72	67	53
1-9	8:15:00	1.10	1.90	160.410	68	72	68	53
1-10	8:25:00	1.10	1.90	168.130	68	73	68	53
1-10	8:35:00	1.10	1.90	175.640	69	73	69	52
1-11	8:45:00	1.10	1.90	181.970	70	74	70	52
1-11	8:55:00	1.10	1.90	189.580	69	74	70	53
1-12	9:05:00	1.10	1.90	196.820	71	72	71	52
1-12	9:15:00	1.10	1.90	204.130	71	70	71	53
	9:25:00			212.090				
2-1	10:00:00	1.60	2.70	216.010	71	70	68	57
2-1	10:10:00	1.50	2.50	220.400	71	73	69	59
2-2	10:20:00	1.50	2.50	231.900	72	74	70	61
2-2	10:30:00	1.50	2.50	235.840	72	75	70	59
2-3	10:40:00	1.50	2.50	244.900	72	77	71	60
2-3	10:50:00	1.50	2.50	253.400	72	78	72	62
2-4	11:00:00	1.60	2.70	262.000	73	80	74	63
2-4	11:10:00	1.60	2.70	270.700	73	81	76	64
2-5	11:20:00	1.60	2.70	279.500	75	83	78	60
2-5	11:30:00	1.70	2.90	288.000	76	85	81	55
2-6	11:40:00	1.70	2.90	296.600	75	87	83	55
2-6	11:50:00	1.60	2.70	305.200	75	90	85	55
2-7	12:00:00	1.60	2.70	313.800	77	91	86	54
2-7	12:10:00	1.60	2.70	322.000	78	93	88	55
2-8	12:20:00	1.60	2.70	333.100	77	94	89	56
2-8	12:30:00	1.60	2.70	343.400	78	95	90	56
2-9	12:40:00	1.60	2.70	352.600	78	96	91	56
2-9	12:50:00	1.60	2.70	361.700	79	97	92	56
2-10	13:00:00	1.50	2.50	369.700	78	97	93	55
2-10	13:10:00	1.50	2.50	378.200	79	98	94	56
2-11	13:20:00	1.50	2.50	384.400	79	97	94	56
	13:30:00			392.100				

Total 7:30:00 356.224 77.2 72.6

Average 2.25  
Min 1.70  
Max 2.90

<b>Client:</b>	PCC Structural, Inc.	
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	
<b>Test Location:</b>	BH9203 Inlet East	
<b>Project #:</b>	M232604	
<b>Test Method:</b>	0061	
<b>Test Engineer:</b>	NCC	
<b>Test Technician:</b>	PPP	
<b>Temp ID:</b>	<b>Run 1</b>	<b>Run 2</b>
CM10	CM10	
<b>Meter ID:</b>	CM10	CM10
<b>Pitot ID:</b>	291	291
<b>Nozzle Diameter (Inches):</b>	0.195	0.195
<b>Meter Calibration Date:</b>	6/19/2023	6/19/2023
<b>Meter Calibration Factor (Y):</b>	0.990	0.990
<b>Meter Orifice Setting (Delta H):</b>	1.849	1.849
<b>Pitot Tube Coefficient:</b>	0.840	
<b>Probe Length (Feet):</b>	4.0	
<b>Probe Liner Material:</b>	Glass	
<b>Sample Plane:</b>	Vertical	
<b>Port Length (Inches):</b>	4.00	
<b>Port Size (Diameter, Inches):</b>	4.00	
<b>Port Type:</b>	Nipple	
<b>Duct Shape:</b>	Circular	
<b>Diameter (Feet):</b>	3	
<b>Duct Area (Square Feet):</b>	7.069	
<b>Upstream Diameters:</b>	2.0	
<b>Downstream Diameters:</b>	>8	
<b>Number of Ports Sampled:</b>	2	
<b>Number of Points per Port:</b>	12	
<b>Minutes per Point:</b>	20.0	
<b>Minutes per Reading:</b>	10.0	
<b>Total Number of Traverse Points:</b>	24	
<b>Test Length (Minutes):</b>	480	
<b>Train Type:</b>	Hot Box	
<b>Source Condition:</b>	Batch Process	
<b># of Runs</b>	2	

## Run 1 - Method 0061

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Inlet East  
 Source Condition: Batch Process

Date: 6/27/23  
 Start Time: 5:15  
 End Time: 13:20

DRY GAS METER CONDITIONS			STACK CONDITIONS		
Meter Temperature, Tm:	68.6	in. H <sub>2</sub> O °F	Static Pressure:	-3.70	in. H <sub>2</sub> O
Sqrt AP:	1.068	in. H <sub>2</sub> O	Flue Pressure (Ps):	29.70	in. Hg. abs.
Stack Temperature, Ts:	70.1	°F			
Meter Volume, Vm:	362.725	ft <sup>3</sup>			
Meter Volume, Vmstd:	360.840	dscf	Gas Weight dry, Md:	29.000	lb/lb mole
Meter Volume, Vwstd:	0.000	wscf	Gas Weight wet, Ms:	28.901	lb/lb mole
Isokinetic Variance:	102.4	%l			
Test Length:	480.00	in mins.	Gas Velocity, Vs:	60.266	fps
Nozzle Diameter:	0.195	in inches	Volumetric Flow:	25,560	acf m
Barometric Pressure:	29.97	in Hg	Volumetric Flow:	25,042	dscfm
			Volumetric Flow:	25,269	scfm

Moisture, Bws: 0.009 Supersaturation Value, Bws: 0.025

Port- Point No.	Clock Time	Velocity Head Δp in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Temp °F	Meter Temp Inlet °F	Meter Temp Outlet °F	Impinger Exit Temp °F
1-1	5:15:00	1.30	2.00	35.151	65	59	59	61
1-1	5:25:00	1.30	2.00	43.040	65	60	59	60
1-2	5:35:00	1.30	2.00	50.840	65	61	59	60
1-2	5:45:00	1.20	1.80	58.660	66	63	59	58
1-3	5:55:00	1.20	1.80	66.150	66	63	60	57
1-3	6:05:00	1.00	1.50	73.650	66	63	60	57
1-4	6:15:00	1.00	1.50	80.510	66	64	60	57
1-4	6:25:00	1.00	1.50	87.350	66	64	60	56
1-5	6:35:00	1.20	1.80	94.220	66	65	61	56
1-5	6:45:00	1.20	1.80	101.710	65	66	61	57
1-6	6:55:00	1.00	1.50	109.230	65	66	62	58
1-6	7:05:00	1.00	1.50	116.060	66	67	62	58
1-7	7:15:00	1.00	1.50	122.920	66	67	63	57
1-7	7:25:00	1.00	1.50	129.770	66	68	63	57
1-8	7:35:00	1.00	1.50	136.630	66	68	63	58
1-8	7:45:00	1.00	1.50	143.440	66	69	63	59
1-9	7:55:00	1.10	1.70	150.320	66	69	64	57
1-9	8:05:00	1.00	1.50	157.510	66	69	64	55
1-10	8:15:00	1.00	1.50	165.312	66	69	64	61
1-10	8:25:00	1.00	1.50	172.820	66	70	64	57
1-11	8:35:00	1.10	1.70	179.230	67	71	65	57
1-11	8:45:00	1.10	1.70	185.880	67	70	65	59
1-12	8:55:00	1.10	1.70	192.120	69	71	66	62
1-12	9:05:00	1.10	1.70	198.550	71	72	66	62
	9:15:00			206.777				
2-1	9:30:00	1.10	1.70	207.551	69	73	68	56
2-1	9:40:00	1.10	1.70	215.270	70	73	68	57
2-2	9:50:00	1.10	1.70	219.150	70	74	68	56
2-2	10:00:00	1.20	1.80	225.620	69	73	68	58
2-3	10:10:00	1.10	1.70	233.050	70	73	69	58
2-3	10:20:00	0.97	1.50	243.520	74	72	68	59
2-4	10:30:00	1.10	1.70	251.020	73	73	68	60
2-4	10:40:00	1.10	1.70	259.640	73	72	68	60
2-5	10:50:00	1.10	1.70	266.250	73	76	69	64
2-5	11:00:00	1.20	1.80	273.760	72	74	68	59
2-6	11:10:00	1.30	2.00	282.090	73	75	68	57
2-6	11:20:00	1.20	1.80	288.970	74	74	70	59
2-7	11:30:00	1.20	1.80	295.980	74	75	70	59
2-7	11:40:00	1.20	1.80	303.660	74	75	70	60
2-8	11:50:00	1.30	2.00	311.540	73	75	72	60
2-8	12:00:00	1.30	2.00	319.120	75	76	70	61
2-9	12:10:00	1.20	1.80	327.120	76	76	71	61
2-9	12:20:00	1.30	2.00	336.350	77	77	73	61
2-10	12:30:00	1.20	1.80	345.320	77	78	72	60
2-10	12:40:00	1.20	1.80	355.360	77	77	73	61
2-11	12:50:00	1.30	2.00	364.560	79	79	72	60
2-11	13:00:00	1.30	2.00	373.870	78	78	73	59
2-12	13:10:00	1.30	2.00	381.230	78	81	74	59
2-12	13:20:00	1.30	2.00	389.130	78	82	76	59
				398.650				

Total ##### 362.725 70.9 66.2

Average 1.74 70.1 68.6  
 Min 1.50 65.0 59.0  
 Max 2.00 79.0 82.0

## Run 2 - Method 0061

Client: PCC Structural, Inc.

Facility: Large Parts Campus Facility - Milwaukie, OR

Test Location: BH9203 Inlet East

Source Condition: Batch Process

Date: 6/30/23  
 Start Time: 5:25  
 End Time: 14:00

DRY GAS METER CONDITIONS			STACK CONDITIONS		
Meter Temperature, Tm:	74.0	in. H <sub>2</sub> O °F	Static Pressure:	-3.70	in. H <sub>2</sub> O
Sqrt AP:	1.061	in. H <sub>2</sub> O	Flue Pressure (Ps):	29.78	in. Hg. abs.
Stack Temperature, Ts:	72.2	°F			
Meter Volume, Vm:	329.806	ft <sup>3</sup>			
Meter Volume, Vmstd:	325.578	dscf	Gas Weight dry, Md:	29.000	lb/lb mole
Meter Volume, Vwstd:	0.000	wscf	Gas Weight wet, Ms:	28.835	lb/lb mole
Isokinetic Variance:	93.5	%l			
Test Length:	480.00	in mins.	Gas Velocity, Vs:	59.985	fps
Nozzle Diameter:	0.195	in inches	Volumetric Flow:	25,441	acfm
Barometric Pressure:	30.05	in Hg	Volumetric Flow:	24,743	dscfm
			Volumetric Flow:	25,120	scfm

Moisture, Bws: 0.015 Supersaturation Value, Bws: 0.027

Port-Point No.	Clock Time	Velocity Head Δp in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Temp °F	Meter Temp Inlet °F	Meter Temp Outlet °F	Impinger Exit Temp °F
1-1	5:25:00	1.20	1.80	5,634	67	59	60	54
1-1	5:35:00	1.20	1.80	12,253	67	63	60	57
1-2	5:45:00	1.20	1.80	20,170	67	67	61	64
1-2	5:55:00	1.20	1.80	27,920	66	70	62	65
1-3	6:05:00	1.20	1.80	36,180	71	63	63	60
1-3	6:15:00	1.10	1.70	43,910	66	74	65	62
1-4	6:25:00	1.10	1.70	51,020	66	72	65	62
1-4	6:35:00	1.10	1.70	58,370	66	72	65	59
1-5	6:45:00	1.10	1.70	65,550	66	74	66	59
1-5	6:55:00	1.10	1.70	72,340	66	75	67	59
1-6	7:05:00	1.00	1.50	79,850	66	75	67	59
1-6	7:15:00	1.10	1.70	87,010	66	73	67	59
1-7	7:25:00	1.10	1.70	93,420	66	74	68	60
1-7	7:35:00	1.10	1.70	100,020	66	74	68	63
1-8	7:45:00	1.10	1.70	107,080	67	74	69	61
1-8	7:55:00	1.10	1.70	114,520	67	75	69	61
1-9	8:05:00	1.20	1.80	122,610	69	76	70	61
1-9	8:15:00	1.20	1.80	129,470	70	76	70	61
1-10	8:25:00	1.10	1.70	137,810	69	77	70	60
1-10	8:35:00	1.00	1.50	145,140	69	77	70	61
1-11	8:45:00	1.10	1.70	152,360	69	77	71	61
1-11	8:55:00	1.20	1.80	159,120	69	79	71	61
1-12	9:05:00	1.10	1.70	166,950	69	78	71	62
1-12	9:15:00	1.20	1.80	174,220	69	77	72	64
	9:25:00			181,261				
2-1	10:00:00	1.00	1.50	181,381	72	78	72	66
2-1	10:10:00	1.20	1.80	188,930	72	78	72	66
2-2	10:20:00	1.10	1.70	196,390	73	80	75	67
2-2	10:30:00	1.10	1.70	203,820	73	80	75	67
2-3	10:40:00	1.10	1.70	210,510	74	81	74	66
2-3	10:50:00	1.20	1.80	218,720	75	81	75	65
2-4	11:00:00	1.10	1.70	225,860	76	82	78	64
2-4	11:10:00	1.10	1.70	231,790	76	81	76	64
2-5	11:20:00	1.20	1.80	238,950	76	82	77	60
2-5	11:30:00	1.10	1.70	247,520	77	83	78	58
2-6	11:40:00	1.20	1.80	254,870	78	82	80	58
2-6	11:50:00	1.10	1.70	262,620	78	81	80	57
2-7	12:00:00	1.10	1.70	270,240	79	79	79	57
2-7	12:10:00	1.10	1.70	277,870	81	79	78	58
2-8	12:20:00	1.20	1.80	284,810	82	79	76	58
2-8	12:30:00	1.10	1.70	292,520	80	78	75	59
2-9	12:40:00	1.10	1.70	299,770	81	79	76	59
2-9	12:50:00	1.10	1.70	306,220	82	81	78	60
2-10	13:00:00	1.00	1.50	314,010	81	82	78	62
2-10	13:10:00	1.10	1.70	321,870	82	83	80	67
2-11	13:20:00	1.30	2.00	328,550	82	84	81	67
2-11	13:30:00			335,560				
2-12	13:40:00							
2-12	13:50:00							
	14:00:00							

Total 8:00:00 329.806 76.5 71.6

Average 1.72  
 Min 1.50  
 Max 2.00

<b>Client:</b>	PCC Structural, Inc.	
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	
<b>Test Location:</b>	BH9203 Outlet West	
<b>Project #:</b>	M232604	
<b>Test Method:</b>	29	
<b>Test Engineer:</b>	VTV	
<b>Test Technician:</b>	CIR1	
	<b>Run 1</b>	<b>Run 2</b>
<b>Temp ID:</b>	CM1	CM1
<b>Meter ID:</b>	CM1	CM1
<b>Pitot ID:</b>	931	931
<b>Nozzle Diameter (Inches):</b>	0.215	0.215
<b>Meter Calibration Date:</b>	6/13/2023	6/13/2023
<b>Meter Calibration Factor (Y):</b>	1.003	1.003
<b>Meter Orifice Setting (Delta H):</b>	1.570	1.570
<b>Nozzle Kit ID Number and Material:</b>	glass	glass
<b>Pitot Tube Coefficient:</b>	0.840	
<b>Probe Length (Feet):</b>	4.0	
<b>Probe Liner Material:</b>	Glass	
<b>Sample Plane:</b>	Horizontal	
<b>Port Length (Inches):</b>	4.00	
<b>Port Size (Diameter, Inches):</b>	4.00	
<b>Port Type:</b>	flange	
<b>Duct Shape:</b>	Circular	
<b>Diameter (Feet):</b>	2.833	
<b>Duct Area (Square Feet):</b>	6.304	
<b>Upstream Diameters:</b>	7.5	
<b>Downstream Diameters:</b>	72.0	
<b>Number of Ports Sampled:</b>	2	
<b>Number of Points per Port:</b>	12	
<b>Minutes per Point:</b>	20.0	
<b>Minutes per Reading:</b>	10.0	
<b>Total Number of Traverse Points:</b>	24	
<b>Test Length (Minutes):</b>	480	
<b>Train Type:</b>	Anderson Box	
<b>Source Condition:</b>	Batch Process	
<b>Moisture Balance ID:</b>	S10-35	
<b># of Runs</b>	2	

## Run 1 - Method 29

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Outlet West

Date: 6/27/23  
 Start Time: 5:15  
 End Time: 13:33

Source Condition: Batch Process

DRY GAS METER CONDITIONS			STACK CONDITIONS		
Meter Temperature, Tm:	85.7	in. H <sub>2</sub> O	Static Pressure	0.50	in. H <sub>2</sub> O
Sqrt ΔP:	1.018	°F	Flue Pressure (Ps):	30.01	in. Hg. abs.
Stack Temperature, Ts:	73.7	°F			
Meter Volume, Vmstd:	422.532	ft <sup>3</sup>	Gas Weight dry, Md:	29.000	lb/lb mole
Meter Volume, Vwstd:	412.857	dscf	Gas Weight wet, Ms:	28.928	lb/lb mole
Isokinetic Variance:	100.7	%l			
Test Length:	480.00	in mins.	Gas Velocity, Vs:	57.331	fpm
Nozzle Diameter:	0.215	in inches	Volumetric Flow:	21,683	acfm
Barometric Pressure:	29.97	in Hg	Volumetric Flow:	21,374	dscfm
			Volumetric Flow:	21,514	scfm

## MOISTURE DETERMINATION

Initial Impinger Content:	3637.0	ml	Silica Initial Wt.	814.4	grams
Final Impinger Content:	3649.2	ml	Silica Final Wt.	859.6	grams
Impinger Difference:	12.2	ml	Silica Difference:	45.2	grams
Total Water Gain:	57.4		Moisture, Bws:	0.007	Supersaturation Value, Bws: 0.028

Port-Point No.	Clock Time	Velocity Head Ap in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Meter Temp			Probe Temp °F	Filter Exit Temp °F	Impinger Exit Temp °F
					Temp °F	Inlet °F	Outlet °F			
1-1	5:15:00	0.83	1.70	46,468	65	58	58	260	250	45
1-1	5:25:00	0.85	1.70	54,250	67	62	58	250	259	48
1-2	5:35:00	0.87	1.80	62,130	66	65	59	260	260	41
1-2	5:45:00	1.00	2.00	70,160	67	68	60	260	262	48
1-3	5:55:00	1.10	2.00	78,150	66	70	61	260	260	49
1-3	6:05:00	1.10	2.00	86,910	67	72	63	258	260	50
1-4	6:15:00	1.10	2.20	95,710	67	73	64	260	260	51
1-4	6:25:00	1.30	2.60	104,240	67	74	65	252	260	51
1-5	6:35:00	1.20	2.40	113,530	67	75	66	260	260	52
1-5	6:45:00	1.20	2.40	122,850	67	76	67	260	260	54
1-6	6:55:00	1.20	2.40	132,330	68	77	68	260	260	57
1-6	7:05:00	1.20	2.40	141,870	69	78	69	250	260	59
1-7	7:15:00	1.20	2.40	151,420	69	80	72	260	260	61
1-7	7:25:00	1.20	2.40	160,470	70	83	74	250	260	62
1-8	7:35:00	1.20	2.50	169,790	70	84	77	260	260	59
1-8	7:45:00	1.20	2.50	179,560	69	84	78	260	260	52
1-9	7:55:00	1.10	2.20	188,830	69	83	77	260	260	51
1-9	8:05:00	1.10	2.30	197,790	67	82	77	250	260	53
1-10	8:15:00	1.00	2.00	206,750	69	82	76	260	260	53
1-10	8:25:00	1.00	2.00	215,530	69	81	76	260	260	50
1-11	8:35:00	0.88	1.80	223,680	69	82	76	260	260	53
1-11	8:45:00	0.88	1.80	232,330	71	83	77	250	260	56
1-12	8:55:00	0.87	1.80	240,470	71	85	79	260	260	58
1-12	9:05:00	0.88	1.80	248,220	74	88	81	250	260	61
	9:15:00			255,951						
2-1	9:33:00	0.78	1.60	256,281	76	91	89	260	260	65
2-1	9:43:00	0.76	1.60	264,150	75	95	91	260	260	55
2-2	9:53:00	0.82	1.70	271,420	75	95	91	262	262	55
2-2	10:03:00	0.83	1.70	279,380	75	95	92	260	260	55
2-3	10:13:00	0.90	1.90	287,210	75	95	91	260	260	53
2-3	10:23:00	0.90	1.90	303,050	76	94	91	260	260	57
2-4	10:33:00	1.00	2.00	308,540	77	97	92	260	260	58
2-4	10:43:00	1.00	2.00	320,190	78	99	95	260	260	59
2-5	10:53:00	1.10	2.30	329,905	78	100	96	260	260	58
2-5	11:03:00	1.10	2.30	338,640	79	100	97	260	260	60
2-6	11:13:00	1.10	2.30	347,940	79	101	98	260	260	61
2-6	11:23:00	1.10	2.20	357,120	79	100	98	260	260	61
2-7	11:33:00	1.20	2.50	366,410	79	100	98	260	260	61
2-7	11:43:00	1.20	2.50	376,020	79	100	98	260	260	61
2-8	11:53:00	1.20	2.50	385,670	80	100	98	260	260	61
2-8	12:03:00	1.20	2.50	394,620	80	100	99	260	260	64
2-9	12:13:00	1.10	2.30	397,950	80	100	99	260	260	67
2-9	12:23:00	1.20	2.50	406,410	81	101	100	260	260	66
2-10	12:33:00	1.10	2.30	416,790	82	100	101	260	260	67
2-10	12:43:00	1.10	2.30	425,360	82	103	101	260	260	61
2-11	12:53:00	1.00	2.00	434,350	83	104	102	260	260	60
2-11	13:03:00	0.95	2.00	443,920	83	104	102	260	260	61
2-12	13:13:00	0.96	2.00	452,120	83	104	103	260	260	61
2-12	13:23:00	0.94	2.00	465,970	83	104	103	260	260	62
	13:33:00			469,330						

Total 8:00:00 422,532 88.1 83.4

Average 2.13 73.7 85.7  
 Min 1.60 65.0 58.0  
 Max 2.60 83.0 104.0

### Impinger Weight Sheet - Run 1

Client:	PCC Structural, Inc.	Scale Calibration Check Date:	6/27/2023
Facility:	Large Parts Campus Facility - Milwaukie, OR		
Test Location:	BH9203 Outlet West		
Project #:	M232604		
Date:	6/27/2023		
Test Method:	29		
Weighed/Measured By:	CST		
Balance ID:	S10-35		

Scale Calibration Check (see QS-6.05C for procedure)

must be within  $\pm 0.5\text{g}$  of certified mass

Certified Weight, grams	Result, grams
-------------------------	---------------

250	250.0
-----	-------

500	500.1
-----	-------

750	750.1
-----	-------

IMPIINGER CONTENTS	FINAL		INITIAL		GAIN	
	MLS / GRAMS		MLS / GRAMS		MLS / GRAMS	
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	700.6		752.6		-52.0	
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	819.5		767.4		52.1	
Empty	659.7		648.5		11.2	
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	761.5		762.3		-0.8	
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	707.9		706.2		1.7	
Silica Gel	859.6		814.4		45.2	
	3,649.2		3,637.0		12.2	
	Liquid Final		Liquid Initial		Liquid Gain	
	859.6		814.4		45.2	
	Silica Final		Silica Initial		Silica Gain	

## Run 2 - Method 29

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Outlet West

Date: 6/30/23  
 Start Time: 5:25  
 End Time: 13:35

Source Condition: Batch Process

DRY GAS METER CONDITIONS			STACK CONDITIONS		
Meter Temperature, Tm:	81.7	in. H <sub>2</sub> O °F	Static Pressure	0.50	in. H <sub>2</sub> O
Sqrt ΔP:	1.048	in. H <sub>2</sub> O	Flue Pressure (Ps):	30.01	in. Hg. abs.
Stack Temperature, Ts:	77.2	°F			
Meter Volume, Vmstd:	430.052	ft <sup>3</sup>			
Meter Volume, Vmstd:	423.437	dscf	Gas Weight dry, Md:	29.000	lb/lb mole
Meter Volume, Vwstd:	4.437	wscf	Gas Weight wet, Ms:	28.886	lb/lb mole
Isokinetic Variance:	101.0	%l			
Test Length:	480.00	in mins.	Gas Velocity, Vs:	59.234	fps
Nozzle Diameter:	0.215	in inches	Volumetric Flow:	22,403	acfm
Barometric Pressure:	29.97	in Hg	Volumetric Flow:	21,855	dscfm
			Volumetric Flow:	22,084	scfm

## MOISTURE DETERMINATION

Initial Impinger Content:	3666.1	ml	Silica Initial Wt.	842.7	grams
Final Impinger Content:	3736.8	ml	Silica Final Wt.	866.2	grams
Impinger Difference:	70.7	ml	Silica Difference:	23.5	grams
Total Water Gain:	94.2		Moisture, Bws:	0.010	Supersaturation Value, Bws: 0.031

Port-Point No.	Clock Time	Velocity Head Ap in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Meter Temp			Probe Temp °F	Filter Exit Temp °F	Impinger Exit Temp °F
					Temp °F	Inlet °F	Outlet °F			
1-1	5:25:00	1.00	2.00	28,873	70	64	64	248	249	55
1-1	5:35:00	1.10	2.10	37,450	70	71	65	250	250	52
1-2	5:45:00	1.10	2.20	46,510	70	75	67	250	255	54
1-2	5:55:00	1.10	2.20	55,170	70	75	68	250	250	54
1-3	6:05:00	1.10	2.20	64,370	70	75	68	247	250	54
1-3	6:15:00	1.10	2.20	72,380	70	76	69	245	250	53
1-4	6:25:00	1.10	2.20	81,560	69	78	71	254	251	52
1-4	6:35:00	1.10	2.20	90,420	70	80	71	250	250	51
1-5	6:45:00	1.10	2.20	98,830	70	79	72	253	248	51
1-5	6:55:00	1.10	2.20	108,550	71	78	71	250	250	50
1-6	7:05:00	1.10	2.20	117,250	71	78	71	250	250	50
1-6	7:15:00	1.10	2.20	126,070	70	79	72	250	250	49
1-7	7:25:00	1.10	2.20	135,210	72	78	72	250	249	48
1-7	7:35:00	1.10	2.20	143,660	71	80	73	250	250	49
1-8	7:45:00	1.10	2.20	152,980	71	79	74	250	250	50
1-8	7:55:00	1.10	2.20	161,720	72	80	74	252	249	47
1-9	8:05:00	1.10	2.20	171,070	71	81	73	249	245	45
1-9	8:15:00	1.10	2.20	180,230	72	82	74	252	249	45
1-10	8:25:00	1.10	2.20	188,740	72	81	74	251	250	45
1-10	8:35:00	1.10	2.20	197,520	73	82	74	250	248	46
1-11	8:45:00	1.10	2.20	206,319	73	82	75	252	250	46
1-11	8:55:00	1.10	2.20	215,790	73	82	75	250	251	47
1-12	9:05:00	1.10	2.20	224,450	75	81	75	246	252	47
1-12	9:15:00	1.10	2.20	233,360	75	83	77	252	250	48
	9:25:00			242,049						
2-1	9:35:00	1.10	2.30	242,049	76	83	80	250	250	47
2-1	9:45:00	1.10	2.20	251,320	77	87	81	251	251	46
2-2	9:55:00	1.10	2.20	260,710	77	89	83	249	249	52
2-2	10:05:00	1.10	2.20	269,850	78	90	83	250	250	49
2-3	10:15:00	1.10	2.20	278,460	78	89	83	246	250	47
2-3	10:25:00	1.10	2.20	287,570	79	88	84	247	250	47
2-4	10:35:00	1.10	2.20	296,220	80	89	84	252	251	47
2-4	10:45:00	1.10	2.20	305,540	80	89	85	253	252	49
2-5	10:55:00	1.10	2.20	314,310	81	90	85	249	249	49
2-5	11:05:00	1.10	2.20	323,930	80	90	85	250	250	50
2-6	11:15:00	1.10	2.20	332,750	81	90	85	255	252	50
2-6	11:25:00	1.10	2.20	341,340	83	91	85	252	256	51
2-7	11:35:00	1.10	2.20	350,780	83	91	85	251	252	52
2-7	11:45:00	1.10	2.20	360,120	84	93	86	257	252	53
2-8	11:55:00	1.10	2.20	368,670	86	93	87	250	250	55
2-8	12:05:00	1.10	2.20	377,260	85	93	87	250	248	56
2-9	12:15:00	1.10	2.20	386,750	87	93	88	250	250	59
2-9	12:25:00	1.10	2.20	395,510	86	93	88	251	256	51
2-10	12:35:00	1.10	2.20	404,770	87	94	88	250	250	51
2-10	12:45:00	1.10	2.20	414,220	89	94	88	244	251	53
2-11	12:55:00	1.10	2.20	422,560	88	94	88	250	250	52
2-11	13:05:00	1.10	2.20	431,980	89	94	88	250	250	52
2-12	13:15:00	1.10	2.20	440,130	89	95	89	250	247	53
2-12	13:25:00	1.10	2.20	450,110	90	95	89	250	250	56
	13:35:00			458,925						

Total 8:00:00 430.052 84.7 78.6

Average 2.20 77.2 81.7  
 Min 2.00 69.0 64.0  
 Max 2.30 90.0 95.0

## Impinger Weight Sheet - Run 2

Client:	PCC Structural, Inc.	Scale Calibration Check Date:	6/30/2023
Facility:	Large Parts Campus Facility - Milwaukie, OR	<u>Scale Calibration Check (see QS-6.05C for procedure)</u>	
Test Location:	BH9203 Outlet West	must be within $\pm 0.5\text{g}$ of certified mass	
Project #:	M232604	<u>Certified Weight, grams</u>	<u>Result, grams</u>
Date:	6/30/2023	250	250.0
Test Method:	29		
Weighed/Measured By:	CST	500	500.1
Balance ID:	S10-35	750	750.1

IMPINGER	FINAL		INITIAL		GAIN	
	CONTENTS	MLS / GRAMS	MLS / GRAMS	MLS / GRAMS	MLS / GRAMS	
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>		756.3		766.1		-9.8
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>		806.0		765.6		40.4
Empty		675.0		651.5		23.5
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>		706.8		702.1		4.7
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>		792.7		780.8		11.9
Silica Gel		866.2		842.7		23.5

<u>3,736.8</u>	<u>3,666.1</u>	<u>70.7</u>
Liquid Final	Liquid Initial	Liquid Gain
<u>866.2</u>	<u>842.7</u>	<u>23.5</u>
Silica Final	Silica Initial	Silica Gain

<b>Client:</b>	PCC Structural, Inc.	
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	
<b>Test Location:</b>	BH9203 Outlet East	
<b>Project #:</b>	M232604	
<b>Test Method:</b>	29	
<b>Test Engineer:</b>	VTV	
<b>Test Technician:</b>	CIR1	
	<b>Run 1</b>	<b>Run 2</b>
<b>Temp ID:</b>	cm34	cm34
<b>Meter ID:</b>	cm34	cm34
<b>Pitot ID:</b>	4037	4037
<b>Nozzle Diameter (Inches):</b>	0.200	0.200
<b>Meter Calibration Date:</b>	6/21/2023	6/21/2023
<b>Meter Calibration Factor (Y):</b>	1.003	1.003
<b>Meter Orifice Setting (Delta H):</b>	1.758	1.758
<b>Nozzle Kit ID Number and Material:</b>	Glass 6	Glass 6
<b>Pitot Tube Coefficient:</b>	0.840	
<b>Probe Length (Feet):</b>	3.0	
<b>Probe Liner Material:</b>	Glass	
<b>Sample Plane:</b>	Horizontal	
<b>Port Length (Inches):</b>	4.00	
<b>Port Size (Diameter, Inches):</b>	4.00	
<b>Port Type:</b>	Flange	
<b>Duct Shape:</b>	Circular	
<b>Diameter (Feet):</b>	2.833	
<b>Duct Area (Square Feet):</b>	6.304	
<b>Upstream Diameters:</b>	7.5	
<b>Downstream Diameters:</b>	72.0	
<b>Number of Ports Sampled:</b>	2	
<b>Number of Points per Port:</b>	12	
<b>Minutes per Point:</b>	20.0	
<b>Minutes per Reading:</b>	10.0	
<b>Total Number of Traverse Points:</b>	24	
<b>Test Length (Minutes):</b>	480	
<b>Train Type:</b>	Anderson Box	
<b>Source Condition:</b>	Batch Process	
<b>Moisture Balance ID:</b>	S10-35	
<b># of Runs</b>	2	

## Run 1 - Method 29

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Outlet East

Date: 6/27/23  
 Start Time: 5:15  
 End Time: 18:05

Source Condition: Batch Process

DRY GAS METER CONDITIONS			STACK CONDITIONS		
Meter Temperature, Tm:	80.9	in. H <sub>2</sub> O °F	Static Pressure:	0.50	in. H <sub>2</sub> O
Sqrt ΔP:	1.032	in. H <sub>2</sub> O	Flue Pressure (Ps):	30.01	in. Hg. abs.
Stack Temperature, Ts:	76.3	°F	Carbon Dioxide:	%	
Meter Volume, Vmstd:	366.177	ft <sup>3</sup>	Oxygen:	%	
Meter Volume, Vmstd:	360.728	dscf	Nitrogen:	#VALUE!	%
Meter Volume, Vwstd:	3.222	wscf	Gas Weight dry, Md:	29.000	lb/lb mole
Isokinetic Variance:	100.8	%l	Gas Weight wet, Ms:	28.903	lb/lb mole
Test Length:	480.00	in mins.	Excess Air:	#VALUE!	%
Nozzle Diameter:	0.200	in inches	Gas Velocity, Vs:	58.266	fps
Barometric Pressure:	29.97	in Hg	Volumetric Flow:	22,037	acfm
			Volumetric Flow:	21,565	dscfm
			Volumetric Flow:	21,757	scfm

## MOISTURE DETERMINATION

Initial Impinger Content:	3543.4	ml	Silica Initial Wt.	867.8	grams
Final Impinger Content:	3566.3	ml	Silica Final Wt.	913.3	grams
Impinger Difference:	22.9	ml	Silica Difference:	45.5	grams
Total Water Gain:	68.4		Moisture, Bws:	0.009	Supersaturation Value, Bws: 0.030

Port-Point No.	Clock Time	Velocity Head Ap in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Meter Temp			Probe Temp °F	Filter Exit Temp °F	Impinger Exit Temp °F
					Temp °F	Inlet °F	Outlet °F			
1-1	5:15:00	1.70	2.70	70,013	68	59	59	250	250	45
1-1	5:25:00	1.20	1.90	78,740	69	62	59	250	250	49
1-2	5:35:00	1.30	2.10	87,350	69	66	60	250	250	54
1-2	5:45:00	1.20	2.00	95,520	68	69	61	250	250	56
1-3	5:55:00	1.30	2.20	103,430	68	71	62	250	250	55
1-3	6:05:00	1.30	2.20	112,270	69	73	64	250	250	56
1-4	6:15:00	1.30	2.20	120,420	69	73	65	250	250	56
1-4	6:25:00	1.30	2.20	128,610	71	74	66	250	250	58
1-5	6:35:00	1.30	2.20	136,220	70	75	66	250	250	58
1-5	6:45:00	1.30	2.20	144,930	70	74	67	250	250	59
1-6	6:55:00	1.30	2.20	153,520	70	75	67	250	250	60
1-6	7:05:00	1.20	2.00	161,550	71	76	68	250	250	60
1-7	7:15:00	1.20	2.00	169,120	72	79	70	250	250	60
1-7	7:25:00	1.20	2.00	177,750	73	80	72	250	250	60
1-8	7:35:00	1.10	1.90	185,820	74	81	75	250	250	55
1-8	7:45:00	1.20	2.00	193,840	72	79	74	250	250	51
1-9	7:55:00	1.10	1.90	201,920	71	78	73	250	250	50
1-9	8:05:00	1.10	1.90	209,680	71	78	72	250	250	49
1-10	8:15:00	0.89	1.50	217,020	71	77	72	250	250	51
1-10	8:25:00	0.89	1.50	224,220	71	77	71	250	250	52
1-11	8:35:00	0.77	1.30	230,910	71	78	71	250	250	52
1-11	8:45:00	0.75	1.30	237,460	71	79	73	250	250	53
1-12	8:55:00	0.73	1.20	243,730	74	81	75	250	250	55
1-12	9:05:00	0.72	1.20	250,070	76	84	78	250	250	56
	9:15:00			256,150						
2-1	9:33:00	0.79	1.40	256,509	80	84	83	250	250	52
2-1	9:43:00	0.79	1.30	268,710	78	88	84	250	250	51
2-2	9:53:00	0.80	1.40	275,780	78	88	85	250	250	51
2-2	10:03:00	0.80	1.40	282,410	78	88	85	250	250	52
2-3	10:13:00	0.89	1.70	288,080	77	89	84	250	250	52
2-3	10:23:00	0.89	1.50	295,390	77	90	85	250	250	52
2-4	10:33:00	1.10	1.90	303,460	78	93	86	250	250	53
2-4	10:43:00	1.10	1.90	311,160	81	93	88	250	250	54
2-5	10:53:00	1.10	1.90	318,660	81	93	88	250	250	55
2-5	11:03:00	1.10	1.90	326,980	81	93	88	250	250	55
2-6	11:13:00	1.20	2.00	334,550	81	92	89	250	250	55
2-6	11:23:00	1.20	2.00	342,870	82	92	90	250	250	58
2-7	11:33:00	1.20	2.00	350,360	83	92	89	250	250	57
2-7	11:43:00	1.20	2.00	358,240	81	94	89	250	250	57
2-8	11:53:00	1.10	1.90	366,800	83	94	90	250	250	58
2-8	12:03:00	1.10	1.90	374,020	82	93	90	250	250	60
2-9	12:13:00	1.10	1.90	377,890	83	91	89	250	250	56
2-9	12:23:00	1.10	1.90	385,760	85	93	90	250	250	56
2-10	12:33:00	0.93	1.60	393,130	85	95	90	250	250	56
2-10	12:43:00	0.95	1.60	400,880	86	95	91	250	250	57
2-11	12:53:00	0.96	1.60	407,510	86	94	92	250	250	60
2-11	13:03:00	0.97	1.70	415,110	86	94	91	250	250	61
2-12	13:13:00	0.92	1.60	422,340	86	95	91	250	250	62
2-12	13:23:00	0.92	1.60	429,460	87	95	92	250	250	62
	13:33:00			436,549						

Total 8:00:00 366,177 83.5 78.3  
 Average 1.82 76.3 80.9  
 Min 1.20 68.0 59.0  
 Max 2.70 87.0 95.0

### Impinger Weight Sheet - Run 1

Client:	PCC Structural, Inc.	Scale Calibration Check Date:	6/27/2023
Facility:	Large Parts Campus Facility - Milwaukie, OR	Scale Calibration Check (see QS-6.05C for procedure)	
Test Location:	BH9203 Outlet East	must be within $\pm 0.5\text{g}$ of certified mass	
Project #:	M232604	Certified Weight, grams	Result, grams
Date:	6/27/2023	250	250.0
Test Method:	29		
Weighed/Measured By:	CST	500	500.1
Balance ID:	S10-35	750	750.1

IMPINGER	FINAL		INITIAL		GAIN	
	CONTENTS		MLS / GRAMS		MLS / GRAMS	
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>		681.5		720.8		-39.3
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>		723.1		722.4		0.7
Empty		666.4		644.2		22.2
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>		796.9		771.4		25.5
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>		698.4		684.6		13.8
Silica Gel		913.3		867.8		45.5

<u>3,566.3</u>	<u>3,543.4</u>	<u>22.9</u>
Liquid Final	Liquid Initial	Liquid Gain
<u>913.3</u>	<u>867.8</u>	<u>45.5</u>
Silica Final	Silica Initial	Silica Gain

## Run 2 - Method 29

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukee, OR  
 Test Location: BH9203 Outlet East  
 Source Condition: Batch Process

Date: 6/30/23  
 Start Time: 5:25  
 End Time: 13:35

## DRY GAS METER CONDITIONS

	ΔH:	1.80	In. H <sub>2</sub> O	Static Pressure	0.50	in. H <sub>2</sub> O
Meter Temperature, Tm:	81.9		°F	Flue Pressure (Ps):	30.01	in. Hg. abs.
Sqrt AP:	1.025		In. H <sub>2</sub> O	Carbon Dioxide:	%	
Stack Temperature, Ts:	77.6		°F	Oxygen:	%	
Meter Volume, Vm:	361.704	ft <sup>3</sup>		Nitrogen:	#VALUE!	%
Meter Volume, Vmstd:	355.670	dscf		Gas Weight dry, Md:	29.000	lb/lb mole
Meter Volume, Vwstd:	3.080	wscf		Gas Weight wet, Ms:	28.906	lb/lb mole
Isokinetic Variance:	100.1	%l		Excess Air:	#VALUE!	%
Test Length:	480.00	in mins.		Gas Velocity, Vs:	57.947	fps
Nozzle Diameter:	0.200	in inches		Volumetric Flow:	21.916	acfmin
Barometric Pressure:	29.97	in Hg		Volumetric Flow:	21.401	dscfm
				Volumetric Flow:	21.586	scfm

## MOISTURE DETERMINATION

Initial Impinger Content:	3309.9	ml	Silica Initial Wt.	821.5	grams
Final Impinger Content:	3354.4	ml	Silica Final Wt.	842.4	grams
Impinger Difference:	44.5	ml	Silica Difference:	20.9	grams

Total Water Gain: 65.4      Moisture, Bws: 0.009      Supersaturation Value, Bws: 0.032

Port-Point No.	Clock Time	Velocity Head Δp	Orifice ΔH	Actual Meter Vol. ft <sup>3</sup>	Stack Temp °F		Meter Temp °F		Probe Temp °F	Filter Exit Temp °F	Impinger Exit Temp °F
					in. H <sub>2</sub> O	in. H <sub>2</sub> O	Inlet °F	Outlet °F			
1-1	5:25:00	0.98	1.70	95.536	71	67	65	249	249	45	
1-1	5:35:00	0.97	1.60	102.870	71	66	66	249	250	53	
1-2	5:45:00	0.96	1.60	110.220	72	76	68	250	251	45	
1-2	5:55:00	0.95	1.60	117.230	72	77	69	250	249	46	
1-3	6:05:00	0.94	1.60	124.160	71	79	69	250	250	46	
1-3	6:15:00	0.98	1.70	131.180	72	79	70	250	248	47	
1-4	6:25:00	1.00	1.70	138.620	72	79	71	250	253	47	
1-4	6:35:00	1.00	1.70	146.030	71	79	71	250	251	47	
1-5	6:45:00	1.00	1.70	153.230	71	79	72	250	248	47	
1-5	6:55:00	1.00	1.70	160.270	71	78	71	250	250	47	
1-6	7:05:00	1.00	1.70	168.480	70	78	71	250	250	47	
1-6	7:15:00	0.98	1.70	175.660	70	79	72	250	246	48	
1-7	7:25:00	1.00	1.70	182.240	71	78	72	250	252	48	
1-7	7:35:00	1.00	1.70	189.400	72	80	72	250	247	49	
1-8	7:45:00	1.00	1.70	197.520	72	81	73	250	250	50	
1-8	7:55:00	1.00	1.70	204.950	73	81	73	250	250	45	
1-9	8:05:00	1.00	1.70	212.170	72	81	73	251	249	44	
1-9	8:15:00	1.00	1.70	219.890	72	82	74	250	249	44	
1-10	8:25:00	1.00	1.70	227.570	73	82	74	250	252	45	
1-10	8:35:00	1.00	1.70	234.220	73	83	74	250	248	45	
1-11	8:45:00	1.00	1.70	241.100	74	82	75	250	252	47	
1-11	8:55:00	1.10	1.90	249.380	74	81	75	250	251	48	
1-12	9:05:00	1.10	1.90	256.520	74	81	75	250	250	47	
1-12	9:15:00	1.10	1.90	264.850	75	83	77	250	250	47	
	9:25:00			269.544							
2-1	9:35:00	1.10	1.90	269.544	76	82	80	250	250	48	
2-1	9:45:00	1.10	1.90	277.370	78	88	82	250	251	49	
2-2	9:55:00	1.10	1.90	285.170	78	89	83	250	250	57	
2-2	10:05:00	1.10	1.90	293.310	79	89	83	250	250	51	
2-3	10:15:00	1.10	1.90	300.980	78	89	83	250	250	47	
2-4	10:25:00	1.10	1.90	308.590	80	90	84	250	250	47	
2-4	10:35:00	1.10	1.90	316.870	80	90	84	250	253	48	
2-4	10:45:00	1.10	1.90	324.920	80	89	84	250	259	49	
2-5	10:55:00	1.10	1.90	332.250	80	89	85	250	250	50	
2-5	11:05:00	1.10	1.90	334.230	81	90	86	250	250	51	
2-6	11:15:00	1.10	1.90	348.050	81	90	86	250	250	51	
2-6	11:25:00	1.10	1.90	355.920	82	91	85	250	251	53	
2-7	11:35:00	1.10	1.90	363.630	83	91	86	250	254	53	
2-7	11:45:00	1.10	1.90	371.920	85	93	86	250	249	55	
2-8	11:55:00	1.10	1.90	379.360	86	93	87	250	250	56	
2-8	12:05:00	1.10	1.90	386.640	86	93	87	250	250	57	
2-9	12:15:00	1.10	1.90	394.580	86	94	88	250	250	59	
2-9	12:25:00	1.10	1.90	402.820	87	93	87	250	247	51	
2-10	12:35:00	1.10	1.90	410.450	88	94	88	250	252	52	
2-10	12:45:00	1.10	1.90	418.330	88	94	88	250	250	53	
2-11	12:55:00	1.10	1.90	426.010	88	94	88	250	250	52	
2-11	13:05:00	1.10	1.90	433.880	89	95	88	250	250	54	
2-12	13:15:00	1.10	1.90	441.620	89	95	88	250	250	55	
2-12	13:25:00	1.10	1.90	449.750	89	95	89	250	248	55	
	13:35:00			457.240							

Total 8:00:00      361.704      85.0      78.7

Average 1.80      77.6      81.9  
 Min 1.60      70.0      65.0  
 Max 1.90      89.0      95.0

## Impinger Weight Sheet - Run 2

Client:	PCC Structural, Inc.	Scale Calibration Check Date:	6/27/2023
Facility:	Large Parts Campus Facility - Milwaukee, OR		
Test Location:	BH9203 Outlet East		
Project #:	M232604	Scale Calibration Check (see QS-6.05C for procedure)	
Date:	6/30/2023	must be within $\pm 0.5\text{g}$ of certified mass	
Test Method:	29	Certified Weight, grams	Result, grams
Weighed/Measured By:	CST	250	250.0
Balance ID:	S10-35	500	500.1
		750	750.1

IMPINGER CONTENTS	FINAL		INITIAL		GAIN	
	MLS / GRAMS		MLS / GRAMS		MLS / GRAMS	
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	728.9		766.0		-37.1	
HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>	821.6		777.7		43.9	
Empty	531.6		507.2		24.4	
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	692.3		689.0		3.3	
KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub>	580.0		570.0		10.0	
Silica Gel	842.4		821.5		20.9	
	3,354.4	Liquid Final	3,309.9	Liquid Initial	44.5	Liquid Gain
	842.4	Silica Final	821.5	Silica Initial	20.9	Silica Gain

<b>Client:</b>	PCC Structural, Inc.	
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	
<b>Test Location:</b>	BH9203 Outlet West	
<b>Project #:</b>	M232604	
<b>Test Method:</b>	0061	
<b>Test Engineer:</b>	MPS	
<b>Test Technician:</b>	CIR1	
	<b>Run 1</b>	<b>Run 2</b>
<b>Temp ID:</b>	CM36	CM14
<b>Meter ID:</b>	CM36	CM14
<b>Pitot ID:</b>	1037	1037
<b>Nozzle Diameter (Inches):</b>	0.207	0.214
<b>Meter Calibration Date:</b>	6/6/2023	6/21/2023
<b>Meter Calibration Factor (Y):</b>	0.991	1.001
<b>Meter Orifice Setting (Delta H):</b>	1.832	1.646
<b>Nozzle Kit ID Number and Material:</b>	GLASS	GLASS
<b>Pitot Tube Coefficient:</b>	0.840	
<b>Probe Length (Feet):</b>	4.0	
<b>Probe Liner Material:</b>	Glass	
<b>Sample Plane:</b>	Horizontal	
<b>Port Length (Inches):</b>	4.00	
<b>Port Size (Diameter, Inches):</b>	4.00	
<b>Port Type:</b>	Flange	
<b>Duct Shape:</b>	Circular	
<b>Diameter (Feet):</b>	2.833	
<b>Duct Area (Square Feet):</b>	6.304	
<b>Upstream Diameters:</b>	>.5	
<b>Downstream Diameters:</b>	>2.0	
<b>Number of Ports Sampled:</b>	2	
<b>Number of Points per Port:</b>	12	
<b>Minutes per Point:</b>	20.0	
<b>Minutes per Reading:</b>	10.0	
<b>Total Number of Traverse Points:</b>	24	
<b>Test Length (Minutes):</b>	480	
<b>Train Type:</b>	Anderson Box	
<b>Source Condition:</b>	Batch Process	
<b># of Runs</b>	2	

## Run 1 - Method 0061

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Outlet West  
 Source Condition: Batch Process

Date: 6/27/23  
 Start Time: 5:15  
 End Time: 13:33

DRY GAS METER CONDITIONS			STACK CONDITIONS		
Meter Temperature, Tm:	2.02	in. H <sub>2</sub> O	Static Pressure	0.50	in. H <sub>2</sub> O
Sqrt AP:	78.3	°F	Flue Pressure (Ps):	30.01	in. Hg. abs.
Stack Temperature, Ts:	0.971	in. H <sub>2</sub> O			
Meter Volume, Vm:	73.6	°F			
Meter Volume, Vmstd:	365.314	ft <sup>3</sup>			
Meter Volume, Vwstd:	357.472	dscf	Gas Weight dry, Md:	29.000	lb/lb mole
Isokinetic Variance:	0.000	wscf	Gas Weight wet, Ms:	28.923	lb/lb mole
Test Length:	480.00	in mins.	Gas Velocity, Vs:	54.703	fps
Nozzle Diameter:	0.207	in inches	Volumetric Flow:	20,689	acf m
Barometric Pressure:	29.97	in Hg	Volumetric Flow:	20,387	dscfm
			Volumetric Flow:	20,531	scfm

Moisture, Bws: 0.007 Supersaturation Value, Bws: 0.028

Port- Point No.	Clock Time	Velocity Head Δp in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Temp °F	Meter Temp Inlet °F	Meter Temp Outlet °F	Impinger Exit Temp °F
1-1	5:15:00	0.96	2.00	80,045	68	57	57	52
1-1	5:25:00	0.96	2.00	87,460	68	57	57	57
1-2	5:35:00	1.00	2.10	94,880	68	58	58	59
1-2	5:45:00	1.00	2.10	102,440	68	58	58	60
1-3	5:55:00	1.00	2.10	110,020	68	59	59	60
1-3	6:05:00	1.00	2.10	117,630	68	60	60	60
1-4	6:15:00	1.00	2.10	125,250	68	61	61	60
1-4	6:25:00	1.00	2.10	132,880	68	62	62	60
1-5	6:35:00	1.00	2.10	140,530	68	62	62	60
1-5	6:45:00	1.00	2.10	148,180	68	63	63	59
1-6	6:55:00	1.00	2.10	155,820	69	64	64	59
1-6	7:05:00	1.00	2.10	163,480	69	65	65	60
1-7	7:15:00	1.00	2.10	171,160	69	67	67	61
1-7	7:25:00	1.00	2.10	178,850	70	69	69	61
1-8	7:35:00	1.00	2.10	186,580	70	71	71	62
1-8	7:45:00	1.00	2.10	194,330	69	72	72	61
1-9	7:55:00	0.90	1.90	202,120	70	72	72	61
1-9	8:05:00	0.90	1.90	209,480	69	72	72	61
1-10	8:15:00	0.85	1.80	216,850	70	72	72	60
1-10	8:25:00	0.83	1.80	224,040	70	72	72	60
1-11	8:35:00	0.75	1.60	231,110	70	72	72	60
1-11	8:45:00	0.75	1.60	237,850	71	73	73	61
1-12	8:55:00	0.80	1.70	244,580	71	74	74	62
1-12	9:05:00	0.85	1.80	251,550	73	76	76	63
	9:15:00			258,721				
2-1	9:33:00	0.85	1.80	258,914	75	82	82	67
2-1	9:43:00	0.85	1.80	266,180	75	84	84	64
2-2	9:53:00	0.95	2.00	273,480	74	85	85	62
2-2	10:03:00	0.94	2.00	281,170	74	86	86	60
2-3	10:13:00	1.00	2.20	288,920	74	86	86	60
2-3	10:23:00	1.00	2.20	296,820	75	85	85	62
2-4	10:33:00	1.00	2.20	304,790	75	86	86	62
2-4	10:43:00	1.00	2.20	312,680	76	88	88	63
2-5	10:53:00	1.00	2.20	320,720	76	90	90	63
2-5	11:03:00	1.00	2.20	328,660	77	92	92	64
2-6	11:13:00	1.00	2.20	336,680	77	94	94	64
2-6	11:23:00	1.00	2.20	344,730	78	95	95	64
2-7	11:33:00	1.00	2.20	352,780	79	94	94	64
2-7	11:43:00	1.00	2.20	360,790	78	93	93	64
2-8	11:53:00	1.00	2.20	368,830	79	92	92	63
2-8	12:03:00	1.00	2.20	376,790	80	92	92	64
2-9	12:13:00	0.95	2.00	384,790	80	92	92	64
2-9	12:23:00	0.95	2.00	392,580	81	92	92	62
2-10	12:33:00	0.90	1.90	400,330	82	92	92	61
2-10	12:43:00	0.90	1.90	407,920	81	93	93	62
2-11	12:53:00	0.90	1.90	415,480	82	94	94	63
2-11	13:03:00	0.90	1.90	423,050	82	94	94	63
2-12	13:13:00	0.88	1.90	430,660	82	94	94	63
2-12	13:23:00	0.85	1.90	438,180	82	94	94	64
	13:33:00			445,552				

Total 8:00:00 365.314 78.3 78.3

Average 2.02 73.6 78.3  
 Min 1.60 68.0 57.0  
 Max 2.20 82.0 95.0

## Run 2 - Method 0061

**Client:** PCC Structural, Inc.  
**Facility:** Large Parts Campus Facility - Milwaukie, OR  
**Test Location:** BH9203 Outlet West  
**Source Condition:** Batch Process

**Date:** 6/30/23  
**Start Time:** 5:25  
**End Time:** 13:25

## DRY GAS METER CONDITIONS

	ΔH:	2.28	In. H <sub>2</sub> O		Stack Pressure:	0.50	in. H <sub>2</sub> O
Meter Temperature, T <sub>m</sub> :	81.1	°F			Flue Pressure (Ps):	30.01	in. Hg. abs.
Sqrt AP:	0.972	In. H <sub>2</sub> O					
Stack Temperature, T <sub>s</sub> :	80.2	°F					
Meter Volume, V <sub>m</sub> :	385.912	ft <sup>3</sup>					
Meter Volume, V <sub>mstd</sub> :	379.700	dscf			Gas Weight dry, M <sub>d</sub> :	29.000	lb/lb mole
Meter Volume, V <sub>wstd</sub> :	0.000	wscf			Gas Weight wet, M <sub>s</sub> :	28.890	lb/lb mole
Isokinetic Variance:	98.8	%l					
Test Length:	480.00	in mins.			Gas Velocity, V <sub>s</sub> :	55.084	fps
Nozzle Diameter:	0.214	in inches			Volumetric Flow:	20,833	acfm
Barometric Pressure:	29.97	in Hg			Volumetric Flow:	20,218	dscfm
					Volumetric Flow:	20,422	scfm

Moisture, Bws: 0.010 Supersaturation Value, Bws: 0.035

Port- Point No.	Clock Time	Velocity Head Δp in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Temp °F	Meter Temp Inlet °F	Meter Temp Outlet °F	Impinger Exit Temp °F
1-1	5:25:00	0.95	2.30	35.338	73	64	64	55
1-1	5:35:00	0.95	2.30	43.370	73	67	65	63
1-2	5:45:00	1.00	2.40	51.430	73	68	65	64
1-2	5:55:00	1.00	2.40	59.710	73	70	66	64
1-3	6:05:00	1.00	2.40	67.970	73	72	67	64
1-3	6:15:00	1.00	2.40	76.310	73	73	68	64
1-4	6:25:00	1.00	2.40	84.650	73	74	69	64
1-4	6:35:00	1.00	2.40	93.010	73	75	70	64
1-5	6:45:00	1.00	2.40	101.380	74	75	71	64
1-5	6:55:00	1.00	2.40	109.730	74	75	72	64
1-6	7:05:00	1.00	2.40	118.140	74	76	72	64
1-6	7:15:00	1.00	2.40	126.550	74	75	72	63
1-7	7:25:00	1.00	2.40	134.920	74	77	72	63
1-7	7:35:00	1.00	2.40	143.350	75	78	73	64
1-8	7:45:00	1.00	2.40	151.740	75	78	74	63
1-8	7:55:00	1.00	2.40	160.140	75	78	74	62
1-9	8:05:00	0.90	2.20	168.540	75	78	74	61
1-9	8:15:00	0.90	2.20	176.560	75	78	75	61
1-10	8:25:00	0.85	2.10	184.520	75	78	75	60
1-10	8:35:00	0.85	2.10	192.320	76	79	75	61
1-11	8:45:00	0.75	1.80	200.030	76	79	75	62
1-11	8:55:00	0.75	1.80	207.350	77	80	76	62
1-12	9:05:00	0.80	1.90	214.640	77	81	77	63
1-12	9:15:00	0.80	1.90	222.220	79	82	78	64
	9:25:00			229.734				
2-1	9:35:00	0.85	2.10	229.734	81	82	79	65
2-1	9:45:00	0.85	2.10	237.470	81	82	79	64
2-2	9:55:00	0.95	2.30	245.250	82	84	80	65
2-2	10:05:00	0.95	2.30	253.470	82	85	81	66
2-3	10:15:00	1.00	2.40	261.730	83	86	82	65
2-3	10:25:00	1.00	2.40	270.220	83	86	82	64
2-4	10:35:00	1.00	2.40	278.690	83	87	83	63
2-4	10:45:00	1.00	2.40	287.220	84	88	84	63
2-5	10:55:00	1.00	2.40	295.690	85	89	85	63
2-5	11:05:00	1.00	2.40	304.220	85	89	86	64
2-6	11:15:00	1.00	2.40	312.680	85	90	86	63
2-6	11:25:00	1.00	2.40	321.230	86	91	87	63
2-7	11:35:00	1.00	2.40	329.770	87	92	88	62
2-7	11:45:00	1.00	2.40	338.340	87	93	88	62
2-8	11:55:00	1.00	2.40	346.820	88	94	89	63
2-8	12:05:00	1.00	2.40	355.370	88	94	90	62
2-9	12:15:00	0.95	2.30	363.990	89	96	91	62
2-9	12:25:00	0.95	2.30	372.340	89	97	92	62
2-10	12:35:00	0.90	2.20	380.710	90	97	93	62
2-10	12:45:00	0.90	2.20	388.880	90	98	93	62
2-11	12:55:00	0.90	2.20	397.020	90	98	93	62
2-11	13:05:00	0.90	2.20	405.180	91	98	93	63
2-12	13:15:00	0.85	2.10	413.330	91	99	94	63
	13:25:00			421.250				

Total 7:50:00 385.912 83.1 79.1

Average 2.28 80.2 81.1  
Min 1.80 73.0 64.0  
Max 2.40 91.0 99.0

<b>Client:</b>	PCC Structural, Inc.	
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	
<b>Test Location:</b>	BH9203 Outlet East	
<b>Project #:</b>	M232604	
<b>Test Method:</b>	0061	
<b>Test Engineer:</b>	MPS	
<b>Test Technician:</b>	CIR1	
	<b>Run 1</b>	<b>Run 2</b>
<b>Temp ID:</b>	CM22	CM40
<b>Meter ID:</b>	CM22	CM40
<b>Pitot ID:</b>	835	835
<b>Nozzle Diameter (Inches):</b>	0.210	0.199
<b>Meter Calibration Date:</b>	6/16/2023	6/20/2023
<b>Meter Calibration Factor (Y):</b>	0.999	0.989
<b>Meter Orifice Setting (Delta H):</b>	1.889	1.774
<b>Nozzle Kit ID Number and Material:</b>	GLASS	GLASS
<b>Pitot Tube Coefficient:</b>	0.840	
<b>Probe Length (Feet):</b>	4.0	
<b>Probe Liner Material:</b>	Glass	
<b>Sample Plane:</b>	Horizontal	
<b>Port Length (Inches):</b>	4.00	
<b>Port Size (Diameter, Inches):</b>	4.00	
<b>Port Type:</b>	Flange	
<b>Duct Shape:</b>	Circular	
<b>Diameter (Feet):</b>	2.833	
<b>Duct Area (Square Feet):</b>	6.304	
<b>Upstream Diameters:</b>	>.5	
<b>Downstream Diameters:</b>	>2.0	
<b>Number of Ports Sampled:</b>	2	
<b>Number of Points per Port:</b>	12	
<b>Minutes per Point:</b>	20.0	
<b>Minutes per Reading:</b>	10.0	
<b>Total Number of Traverse Points:</b>	24	
<b>Test Length (Minutes):</b>	480	
<b>Train Type:</b>	Anderson Box	
<b>Source Condition:</b>	Batch Process	
<b># of Runs</b>	2	

## Run 1 - Method 0061

Client: PCC Structural, Inc.  
 Facility: Large Parts Campus Facility - Milwaukie, OR  
 Test Location: BH9203 Outlet East  
 Source Condition: Batch Process

Date: 6/27/23  
 Start Time: 5:15  
 End Time: 13:33

DRY GAS METER CONDITIONS			STACK CONDITIONS		
Meter Temperature, Tm:	87.5	in. H <sub>2</sub> O	Static Pressure	0.50	in. H <sub>2</sub> O
Sqrt AP:	0.993	in. H <sub>2</sub> O	Flue Pressure (Ps):	30.01	in. Hg. abs.
Stack Temperature, Ts:	76.4	°F			
Meter Volume, Vm:	394.654	ft <sup>3</sup>			
Meter Volume, Vmstd:	382.895	dscf	Gas Weight dry, Md:	29.000	lb/lb mole
Meter Volume, Vwstd:	0.000	wscf	Gas Weight wet, Ms:	28.901	lb/lb mole
Isokinetic Variance:	100.8	%l			
Test Length:	480.00	in mins.	Gas Velocity, Vs:	56.087	fps
Nozzle Diameter:	0.210	in inches	Volumetric Flow:	21,213	acfm
Barometric Pressure:	29.97	in Hg	Volumetric Flow:	20,753	dscfm
			Volumetric Flow:	20,941	scfm

Moisture, Bws: 0.009 Supersaturation Value, Bws: 0.031

Port- Point No.	Clock Time	Velocity Head Δp in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Temp °F	Meter Temp Inlet °F	Meter Temp Outlet °F	Impinger Exit Temp °F
1-1	5:15:00	1.00	2.20	56.216	68	65	66	51
1-1	5:25:00	0.96	2.10	64.230	68	63	66	54
1-2	5:35:00	1.00	2.20	72.030	68	61	66	58
1-2	5:45:00	1.00	2.20	80.020	68	61	67	60
1-3	5:55:00	1.00	2.20	87.980	68	63	68	62
1-3	6:05:00	1.00	2.20	95.980	68	64	68	63
1-4	6:15:00	1.00	2.20	104.040	68	65	69	63
1-4	6:25:00	1.00	2.20	112.110	69	65	70	62
1-5	6:35:00	1.00	2.20	120.130	69	65	71	62
1-5	6:45:00	1.00	2.20	128.170	69	65	71	62
1-6	6:55:00	1.00	2.20	136.220	70	67	73	62
1-6	7:05:00	1.00	2.20	144.280	71	68	75	62
1-7	7:15:00	1.00	2.20	152.370	72	74	81	63
1-7	7:25:00	1.00	2.20	160.530	73	79	86	63
1-8	7:35:00	1.00	2.20	168.720	72	83	89	63
1-8	7:45:00	1.00	2.20	176.960	71	81	87	63
1-9	7:55:00	1.00	2.20	185.270	71	78	82	63
1-9	8:05:00	1.00	2.20	193.520	71	76	80	63
1-10	8:15:00	1.00	2.20	201.660	71	74	78	63
1-10	8:25:00	1.00	2.20	209.780	71	74	77	62
1-11	8:35:00	0.90	2.00	217.950	71	74	78	62
1-11	8:45:00	0.90	2.00	225.660	73	77	82	63
1-12	8:55:00	0.95	2.10	233.440	74	80	86	64
1-12	9:05:00	0.95	2.10	241.450	76	87	94	65
	9:15:00			249.596				
2-1	9:33:00	0.95	2.20	249.983	79	104	107	64
2-1	9:43:00	0.96	2.20	258.320	78	103	108	61
2-2	9:53:00	1.00	2.30	266.640	78	100	104	58
2-2	10:03:00	1.00	2.30	275.120	77	99	103	57
2-3	10:13:00	1.10	2.50	283.620	77	96	99	58
2-3	10:23:00	1.10	2.50	292.440	79	95	98	58
2-4	10:33:00	1.10	2.50	301.250	80	97	99	59
2-4	10:43:00	1.10	2.50	310.110	81	101	103	59
2-5	10:53:00	1.00	2.30	318.930	81	104	105	60
2-5	11:03:00	1.00	2.30	327.460	82	106	106	61
2-6	11:13:00	1.00	2.30	335.970	82	106	106	61
2-6	11:23:00	1.00	2.30	344.530	83	106	105	61
2-7	11:33:00	1.00	2.30	352.970	83	103	102	61
2-7	11:43:00	1.00	2.30	361.460	83	100	99	60
2-8	11:53:00	1.00	2.30	369.880	83	98	98	61
2-8	12:03:00	1.00	2.30	378.260	84	97	98	62
2-9	12:13:00	1.00	2.30	386.630	85	98	99	60
2-9	12:23:00	1.00	2.30	395.040	85	99	100	57
2-10	12:33:00	0.90	2.00	403.370	86	99	100	58
2-10	12:43:00	0.90	2.00	411.360	86	100	102	58
2-11	12:53:00	0.90	2.00	419.310	86	101	102	58
2-11	13:03:00	0.90	2.00	427.320	86	101	102	58
2-12	13:13:00	0.90	2.00	435.310	87	101	102	60
2-12	13:23:00	0.90	2.00	443.270	86	101	102	61
	13:33:00			451.257				

Total 8:00:00 394.654 85.9 89.1

Average 2.21 76.4 87.5  
 Min 2.00 68.0 61.0  
 Max 2.50 87.0 108.0

**Run 2 - Method 0061**

**Client: PCC Structural, Inc.**  
**Facility: Large Parts Campus Facility - Milwaukie, OR**  
**Test Location: BH9203 Outlet East**  
**Source Condition: Batch Process**

Date: 6/30/23  
Start Time: 5:25  
End Time: 13:25

DRY GAS METER CONDITIONS			STACK CONDITIONS		
Meter Temperature, Tm:	74.1	in. H <sub>2</sub> O	Static Pressure	0.50	in. H <sub>2</sub> O
Sqrt AP:	0.990	in. H <sub>2</sub> O	Flue Pressure (Ps):	30.01	in. Hg. abs.
Stack Temperature, Ts:	77.9	°F			
Meter Volume, Vm:	340.243	ft <sup>3</sup>			
Meter Volume, Vmstd:	334.654	dscf	Gas Weight dry, Md:	29.000	lb/lb mole
Meter Volume, Vwstd:	0.000	wscf	Gas Weight wet, Ms:	28.901	lb/lb mole
Isokinetic Variance:	98.6	%l			
Test Length:	480.00	in mins.	Gas Velocity, Vs:	55.972	fps
Nozzle Diameter:	0.199	in inches	Volumetric Flow:	21,169	acfm
Barometric Pressure:	29.97	in Hg	Volumetric Flow:	20,652	dscfm
			Volumetric Flow:	20,839	scfm

Moisture, Bws: 0.009 Supersaturation Value, Bws: 0.032

Port- Point No.	Clock Time	Velocity Head Δp in. H <sub>2</sub> O	Orifice ΔH in. H <sub>2</sub> O	Actual Meter Vol. ft <sup>3</sup>	Stack Temp °F	Meter Temp Inlet °F	Meter Temp Outlet °F	Impinger Exit Temp °F
1-1	5:25:00	1.00	1.70	86.937	71	61	61	54
1-1	5:35:00	0.95	1.70	94.110	71	62	62	54
1-2	5:45:00	1.00	1.70	101.140	71	62	62	54
1-2	5:55:00	1.00	1.70	108.320	70	63	63	55
1-3	6:05:00	1.00	1.70	115.520	70	64	64	54
1-3	6:15:00	1.00	1.70	122.740	71	65	65	55
1-4	6:25:00	1.00	1.70	130.010	71	66	66	55
1-4	6:35:00	1.00	1.70	137.020	71	66	66	55
1-5	6:45:00	1.00	1.70	144.510	71	67	67	56
1-5	6:55:00	1.00	1.70	151.770	71	67	67	56
1-6	7:05:00	1.00	1.70	159.030	71	68	68	56
1-6	7:15:00	1.00	1.70	166.310	71	68	68	57
1-7	7:25:00	1.00	1.80	173.620	72	68	68	57
1-7	7:35:00	1.00	1.80	180.850	72	68	68	58
1-8	7:45:00	1.00	1.80	188.150	72	69	69	58
1-8	7:55:00	1.00	1.80	195.440	72	69	69	57
1-9	8:05:00	1.00	1.80	202.730	72	70	70	55
1-9	8:15:00	1.00	1.80	210.040	72	70	70	55
1-10	8:25:00	1.00	1.80	217.340	73	70	70	55
1-10	8:35:00	1.00	1.80	224.630	73	70	70	56
1-11	8:45:00	0.90	1.60	231.920	74	71	71	56
1-11	8:55:00	0.90	1.60	238.860	74	71	71	56
1-12	9:05:00	0.95	1.70	245.730	75	72	72	57
1-12	9:15:00	0.95	1.70	252.880	77	72	72	58
	9:25:00			260.002				
2-1	9:35:00	0.95	1.70	260.002	79	74	74	60
2-1	9:45:00	0.95	1.70	267.080	79	74	74	61
2-2	9:55:00	1.00	1.80	274.220	80	75	75	62
2-2	10:05:00	1.00	1.80	281.570	80	76	76	63
2-3	10:15:00	1.00	1.80	288.890	81	77	77	62
2-3	10:25:00	1.00	1.80	296.190	81	78	78	60
2-4	10:35:00	1.00	1.80	303.620	81	79	79	60
2-4	10:45:00	1.00	1.80	310.970	82	79	79	60
2-5	10:55:00	1.00	1.80	318.330	83	80	80	61
2-5	11:05:00	1.00	1.80	325.690	83	81	81	61
2-6	11:15:00	1.00	1.80	333.050	83	81	81	61
2-6	11:25:00	1.00	1.80	340.380	84	82	82	62
2-7	11:35:00	1.00	1.80	347.750	84	82	82	62
2-7	11:45:00	1.00	1.80	355.140	85	82	82	62
2-8	11:55:00	1.00	1.80	362.510	86	83	83	63
2-8	12:05:00	1.00	1.80	369.940	88	84	84	64
2-9	12:15:00	1.00	1.80	377.350	87	84	84	63
2-9	12:25:00	1.00	1.80	384.740	87	85	85	64
2-10	12:35:00	0.90	1.60	392.150	88	85	85	64
2-10	12:45:00	0.90	1.60	399.130	88	85	85	64
2-11	12:55:00	0.90	1.60	406.140	88	85	85	65
2-11	13:05:00	0.90	1.60	413.160	88	85	85	65
2-12	13:15:00	0.90	1.60	420.180	89	86	86	64
	13:25:00			427.180				

Total 7:50:00 340.243 74.1 74.1

Average 1.74  
Min 1.60  
Max 1.80 89.0 86.0

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

Date	Time	Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
		Temp, °F	dP, "H <sub>2</sub> O						
6/27/2023	5:15:00	81.6	0.99	78.1	1	79.8	1.14	64.9	0.95
6/27/2023	5:16:00	81.7	0.99	78.2	1	76.6	1.13	64.9	0.95
6/27/2023	5:17:00	81.9	0.99	78.2	1	76.8	1.12	64.9	0.95
6/27/2023	5:18:00	82	0.99	78.4	1	76.8	1.12	64.9	0.95
6/27/2023	5:19:00	82.1	0.99	78.5	1	76.8	1.12	64.9	0.95
6/27/2023	5:20:00	82.3	0.99	78.6	1	76.8	1.15	64.9	0.96
6/27/2023	5:21:00	82.4	0.99	78.6	1	76.8	1.16	64.9	0.98
6/27/2023	5:22:00	82.5	1	78.6	1	76.8	1.17	64.9	0.99
6/27/2023	5:23:00	82.7	1	78.6	1	76.8	1.18	64.9	0.99
6/27/2023	5:24:00	82.8	1	78.6	1	76.8	1.17	64.9	0.99
6/27/2023	5:25:00	82.9	1	78.5	1	76.8	1.17	64.9	0.99
6/27/2023	5:26:00	83	1	78.5	1	76.8	1.17	64.9	0.99
6/27/2023	5:27:00	83	1	78.4	1	76.8	1.17	64.9	1
6/27/2023	5:28:00	83.1	1	78.3	1	76.8	1.17	64.9	0.99
6/27/2023	5:29:00	83.2	1	78	1	76.8	1.17	64.9	0.99
6/27/2023	5:30:00	83.2	1	77.8	1	76.8	1.17	64.9	0.99
6/27/2023	5:31:00	83.2	1	77.5	1	76.8	1.17	64.9	0.99
6/27/2023	5:32:00	83.2	1	77.3	1	76.8	1.17	64.9	0.99
6/27/2023	5:33:00	83.3	1	77.2	1	76.8	1.17	64.9	0.99
6/27/2023	5:34:00	83.4	1	77.1	1	76.8	1.17	64.9	1
6/27/2023	5:35:00	83.4	1	76.9	1	76.8	1.17	64.9	0.99
6/27/2023	5:36:00	83.4	1	76.7	1	76.8	1.17	64.9	0.99
6/27/2023	5:37:00	83.4	1	76.6	1	76.8	1.17	64.9	0.99
6/27/2023	5:38:00	83.5	1	76.5	1	76.8	1.17	64.9	0.99
6/27/2023	5:39:00	83.5	1	76.5	1	76.8	1.16	64.9	0.99
6/27/2023	5:40:00	83.6	1	76.4	1	76.8	1.16	64.9	0.99
6/27/2023	5:41:00	83.6	1	76.3	1	76.8	1.16	64.9	0.99
6/27/2023	5:42:00	83.6	1	76.3	1	76.8	1.16	64.9	1
6/27/2023	5:43:00	83.7	1	76.2	1	76.8	1.16	64.9	0.99
6/27/2023	5:44:00	83.7	1	76.1	1	76.8	1.16	64.9	0.99
6/27/2023	5:45:00	83.8	1	76	1	76.8	1.16	64.9	0.99
6/27/2023	5:46:00	83.8	1	76	1	76.8	1.16	64.9	0.99
6/27/2023	5:47:00	83.8	1	75.9	1	76.8	1.16	64.9	0.99
6/27/2023	5:48:00	83.9	1	75.9	1	76.8	1.16	64.9	0.99
6/27/2023	5:49:00	83.9	1	76	1	76.8	1.16	64.9	0.99
6/27/2023	5:50:00	84	1	75.9	1	76.8	1.16	64.9	0.99
6/27/2023	5:51:00	84	1	75.9	1	76.8	1.16	64.9	0.99
6/27/2023	5:52:00	84	1	75.8	1	76.8	1.16	64.9	0.99
6/27/2023	5:53:00	84.2	1	75.6	1	76.8	1.16	64.9	0.99
6/27/2023	5:54:00	84.2	1	75.5	1	76.8	1.16	64.9	0.99
6/27/2023	5:55:00	84.2	1	75.4	1	76.8	1.16	64.9	0.99
6/27/2023	5:56:00	84.2	1	75.3	1	76.8	1.16	64.9	0.99
6/27/2023	5:57:00	84.2	1	75.1	1	76.8	1.16	64.9	0.99
6/27/2023	5:58:00	84.2	1	74.9	1	76.8	1.16	64.9	0.99
6/27/2023	5:59:00	84.2	1	74.6	1	76.8	1.16	64.9	0.99
6/27/2023	6:00:00	84.2	1	74.4	1	76.8	1.16	64.9	0.99
6/27/2023	6:01:00	84.1	1	74.3	1	76.8	1.16	64.9	0.99
6/27/2023	6:02:00	84	1	74	1	76.8	1.16	64.9	0.99
6/27/2023	6:03:00	83.9	1	73.7	1	76.8	1.16	64.9	0.99
6/27/2023	6:04:00	83.9	1	73.4	1	76.8	1.15	64.9	0.99
6/27/2023	6:05:00	83.8	1	73.2	1	76.8	1.16	64.9	1
6/27/2023	6:06:00	83.8	1	73.1	1	76.8	1.15	64.9	0.99
6/27/2023	6:07:00	83.7	1	72.9	1	76.8	1.15	64.9	0.99
6/27/2023	6:08:00	83.9	1	72.8	1	76.8	1.15	64.9	1
6/27/2023	6:09:00	83.9	1	72.6	1	76.8	1.15	64.9	0.99
6/27/2023	6:10:00	83.9	1	72.5	1	76.8	1.15	64.9	0.99
6/27/2023	6:11:00	84	1	72.4	1	76.8	1.15	64.9	1
6/27/2023	6:12:00	84.1	1	72.3	1	76.8	1.15	64.9	0.99
6/27/2023	6:13:00	84.2	1	72.1	1	76.8	1.15	64.9	0.99
6/27/2023	6:14:00	84.2	1	71.8	1	76.8	1.15	64.9	0.99
6/27/2023	6:15:00	84.2	1	71.4	1	76.8	1.15	64.9	0.99
6/27/2023	6:16:00	84.1	1	70.9	1	76.8	1.15	64.9	0.99
6/27/2023	6:17:00	84.1	1	70.3	1	76.8	1.15	64.9	0.99
6/27/2023	6:18:00	84	1	69.6	1	76.8	1.15	64.9	0.99

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

Date	Time	Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
		Temp, °F	dP, "H <sub>2</sub> O						
6/27/2023	6:19:00	83.9	1	69	1	76.8	1.15	64.9	1
6/27/2023	6:20:00	83.9	1	68.3	1	76.8	1.15	64.9	1
6/27/2023	6:21:00	83.7	1	67.7	1	76.8	1.15	64.9	0.99
6/27/2023	6:22:00	83.7	1	67.1	1	76.8	1.15	64.9	0.99
6/27/2023	6:23:00	83.7	1	66.4	1	76.8	1.15	64.9	0.99
6/27/2023	6:24:00	83.7	1	65.9	1	76.8	1.15	64.9	0.99
6/27/2023	6:25:00	83.8	1	65.3	1	76.8	1.15	64.9	1
6/27/2023	6:26:00	83.8	1	71.8	1	76.8	1.15	64.9	1
6/27/2023	6:27:00	83.7	1	71.2	1	76.8	1.15	64.9	1
6/27/2023	6:28:00	83.7	1	70.8	1	76.8	1.15	64.9	1
6/27/2023	6:29:00	83.7	1	70.3	1	76.8	1.15	64.9	0.99
6/27/2023	6:30:00	83.7	1	69.8	1	76.8	1.15	64.9	0.99
6/27/2023	6:31:00	83.6	1	69.4	1	76.8	1.15	64.9	1
6/27/2023	6:32:00	83.7	1	69	1	76.8	1.14	64.9	0.99
6/27/2023	6:33:00	83.8	1	68.6	1	76.8	1.14	64.9	1
6/27/2023	6:34:00	83.8	1	68.3	1	76.8	1.14	64.9	1
6/27/2023	6:35:00	83.6	1	67.9	1	76.8	1.14	64.9	0.99
6/27/2023	6:36:00	83.6	1	67.6	1	76.8	1.14	64.9	1
6/27/2023	6:37:00	83.5	1	67.3	1	76.8	1.14	64.9	0.99
6/27/2023	6:38:00	83.6	1	67	1	77.8	1.14	64.9	0.99
6/27/2023	6:39:00	83.5	1	66.7	1	77.3	1.14	64.9	0.99
6/27/2023	6:40:00	83.6	1	69.5	1	76.5	1.14	64.9	0.99
6/27/2023	6:41:00	83.6	1	69.3	1	75.8	1.14	64.9	0.99
6/27/2023	6:42:00	83.6	1	69.1	1	74.7	1.14	64.9	0.99
6/27/2023	6:43:00	83.7	1	68.9	1	74.1	1.14	64.9	0.99
6/27/2023	6:44:00	83.8	1	68.7	1	73.5	1.14	64.9	1
6/27/2023	6:45:00	83.8	1	68.5	1	72.7	1.14	64.9	1
6/27/2023	6:46:00	83.8	1	68.4	1	72	1.14	64.9	0.99
6/27/2023	6:47:00	83.8	1	68.2	1	71.3	1.14	64.9	0.99
6/27/2023	6:48:00	83.8	1	68.1	1	70.7	1.14	64.9	1
6/27/2023	6:49:00	83.8	1	68	1	70.3	1.14	64.9	0.99
6/27/2023	6:50:00	83.9	1	67.9	1	69.6	1.14	64.9	1
6/27/2023	6:51:00	83.9	1	67.8	1	69.1	1.14	64.9	1
6/27/2023	6:52:00	83.8	1	67.7	1	68.3	1.13	64.9	0.99
6/27/2023	6:53:00	83.9	1	67.6	1	68	1.13	64.9	0.99
6/27/2023	6:54:00	84	1	67.5	1	67.7	1.13	64.9	1
6/27/2023	6:55:00	84	1	67.4	1	67.3	1.13	64.9	1
6/27/2023	6:56:00	84.1	1	67.4	1	66.9	1.13	64.9	1
6/27/2023	6:57:00	84.1	1	67.3	1	66.5	1.13	64.9	0.99
6/27/2023	6:58:00	84.1	1	67.3	1	66.2	1.13	64.9	1
6/27/2023	6:59:00	84.1	1	67.2	1	65.8	1.13	64.9	1
6/27/2023	7:00:00	83.9	1	67.2	1	65.5	1.13	64.9	1
6/27/2023	7:01:00	83.9	1	67.2	1	65.2	1.13	64.9	1
6/27/2023	7:02:00	83.9	1	67.2	1	65	1.13	64.9	1
6/27/2023	7:03:00	83.9	1	67.1	1	64.9	1.13	64.9	1
6/27/2023	7:04:00	84	1	67.1	1	64.6	1.13	64.9	1
6/27/2023	7:05:00	84	1	67	1	64.5	1.13	64.9	1
6/27/2023	7:06:00	84	1	67	1	64.3	1.13	64.9	0.99
6/27/2023	7:07:00	84	1	67	1	63.9	1.13	64.9	1
6/27/2023	7:08:00	84.1	1	67	1	63.6	1.13	64.9	1
6/27/2023	7:09:00	84.1	1	67	1	63.4	1.13	64.9	1
6/27/2023	7:10:00	84.1	1	67.1	1	63.2	1.13	64.9	1
6/27/2023	7:11:00	84	1	67.1	1	63.1	1.13	64.9	0.99
6/27/2023	7:12:00	84.1	1	67.2	1	63	1.13	64.9	1
6/27/2023	7:13:00	84.2	1	67.3	1	62.9	1.13	64.9	1
6/27/2023	7:14:00	84.2	1	67.4	1	62.8	1.13	64.9	0.99
6/27/2023	7:15:00	84.2	1	67.5	1	62.6	1.12	64.9	0.99
6/27/2023	7:16:00	84.1	1	67.7	1	62.5	1.12	64.9	0.99
6/27/2023	7:17:00	84	1	67.9	1	62.3	1.12	64.9	0.99
6/27/2023	7:18:00	84	1	68.1	1	62.3	1.12	64.9	0.99
6/27/2023	7:19:00	84	1	68.3	1	62.3	1.12	64.9	1
6/27/2023	7:20:00	84	1	68.5	1	62.3	1.12	64.9	1
6/27/2023	7:21:00	84	1	68.7	1	62.3	1.12	64.9	0.99
6/27/2023	7:22:00	83.9	1	68.9	1	62.3	1.12	64.9	1

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

Date	Time	Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
		Temp, °F	dP, "H <sub>2</sub> O						
6/27/2023	7:23:00	83.8	1	69.1	1	62.3	1.12	64.9	1
6/27/2023	7:24:00	83.8	1	69.2	1	62.2	1.12	64.9	1
6/27/2023	7:25:00	83.8	1	69.4	1	62.1	1.12	64.9	1
6/27/2023	7:26:00	83.9	1	69.6	1	62.1	1.12	64.9	1
6/27/2023	7:27:00	84	1	69.7	1	62	1.12	64.9	1
6/27/2023	7:28:00	84.1	1	69.8	1	62	1.12	64.9	1
6/27/2023	7:29:00	84.1	1	69.9	1	62	1.12	64.9	1
6/27/2023	7:30:00	84.2	1	70	1	61.7	1.12	64.9	1
6/27/2023	7:31:00	84.3	1	70.1	1	61.8	1.12	64.9	1
6/27/2023	7:32:00	84.3	1	70.1	1	62	1.12	64.9	1
6/27/2023	7:33:00	84.5	1	70.1	1	62	1.12	64.9	1
6/27/2023	7:34:00	84.4	1	70.1	1	62	1.12	64.9	1
6/27/2023	7:35:00	84.4	1	70.1	1	62	1.12	64.9	1
6/27/2023	7:36:00	84.3	1	70	1	62	1.12	64.9	1
6/27/2023	7:37:00	84.3	1	69.9	1	62	1.12	64.9	1
6/27/2023	7:38:00	84.2	1	69.8	1	62	1.11	64.9	1
6/27/2023	7:39:00	84.1	1	69.6	1	62	1.11	64.9	1
6/27/2023	7:40:00	84.1	1	69.5	1	62	1.11	64.9	1
6/27/2023	7:41:00	83.9	1	69.4	1	62	1.11	64.9	1
6/27/2023	7:42:00	83.8	1	69.3	1	62	1.11	64.9	1
6/27/2023	7:43:00	83.8	1	69.1	1	62	1.11	64.9	1
6/27/2023	7:44:00	83.8	1	69	1	62	1.11	64.9	1
6/27/2023	7:45:00	83.7	1	68.9	1	61.8	1.11	64.9	1
6/27/2023	7:46:00	83.7	1	68.8	1	61.7	1.11	64.9	1
6/27/2023	7:47:00	83.6	1	68.7	1	61.9	1.11	64.9	1
6/27/2023	7:48:00	83.5	1	68.6	1	61.7	1.11	64.9	1
6/27/2023	7:49:00	83.4	1	68.6	1	61.8	1.11	64.9	1
6/27/2023	7:50:00	83.3	1	68.5	1	62	1.11	64.9	1
6/27/2023	7:51:00	83.2	1	68.4	1	62	1.11	64.9	1
6/27/2023	7:52:00	83.2	1	68.3	1	62	1.11	64.9	1
6/27/2023	7:53:00	83	1	68.2	1	62	1.11	64.9	1
6/27/2023	7:54:00	82.9	1	68.2	1	62	1.11	64.9	1
6/27/2023	7:55:00	82.9	1	68.1	1	62.1	1.11	64.9	1
6/27/2023	7:56:00	82.8	1	68	1	62.2	1.11	64.9	1
6/27/2023	7:57:00	82.9	1	67.9	1	62.3	1.11	64.9	1
6/27/2023	7:58:00	82.8	1	67.9	1	62.3	1.11	64.9	1
6/27/2023	7:59:00	82.7	1	67.8	1	62.6	1.11	64.9	1
6/27/2023	8:00:00	82.7	1	67.8	1	62.9	1.11	64.9	1
6/27/2023	8:01:00	82.5	1	67.7	1	63.2	1.1	64.9	1
6/27/2023	8:02:00	82.5	1	67.6	1	63.3	1.1	64.9	1
6/27/2023	8:03:00	82.4	1	67.5	1	63.5	1.1	64.9	1
6/27/2023	8:04:00	82.3	1	67.5	1	63.9	1.1	64.9	1
6/27/2023	8:05:00	82.2	1	67.4	1	64.3	1.1	64.9	0.99
6/27/2023	8:06:00	82	1	67.4	1	64.5	1.1	64.9	1
6/27/2023	8:07:00	81.9	1	67.3	1	64.7	1.1	64.9	1
6/27/2023	8:08:00	81.8	1	67.3	1	65	1.1	64.9	1
6/27/2023	8:09:00	81.8	1	67.2	1	65.1	1.1	64.9	1
6/27/2023	8:10:00	81.8	1	67.2	1	65.3	1.1	64.9	1
6/27/2023	8:11:00	81.7	1	67.1	1	65.2	1.1	64.9	1
6/27/2023	8:12:00	81.8	1	67.1	1	65.3	1.1	64.9	1
6/27/2023	8:13:00	81.8	1	67	1	65.3	1.1	64.9	1
6/27/2023	8:14:00	81.7	1	66.9	1	65.3	1.1	64.9	1
6/27/2023	8:15:00	81.6	1	66.8	1	65.2	1.09	64.9	1
6/27/2023	8:16:00	81.5	1	66.7	1	65	1.09	64.9	1
6/27/2023	8:17:00	81.5	1	66.7	1	65	1.09	64.9	1
6/27/2023	8:18:00	81.5	1	66.6	1	65.1	1.09	64.9	1
6/27/2023	8:19:00	81.5	1	66.6	1	65.2	1.09	64.9	1
6/27/2023	8:20:00	81.4	1	66.6	1	65.2	1.09	64.9	1
6/27/2023	8:21:00	81.3	1	66.5	1	65.3	1.09	64.9	1
6/27/2023	8:22:00	81.2	1	66.5	1	65.1	1.09	64.9	1
6/27/2023	8:23:00	81.1	1	66.4	1	65.1	1.09	64.9	1
6/27/2023	8:24:00	81	1	66.3	1	65.2	1.09	64.9	1
6/27/2023	8:25:00	81	1	66.3	1	65.2	1.09	64.9	1
6/27/2023	8:26:00	80.9	1	66.2	1	65.2	1.09	64.9	1

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

Date	Time	Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
		Temp, °F	dP, "H <sub>2</sub> O						
6/27/2023	8:27:00	80.8	1	66.1	1	65.2	1.08	64.9	1
6/27/2023	8:28:00	80.7	1	66.1	1	65.2	1.08	64.9	1
6/27/2023	8:29:00	80.6	1	66	1	65.1	1.08	64.9	1
6/27/2023	8:30:00	80.5	1	65.9	1	65.1	1.08	64.9	1
6/27/2023	8:31:00	80.3	1	65.8	1	65.1	1.08	64.9	1
6/27/2023	8:32:00	80.2	1	65.6	1	65	1.08	64.9	1.01
6/27/2023	8:33:00	80.1	1	65.5	1	64.8	1.08	64.9	1
6/27/2023	8:34:00	79.9	1	65.4	1	64.8	1.08	64.9	1
6/27/2023	8:35:00	79.8	1	65.3	1	64.7	1.08	64.9	1
6/27/2023	8:36:00	79.8	1	65.2	1	64.7	1.08	64.9	1
6/27/2023	8:37:00	79.7	1	65	1	64.7	1.08	64.9	1
6/27/2023	8:38:00	79.6	1	64.9	1	64.7	1.07	64.9	1
6/27/2023	8:39:00	79.5	1	64.8	1	64.8	1.07	64.9	1
6/27/2023	8:40:00	79.4	1	64.7	1	64.5	1.07	64.9	1.01
6/27/2023	8:41:00	79.2	1	64.6	1	64.4	1.07	64.9	1
6/27/2023	8:42:00	79.1	1	64.5	1	64.4	1.07	64.9	1
6/27/2023	8:43:00	79.2	1	64.4	1	64.2	1.07	64.9	1
6/27/2023	8:44:00	79.1	1	64.3	1	64.2	1.07	64.9	1
6/27/2023	8:45:00	79.1	1	64.2	1	64.2	1.07	64.9	1
6/27/2023	8:46:00	79	1	64	1	64	1.07	64.9	1
6/27/2023	8:47:00	79	1	63.9	1	63.9	1.06	64.9	1
6/27/2023	8:48:00	78.9	1	63.8	1	63.9	1.06	64.9	1
6/27/2023	8:49:00	78.9	1	63.7	1	64	1.06	64.9	1
6/27/2023	8:50:00	78.9	1	63.6	1	63.9	1.06	64.9	1
6/27/2023	8:51:00	78.8	1	63.5	1	64	1.06	64.9	1
6/27/2023	8:52:00	78.8	1	63.4	1	64	1.06	64.9	1
6/27/2023	8:53:00	78.8	1	63.3	1	64	1.06	64.9	1
6/27/2023	8:54:00	78.7	1	63.2	1	63.8	1.06	64.9	1
6/27/2023	8:55:00	78.6	1	63.1	1	63.6	1.05	64.9	1
6/27/2023	8:56:00	78.6	1	63	1	63.4	1.05	64.9	1
6/27/2023	8:57:00	78.5	1	62.9	1	63.4	1.05	64.9	1
6/27/2023	8:58:00	78.5	1	62.8	1	63.3	1.05	64.9	1
6/27/2023	8:59:00	78.4	1	62.7	1	63.2	1.05	64.9	1
6/27/2023	9:00:00	78.3	1	62.6	1	63	1.05	64.9	1
6/27/2023	9:01:00	78.4	1	62.5	1	62.8	1.05	64.9	1
6/27/2023	9:02:00	78.3	1	62.4	1	62.4	1.05	64.9	1
6/27/2023	9:03:00	78.2	1	62.3	1	62.2	1.05	64.9	1
6/27/2023	9:04:00	78.1	1	62.3	1	62.2	1.04	64.9	1
6/27/2023	9:05:00	78	1	62.2	1	62.2	1.04	64.9	1
6/27/2023	9:06:00	77.9	1	62.1	1	62	1.04	64.9	1
6/27/2023	9:07:00	77.9	1	62	1	61.8	1.04	64.9	1
6/27/2023	9:08:00	77.8	1	61.8	1	61.5	1.04	64.9	1
6/27/2023	9:09:00	77.8	1	61.7	1	61.2	1.04	64.9	1
6/27/2023	9:10:00	77.7	1	61.6	1	60.9	1.04	64.9	1
6/27/2023	9:11:00	77.6	1	61.5	1	60.8	1.04	64.9	1
6/27/2023	9:12:00	77.6	1	61.4	1	60.5	1.04	64.9	1
6/27/2023	9:13:00	77.5	1	61.3	1	60.4	1.03	64.9	1
6/27/2023	9:14:00	77.5	1	61.2	1	60.3	1.03	64.9	1
6/27/2023	9:15:00	77.4	1	61.1	1	60.2	1.03	64.9	1
6/27/2023	9:16:00	77.4	1	61.1	1	69.8	1.03	64.9	1
6/27/2023	9:17:00	77.4	1	61	1	69.6	1.03	64.9	1
6/27/2023	9:18:00	77.4	1	60.9	1	69.5	1.03	64.9	1
6/27/2023	9:19:00	77.3	1	60.8	1	69.5	1.03	64.9	1
6/27/2023	9:20:00	77.3	1	60.7	1	69.5	1.03	64.9	1
6/27/2023	9:21:00	77.2	1	60.6	1	69.5	1.03	64.9	1
6/27/2023	9:22:00	77.1	1	60.6	1	69.5	1.02	64.9	1
6/27/2023	9:23:00	77.1	1	60.5	1	69.5	1.02	64.9	1
6/27/2023	9:24:00	77	1.01	60.4	1	69.5	1.02	64.9	1
6/27/2023	9:25:00	76.9	1.01	60.3	1	69.5	1.02	64.9	1
6/27/2023	9:26:00	76.8	1.01	60.2	1	69.5	1.02	64.9	1
6/27/2023	9:27:00	76.8	1.01	60.2	1	69.5	1.02	64.9	1
6/27/2023	9:28:00	76.7	1.01	60.1	1	69.3	1.02	64.9	1
6/27/2023	9:29:00	76.6	1.01	60.1	1	69.2	1.02	64.9	1
6/27/2023	9:30:00	76.5	1.01	60	1	69	1.02	64.9	1

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

Date	Time	Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
		Temp, °F	dP, "H <sub>2</sub> O						
6/27/2023	9:31:00	76.4	1.01	60	1	68.9	1.02	64.9	1
6/27/2023	9:32:00	76.3	1.01	79.9	1	68.9	1.02	64.9	1
6/27/2023	9:33:00	76.2	1.01	79.9	1	68.8	1.01	64.9	1
6/27/2023	9:34:00	76.2	1.01	79.8	1	68.6	1.01	64.9	1
6/27/2023	9:35:00	76	1.01	79.7	1	68.5	1.01	64.9	1
6/27/2023	9:36:00	75.9	1.01	79.6	1	68.1	1.01	64.9	1.01
6/27/2023	9:37:00	75.8	1.01	79.6	1	68	1.01	64.9	1
6/27/2023	9:38:00	75.6	1.01	79.6	1	67.7	1.01	64.9	1
6/27/2023	9:39:00	75.5	1.01	79.5	1	67.5	1.01	64.9	1
6/27/2023	9:40:00	75.3	1.01	79.4	1	67.3	1.01	64.9	1.01
6/27/2023	9:41:00	75.1	1.01	79.3	1	67.1	1.01	64.8	1.01
6/27/2023	9:42:00	75	1.01	79.3	1	66.9	1	64.8	1
6/27/2023	9:43:00	74.8	1.01	79.2	1	66.5	1	64.8	1
6/27/2023	9:44:00	74.7	1.01	79.1	1	66.5	1	64.8	1
6/27/2023	9:45:00	74.5	1.01	79	1	66.5	1	64.8	1.01
6/27/2023	9:46:00	74.3	1.01	78.9	1	66.3	1	64.8	1.01
6/27/2023	9:47:00	74.2	1.01	78.8	1	65.8	1	64.8	1
6/27/2023	9:48:00	74	1.01	78.8	1	65.5	1	64.8	1.01
6/27/2023	9:49:00	73.8	1.01	78.7	1	65.3	1	64.8	1.01
6/27/2023	9:50:00	73.6	1.01	78.6	1	65.2	0.99	64.8	1
6/27/2023	9:51:00	73.4	1.01	78.5	1	65.1	0.99	64.8	1.01
6/27/2023	9:52:00	73.2	1.01	78.4	1	64.9	0.99	64.8	1
6/27/2023	9:53:00	73.1	1.01	78.3	1	64.6	0.99	64.8	1
6/27/2023	9:54:00	72.9	1.01	78.2	1	64.4	0.99	64.8	1.01
6/27/2023	9:55:00	72.8	1.01	78.1	1	64.3	0.99	64.8	1.01
6/27/2023	9:56:00	72.7	1.01	78	1	64.1	0.98	64.8	1.01
6/27/2023	9:57:00	72.5	1.01	77.9	1	63.9	0.98	64.8	1.01
6/27/2023	9:58:00	72.4	1.01	77.8	1	63.7	0.98	64.8	1.01
6/27/2023	9:59:00	72.3	1.01	77.7	1	63.8	0.98	64.8	1.01
6/27/2023	10:00:00	72.1	1.01	77.5	1	63.7	0.98	64.8	1.01
6/27/2023	10:01:00	72	1.01	77.5	1	63.5	0.98	64.8	1.01
6/27/2023	10:02:00	71.9	1.01	77.4	1	63.3	0.98	64.8	1.01
6/27/2023	10:03:00	71.8	1.01	77.3	1	63	0.97	64.8	1.01
6/27/2023	10:04:00	71.6	1.01	77.2	1	63.1	0.97	64.8	1.01
6/27/2023	10:05:00	71.6	1.01	77.1	1	63	0.97	64.8	1.01
6/27/2023	10:06:00	71.4	1.01	77	1	62.8	0.97	64.8	1.01
6/27/2023	10:07:00	71.4	1.01	76.9	1	62.3	0.97	64.8	1.01
6/27/2023	10:08:00	71.3	1.01	76.7	1	62.3	0.97	64.8	1.01
6/27/2023	10:09:00	71.2	1.01	76.6	1	62.2	0.96	64.8	1.01
6/27/2023	10:10:00	71	1.01	76.5	1	62.1	0.96	64.8	1.01
6/27/2023	10:11:00	70.9	1.01	76.5	1	62	0.96	64.8	1.01
6/27/2023	10:12:00	70.9	1.01	76.4	1	61.7	0.96	64.8	1.01
6/27/2023	10:13:00	70.8	1.01	76.3	1	61.7	0.96	64.8	1.01
6/27/2023	10:14:00	70.7	1.01	76.3	1	61.7	0.96	64.8	1.01
6/27/2023	10:15:00	70.7	1.01	76.2	1	63.3	0.96	64.8	1.01
6/27/2023	10:16:00	70.6	1.01	76.1	1	64.5	0.95	64.8	1.01
6/27/2023	10:17:00	70.5	1.01	76	1	65.6	0.95	64.8	1.01
6/27/2023	10:18:00	70.4	1.01	75.9	1	65.5	0.95	64.8	1.01
6/27/2023	10:19:00	70.4	1.01	75.9	1	64.5	0.95	64.8	1.01
6/27/2023	10:20:00	70.3	1.01	75.8	1	63.2	0.95	64.8	1.01
6/27/2023	10:21:00	70.2	1.01	75.7	1	65.6	0.95	64.8	1.01
6/27/2023	10:22:00	70.1	1.01	75.6	1	66.6	0.95	64.8	1.01
6/27/2023	10:23:00	70	1.01	75.6	1	66.2	0.94	64.8	1.01
6/27/2023	10:24:00	70	1.01	75.5	1	66.3	0.94	64.8	1.01
6/27/2023	10:25:00	69.9	1.01	75.4	1	66.4	0.94	64.8	1.01
6/27/2023	10:26:00	69.8	1.01	75.3	1	66.4	0.94	64.8	1.01
6/27/2023	10:27:00	69.8	1.01	75.2	1	66.8	0.94	64.8	1.01
6/27/2023	10:28:00	69.8	1.02	75.2	1	66.4	0.94	64.8	1.01
6/27/2023	10:29:00	69.6	1.02	75.1	1	66.8	0.94	64.8	1.01
6/27/2023	10:30:00	69.6	1.02	75	1	68.4	0.93	64.8	1.01
6/27/2023	10:31:00	69.5	1.02	75	1	67.8	0.93	64.8	1.01
6/27/2023	10:32:00	69.4	1.02	74.9	1	67.5	0.93	64.8	1.01
6/27/2023	10:33:00	69.4	1.02	74.8	1	64.3	0.93	64.8	1.01
6/27/2023	10:34:00	69.3	1.02	74.8	1	64.2	0.93	64.8	1.01

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

Date	Time	Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
		Temp, °F	dP, "H <sub>2</sub> O						
6/27/2023	10:35:00	69.3	1.02	74.7	1	65	0.93	64.8	1.01
6/27/2023	10:36:00	69.1	1.02	74.7	1	66.7	0.93	64.8	1.01
6/27/2023	10:37:00	69.1	1.02	74.6	1	66.3	0.92	64.8	1.01
6/27/2023	10:38:00	69.1	1.02	74.5	1	66.5	0.92	64.8	1.02
6/27/2023	10:39:00	69	1.02	74.4	1	66.3	0.92	64.8	1.02
6/27/2023	10:40:00	68.9	1.02	74.3	1	68	0.92	64.8	1.01
6/27/2023	10:41:00	68.9	1.02	74.3	1	68.2	0.92	64.8	1.01
6/27/2023	10:42:00	68.8	1.02	74.2	1	68.8	0.92	64.8	1.01
6/27/2023	10:43:00	68.7	1.02	74.2	1	69.1	0.91	64.8	1.01
6/27/2023	10:44:00	68.7	1.02	74.1	1	68.2	0.91	64.8	1.01
6/27/2023	10:45:00	68.6	1.02	74	1	68	0.91	64.8	1.02
6/27/2023	10:46:00	68.5	1.02	74	1	67	0.91	64.8	1.02
6/27/2023	10:47:00	68.5	1.02	73.9	1	66.5	0.91	64.8	1.02
6/27/2023	10:48:00	68.4	1.02	73.9	1	66.4	0.91	64.8	1.01
6/27/2023	10:49:00	68.3	1.02	73.8	1	66.8	0.91	64.8	1.02
6/27/2023	10:50:00	68.3	1.02	73.8	1	66.7	0.9	64.8	1.02
6/27/2023	10:51:00	68.2	1.02	73.7	1	67.2	0.9	64.8	1.02
6/27/2023	10:52:00	68.2	1.02	73.7	1	68.2	0.9	64.8	1.02
6/27/2023	10:53:00	68.1	1.02	73.6	1	67.9	0.9	64.8	1.02
6/27/2023	10:54:00	68.1	1.02	73.5	1	67	0.9	64.8	1.02
6/27/2023	10:55:00	68	1.02	73.5	1	67.5	0.9	64.8	1.02
6/27/2023	10:56:00	68	1.02	73.4	1	69.2	0.9	64.8	1.02
6/27/2023	10:57:00	67.9	1.02	73.4	1	69.4	0.89	64.8	1.02
6/27/2023	10:58:00	67.8	1.02	73.3	1	68.8	0.89	64.8	1.02
6/27/2023	10:59:00	67.8	1.02	73.2	1	67.1	0.89	64.8	1.02
6/27/2023	11:00:00	67.7	1.02	73.1	1	67.4	0.89	64.8	1.02
6/27/2023	11:01:00	67.6	1.02	73	1	67	0.89	64.8	1.02
6/27/2023	11:02:00	67.6	1.02	73	1	68.3	0.89	64.8	1.02
6/27/2023	11:03:00	67.5	1.02	72.9	1	68	0.88	64.8	1.02
6/27/2023	11:04:00	67.4	1.02	72.8	1	69.1	0.88	64.8	1.02
6/27/2023	11:05:00	67.3	1.02	72.8	1	67	0.88	64.8	1.02
6/27/2023	11:06:00	67.3	1.02	72.7	1	67.3	0.88	64.8	1.02
6/27/2023	11:07:00	67.2	1.02	72.6	1	67.5	0.88	64.8	1.02
6/27/2023	11:08:00	67.2	1.02	72.5	1	68	0.88	64.8	1.02
6/27/2023	11:09:00	67.1	1.02	72.5	1	68.1	0.88	64.8	1.02
6/27/2023	11:10:00	67	1.02	72.4	1	68.4	0.87	64.8	1.02
6/27/2023	11:11:00	67	1.02	72.3	1	68.7	0.87	64.8	1.02
6/27/2023	11:12:00	66.9	1.02	72.2	1	66.9	0.87	64.8	1.02
6/27/2023	11:13:00	66.9	1.02	72.2	1	66.9	0.87	64.8	1.02
6/27/2023	11:14:00	66.9	1.02	72.1	1	66.9	0.87	64.8	1.02
6/27/2023	11:15:00	66.8	1.03	72.1	1	66.9	0.87	64.8	1.02
6/27/2023	11:16:00	66.7	1.02	72	1	66.9	0.87	64.8	1.02
6/27/2023	11:17:00	66.7	1.02	71.9	1	66.9	0.86	64.8	1.02
6/27/2023	11:18:00	66.6	1.03	71.8	1	66.9	0.86	64.8	1.02
6/27/2023	11:19:00	66.5	1.03	71.8	1	66.9	0.86	64.8	1.02
6/27/2023	11:20:00	66.6	1.03	71.7	1	66.9	0.86	64.8	1.02
6/27/2023	11:21:00	66.5	1.03	71.6	1	66.9	0.86	64.8	1.02
6/27/2023	11:22:00	66.3	1.03	71.6	1	66.9	0.86	64.8	1.02
6/27/2023	11:23:00	66.3	1.03	71.6	1	66.9	0.86	64.8	1.02
6/27/2023	11:24:00	66.3	1.03	71.5	1	66.9	0.85	64.8	1.02
6/27/2023	11:25:00	66.3	1.03	71.4	1	66.9	0.85	64.8	1.02
6/27/2023	11:26:00	66.3	1.03	71.4	1	66.9	0.85	64.8	1.02
6/27/2023	11:27:00	66.3	1.03	71.3	1	66.9	0.85	64.8	1.02
6/27/2023	11:28:00	66.2	1.03	71.3	1	66.9	0.85	64.8	1.02
6/27/2023	11:29:00	66.1	1.03	71.2	1	66.9	0.85	64.8	1.03
6/27/2023	11:30:00	66.1	1.03	71.2	1	66.9	0.85	64.8	1.02
6/27/2023	11:31:00	66	1.03	71.2	1	66.9	0.84	64.8	1.03
6/27/2023	11:32:00	66	1.03	71.1	1	66.9	0.84	64.8	1.03
6/27/2023	11:33:00	66	1.03	71.1	1	66.9	0.84	64.8	1.02
6/27/2023	11:34:00	65.9	1.03	71.1	1	66.9	0.84	64.8	1.03
6/27/2023	11:35:00	65.9	1.03	71	1	66.9	0.84	64.8	1.02
6/27/2023	11:36:00	65.8	1.03	71	1	66.9	0.84	64.8	1.03
6/27/2023	11:37:00	65.8	1.03	70.9	1	66.9	0.84	64.8	1.03
6/27/2023	11:38:00	65.7	1.03	70.9	1	66.9	0.84	64.8	1.03

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

Date	Time	Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
		Temp, °F	dP, "H <sub>2</sub> O						
6/27/2023	11:39:00	65.6	1.03	70.8	1	66.9	0.84	64.8	1.03
6/27/2023	11:40:00	65.6	1.03	70.7	1	66.9	0.83	64.8	1.03
6/27/2023	11:41:00	65.6	1.03	70.7	1	66.9	0.83	64.8	1.03
6/27/2023	11:42:00	65.5	1.03	70.6	1	66.9	0.83	64.8	1.03
6/27/2023	11:43:00	65.5	1.03	70.5	1	66.9	0.83	64.8	1.03
6/27/2023	11:44:00	65.4	1.03	70.5	1	66.9	0.83	64.8	1.03
6/27/2023	11:45:00	65.4	1.03	70.4	1	66.9	0.83	64.8	1.03
6/27/2023	11:46:00	65.3	1.03	70.4	1	66.9	0.83	64.8	1.03
6/27/2023	11:47:00	65.3	1.03	70.3	1	66.9	0.83	64.8	1.03
6/27/2023	11:48:00	65.2	1.03	70.3	1	66.9	0.83	64.8	1.03
6/27/2023	11:49:00	65.2	1.03	70.2	1	66.9	0.83	64.8	1.03
6/27/2023	11:50:00	65.2	1.03	70.2	1	66.9	0.82	64.8	1.03
6/27/2023	11:51:00	65.1	1.03	70.2	1	66.9	0.82	64.8	1.03
6/27/2023	11:52:00	65.1	1.03	70.1	1	66.9	0.82	64.8	1.03
6/27/2023	11:53:00	65.1	1.03	70.1	1	66.9	0.82	64.8	1.03
6/27/2023	11:54:00	65	1.03	70.1	1	66.9	0.82	64.8	1.03
6/27/2023	11:55:00	64.9	1.03	70	1	66.9	0.82	64.8	1.03
6/27/2023	11:56:00	64.9	1.03	70	1	66.9	0.82	64.8	1.03
6/27/2023	11:57:00	64.9	1.03	70	1	66.9	0.82	64.8	1.03
6/27/2023	11:58:00	64.9	1.03	69.9	1	66.9	0.82	64.8	1.03
6/27/2023	11:59:00	64.9	1.03	69.9	1	66.9	0.82	64.8	1.03
6/27/2023	12:00:00	64.8	1.03	69.9	1	66.9	0.81	64.8	1.03
6/27/2023	12:01:00	64.7	1.03	69.8	1	66.9	0.81	64.8	1.03
6/27/2023	12:02:00	64.7	1.03	69.8	1	66.9	0.81	64.8	1.03
6/27/2023	12:03:00	64.7	1.03	69.8	1	66.9	0.81	64.8	1.03
6/27/2023	12:04:00	64.7	1.03	69.8	1	66.9	0.81	64.8	1.03
6/27/2023	12:05:00	64.6	1.03	69.8	1	66.9	0.81	64.8	1.03
6/27/2023	12:06:00	64.6	1.03	69.8	1	66.9	0.81	64.8	1.03
6/27/2023	12:07:00	64.5	1.03	69.7	1	66.9	0.81	64.8	1.03
6/27/2023	12:08:00	64.6	1.03	69.7	1	66.9	0.81	64.8	1.03
6/27/2023	12:09:00	64.6	1.03	69.6	1	66.9	0.81	64.8	1.03
6/27/2023	12:10:00	64.5	1.03	69.6	1	66.9	0.8	64.8	1.03
6/27/2023	12:11:00	64.5	1.03	69.6	1	66.9	0.8	64.8	1.03
6/27/2023	12:12:00	64.5	1.03	69.6	1	66.9	0.8	64.8	1.03
6/27/2023	12:13:00	64.4	1.03	69.5	1	66.9	0.8	64.8	1.03
6/27/2023	12:14:00	64.4	1.03	69.5	1	66.9	0.8	64.8	1.03
6/27/2023	12:15:00	64.4	1.03	69.5	1	66.9	0.8	64.8	1.03
6/27/2023	12:16:00	64.4	1.03	69.4	1	66.9	0.8	64.8	1.04
6/27/2023	12:17:00	64.4	1.03	69.4	1	66.9	0.8	64.8	1.04
6/27/2023	12:18:00	64.3	1.03	69.4	1	66.9	0.8	64.8	1.03
6/27/2023	12:19:00	64.2	1.03	69.4	1	66.9	0.8	64.8	1.03
6/27/2023	12:20:00	64.2	1.03	69.4	1	66.9	0.79	64.8	1.03
6/27/2023	12:21:00	64.2	1.03	69.3	1	66.9	0.79	64.8	1.03
6/27/2023	12:22:00	64.2	1.03	69.3	1	66.9	0.79	64.8	1.03
6/27/2023	12:23:00	64.2	1.03	69.3	1	66.9	0.79	64.8	1.03
6/27/2023	12:24:00	64.1	1.03	69.2	1	66.9	0.79	64.8	1.03
6/27/2023	12:25:00	64.1	1.03	69.2	1	66.9	0.79	64.8	1.03
6/27/2023	12:26:00	64	1.03	69.2	1	66.9	0.79	64.8	1.03
6/27/2023	12:27:00	64	1.03	69.2	1	66.9	0.79	64.8	1.03
6/27/2023	12:28:00	63.9	1.03	69.2	1	66.9	0.79	64.8	1.03
6/27/2023	12:29:00	63.9	1.03	69.1	1	66.9	0.79	64.8	1.04
6/27/2023	12:30:00	63.9	1.03	69.1	1	66.9	0.79	64.8	1.03
6/27/2023	12:31:00	63.8	1.04	69.1	1	66.9	0.79	64.8	1.03
6/27/2023	12:32:00	63.8	1.03	69	1	66.9	0.78	64.8	1.03
6/27/2023	12:33:00	63.8	1.03	68.9	1	66.9	0.78	64.8	1.04
6/27/2023	12:34:00	63.7	1.03	68.8	1	66.9	0.78	64.8	1.03
6/27/2023	12:35:00	63.7	1.03	68.8	1	66.9	0.78	64.8	1.04
6/27/2023	12:36:00	63.7	1.03	68.7	1	66.9	0.78	64.8	1.04
6/27/2023	12:37:00	63.6	1.03	68.7	1	66.9	0.78	64.8	1.03
6/27/2023	12:38:00	63.5	1.04	68.6	1	66.9	0.78	64.8	1.04
6/27/2023	12:39:00	63.5	1.04	68.5	1	66.9	0.78	64.7	1.04
6/27/2023	12:40:00	63.5	1.04	68.5	1	66.9	0.78	64.7	1.03
6/27/2023	12:41:00	63.4	1.04	68.4	1	66.9	0.78	64.7	1.04
6/27/2023	12:42:00	63.4	1.04	68.4	1	66.9	0.77	64.7	1.04

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

Date	Time	Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
		Temp, °F	dP, "H <sub>2</sub> O						
6/27/2023	12:43:00	63.3	1.04	68.3	1	66.9	0.77	64.7	1.04
6/27/2023	12:44:00	63.3	1.04	68.3	1	66.9	0.77	64.7	1.04
6/27/2023	12:45:00	63.3	1.04	68.2	1	66.9	0.77	64.7	1.04
6/27/2023	12:46:00	63.2	1.04	68.2	1	66.9	0.77	64.7	1.04
6/27/2023	12:47:00	63.1	1.04	68.1	1	66.9	0.77	64.7	1.04
6/27/2023	12:48:00	63.1	1.04	68.1	1	66.9	0.77	64.7	1.04
6/27/2023	12:49:00	63.1	1.04	68.1	1	66.9	0.77	64.7	1.04
6/27/2023	12:50:00	63.1	1.04	68	1	66.9	0.77	64.7	1.04
6/27/2023	12:51:00	63.1	1.04	68	1	66.9	0.77	64.7	1.04
6/27/2023	12:52:00	63	1.04	68	1	66.9	0.77	64.7	1.04
6/27/2023	12:53:00	62.9	1.04	67.9	1	66.9	0.77	64.7	1.04
6/27/2023	12:54:00	63	1.04	67.9	1	66.9	0.76	64.7	1.04
6/27/2023	12:55:00	62.8	1.04	67.8	1	66.9	0.76	64.7	1.04
6/27/2023	12:56:00	62.9	1.04	67.8	1	66.9	0.76	64.7	1.04
6/27/2023	12:57:00	62.8	1.04	67.8	1	66.9	0.76	64.7	1.04
6/27/2023	12:58:00	62.8	1.04	67.7	1	66.9	0.76	64.7	1.04
6/27/2023	12:59:00	62.8	1.04	67.7	1	66.9	0.76	64.7	1.04
6/27/2023	13:00:00	62.7	1.04	67.6	1	66.9	0.76	64.7	1.04
6/27/2023	13:01:00	62.7	1.04	67.6	1	66.9	0.76	64.7	1.04
6/27/2023	13:02:00	62.6	1.04	67.6	1	66.9	0.76	64.7	1.04
6/27/2023	13:03:00	62.6	1.04	67.5	1	66.9	0.76	64.7	1.04
6/27/2023	13:04:00	62.6	1.04	67.5	1	66.9	0.76	64.7	1.04
6/27/2023	13:05:00	62.6	1.04	67.4	1	66.9	0.76	64.7	1.04
6/27/2023	13:06:00	62.5	1.04	67.4	1	66.9	0.76	64.7	1.04
6/27/2023	13:07:00	62.5	1.04	67.3	1	66.9	0.76	64.7	1.04
6/27/2023	13:08:00	62.3	1.04	67.3	1	66.9	0.75	64.7	1.04
6/27/2023	13:09:00	62.4	1.04	67.2	1	66.9	0.75	64.7	1.04
6/27/2023	13:10:00	62.3	1.04	67.2	1	66.9	0.75	64.7	1.04
6/27/2023	13:11:00	62.3	1.04	67.2	1	66.9	0.75	64.7	1.04
6/27/2023	13:12:00	62.3	1.04	67.2	1	66.9	0.75	64.7	1.04
6/27/2023	13:13:00	62.3	1.04	67.1	1	66.9	0.75	64.7	1.04
6/27/2023	13:14:00	62.2	1.04	67.1	1	66.9	0.75	64.7	1.04
6/27/2023	13:15:00	62.1	1.04	67.1	1	66.9	0.75	64.7	1.04
6/27/2023	13:16:00	62.2	1.04	67	1	66.9	0.75	64.7	1.04
6/27/2023	13:17:00	62.1	1.04	67	1	66.9	0.75	64.7	1.04
6/27/2023	13:18:00	62.1	1.04	67	1	66.6	0.75	64.7	1.04
6/27/2023	13:19:00	62.1	1.04	66.9	1	66.6	0.75	64.7	1.04
6/27/2023	13:20:00	62.1	1.04	66.9	1	66.6	0.75	64.7	1.04
6/27/2023	13:21:00	62.1	1.04	66.9	1	66.6	0.74	64.7	1.04
6/27/2023	13:22:00	62.1	1.04	66.9	1	66.6	0.74	64.7	1.04
6/27/2023	13:23:00	62	1.04	66.9	1	66.6	0.74	64.7	1.04
6/27/2023	13:24:00	62	1.04	66.9	1	66.6	0.74	64.7	1.04
6/27/2023	13:25:00	62	1.04	66.8	1	66.6	0.74	64.7	1.04
6/27/2023	13:26:00	62	1.04	66.8	1	66.6	0.74	64.7	1.04
6/27/2023	13:27:00	61.9	1.04	66.8	1	66.6	0.74	64.7	1.04
6/27/2023	13:28:00	61.8	1.04	66.7	1	66.6	0.74	64.7	1.04
6/27/2023	13:29:00	61.8	1.04	66.7	1	66.6	0.74	64.7	1.04
6/27/2023	13:30:00	61.8	1.04	66.7	1	66.6	0.74	64.7	1.04
6/27/2023	13:31:00	61.7	1.04	66.6	1	66.6	0.74	64.7	1.04
6/27/2023	13:32:00	61.7	1.04	66.6	1	66.6	0.74	64.7	1.04
6/27/2023	13:33:00	61.7	1.04	66.6	1	66.6	0.74	64.7	1.04
Average		74.7	1.01	70.2	1.00	67.7	0.99	64.8	1.01
Min		61.7	0.99	60.0	1.00	60.2	0.74	64.7	0.95
Max		84.5	1.04	79.9	1.00	79.8	1.18	64.9	1.04
Sqrt DP		1.006		Sqrt DP	1.000	Sqrt DP	0.994	Sqrt DP	1.005
Vs		56.640		Vs	56.053	Vs	55.608	Vs	56.028
ACFM		21,424		ACFM	21,202	ACFM	21,033	ACFM	21,192
DSCFM		21,027		DSCFM	20,985	DSCFM	20,920	DSCFM	21,192

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

		Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
Date	Time	Temp, °F	dP, "H <sub>2</sub> O						
6/30/2023	5:36:00	67.1	1.11	72.3	1	67.1	0.69	75.5	1.08
6/30/2023	5:37:00	67	1.11	72.2	1	67	0.67	75.5	1.1
6/30/2023	5:38:00	67.2	1.11	72.2	1	66.9	0.67	75.5	1.14
6/30/2023	5:39:00	67.3	1.11	72.4	1	67	0.66	75.5	1.2
6/30/2023	5:40:00	67.5	1.11	72.5	1	67.1	0.66	75.5	1.11
6/30/2023	5:41:00	67.4	1.1	72.5	1	67.2	0.66	75.5	1.08
6/30/2023	5:42:00	67.4	1	72.5	1	67.1	0.67	75.5	1.1
6/30/2023	5:43:00	67.5	1.04	72.5	1	67.1	0.67	75.5	1
6/30/2023	5:44:00	67.5	1.09	72.5	1	67	0.67	75.5	1.03
6/30/2023	5:45:00	67.4	1	72.4	1	67	0.67	75.5	1
6/30/2023	5:46:00	67.3	1	72.4	1	67	0.68	75.5	1.15
6/30/2023	5:47:00	67.3	0.99	72.3	1	67.1	0.68	75.5	1.16
6/30/2023	5:48:00	67.1	0.99	72.2	1	67	0.69	75.5	1.13
6/30/2023	5:49:00	67.1	0.99	72.2	1	67	0.65	75.5	1.2
6/30/2023	5:50:00	67.1	0.98	72.1	1	67	0.66	75.5	1.22
6/30/2023	5:51:00	67	0.99	72.1	1	66.9	0.66	75.5	1.18
6/30/2023	5:52:00	67	0.98	72.1	1	66.8	0.67	75.5	1.13
6/30/2023	5:53:00	67	0.98	72.1	1	66.8	0.67	75.5	1.19
6/30/2023	5:54:00	67	0.99	72.1	1	66.7	0.67	75.5	1.2
6/30/2023	5:55:00	66.9	0.98	72.1	1	66.8	0.67	75.5	1.19
6/30/2023	5:56:00	67	0.98	72	1	66.7	0.67	75.5	1.11
6/30/2023	5:57:00	67.1	0.98	72.1	1	66.7	0.66	75.5	1.1
6/30/2023	5:58:00	67.1	0.98	72.1	1	66.7	0.64	75.5	1.04
6/30/2023	5:59:00	67.1	0.99	72.2	1	67	0.65	75.5	1.1
6/30/2023	6:00:00	67.1	0.98	72.1	1	67	0.67	75.5	1.12
6/30/2023	6:01:00	67.1	0.99	72	1	66.9	0.66	75.5	1.15
6/30/2023	6:02:00	67	0.98	72.1	1	66.9	0.66	75.5	1.04
6/30/2023	6:03:00	67.1	0.97	72.1	1	67	0.65	75.5	1.02
6/30/2023	6:04:00	67	0.98	72.1	1	66.9	0.66	75.5	1
6/30/2023	6:05:00	67	1	72.1	1	66.9	0.67	75.5	0.66
6/30/2023	6:06:00	67	1.01	72.1	1	66.9	0.67	75.5	0.66
6/30/2023	6:07:00	66.9	0.99	72	1	66.7	0.67	75.5	0.67
6/30/2023	6:08:00	66.9	0.99	72.1	1	66.8	0.68	75.5	0.68
6/30/2023	6:09:00	67	0.98	72.1	1	66.9	0.68	75.5	0.72
6/30/2023	6:10:00	67	0.98	72.1	1	66.9	0.69	75.5	0.7
6/30/2023	6:11:00	67	0.99	72.1	1	67.1	0.68	75.5	0.69
6/30/2023	6:12:00	66.9	0.99	72.1	1	67	0.7	75.5	0.67
6/30/2023	6:13:00	67	0.98	72.1	1	66.9	0.7	75.5	0.66
6/30/2023	6:14:00	67	0.99	72.1	1	67	0.7	75.5	0.67
6/30/2023	6:15:00	67	0.99	72.1	1	66.9	0.67	75.5	0.7
6/30/2023	6:16:00	67	0.98	72.1	1	66.9	0.68	75.5	0.7
6/30/2023	6:17:00	67.1	0.98	72.2	1	66.9	0.65	75.5	0.7
6/30/2023	6:18:00	67.1	0.99	72.2	1	66.9	0.66	75.5	0.72
6/30/2023	6:19:00	67.1	0.99	72.2	1	67	0.67	75.5	0.66
6/30/2023	6:20:00	67.1	0.99	72.3	1	66.9	0.67	75.5	0.7
6/30/2023	6:21:00	67.2	0.98	72.3	1	67	0.67	75.5	0.7
6/30/2023	6:22:00	67.2	0.99	72.3	1	67	0.66	75.5	0.7
6/30/2023	6:23:00	67.2	1	72.3	1	67	0.65	75.5	0.6
6/30/2023	6:24:00	67.2	0.98	72.3	1	67	0.66	75.5	0.68
6/30/2023	6:25:00	67.2	0.99	72.3	1	67.3	0.67	75.5	0.67
6/30/2023	6:26:00	67.1	1	72.4	1	67.3	0.67	75.5	0.67
6/30/2023	6:27:00	67.2	0.98	72.4	1	67.3	0.67	75.5	0.66
6/30/2023	6:28:00	67.1	0.98	72.5	1	67.3	0.7	75.5	0.65
6/30/2023	6:29:00	67.3	0.99	72.6	1	67.5	0.7	75.5	0.6
6/30/2023	6:30:00	67.3	0.98	72.7	1	67.5	0.7	75.5	0.68
6/30/2023	6:31:00	67.4	0.98	72.7	1	67.6	0.7	75.5	0.67
6/30/2023	6:32:00	67.4	0.98	72.8	1	67.8	0.73	75.5	0.67
6/30/2023	6:33:00	67.6	0.98	72.9	1	67.9	0.73	75.5	0.68
6/30/2023	6:34:00	67.7	0.98	72.9	1	67.9	0.72	75.5	0.66
6/30/2023	6:35:00	67.6	0.99	72.9	1	67.8	0.7	75.5	0.65
6/30/2023	6:36:00	67.6	0.98	72.8	1	67.8	0.67	75.5	0.66
6/30/2023	6:37:00	67.6	0.98	72.9	1	67.9	0.68	75.5	0.66
6/30/2023	6:38:00	67.7	0.99	72.9	1	67.9	0.7	75.5	0.67

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

		Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
Date	Time	Temp, °F	dP, "H <sub>2</sub> O						
6/30/2023	6:39:00	67.7	0.98	72.9	1	67.9	0.73	75.5	0.68
6/30/2023	6:40:00	67.8	0.99	73	1	67.9	0.71	75.5	0.65
6/30/2023	6:41:00	67.8	0.99	72.9	1	67.9	0.7	75.5	0.66
6/30/2023	6:45:00	64.5	0.95	70.4	1	65	0.82	73	0.68
6/30/2023	6:46:00	67.9	1.26	73	1	67.9	0.86	75.5	0.63
6/30/2023	6:49:00	67.9	1.26	73.2	1	67.9	0.83	75.5	0.61
6/30/2023	6:50:00	67.9	1.26	73.2	1	67.9	0.82	75.5	0.61
6/30/2023	6:51:00	68	1.26	73.2	0.9	67.9	0.84	75.5	0.61
6/30/2023	6:52:00	68	1.28	73.2	0.9	67.9	0.84	75.5	0.61
6/30/2023	6:53:00	68	1.27	73.2	0.91	67.9	0.83	75.5	0.6
6/30/2023	6:54:00	68	1.25	73.2	0.89	68	0.84	75.5	0.62
6/30/2023	6:55:00	68	1.29	73.2	0.9	68	0.84	75.5	0.61
6/30/2023	6:56:00	67.9	1.26	73.2	0.89	68.1	0.85	75.5	0.61
6/30/2023	6:57:00	68	1.25	73.2	0.9	68	0.85	75.5	0.61
6/30/2023	6:58:00	68	1.28	73.2	0.91	67.9	0.84	75.5	0.6
6/30/2023	6:59:00	68	1.26	73.2	0.89	68	0.85	75.5	0.62
6/30/2023	7:00:00	67.9	1.27	73.2	0.9	67.9	0.85	75.5	0.6
6/30/2023	7:01:00	68	1.26	73.2	0.9	67.9	0.84	75.5	0.61
6/30/2023	7:02:00	68	1.26	73.2	0.89	67.9	0.85	75.5	0.61
6/30/2023	7:03:00	68	1.26	73.3	0.89	67.9	0.84	75.5	0.61
6/30/2023	7:04:00	68.1	1.27	73.3	0.89	67.9	0.85	75.5	0.61
6/30/2023	7:05:00	68	1.25	73.3	0.9	67.9	0.84	75.5	0.6
6/30/2023	7:06:00	67.9	1.26	73.3	0.89	67.9	0.84	75.5	0.61
6/30/2023	7:07:00	68	1.24	73.2	0.89	67.9	0.84	75.5	0.61
6/30/2023	7:08:00	67.9	1.25	73.2	0.9	67.9	0.84	75.5	0.61
6/30/2023	7:09:00	67.8	1.24	73.2	0.9	67.9	0.84	75.5	0.61
6/30/2023	7:10:00	67.9	1.25	73.2	0.88	67.8	0.84	75.5	0.62
6/30/2023	7:11:00	67.8	1.26	73.2	0.89	67.9	0.84	75.6	0.61
6/30/2023	7:12:00	67.8	1.26	73.2	0.89	67.9	0.85	75.6	0.61
6/30/2023	7:13:00	67.8	1.26	73.2	0.88	67.9	0.85	75.6	0.61
6/30/2023	7:14:00	67.7	1.24	73.2	0.88	67.9	0.85	75.6	0.62
6/30/2023	7:15:00	67.8	1.26	73.3	0.88	67.9	0.85	75.6	0.61
6/30/2023	7:16:00	67.8	1.26	73.4	0.88	67.9	0.85	75.6	0.62
6/30/2023	7:17:00	67.9	1.24	73.5	0.89	68	0.84	75.6	0.66
6/30/2023	7:18:00	68	1.25	73.6	0.89	68.1	0.83	75.6	0.66
6/30/2023	7:19:00	68.2	1.26	73.8	0.89	68.2	0.85	75.6	0.6
6/30/2023	7:20:00	68.3	1.25	73.9	0.88	68.5	0.86	75.6	0.6
6/30/2023	7:21:00	68.4	1.24	74	0.88	68.5	0.86	75.6	0.6
6/30/2023	7:22:00	68.4	1.25	74	0.88	68.6	0.87	75.6	0.61
6/30/2023	7:23:00	68.3	1.25	74	0.88	68.6	0.86	75.6	0.61
6/30/2023	7:24:00	68.4	1.27	74.1	0.87	68.6	0.86	75.6	0.6
6/30/2023	7:25:00	68.4	1.25	74.2	0.88	68.7	0.87	75.6	0.61
6/30/2023	7:26:00	68.5	1.26	74.2	0.88	68.8	0.86	75.6	0.61
6/30/2023	7:27:00	68.5	1.25	74.3	0.88	69	0.87	75.6	0.61
6/30/2023	7:28:00	68.6	1.25	74.4	0.88	69.1	0.86	75.6	0.61
6/30/2023	7:29:00	68.7	1.26	74.5	0.88	69.1	0.86	75.6	0.61
6/30/2023	7:30:00	68.8	1.25	74.5	0.88	69.1	0.86	75.6	0.62
6/30/2023	7:31:00	68.8	1.25	74.5	0.88	69.1	0.86	75.6	0.61
6/30/2023	7:32:00	68.8	1.26	74.5	0.9	69.1	0.87	75.6	0.63
6/30/2023	7:33:00	68.7	1.26	74.5	0.9	69.1	0.86	75.6	0.6
6/30/2023	7:34:00	68.8	1.26	74.6	0.9	69.3	0.87	75.6	0.61
6/30/2023	7:35:00	68.7	1.27	74.6	0.88	69.4	0.88	75.6	0.61
6/30/2023	7:36:00	68.8	1.25	74.6	0.89	69.4	0.87	75.6	0.63
6/30/2023	7:37:00	68.8	1.25	74.6	0.89	69.4	0.88	75.6	0.61
6/30/2023	7:38:00	68.7	1.26	74.6	0.88	69.4	0.88	75.6	0.6
6/30/2023	7:39:00	68.8	1.25	74.6	0.9	69.3	0.87	75.6	0.61
6/30/2023	7:40:00	68.8	1.26	74.6	0.89	69.1	0.88	75.6	0.61
6/30/2023	7:41:00	68.8	1.26	74.6	0.88	69.1	0.89	75.6	0.61
6/30/2023	7:42:00	68.7	1.26	74.5	0.89	69.1	0.87	75.6	0.6
6/30/2023	7:43:00	68.7	1.25	74.5	0.89	69.4	0.88	75.6	0.61
6/30/2023	7:44:00	68.9	1.26	74.5	0.9	69.3	0.86	75.6	0.61
6/30/2023	7:45:00	68.9	1.26	74.6	0.89	69.4	0.87	75.6	0.63
6/30/2023	7:46:00	68.9	1.26	74.6	0.9	69.3	0.87	75.6	0.61

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

		Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
Date	Time	Temp, °F	dP, "H <sub>2</sub> O						
6/30/2023	7:47:00	68.9	1.26	74.6	0.91	69.3	0.87	75.6	0.61
6/30/2023	7:48:00	69	1.24	74.7	0.89	69.4	0.88	75.6	0.63
6/30/2023	7:49:00	69	1.25	74.7	0.89	69.4	0.88	75.6	0.61
6/30/2023	7:50:00	69.1	1.26	74.8	0.87	69.5	0.89	75.6	0.61
6/30/2023	7:51:00	69	1.26	74.7	0.87	69.4	0.89	75.6	0.62
6/30/2023	7:52:00	69.1	1.26	74.6	0.89	69.2	0.89	75.6	0.61
6/30/2023	7:53:00	69	1.26	74.6	0.89	69.2	0.88	75.6	0.6
6/30/2023	7:54:00	69	1.25	74.6	0.87	69.1	0.89	75.6	0.62
6/30/2023	7:55:00	68.9	1.25	74.6	0.89	69.4	0.89	75.6	0.6
6/30/2023	7:56:00	69	1.25	74.6	0.89	69.4	0.88	75.6	0.61
6/30/2023	7:57:00	68.9	1.25	74.6	0.9	69.4	0.88	75.6	0.62
6/30/2023	7:58:00	68.9	1.25	74.7	0.9	69.4	0.87	75.6	0.6
6/30/2023	7:59:00	68.9	1.26	74.7	0.89	69.4	0.89	75.6	0.59
6/30/2023	8:00:00	68.9	1.25	74.6	0.89	69.4	0.88	75.6	0.61
6/30/2023	8:01:00	68.9	1.25	74.6	0.88	69.3	0.89	75.6	0.61
6/30/2023	8:02:00	68.9	1.27	74.6	0.88	69.2	0.89	75.6	0.61
6/30/2023	8:03:00	68.8	1.26	74.5	0.89	69.2	0.89	75.6	0.6
6/30/2023	8:04:00	68.9	1.25	74.5	0.9	69.1	0.88	75.6	0.62
6/30/2023	8:05:00	68.7	1.24	74.4	0.89	69.1	0.9	75.6	0.61
6/30/2023	8:06:00	68.7	1.26	74.3	0.88	69	0.89	75.6	0.61
6/30/2023	8:07:00	68.7	1.24	74.3	0.87	68.8	0.91	75.6	0.6
6/30/2023	8:08:00	68.6	1.26	74.4	0.88	68.9	0.91	75.6	0.61
6/30/2023	8:09:00	68.8	1.26	74.4	0.88	69	0.91	75.6	0.61
6/30/2023	8:10:00	68.8	1.25	74.4	0.89	68.8	0.89	75.6	0.61
6/30/2023	8:11:00	68.8	1.24	74.4	0.89	68.9	0.88	75.6	0.62
6/30/2023	8:12:00	68.8	1.24	74.5	0.89	69	0.9	75.6	0.6
6/30/2023	8:13:00	68.9	1.25	74.5	0.88	69.3	0.88	75.6	0.62
6/30/2023	8:14:00	68.9	1.25	74.6	0.9	69.3	0.89	75.6	0.6
6/30/2023	8:15:00	68.9	1.25	74.6	0.9	69.4	0.89	75.6	0.61
6/30/2023	8:16:00	69	1.24	74.8	0.88	69.4	0.9	75.6	0.61
6/30/2023	8:17:00	69.1	1.25	74.9	0.89	69.5	0.91	75.6	0.61
6/30/2023	8:18:00	69.1	1.25	74.9	0.9	69.6	0.89	75.6	0.61
6/30/2023	8:19:00	69.2	1.25	75	0.89	69.7	0.89	75.6	0.59
6/30/2023	8:20:00	69.2	1.27	75	0.87	69.7	0.91	75.6	0.6
6/30/2023	8:21:00	69.3	1.27	75.1	0.89	69.8	0.91	75.6	0.61
6/30/2023	8:22:00	69.2	1.26	75.1	0.87	69.7	0.91	75.6	0.62
6/30/2023	8:23:00	69.3	1.25	75.2	0.87	69.8	0.91	75.6	0.61
6/30/2023	8:24:00	69.4	1.25	75.2	0.87	69.7	0.91	75.6	0.61
6/30/2023	8:25:00	69.3	1.25	75.2	0.88	69.8	0.91	75.6	0.62
6/30/2023	8:26:00	69.3	1.26	75.2	0.87	69.7	0.9	75.6	0.63
6/30/2023	8:27:00	69.5	1.24	75.3	0.88	69.8	0.89	75.6	0.6
6/30/2023	8:28:00	69.4	1.24	75.3	0.89	69.9	0.88	75.6	0.6
6/30/2023	8:29:00	69.4	1.23	75.3	0.89	65	0.89	75.6	0.6
6/30/2023	8:30:00	69.5	1.24	75.5	0.87	65	0.91	75.6	0.61
6/30/2023	8:31:00	69.5	1.23	75.5	0.87	65	0.91	75.6	0.59
6/30/2023	8:32:00	69.6	1.24	75.6	0.89	65	0.9	75.6	0.6
6/30/2023	8:33:00	69.6	1.24	75.6	0.88	65.3	0.89	75.6	0.6
6/30/2023	8:34:00	69.6	1.25	75.7	0.87	65.3	0.92	75.6	0.61
6/30/2023	8:35:00	69.6	1.24	75.7	0.87	65.2	0.9	75.6	0.62
6/30/2023	8:36:00	69.6	1.25	75.7	0.87	65.2	0.91	75.6	0.6
6/30/2023	8:37:00	69.7	1.25	75.7	0.87	65.3	0.91	75.6	0.6
6/30/2023	8:38:00	69.6	1.24	75.7	0.86	65.3	0.92	75.6	0.61
6/30/2023	8:39:00	69.6	1.25	75.7	0.87	65.3	0.91	75.6	0.62
6/30/2023	8:40:00	69.7	1.24	75.8	0.87	65.3	0.91	75.6	0.62
6/30/2023	8:41:00	69.7	1.26	75.8	0.87	65.2	0.91	75.6	0.62
6/30/2023	8:42:00	69.8	1.25	75.9	0.88	65.6	0.9	75.6	0.67
6/30/2023	8:43:00	69.7	1.23	75.9	0.88	65.6	0.9	75.6	0.65
6/30/2023	8:44:00	69.9	1.24	76	0.87	65.6	0.9	75.6	0.66
6/30/2023	8:45:00	69.9	1.23	76	0.87	65.6	0.91	75.6	0.64
6/30/2023	8:46:00	70	1.24	76.1	0.87	65.8	0.91	75.6	0.62
6/30/2023	8:47:00	69.9	1.24	76.1	0.87	65.9	0.92	75.6	0.63
6/30/2023	8:48:00	69.9	1.23	76.1	0.86	65.9	0.93	75.6	0.61
6/30/2023	8:49:00	70	1.24	76.2	0.87	65.9	0.93	75.6	0.61

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

		Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
Date	Time	Temp, °F	dP, "H <sub>2</sub> O						
6/30/2023	8:50:00	70.1	1.24	76.2	0.87	65.9	0.94	75.6	0.61
6/30/2023	8:51:00	70.2	1.24	76.4	0.89	66	0.92	75.6	0.65
6/30/2023	8:52:00	70.3	1.25	76.5	0.89	66.2	0.91	75.6	0.68
6/30/2023	8:53:00	70.4	1.24	76.5	0.87	66.2	0.91	75.6	0.64
6/30/2023	8:54:00	70.4	1.26	76.6	0.87	66.1	0.92	75.6	0.65
6/30/2023	8:55:00	70.3	1.22	76.6	0.87	66	0.93	75.6	0.62
6/30/2023	8:56:00	70.4	1.24	76.6	0.87	66.1	0.92	75.6	0.62
6/30/2023	8:57:00	70.3	1.23	76.6	0.85	66.2	0.94	75.6	0.6
6/30/2023	8:58:00	70.4	1.23	76.7	0.87	66.2	0.93	75.6	0.65
6/30/2023	8:59:00	70.5	1.23	76.8	0.88	66.2	0.91	75.6	0.68
6/30/2023	9:00:00	70.6	1.24	77	0.86	66.4	0.92	75.6	0.69
6/30/2023	9:01:00	70.8	1.22	77.1	0.87	66.6	0.93	75.6	0.62
6/30/2023	9:02:00	70.9	1.23	77.3	0.87	66.7	0.93	75.6	0.64
6/30/2023	9:03:00	70.9	1.22	77.4	0.86	67.1	0.94	75.6	0.61
6/30/2023	9:04:00	71	1.23	77.6	0.86	67.1	0.94	75.6	0.61
6/30/2023	9:05:00	71	1.24	77.8	0.86	67.3	0.95	75.6	0.61
6/30/2023	9:06:00	71	1.24	77.8	0.86	67.2	0.94	75.6	0.61
6/30/2023	9:07:00	71.1	1.22	77.8	0.85	67.2	0.95	75.6	0.6
6/30/2023	9:08:00	71.1	1.23	77.9	0.86	67.2	0.94	75.6	0.61
6/30/2023	9:09:00	71.1	1.25	78.2	0.86	67.8	0.94	75.6	0.61
6/30/2023	9:10:00	71.2	1.23	78.6	0.86	68.1	0.95	75.6	0.61
6/30/2023	9:11:00	71.5	1.22	79	0.86	68.4	0.94	75.6	0.62
6/30/2023	9:12:00	71.8	1.23	79.3	0.86	68.6	0.94	75.6	0.63
6/30/2023	9:13:00	72	1.24	79.7	0.87	68.8	0.93	75.6	0.65
6/30/2023	9:14:00	72.2	1.22	80	0.86	69.4	0.94	75.6	0.65
6/30/2023	9:15:00	72.3	1.21	80.2	0.86	69.6	0.94	75.6	0.62
6/30/2023	9:16:00	72.4	1.2	80.4	0.85	69.7	0.95	75.6	0.61
6/30/2023	9:17:00	72.7	1.23	80.6	0.84	69.8	0.95	75.6	0.6
6/30/2023	9:18:00	72.7	1.23	80.6	0.85	70	0.96	75.6	0.6
6/30/2023	9:19:00	72.7	1.24	80.5	0.85	70	0.96	75.6	0.61
6/30/2023	9:20:00	72.7	1.22	80.5	0.85	69.8	0.96	75.6	0.62
6/30/2023	9:21:00	72.7	1.22	80.5	0.86	69.7	0.94	75.6	0.63
6/30/2023	9:22:00	72.7	1.21	80.6	0.87	69.7	0.95	75.6	0.62
6/30/2023	9:23:00	72.9	1.21	80.8	0.86	70.1	0.95	75.6	0.61
6/30/2023	9:24:00	72.9	1.22	80.9	0.85	70.2	0.96	75.6	0.61
6/30/2023	9:25:00	73	1.22	81	0.84	65.4	0.97	75.6	0.61
6/30/2023	9:26:00	73	1.23	81.1	0.85	65.4	0.97	75.6	0.6
6/30/2023	9:27:00	73.2	1.22	81.2	0.85	65.4	0.97	75.6	0.6
6/30/2023	9:28:00	73.2	1.22	81.3	0.85	65.8	0.97	75.6	0.6
6/30/2023	9:29:00	73.3	1.22	81.4	0.85	65.8	0.95	75.6	0.64
6/30/2023	9:30:00	73.4	1.21	81.6	0.85	66.1	0.96	75.6	0.65
6/30/2023	9:31:00	73.6	1.21	81.7	0.84	66.2	0.96	75.6	0.63
6/30/2023	9:32:00	73.6	1.21	81.7	0.85	66.2	0.98	75.6	0.63
6/30/2023	9:33:00	73.5	1.22	81.8	0.85	66.2	0.99	75.6	0.61
6/30/2023	9:34:00	73.6	1.23	81.8	0.87	66.2	0.97	75.6	0.59
6/30/2023	9:35:00	73.7	1.28	81.9	0.88	66.4	1	75.6	0.62
6/30/2023	9:36:00	73.8	1.27	82.1	0.88	66.4	1.01	75.6	0.64
6/30/2023	9:37:00	73.9	1.25	82.1	0.89	66.4	1	75.6	0.66
6/30/2023	9:38:00	73.9	1.27	82.2	0.88	66.4	1	75.6	0.7
6/30/2023	9:39:00	74	1.27	82.2	0.9	66.4	0.99	75.6	0.7
6/30/2023	9:40:00	74.1	1.29	82.3	0.89	66.7	1	75.6	0.7
6/30/2023	9:41:00	74.2	1.27	82.3	0.88	67	1	75.6	0.65
6/30/2023	9:42:00	74.1	1.26	82.4	0.88	67	1.01	75.6	0.64
6/30/2023	9:43:00	74.2	1.26	82.4	0.87	66.8	1.02	75.6	0.64
6/30/2023	9:44:00	74.3	1.25	82.4	0.88	66.7	1.01	75.6	0.64
6/30/2023	9:45:00	74.3	1.27	82.4	0.89	66.7	1.01	75.6	0.69
6/30/2023	9:46:00	74.3	1.28	82.4	0.89	66.9	1	75.6	0.71
6/30/2023	9:47:00	74.3	1.24	82.5	0.89	67	1.02	75.6	0.66
6/30/2023	9:48:00	74.3	1.27	82.5	0.87	67	1.03	75.6	0.62
6/30/2023	9:49:00	74.2	1.27	82.6	0.87	66.9	1.03	75.6	0.63
6/30/2023	9:50:00	74.2	1.26	82.6	0.88	66.9	1.03	75.6	0.64
6/30/2023	9:51:00	74.2	1.27	82.6	0.86	67	1.03	75.6	0.63
6/30/2023	9:52:00	74.2	1.26	82.6	0.89	67	1.03	75.6	0.63

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

		Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
Date	Time	Temp, °F	dP, "H <sub>2</sub> O						
6/30/2023	9:53:00	74.2	1.27	82.6	0.89	66.9	1.02	75.6	0.63
6/30/2023	9:54:00	74.2	1.25	82.6	0.87	67	1.03	75.6	0.65
6/30/2023	9:55:00	74.2	1.26	82.7	0.88	67	1.02	75.6	0.66
6/30/2023	9:56:00	74.3	1.25	82.7	0.87	67.1	1.03	75.6	0.63
6/30/2023	9:57:00	74.4	1.26	82.8	0.89	67.1	1.02	75.6	0.66
6/30/2023	9:58:00	74.4	1.24	82.8	0.88	67.1	1.03	75.6	0.66
6/30/2023	9:59:00	74.6	1.25	82.9	0.89	67.2	1.03	75.6	0.65
6/30/2023	10:00:00	74.6	1.27	82.9	0.88	67.6	1.03	75.6	0.64
6/30/2023	10:01:00	74.7	1.26	83	0.89	67.5	1.03	75.6	0.7
6/30/2023	10:02:00	74.7	1.25	83	0.87	67.3	1.04	75.6	0.68
6/30/2023	10:03:00	74.7	1.26	83.1	0.88	67.4	1.03	75.6	0.66
6/30/2023	10:04:00	74.8	1.27	83.2	0.89	67.6	1.03	75.6	0.71
6/30/2023	10:05:00	74.9	1.25	83.2	0.94	67.6	1.03	75.6	0.73
6/30/2023	10:06:00	75	1.25	83.3	0.92	67.8	1.04	75.6	0.65
6/30/2023	10:07:00	75.1	1.27	83.4	0.92	67.7	1.05	75.6	0.65
6/30/2023	10:08:00	75.2	1.24	83.5	0.94	68.1	1.02	75.6	0.65
6/30/2023	10:09:00	75.3	1.25	83.5	0.95	68.2	1.03	75.6	0.64
6/30/2023	10:10:00	75.2	1.25	83.6	0.93	68.2	1.05	75.6	0.63
6/30/2023	10:11:00	75.3	1.25	83.7	0.9	68.2	1.06	75.6	0.65
6/30/2023	10:12:00	75.3	1.25	83.7	0.91	68.1	1.05	75.6	0.65
6/30/2023	10:13:00	75.3	1.26	83.7	0.93	68.2	1.05	75.6	0.63
6/30/2023	10:14:00	75.3	1.26	83.7	0.94	68.2	1.05	75.6	0.63
6/30/2023	10:15:00	75.3	1.24	83.7	0.93	68.2	1.05	75.6	0.63
6/30/2023	10:16:00	75.4	1.25	83.7	0.93	68	1.05	75.6	0.63
6/30/2023	10:17:00	75.4	1.26	83.8	0.92	68.3	1.05	75.6	0.65
6/30/2023	10:18:00	75.4	1.24	83.9	0.91	68.6	1.05	75.6	0.72
6/30/2023	10:19:00	75.6	1.24	83.9	0.91	68.6	1.05	75.6	0.71
6/30/2023	10:20:00	75.7	1.23	84	0.91	68.6	1.06	75.6	0.7
6/30/2023	10:21:00	75.8	1.25	84.2	0.9	68.7	1.06	75.6	0.66
6/30/2023	10:22:00	75.9	1.24	84.3	0.91	68.8	1.07	75.6	0.66
6/30/2023	10:23:00	75.8	1.24	84.3	0.92	68.8	1.05	75.6	0.67
6/30/2023	10:24:00	76	1.25	84.3	0.92	69.1	1.05	75.6	0.7
6/30/2023	10:25:00	76.2	1.25	84.4	0.91	69.1	1.07	75.6	0.64
6/30/2023	10:26:00	76.3	1.25	84.5	0.9	69.2	1.06	75.6	0.66
6/30/2023	10:27:00	76.3	1.23	84.5	0.89	69.2	1.09	75.6	0.65
6/30/2023	10:28:00	76.2	1.24	84.5	0.89	69.1	1.09	75.6	0.64
6/30/2023	10:29:00	76.2	1.25	84.5	0.9	69.3	1.09	75.6	0.63
6/30/2023	10:30:00	76.2	1.23	84.4	0.9	69.3	1.09	75.6	0.63
6/30/2023	10:31:00	76.1	1.24	84.4	0.91	69.2	1.08	75.6	0.63
6/30/2023	10:32:00	76.1	1.25	84.4	0.89	69.1	1.1	75.6	0.64
6/30/2023	10:33:00	76.2	1.23	84.4	0.92	69.1	1.07	75.6	0.63
6/30/2023	10:34:00	76.2	1.23	84.4	0.89	69.1	1.09	75.6	0.65
6/30/2023	10:35:00	76.1	1.23	84.5	0.89	69.1	1.09	75.6	0.66
6/30/2023	10:36:00	76.1	1.24	84.5	0.89	69.1	1.1	75.6	0.64
6/30/2023	10:37:00	76.2	1.23	84.5	0.9	69.4	1.09	75.6	0.64
6/30/2023	10:38:00	76.3	1.24	84.6	0.89	69.4	1.1	75.6	0.63
6/30/2023	10:39:00	76.2	1.22	84.6	0.89	69.4	1.1	75.6	0.64
6/30/2023	10:40:00	76.2	1.23	84.7	0.89	69.4	1.09	75.6	0.66
6/30/2023	10:41:00	76.3	1.24	84.6	0.9	69.4	1.09	75.6	0.68
6/30/2023	10:42:00	76.4	1.23	84.8	0.89	69.4	1.1	75.6	0.64
6/30/2023	10:43:00	76.5	1.24	84.8	0.9	69.4	1.1	75.6	0.67
6/30/2023	10:44:00	76.4	1.22	84.8	0.89	69.4	1.09	75.6	0.64
6/30/2023	10:45:00	76.5	1.2	84.7	0.89	69.5	1.09	75.6	0.65
6/30/2023	10:46:00	76.5	1.21	84.8	0.88	69.5	1.1	75.6	0.65
6/30/2023	10:47:00	76.5	1.22	84.8	0.88	69.6	1.1	75.6	0.67
6/30/2023	10:48:00	76.5	1.23	84.8	0.88	69.6	1.1	75.6	0.64
6/30/2023	10:49:00	76.4	1.23	84.7	0.88	69.6	1.11	75.6	0.64
6/30/2023	10:50:00	76.5	1.21	84.7	0.89	69.6	1.1	75.6	0.66
6/30/2023	10:51:00	76.4	1.21	84.8	0.89	69.6	1.12	75.7	0.63
6/30/2023	10:52:00	76.4	1.21	84.9	0.88	69.7	1.14	75.7	0.63
6/30/2023	10:53:00	76.5	1.21	85	0.87	69.8	1.14	75.7	0.64
6/30/2023	10:54:00	76.5	1.21	85.1	0.89	69.9	1.15	75.7	0.64
6/30/2023	10:55:00	76.5	1.23	85.1	0.88	69.9	1.18	75.7	0.64

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

		Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
Date	Time	Temp, °F	dP, "H <sub>2</sub> O						
6/30/2023	10:56:00	76.4	1.21	85.1	0.9	70	1.17	75.7	0.64
6/30/2023	10:57:00	76.5	1.21	85.1	0.9	70.1	1.2	75.7	0.63
6/30/2023	10:58:00	76.3	1.22	85.1	0.87	69.9	1.22	75.7	0.64
6/30/2023	10:59:00	76.3	1.2	85.2	0.88	70.2	1.24	75.7	0.65
6/30/2023	11:00:00	76.3	1.2	85.1	0.88	70.1	1.26	75.7	0.64
6/30/2023	11:01:00	76.2	1.19	85	0.88	69.8	1.28	75.7	0.64
6/30/2023	11:02:00	76.1	1.2	84.9	0.87	70	1.3	75.7	0.65
6/30/2023	11:03:00	75.9	1.2	84.8	0.87	69.7	1.31	75.7	0.65
6/30/2023	11:04:00	75.8	1.21	84.7	0.87	69.6	1.33	75.7	0.65
6/30/2023	11:05:00	75.8	1.19	84.8	0.87	69.7	1.34	75.7	0.65
6/30/2023	11:06:00	75.9	1.2	84.8	0.88	69.8	1.36	75.7	0.65
6/30/2023	11:07:00	76	1.2	84.9	0.88	69.9	1.36	75.7	0.67
6/30/2023	11:08:00	76.2	1.19	85.1	0.87	70.2	1.36	75.7	0.7
6/30/2023	11:09:00	76.2	1.18	85.1	0.87	70.2	1.37	75.7	0.67
6/30/2023	11:10:00	76.3	1.19	85.2	0.87	70.4	1.4	75.7	0.65
6/30/2023	11:11:00	76.3	1.19	85.1	0.87	70.2	1.41	75.7	0.64
6/30/2023	11:12:00	76.3	1.18	85.1	0.86	70.1	1.41	75.7	0.64
6/30/2023	11:13:00	76.3	1.18	85	0.86	70.1	1.41	75.7	0.64
6/30/2023	11:14:00	76.3	1.19	85.1	0.87	70	1.42	75.7	0.65
6/30/2023	11:15:00	76.4	1.2	85.1	0.89	70.1	1.39	75.7	0.64
6/30/2023	11:16:00	76.4	1.2	85.2	0.89	70.3	1.39	75.7	0.69
6/30/2023	11:17:00	76.5	1.21	85.5	0.9	70.4	1.41	75.7	0.72
6/30/2023	11:18:00	76.7	1.24	85.6	0.9	70.7	1.42	75.7	0.7
6/30/2023	11:19:00	76.9	1.25	85.8	0.9	70.9	1.41	75.7	0.7
6/30/2023	11:20:00	77.1	1.24	85.8	0.91	71.3	1.41	75.7	0.73
6/30/2023	11:21:00	77.3	1.21	85.9	0.88	71.3	1.43	75.7	0.69
6/30/2023	11:22:00	77.5	1.22	86	0.88	71.4	1.43	75.7	0.66
6/30/2023	11:23:00	77.6	1.23	86	0.89	71.6	1.42	75.7	0.63
6/30/2023	11:24:00	77.7	1.23	86.1	0.89	71.6	1.42	75.7	0.65
6/30/2023	11:25:00	77.7	1.22	86.1	0.9	71.5	1.4	75.7	0.63
6/30/2023	11:26:00	77.8	1.22	86.1	0.9	71.7	1.41	75.7	0.63
6/30/2023	11:27:00	77.9	1.22	86.2	0.88	71.8	1.41	75.7	0.64
6/30/2023	11:28:00	77.8	1.19	86.1	0.87	71.6	1.42	75.7	0.64
6/30/2023	11:29:00	77.8	1.2	86	0.87	71.5	1.42	75.7	0.64
6/30/2023	11:30:00	77.7	1.21	86	0.88	71.5	1.42	75.7	0.62
6/30/2023	11:31:00	77.7	1.21	86	0.87	71.5	1.42	75.7	0.63
6/30/2023	11:32:00	77.7	1.2	86	0.87	71.4	1.41	75.7	0.63
6/30/2023	11:33:00	77.7	1.21	86	0.87	71.4	1.42	75.7	0.63
6/30/2023	11:34:00	77.6	1.21	86.1	0.87	71.6	1.41	75.7	0.63
6/30/2023	11:35:00	77.6	1.21	86.1	0.87	71.7	1.43	75.7	0.62
6/30/2023	11:36:00	77.5	1.18	86.1	0.86	71.7	1.43	75.7	0.63
6/30/2023	11:37:00	77.5	1.2	86.1	0.87	71.6	1.44	75.7	0.63
6/30/2023	11:38:00	77.4	1.18	86.1	0.86	71.8	1.44	75.7	0.63
6/30/2023	11:39:00	77.3	1.19	86	0.88	72	1.43	75.7	0.61
6/30/2023	11:40:00	77.3	1.19	86.1	0.86	72	1.46	75.7	0.63
6/30/2023	11:41:00	77.4	1.2	86.1	0.86	72	1.47	75.7	0.62
6/30/2023	11:42:00	77.4	1.19	86.1	0.86	72.1	1.47	75.7	0.62
6/30/2023	11:43:00	77.4	1.19	86.2	0.87	72.2	1.46	75.7	0.64
6/30/2023	11:44:00	77.4	1.16	86.4	0.87	72.2	1.47	75.7	0.68
6/30/2023	11:45:00	77.6	1.2	86.4	0.86	72.3	1.49	75.7	0.67
6/30/2023	11:46:00	77.6	1.19	86.5	0.86	72.5	1.49	75.7	0.62
6/30/2023	11:47:00	77.7	1.16	86.6	0.86	72.5	1.49	75.7	0.64
6/30/2023	11:48:00	77.7	1.16	86.7	0.85	72.7	1.5	75.8	0.64
6/30/2023	11:49:00	77.7	1.17	86.7	0.84	72.5	1.52	75.8	0.61
6/30/2023	11:50:00	77.7	1.17	86.6	0.84	72.5	1.52	75.8	0.6
6/30/2023	11:51:00	77.7	1.17	86.6	0.84	72.4	1.53	75.8	0.59
6/30/2023	11:52:00	77.7	1.17	86.5	0.85	72.4	1.52	75.8	0.61
6/30/2023	11:53:00	77.7	1.17	86.6	0.85	72.5	1.53	75.8	0.62
6/30/2023	11:54:00	77.7	1.15	86.6	0.87	72.5	1.52	75.8	0.59
6/30/2023	11:55:00	77.7	1.15	86.7	0.83	72.7	1.55	75.8	0.6
6/30/2023	11:56:00	77.7	1.14	86.7	0.85	72.6	1.53	75.8	0.59
6/30/2023	11:57:00	77.9	1.14	86.7	0.84	72.7	1.54	75.8	0.59
6/30/2023	11:58:00	78	1.14	86.8	0.83	72.6	1.55	75.8	0.61

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

		Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
Date	Time	Temp, °F	dP, "H <sub>2</sub> O						
6/30/2023	11:59:00	78	1.14	86.9	0.82	72.8	1.55	75.8	0.61
6/30/2023	12:00:00	78	1.13	86.8	0.81	72.8	1.57	75.8	0.6
6/30/2023	12:01:00	77.9	1.14	86.8	0.83	72.6	1.55	75.8	0.57
6/30/2023	12:02:00	77.9	1.15	86.8	0.84	72.7	1.55	75.8	0.57
6/30/2023	12:03:00	78.1	1.12	86.9	0.81	72.5	1.56	75.8	0.59
6/30/2023	12:04:00	78.2	1.13	87	0.81	72.8	1.57	75.8	0.58
6/30/2023	12:05:00	78.3	1.14	87	0.83	72.8	1.55	75.8	0.57
6/30/2023	12:06:00	78.4	1.12	87.1	0.8	72.8	1.57	75.8	0.59
6/30/2023	12:07:00	78.5	1.12	87.1	0.8	73	1.56	75.8	0.58
6/30/2023	12:08:00	78.5	1.12	87.1	0.8	73.1	1.56	75.8	0.59
6/30/2023	12:09:00	78.5	1.13	87.2	0.81	73.1	1.56	75.8	0.58
6/30/2023	12:10:00	78.7	1.11	87.3	0.8	73.1	1.55	75.8	0.58
6/30/2023	12:11:00	78.7	1.11	87.5	0.81	73.4	1.54	75.8	0.57
6/30/2023	12:12:00	78.8	1.12	87.5	0.8	73.3	1.55	75.8	0.58
6/30/2023	12:13:00	79	1.12	87.6	0.81	73.4	1.57	75.8	0.58
6/30/2023	12:14:00	79.1	1.13	87.6	0.82	73.5	1.55	75.8	0.6
6/30/2023	12:15:00	79	1.12	87.7	0.82	73.8	1.55	75.8	0.57
6/30/2023	12:16:00	79.1	1.14	87.7	0.82	73.8	1.55	75.8	0.57
6/30/2023	12:17:00	79.1	1.12	87.6	0.82	73.5	1.55	75.8	0.58
6/30/2023	12:18:00	79	1.11	87.5	0.81	73.4	1.54	75.8	0.58
6/30/2023	12:19:00	78.9	1.08	87.5	0.8	73.4	1.54	75.8	0.58
6/30/2023	12:20:00	78.9	1.1	87.5	0.81	73.4	1.53	75.8	0.59
6/30/2023	12:21:00	79	1.13	87.5	0.79	73.4	1.53	75.8	0.57
6/30/2023	12:22:00	79.1	1.1	87.6	0.8	73.4	1.53	75.8	0.57
6/30/2023	12:23:00	79.2	1.11	87.7	0.81	73.4	1.52	75.8	0.57
6/30/2023	12:24:00	79.3	1.1	87.7	0.81	73.7	1.52	75.8	0.56
6/30/2023	12:25:00	79.3	1.09	87.8	0.8	73.8	1.52	75.8	0.57
6/30/2023	12:26:00	79.5	1.1	87.9	0.81	74	1.5	75.8	0.56
6/30/2023	12:27:00	79.5	1.12	87.9	0.82	74	1.48	75.8	0.56
6/30/2023	12:28:00	79.5	1.09	88	0.83	74	1.49	75.8	0.57
6/30/2023	12:29:00	79.7	1.11	88.1	0.81	74.3	1.5	75.8	0.56
6/30/2023	12:30:00	79.7	1.1	88.1	0.81	74.3	1.49	75.8	0.56
6/30/2023	12:31:00	79.8	1.09	88.1	0.81	74.3	1.49	75.8	0.56
6/30/2023	12:32:00	79.8	1.09	88.1	0.79	74	1.5	75.8	0.56
6/30/2023	12:33:00	79.8	1.09	88	0.8	74	1.49	75.8	0.56
6/30/2023	12:34:00	79.8	1.09	88	0.81	74	1.48	75.8	0.56
6/30/2023	12:35:00	79.9	1.08	88.1	0.78	74.1	1.48	75.8	0.57
6/30/2023	12:36:00	80	1.08	88.2	0.81	74.1	1.45	75.8	0.57
6/30/2023	12:37:00	80.2	1.08	88.3	0.81	74.4	1.45	75.8	0.6
6/30/2023	12:38:00	80.4	1.08	88.6	0.79	74.8	1.46	75.8	0.6
6/30/2023	12:39:00	80.5	1.08	88.5	0.79	74.9	1.46	75.8	0.58
6/30/2023	12:40:00	80.5	1.08	88.5	0.79	74.9	1.45	75.8	0.59
6/30/2023	12:41:00	80.5	1.08	88.5	0.8	74.9	1.45	75.8	0.62
6/30/2023	12:42:00	80.5	1.07	88.5	0.8	74.9	1.44	75.8	0.6
6/30/2023	12:43:00	80.6	1.07	88.6	0.79	74.9	1.44	75.8	0.58
6/30/2023	12:44:00	80.7	1.07	88.6	0.79	74.9	1.44	75.8	0.55
6/30/2023	12:45:00	80.7	1.08	88.7	0.8	74.9	1.43	75.8	0.56
6/30/2023	12:46:00	80.7	1.09	88.6	0.78	75	1.44	75.8	0.56
6/30/2023	12:47:00	80.6	1.07	88.6	0.78	74.9	1.43	75.8	0.57
6/30/2023	12:48:00	80.6	1.1	88.5	0.78	74.9	1.43	75.8	0.57
6/30/2023	12:49:00	80.6	1.08	88.5	0.79	74.9	1.43	75.8	0.57
6/30/2023	12:50:00	80.6	1.09	88.5	0.79	74.9	1.43	75.8	0.56
6/30/2023	12:51:00	80.6	1.08	88.6	0.78	74.9	1.44	75.8	0.57
6/30/2023	12:52:00	80.7	1.08	88.5	0.78	74.8	1.43	75.8	0.57
6/30/2023	12:53:00	80.4	1.08	88.4	0.8	74.6	1.41	75.8	0.57
6/30/2023	12:54:00	80.4	1.08	88.4	0.77	74.6	1.43	75.8	0.57
6/30/2023	12:55:00	80.4	1.05	88.4	0.78	74.8	1.43	75.8	0.57
6/30/2023	12:56:00	80.4	1.07	88.4	0.77	74.9	1.42	75.8	0.55
6/30/2023	12:57:00	80.5	1.08	88.4	0.81	74.9	1.4	75.8	0.55
6/30/2023	12:58:00	80.5	1.07	88.3	0.78	74.9	1.41	75.8	0.56
6/30/2023	12:59:00	80.5	1.07	88.4	0.78	74.9	1.42	75.8	0.56
6/30/2023	13:00:00	80.6	1.06	88.5	0.76	74.9	1.43	75.8	0.56
6/30/2023	13:01:00	80.7	1.07	88.7	0.77	74.9	1.41	75.8	0.58

PCC Structural - Milwaukie, OR Facility

9203 Outlet

Volumetric Flow Rate Continuous Data

		Southwest Stack		Southeast Stack		Northeast Stack		Northwest Stack	
Date	Time	Temp, °F	dP, "H <sub>2</sub> O						
6/30/2023	13:02:00	80.8	1.06	88.8	0.76	74.9	1.42	75.8	0.57
6/30/2023	13:03:00	80.9	1.07	88.9	0.77	75	1.4	75.8	0.56
6/30/2023	13:04:00	81	1.05	89	0.73	75.1	1.42	75.8	0.56
6/30/2023	13:05:00	81.1	1.07	89	0.75	75.2	1.43	75.8	0.55
6/30/2023	13:06:00	81.2	1.06	89	0.76	75.2	1.41	75.8	0.58
6/30/2023	13:07:00	81.3	1.05	89	0.74	75.2	1.42	75.8	0.56
6/30/2023	13:08:00	81.3	1.05	89	0.74	75.1	1.42	75.8	0.57
6/30/2023	13:09:00	81.3	1.05	89	0.73	74.9	1.42	75.8	0.57
6/30/2023	13:10:00	81.3	1.04	89	0.73	74.9	1.43	75.8	0.57
6/30/2023	13:11:00	81.3	1.04	88.9	0.73	74.9	1.43	75.8	0.57
6/30/2023	13:12:00	81.3	1.04	88.9	0.74	74.9	1.42	75.8	0.58
6/30/2023	13:13:00	81.4	0.85	88.9	0.75	74.9	1.26	75.8	0.65
6/30/2023	13:14:00	81	0.47	88.4	0.73	74.7	1	75.8	0.67
6/30/2023	13:15:00	80.6	0.45	88	0.75	74.3	0.99	75.8	0.67
6/30/2023	13:16:00	80.6	0.45	87.9	0.73	74	0.99	75.8	0.67
6/30/2023	13:17:00	80.7	0.61	87.9	0.7	74	1.11	75.8	0.7
6/30/2023	13:18:00	81.3	1.03	88.6	0.7	74.5	1.39	75.8	0.71
6/30/2023	13:19:00	81.9	1.05	89.2	0.72	75	1.41	75.8	0.67
6/30/2023	13:20:00	82.1	1.04	89.3	0.71	75.2	1.43	75.8	0.66
6/30/2023	13:21:00	82.1	1.05	89.4	0.74	75.2	1.39	75.8	0.57
6/30/2023	13:22:00	82	1.06	89.4	0.73	75.2	1.4	75.8	0.56
6/30/2023	13:23:00	82	1.04	89.4	0.71	75.2	1.42	75.8	0.56
6/30/2023	13:24:00	82.1	1.04	89.4	0.71	75.2	1.42	75.8	0.56
6/30/2023	13:25:00	81.9	1.02	89.4	0.7	74.9	1.42	75.8	0.56
6/30/2023	13:26:00	81.9	1.05	89.3	0.71	74.9	1.43	75.8	0.56
6/30/2023	13:27:00	81.8	1.06	89.3	0.71	74.9	1.41	75.8	0.57
6/30/2023	13:28:00	81.8	1.05	89.4	0.7	74.9	1.42	75.8	0.57
6/30/2023	13:29:00	81.9	1.06	89.5	0.7	74.9	1.42	75.8	0.57
6/30/2023	13:30:00	82	1.05	89.5	0.7	74.9	1.43	75.8	0.57
6/30/2023	13:31:00	82	1.06	89.6	0.71	74.9	1.42	75.8	0.57
6/30/2023	13:32:00	82	1.05	89.6	0.7	74.9	1.43	75.8	0.57
6/30/2023	13:33:00	82.1	1.07	89.6	0.71	74.9	1.42	75.8	0.57
6/30/2023	13:34:00	82.2	1.06	89.6	0.71	74.9	1.42	75.8	0.56
6/30/2023	13:35:00	82.4	1.07	89.7	0.71	75	1.41	75.8	0.6
Average		73.4	1.17	80.5	0.88	69.6	1.07	75.6	0.65
Min		64.5	0.45	70.4	0.70	65.0	0.64	73.0	0.55
Max		82.4	1.29	89.7	1.00	75.2	1.57	75.8	1.22
Sqrt DP		1.080		Sqrt DP	0.936	Sqrt DP	1.036	Sqrt DP	0.808
Vs		60.697		Vs	52.991	Vs	58.063	Vs	45.531
ACFM		22,958		ACFM	20,043	ACFM	21,962	ACFM	17,222
DSCFM		22,588		DSCFM	19,462	DSCFM	21,762	DSCFM	16,874

### Method 1 and 2 Cyclonic Flow Check Data

<b>Project Number</b>	M232604	<b>Source Condition:</b>	Batch Process
<b>Client:</b>	PCC Structural, Inc.	<b>Run No.:</b>	1
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	<b>Date:</b>	6/26/2023
<b>Location:</b>	BH 9203 Inlet East	<b>Start Time:</b>	12:07
<b>Pitot ID:</b>	289	<b>End Time:</b>	12:22
<b>Pitot Coefficient:</b>	0.840	<b>RM Testers:</b>	NCC/EE
<b>Probe Length:</b>	4	<b>Port Length:</b>	4.00

Port	Point	DP	Sqrt.	Yaw	Velocity	Port	Point	DP	Sqrt.	Yaw	Velocity
		(in. H <sub>2</sub> O)	DP	(o)	(V)			(in. H <sub>2</sub> O)	DP	(o)	(V)
A	1	1.30	1.1402	4.0	61.31	B	1	1.30	1.1402	4.0	61.31
A	2	1.30	1.1402	3.0	61.31	B	2	1.30	1.1402	4.0	61.31
A	3	1.20	1.0954	3.0	58.90	B	3	1.30	1.1402	4.0	61.31
A	4	1.30	1.1402	4.0	61.31	B	4	1.30	1.1402	3.0	61.31
A	5	1.30	1.1402	5.0	61.31	B	5	1.30	1.1402	3.0	61.31
A	6	1.10	1.0488	4.0	56.39	B	6	1.20	1.0954	4.0	58.90
A	7	0.90	0.9487	4.0	51.01	B	7	1.30	1.1402	4.0	61.31
A	8	0.95	0.9747	3.0	52.41	B	8	1.20	1.0954	2.0	58.90
A	9	0.77	0.8775	5.0	47.18	B	9	1.10	1.0488	4.0	56.39
A	10	0.57	0.7550	7.0	40.59	B	10	0.95	0.9747	5.0	52.41
A	11	0.82	0.9055	5.0	48.69	B	11	0.84	0.9165	6.0	49.28
A	12	0.45	0.6708	6.0	36.07	B	12	0.84	0.9165	8.0	49.28

**Average Yaw Angle**

4.3 °

## Method 1 and 2 Cyclonic Flow Check Data

<b>Project Number:</b>	M232604	<b>Source Condition:</b>	Batch Process
<b>Client:</b>	PCC Structural, Inc.	<b>Run No.:</b>	1
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	<b>Date:</b>	6/26/2023
<b>Location:</b>	BH 9203 Inlet Center	<b>Start Time:</b>	12:25
<b>Pitot ID:</b>	289	<b>End Time:</b>	12:42
<b>Pitot Coefficient:</b>	0.840	<b>RM Testers:</b>	NCC/EE
<b>Probe Length:</b>	4	<b>Port Length:</b>	4.00

DP			Sqrт.		Yaw		Velocity		DP			Sqrт.		Yaw		Velocity	
Port	Point	(in. H <sub>2</sub> O)	DP	(o)	(V)			Port	Point	(in. H <sub>2</sub> O)	DP	(o)	(V)				
A	1	1.60	1.2649	4.0	68.01			B	1	1.40	1.1832	2.0	63.62				
A	2	1.60	1.2649	3.0	68.01			B	2	1.50	1.2247	3.0	65.85				
A	3	1.50	1.2247	4.0	65.85			B	3	1.50	1.2247	3.0	65.85				
A	4	1.50	1.2247	3.0	65.85			B	4	1.50	1.2247	4.0	65.85				
A	5	1.60	1.2649	4.0	68.01			B	5	1.50	1.2247	4.0	65.85				
A	6	1.50	1.2247	3.0	65.85			B	6	1.40	1.1832	3.0	63.62				
A	7	1.30	1.1402	4.0	61.31			B	7	1.30	1.1402	4.0	61.31				
A	8	1.20	1.0954	3.0	58.90			B	8	1.20	1.0954	3.0	58.90				
A	9	0.97	0.9849	3.0	52.96			B	9	1.20	1.0954	3.0	58.90				
A	10	0.80	0.8944	4.0	48.09			B	10	0.97	0.9849	4.0	52.96				
A	11	0.65	0.8062	3.0	43.35			B	11	0.95	0.9747	3.0	52.41				
A	12	0.62	0.7874	4.0	42.34			B	12	0.92	0.9592	4.0	51.57				

Average Yaw Angle 3.4 °

### Method 1 and 2 Cyclonic Flow Check Data

<b>Project Number</b>	M232604	<b>Source Condition:</b>	Batch Process
<b>Client:</b>	PCC Structural, Inc.	<b>Run No.:</b>	1
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	<b>Date:</b>	6/26/2023
<b>Location:</b>	BH 9203 Inlet West	<b>Start Time:</b>	11:45
<b>Pitot ID:</b>	289	<b>End Time:</b>	12:02
<b>Pitot Coefficient:</b>	0.840	<b>RM Testers:</b>	NCC/EE
<b>Probe Length:</b>	4	<b>Port Length:</b>	4.00

Port	Point	DP	Sqrт.	Yaw	Velocity	Port	Point	DP	Sqrт.	Yaw	Velocity
		(in. H <sub>2</sub> O)	DP	(o)	(V)			(in. H <sub>2</sub> O)	DP	(o)	(V)
A	1	1.40	1.1832	5.0	63.62	B	1	1.60	1.2649	4.0	68.01
A	2	1.50	1.2247	1.0	65.85	B	2	1.70	1.3038	3.0	70.11
A	3	1.50	1.2247	2.0	65.85	B	3	1.70	1.3038	3.0	70.11
A	4	1.60	1.2649	3.0	68.01	B	4	1.70	1.3038	2.0	70.11
A	5	1.70	1.3038	3.0	70.11	B	5	1.70	1.3038	3.0	70.11
A	6	1.70	1.3038	4.0	70.11	B	6	1.60	1.2649	5.0	68.01
A	7	1.60	1.2649	3.0	68.01	B	7	1.40	1.1832	5.0	63.62
A	8	1.50	1.2247	2.0	65.85	B	8	1.20	1.0954	4.0	58.90
A	9	1.30	1.1402	3.0	61.31	B	9	1.20	1.0954	3.0	58.90
A	10	1.20	1.0954	5.0	58.90	B	10	1.00	1.0000	5.0	53.77
A	11	1.00	1.0000	7.0	53.77	B	11	0.95	0.9747	7.0	52.41
A	12	0.95	0.9747	7.0	52.41	B	12	0.83	0.9110	9.0	48.99

**Average Yaw Angle**

4.1 °

### Method 1 and 2 Cyclonic Flow Check Data

<b>Project Number</b>	M232604	<b>Source Condition:</b>	Batch Process
<b>Client:</b>	PCC Structural, Inc.	<b>Run No.:</b>	1
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	<b>Date:</b>	6/26/2023
<b>Location:</b>	BH 9203 Outlet Southeast	<b>Start Time:</b>	17:29
<b>Pitot ID:</b>	289	<b>End Time:</b>	17:38
<b>Pitot Coefficient:</b>	0.840	<b>RM Testers:</b>	VTM/MPS
<b>Probe Length:</b>	4	<b>Port Length:</b>	4.00

Port	Point	DP	Sqrт.	Yaw	Velocity	Port	Point	DP	Sqrт.	Yaw	Velocity
		(in. H <sub>2</sub> O)	DP	(o)	(V)			(in. H <sub>2</sub> O)	DP	(o)	(V)
A	1	0.63	0.7937	3.0	42.68	B	1	0.76	0.8718	4.0	46.87
A	2	0.74	0.8602	2.0	46.25	B	2	0.77	0.8775	3.0	47.18
A	3	0.76	0.8718	3.0	46.87	B	3	0.79	0.8888	3.0	47.79
A	4	0.77	0.8775	3.0	47.18	B	4	0.79	0.8888	3.0	47.79
A	5	0.78	0.8832	3.0	47.49	B	5	0.80	0.8944	3.0	48.09
A	6	0.79	0.8888	3.0	47.79	B	6	0.79	0.8888	3.0	47.79
A	7	0.81	0.9000	4.0	48.39	B	7	0.79	0.8888	4.0	47.79
A	8	0.80	0.8944	3.0	48.09	B	8	0.79	0.8888	4.0	47.79
A	9	0.81	0.9000	3.0	48.39	B	9	0.81	0.9000	3.0	48.39
A	10	0.82	0.9055	3.0	48.69	B	10	0.77	0.8775	3.0	47.18
A	11	0.81	0.9000	3.0	48.39	B	11	0.77	0.8775	3.0	47.18
A	12	0.81	0.9000	4.0	48.39	B	12	0.71	0.8426	3.0	45.31

**Average Yaw Angle**                                    3.2 °

### Method 1 and 2 Cyclonic Flow Check Data

<b>Project Number</b>	M232604	<b>Source Condition:</b>	Batch Process
<b>Client:</b>	PCC Structural, Inc.	<b>Run No.:</b>	1
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	<b>Date:</b>	6/26/2023
<b>Location:</b>	BH 9203 Outlet Southwest	<b>Start Time:</b>	16:18
<b>Pitot ID:</b>	289	<b>End Time:</b>	16:52
<b>Pitot Coefficient:</b>	0.840	<b>RM Testers:</b>	VTM/MPS
<b>Probe Length:</b>	4	<b>Port Length:</b>	4.00

Port	Point	DP	Sqrт.	Yaw	Velocity	Port	Point	DP	Sqrт.	Yaw	Velocity
		(in. H <sub>2</sub> O)	DP	(o)	(V)			(in. H <sub>2</sub> O)	DP	(o)	(V)
A	1	0.73	0.8544	9.0	45.94	B	1	0.82	0.9055	4.0	48.69
A	2	0.75	0.8660	7.0	46.56	B	2	0.84	0.9165	5.0	49.28
A	3	0.80	0.8944	4.0	48.09	B	3	0.85	0.9220	5.0	49.57
A	4	0.79	0.8888	5.0	47.79	B	4	0.86	0.9274	4.0	49.86
A	5	0.78	0.8832	8.0	47.49	B	5	0.84	0.9165	3.0	49.28
A	6	0.80	0.8944	9.0	48.09	B	6	0.85	0.9220	5.0	49.57
A	7	0.81	0.9000	8.0	48.39	B	7	0.86	0.9274	5.0	49.86
A	8	0.80	0.8944	5.0	48.09	B	8	0.85	0.9220	5.0	49.57
A	9	0.81	0.9000	5.0	48.39	B	9	0.84	0.9165	3.0	49.28
A	10	0.82	0.9055	5.0	48.69	B	10	0.84	0.9165	3.0	49.28
A	11	0.78	0.8832	5.0	47.49	B	11	0.79	0.8888	4.0	47.79
A	12	0.77	0.8775	7.0	47.18	B	12	0.70	0.8367	5.0	44.99

**Average Yaw Angle**                            5.3 °

### Method 1 and 2 Cyclonic Flow Check Data

<b>Project Number</b>	M232604	<b>Source Condition:</b>	Batch Process
<b>Client:</b>	PCC Structural, Inc.	<b>Run No.:</b>	1
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	<b>Date:</b>	6/26/2023
<b>Location:</b>	BH 9203 Outlet Northwest	<b>Start Time:</b>	16:55
<b>Pitot ID:</b>	289	<b>End Time:</b>	17:08
<b>Pitot Coefficient:</b>	0.840	<b>RM Testers:</b>	VTM/MPS
<b>Probe Length:</b>	4	<b>Port Length:</b>	4.00

Port	Point	DP	Sqrт.	Yaw	Velocity	Port	Point	DP	Sqrт.	Yaw	Velocity
		(in. H <sub>2</sub> O)	DP	(o)	(V)			(in. H <sub>2</sub> O)	DP	(o)	(V)
A	1	0.63	0.7937	6.0	42.68	B	1	0.63	0.7937	7.0	42.68
A	2	0.72	0.8485	4.0	45.62	B	2	0.70	0.8367	5.0	44.99
A	3	0.76	0.8718	4.0	46.87	B	3	0.77	0.8775	3.0	47.18
A	4	0.78	0.8832	3.0	47.49	B	4	0.75	0.8660	2.0	46.56
A	5	0.76	0.8718	4.0	46.87	B	5	0.78	0.8832	3.0	47.49
A	6	0.76	0.8718	3.0	46.87	B	6	0.78	0.8832	3.0	47.49
A	7	0.78	0.8832	4.0	47.49	B	7	0.78	0.8832	3.0	47.49
A	8	0.80	0.8944	3.0	48.09	B	8	0.78	0.8832	4.0	47.49
A	9	0.80	0.8944	4.0	48.09	B	9	0.78	0.8832	3.0	47.49
A	10	0.79	0.8888	3.0	47.79	B	10	0.80	0.8944	3.0	48.09
A	11	0.77	0.8775	4.0	47.18	B	11	0.80	0.8944	3.0	48.09
A	12	0.73	0.8544	4.0	45.94	B	12	0.78	0.8832	3.0	47.49

**Average Yaw Angle**                                    3.7 °

### Method 1 and 2 Cyclonic Flow Check Data

<b>Project Number</b>	M232604	<b>Source Condition:</b>	Batch Process
<b>Client:</b>	PCC Structural, Inc.	<b>Run No.:</b>	1
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	<b>Date:</b>	6/26/2023
<b>Location:</b>	BH 9203 Outlet Northeast	<b>Start Time:</b>	16:55
<b>Pitot ID:</b>	289	<b>End Time:</b>	17:08
<b>Pitot Coefficient:</b>	0.840	<b>RM Testers:</b>	VTM/MPS
<b>Probe Length:</b>	4	<b>Port Length:</b>	4.00

Port	Point	DP	Sqrт.	Yaw	Velocity	Port	Point	DP	Sqrт.	Yaw	Velocity
		(in. H <sub>2</sub> O)	DP	(o)	(V)			(in. H <sub>2</sub> O)	DP	(o)	(V)
A	1	0.72	0.8485	4.0	45.62	B	1	0.75	0.8660	6.0	46.56
A	2	0.72	0.8485	3.0	45.62	B	2	0.76	0.8718	7.0	46.87
A	3	0.73	0.8544	3.0	45.94	B	3	0.78	0.8832	6.0	47.49
A	4	0.75	0.8660	4.0	46.56	B	4	0.76	0.8718	6.0	46.87
A	5	0.76	0.8718	3.0	46.87	B	5	0.76	0.8718	6.0	46.87
A	6	0.77	0.8775	3.0	47.18	B	6	0.76	0.8718	5.0	46.87
A	7	0.77	0.8775	3.0	47.18	B	7	0.76	0.8718	5.0	46.87
A	8	0.76	0.8718	4.0	46.87	B	8	0.76	0.8718	5.0	46.87
A	9	0.78	0.8832	3.0	47.49	B	9	0.77	0.8775	6.0	47.18
A	10	0.77	0.8775	4.0	47.18	B	10	0.75	0.8660	6.0	46.56
A	11	0.78	0.8832	3.0	47.49	B	11	0.75	0.8660	5.0	46.56
A	12	0.72	0.8485	4.0	45.62	B	12	0.69	0.8307	7.0	44.66

**Average Yaw Angle**

4.6 °

### Method 1 and 2 Cyclonic Flow Check Data

<b>Project Number</b>	M232604	<b>Source Condition:</b>	Batch Process
<b>Client:</b>	PCC Structural, Inc.	<b>Run No.:</b>	1
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	<b>Date:</b>	6/26/2023
<b>Location:</b>	BH 9203 Outlet West Center	<b>Start Time:</b>	16:00
<b>Pitot ID:</b>	289	<b>End Time:</b>	16:15
<b>Pitot Coefficient:</b>	0.840	<b>RM Testers:</b>	VTM/MPS
<b>Probe Length:</b>	4	<b>Port Length:</b>	4.00

Port	Point	DP	Sqrт.	Yaw	Velocity	Port	Point	DP	Sqrт.	Yaw	Velocity
		(in. H <sub>2</sub> O)	DP	(o)	(V)			(in. H <sub>2</sub> O)	DP	(o)	(V)
A	1	0.81	0.9000	3.0	48.39	B	1	0.81	0.9000	3.0	48.39
A	2	0.82	0.9055	3.0	48.69	B	2	0.83	0.9110	3.0	48.99
A	3	0.80	0.8944	2.0	48.09	B	3	0.81	0.9000	5.0	48.39
A	4	0.79	0.8888	5.0	47.79	B	4	0.80	0.8944	4.0	48.09
A	5	0.78	0.8832	2.0	47.49	B	5	0.80	0.8944	3.0	48.09
A	6	0.80	0.8944	3.0	48.09	B	6	0.79	0.8888	4.0	47.79
A	7	0.81	0.9000	3.0	48.39	B	7	0.82	0.9055	5.0	48.69
A	8	0.80	0.8944	4.0	48.09	B	8	0.80	0.8944	5.0	48.09
A	9	0.79	0.8888	5.0	47.79	B	9	0.79	0.8888	4.0	47.79
A	10	0.76	0.8718	6.0	46.87	B	10	0.78	0.8832	7.0	47.49
A	11	0.75	0.8660	6.0	46.56	B	11	0.77	0.8775	6.0	47.18
A	12	0.70	0.8367	7.0	44.99	B	12	0.73	0.8544	8.0	45.94

**Average Yaw Angle**

4.4 °

### Method 1 and 2 Cyclonic Flow Check Data

<b>Project Number</b>	M232604	<b>Source Condition:</b>	Batch Process
<b>Client:</b>	PCC Structural, Inc.	<b>Run No.:</b>	1
<b>Facility:</b>	Large Parts Campus Facility - Milwaukie, OR	<b>Date:</b>	6/26/2023
<b>Location:</b>	BH 9203 Outlet East Center	<b>Start Time:</b>	15:38
<b>Pitot ID:</b>	289	<b>End Time:</b>	15:52
<b>Pitot Coefficient:</b>	0.840	<b>RM Testers:</b>	VTM/MPS
<b>Probe Length:</b>	4	<b>Port Length:</b>	4.00

Port	Point	DP	Sqrт.	Yaw	Velocity	Port	Point	DP	Sqrт.	Yaw	Velocity
		(in. H <sub>2</sub> O)	DP	(o)	(V)			(in. H <sub>2</sub> O)	DP	(o)	(V)
A	1	0.83	0.9110	4.0	48.99	B	1	0.78	0.8832	5.0	47.49
A	2	0.81	0.9000	4.0	48.39	B	2	0.82	0.9055	3.0	48.69
A	3	0.79	0.8888	3.0	47.79	B	3	0.80	0.8944	5.0	48.09
A	4	0.82	0.9055	4.0	48.69	B	4	0.81	0.9000	4.0	48.39
A	5	0.80	0.8944	3.0	48.09	B	5	0.80	0.8944	5.0	48.09
A	6	0.79	0.8888	4.0	47.79	B	6	0.82	0.9055	4.0	48.69
A	7	0.80	0.8944	4.0	48.09	B	7	0.79	0.8888	5.0	47.79
A	8	0.80	0.8944	5.0	48.09	B	8	0.81	0.9000	6.0	48.39
A	9	0.80	0.8944	5.0	48.09	B	9	0.80	0.8944	5.0	48.09
A	10	0.78	0.8832	4.0	47.49	B	10	0.80	0.8944	6.0	48.09
A	11	0.74	0.8602	5.0	46.25	B	11	0.75	0.8660	7.0	46.56
A	12	0.72	0.8485	4.0	45.62	B	12	0.73	0.8544	7.0	45.94

**Average Yaw Angle**

4.6 °

## **Appendix E - Plant Operating Data**

## BH 9203

## Testing Production Data

Casting No.	Casting Weight <sup>(1)</sup> (lb)	
	Run 1 6/27/2023	Run 2 6/30/2023
1	3,084	455
2	316	760
3	316	1,080
4	430	760
5	430	1,080
6	440	3,100
7	440	1,890
8	430	760
9	420	440
10	1,415	590
11	1,600	440
12	440	1,415
13	430	760
14	430	760
15	440	760
16	420	1,415
17	440	1,555
18	440	1,080
19	1,600	--
20	2,025	--
21	430	--
22	430	--
23	430	--
24	430	--
<b>Total Casting (lb)</b>	<b>17,706</b>	<b>19,100</b>

(1) Sampling equipment was down for a period of 15-30 min for each run, on both the inlet and outlet.

The period of downtime cannot be clearly linked to a specific period of production, so no adjustments are made to the production data.

Time	Differential Pressure (inches w.c.)			
	Primary (West)	HEPA (West)	Primary (East)	HEPA (East)
<b>Run 1 (6/27/2023)</b>				
5:16	0.3	1.2	0.2	1.2
5:46	0.3	1.2	0.3	1.2
6:16	0.3	1.2	0.3	1.2
6:46	0.3	1.2	0.2	1.2
7:16	0.2	1.2	0.3	1.2
7:46	0.2	1.2	0.3	1.2
8:16	0.3	1.2	0.3	1.2
8:46	0.3	1.2	0.3	1.2
9:15	0.3	1.2	0.3	1.2
9:46	0.3	1.2	0.3	1.2
10:17	0.3	1.2	0.3	1.2
10:47	0.3	1.2	0.3	1.2
11:16	0.3	1.2	0.3	1.2
11:46	0.3	1.2	0.3	1.2
12:16	0.3	1.2	0.3	1.2
12:47	0.3	1.2	0.3	1.2
13:15	0.3	1.2	0.3	1.2
13:45	0.3	1.2	0.3	1.2
<b>Run 2 (6/30/2023)</b>				
5:25	0.2	1.2	0.3	1.2
5:55	0.2	1.2	0.3	1.2
6:25	0.3	1.2	0.3	1.2
6:55	0.2	1.2	0.3	1.2
7:25	0.3	1.2	0.2	1.2
7:55	0.2	1.2	0.2	1.2
8:25	0.2	1.2	0.2	1.2
8:55	0.2	1.2	0.3	1.2
9:25	0.2	1.2	0.3	1.2
9:55	0.2	1.2	0.3	1.2
10:25	0.3	1.2	0.3	1.2
10:55	0.2	1.2	0.3	1.2
11:25	0.3	1.3	0.3	1.2
11:55	0.3	1.4	0.3	1.4
12:25	0.3	1.2	0.3	1.2
12:55	0.2	1.2	0.3	1.2
13:25	0.3	1.2	0.3	1.2

## **Appendix F - Field Data Sheets**

**Isokinetic Sampling Cover Sheet**

Client:	PCC Structural Inc	Pitot Tube Cp:	> 84
Facility:	Large parts campus Milwaukee	Probe Length (Feet):	4
Test Location:	BH 9203 Inlet North	Probe Liner Material:	Glass
Project #:	M232604	Sample Plane:	(Hrz) or Vert.
Test Method(s):	M29	Port Length ("):	4
Test Engineer:	JX	Port Diameter ("):	4
Test Technician:	FJD	Port Type:	Nipple
Upstream Diameters:	22 ft	Duct Shape:	(Circ) or Rect.
Downstream Diameters:	18 ft	Diameter (Feet):	3
# of Ports Sampled:	2	Length (Feet):	
# of Points per Port:	12	Width (Feet):	
Source Condition:	Normal	Duct Area (Sq. Feet):	7.069
Diluent Model/SN:	N/A	Minutes per Point:	20
Mid Gas ID/concentration:	N/A	Total Traverse Points:	34
High Gas ID/concentration:	N/A	Test Length (Min.):	480
Moisture Balance ID:		Train Type:	Hot Box

R# 1

R# 2

R#

Meter ID:	cm 43	cm 43	
Pitot ID:	312	312	
Filter ID:	N/A	N/A	
Filter Pre-Weight (g):	N/A	N/A	
Nozzle Diameter ("):	.200	.200	
Meter Cal Factor (Y):	- .992	.992	
Meter Orifice Setting (DH):	1.810	1.810	
Nozzle Kit ID:			
Individual Nozzle ID:			
Pre Pitot Leak Check:	0.000 @ 3.5 "H <sub>2</sub> O	0.000 @ 6 "H <sub>2</sub> O	@ "H <sub>2</sub> O
Post Pitot Leak Check:	0.000 @ 5 "H <sub>2</sub> O	0.000 @ 7 "H <sub>2</sub> O	@ "H <sub>2</sub> O
Pre Nozzle Leak Check:	0.000 @ 10 "Hg	0.000 @ 10 "Hg	@ "Hg
Post Nozzle Leak Check:	0.000 @ 10 "Hg	0.000 @ 10 "Hg	@ "Hg
Barometric Pressure, "Hg:	29.97	29.97	
Static Pressure, "H <sub>2</sub> O:	-4	-3.7	
CO <sub>2</sub> %:			
O <sub>2</sub> %:			

Comments:

## **Isokinetic Sampling Field Data Sheet**

Project Number: M232604 Date: 6/27/2023 Test Number: 1  
Client: PCC Structural, Inc Test Location: BH9103 Inlet Operator: jxj Test Tech: PPP  
Plant: Milwaukee, OR Test Method: M29 Page Number: 1 of 2

## **Isokinetic Sampling Field Data Sheet**

Project Number: M232604  
Client: PCC Structural Inc  
Plant: Milwaukee, OR

Date: 8/27/2023 Test Number:  
Test Location: BH9203 Inlet N Operator:  
Test Method: M29 Page Number:

1 JKS Test Tech: PPP  
2 of 2

**IMPINGER WEIGHT SHEET**

PLANT: PCC STRUCTURALS

Scale ID Number S10-85

UNIT NO: Baghouse 9203

Scale Calibration Check Date: 6-27-23

LOCATION: INLET NORTH

Scale Calibration Check (see QS-6.05C for procedure)  
must be within  $\pm 0.5\text{g}$  of certified mass

DATE: 6-27-23

250 grams 250.0

TEST NO: #1

500 grams 500.1

METHOD: M29

750 grams 750.1

WEIGHED/MEASURED BY: Gf

	FINAL WEIGHT	INITIAL WEIGHT	IMPIINGER	IMPIINGER
Circle One:	MLS / GRAMS	MLS / GRAMS	GAIN	CONTENTS
IMPIINGER 1	608.3	603.6		O.1N HNO3/H2O2
IMPIINGER 2	780.9	777.6		O.1N HNO3/H2O2
IMPIINGER 3	658.6	657.0		EMPTY
IMPIINGER 4	620.4	625.7		EMPTY
IMPIINGER 5	780.2	750.3		EMPTY
IMPIINGER 6	861.6	810.9		SILICA
IMPIINGER 7				
IMPIINGER 8				

**IMPIINGERS**

FINAL TOTAL      INITIAL TOTAL      TOTAL IMPINGER GAIN

**SILICA**

FINAL TOTAL      INITIAL TOTAL      TOTAL SILICA GAIN

## **Isokinetic Sampling Field Data Sheet**

Project Number: M232604  
Client: PCC STRUCTURALS  
Plant: Milwaukee, OR

Date: 6/30/73 Test Number:  
Test Location: BH 1203 inlet Operator:  
Test Method: 29 Page Number:

2  
JXJ Test Tech: EJD1  
of 2

## **Isokinetic Sampling Field Data Sheet**

Project Number: M232604  
Client: PCC Structural's  
Plant: Milwaukee, OR

Date: 6/30/03 Test Number:  
Test Location: BH9203 Inlet N Operator:  
Test Method: 29 Page Number:

2  
3x) Test Tech: EJ01  
2 of 2

**IMPINGER WEIGHT SHEET**

PLANT: PCC STRUCTURALS Scale ID Number S10-35

UNIT NO: BH 9203 Scale Calibration Check Date: 6-30-23

LOCATION: INLET NORTH Scale Calibration Check (see QS-6.05C for procedure)

must be within  $\pm 0.5\text{g}$  of certified mass

DATE: 6-30-23 250 grams 250.0

TEST NO: #2 500 grams 500.1

METHOD: 29 750 grams 750.1

WEIGHED/MEASURED BY: dt

	FINAL WEIGHT	INITIAL WEIGHT	IMPIINGER	IMPIINGER
Circle One:	MLS / GRAMS	MLS / GRAMS	GAIN	CONTENTS
IMPIINGER 1	780.6	735.2		HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>
IMPIINGER 2	765.8	764.2		HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>
IMPIINGER 3	661.2	655.5		EMPTY
IMPIINGER 4	741.3	739.3		KMNO <sub>4</sub>
IMPIINGER 5	738.3	738.3		KMNO <sub>4</sub>
IMPIINGER 6	871.6	807.3		SILICA
IMPIINGER 7				
IMPIINGER 8				

IMPINGERS      FINAL TOTAL      INITIAL TOTAL      TOTAL IMPINGER GAIN

SILICA      FINAL TOTAL      INITIAL TOTAL      TOTAL SILICA GAIN

**Isokinetic Sampling Cover Sheet**

<b>Client:</b>	<i>PCC</i>	<b>Pitot Tube Cp:</b>	<i>0.816</i>
<b>Facility:</b>	<i>LPC - Milwaukee</i>	<b>Probe Length (Feet):</b>	<i>4</i>
<b>Test Location:</b>	<i>9203 York - Center</i>	<b>Probe Liner Material:</b>	<i>Glass</i>
<b>Project #:</b>	<i>M232604</i>	<b>Sample Plane:</b>	<i>Hrztl. or Vert.</i>
<b>Test Method(s):</b>	<i>29</i>	<b>Port Length ("):</b>	<i>4</i>
<b>Test Engineer:</b>	<i>EE</i>	<b>Port Diameter ("):</b>	<i>4</i>
<b>Test Technician:</b>	<i>PPP</i>	<b>Port Type:</b>	<i>Nozzle</i>
<b>Upstream Diameters:</b>		<b>Duct Shape:</b>	<i>(Circ) or Rect.</i>
<b>Downstream Diameters:</b>		<b>Diameter (Feet):</b>	<i>3.0</i>
<b># of Ports Sampled:</b>	<i>2</i>	<b>Length (Feet):</b>	<i>—</i>
<b># of Points per Port:</b>	<i>12</i>	<b>Width (Feet):</b>	<i>—</i>
<b>Source Condition:</b>	<i>Normal</i>	<b>Duct Area (Sq. Feet):</b>	<i>7.069</i>
<b>Diluent Model/SN:</b>		<b>Minutes per Point:</b>	<i>20/10</i>
<b>Mid Gas ID/concentration:</b>	<i>— /%CO<sub>2</sub> — %O<sub>2</sub></i>	<b>Total Traverse Points:</b>	<i>24</i>
<b>High Gas ID/concentration:</b>	<i>— /%CO<sub>2</sub> — %O<sub>2</sub></i>	<b>Test Length (Min.):</b>	<i>450</i>
<b>Moisture Balance ID:</b>		<b>Train Type:</b>	<i>Hof B4</i>

	<u>R# 1</u>	<u>R# 2</u>	<u>R#</u>
<b>Meter ID:</b>	<i>Cm7</i>	<i>Cm7</i>	
<b>Pitot ID:</b>	<i>288</i>	<i>288</i>	
<b>Filter ID:</b>	<i>—</i>	<i>—</i>	
<b>Filter Pre-Weight (g):</b>	<i>—</i>	<i>—</i>	
<b>Nozzle Diameter ("):</b>	<i>0.196</i>	<i>0.196</i>	
<b>Meter Cal Factor (Y):</b>	<i>0.988</i>	<i>0.988</i>	
<b>Meter Orifice Setting (DH):</b>	<i>1.533</i>	<i>1.533</i>	
<b>Nozzle Kit ID:</b>			
<b>Individual Nozzle ID:</b>			
<b>Pre Pitot Leak Check:</b>	<i>230.0 @ 3.3 "H<sub>2</sub>O</i>	<i>0.6 @ 3.7 "H<sub>2</sub>O</i>	<i>@ "H<sub>2</sub>O</i>
<b>Post Pitot Leak Check:</b>	<i>0.0 @ 4.0 "H<sub>2</sub>O</i>	<i>0.0 @ 3.3 "H<sub>2</sub>O</i>	<i>@ "H<sub>2</sub>O</i>
<b>Pre Nozzle Leak Check:</b>	<i>0.002 @ 18 "Hg</i>	<i>0.003 @ 12 "Hg</i>	<i>@ "Hg</i>
<b>Post Nozzle Leak Check:</b>	<i>0.004 @ 20 "Hg</i>	<i>0.002 @ 11 "Hg</i>	<i>@ "Hg</i>
<b>Barometric Pressure, "Hg:</b>	<i>29.97</i>	<i>29.97</i>	
<b>Static Pressure, "H<sub>2</sub>O:</b>	<i>-3.7</i>	<i>-3.5</i>	
<b>CO<sub>2</sub> %:</b>	<i>—</i>	<i>—</i>	
<b>O<sub>2</sub> %:</b>	<i>—</i>	<i>—</i>	

**Comments:**

## **Isokinetic Sampling Field Data Sheet**

Project Number: M23264  
Client: PCC  
Plant: LPC-milwaukee, WI

Date: 6/27/23 Test Number: 1  
Test Location: 9203 Inlet-Center Operator: CE Test Tech: mjo  
Test Method: 29 Page Number: 1 of 2

## **Isokinetic Sampling Field Data Sheet**

Project Number: 323264  
Client: DCC  
Plant: LPC-Milwaukee DR

Date: 6/27/23  
Test Location: 9203 Inlet Center  
Test Method: 29

Test Number: 1  
Operator: LEE Test Tech: MTO  
Page Number: 2 of 2

**IMPINGER WEIGHT SHEET**

PLANT: PCC STRUCTURALS

Scale ID Number S10-35

UNIT NO: Baghouse 9203

Scale Calibration Check Date: 6-27-23

LOCATION: INLET CENTER

Scale Calibration Check (see QS-6.05C for procedure)  
must be within  $\pm 0.5\text{g}$  of certified mass

DATE: 6-27-23

250 grams 250.0

TEST NO: #1

500 grams 500.1

METHOD: M29

750 grams 750.1

WEIGHED/MEASURED BY: CB

Circle One:	FINAL WEIGHT MLS / GRAMS	INITIAL WEIGHT MLS / GRAMS	IMPINGER GAIN	IMPINGER CONTENTS
IMPINGER 1	710.0	752.2	17.8	G.LN HNO <sub>3</sub> / H <sub>2</sub> O <sub>2</sub>
IMPINGER 2	744.5	741.2	3.3	G.LN HNO <sub>3</sub> / H <sub>2</sub> O <sub>2</sub>
IMPINGER 3	653.2	653.50	-10.2	EMPTY
IMPINGER 4	746.4	756.6	-8.3	KMNO <sub>4</sub>
IMPINGER 5	728.7	737.0		KMNO <sub>4</sub>
IMPINGER 6	871.5	816.1	55.4	SILICA
IMPINGER 7				
IMPINGER 8				

**IMPINGERS**

FINAL TOTAL      INITIAL TOTAL      TOTAL IMPINGER GAIN

**SILICA**

FINAL TOTAL      INITIAL TOTAL      TOTAL SILICA GAIN

## **Isokinetic Sampling Field Data Sheet**

Project Number: m232604  
Client: Pcc  
Plant: LPC-milwaukee-OR

Date: 6/30/23  
Test Location: 9203 Inlet Center  
Test Method: 29

Test Number: 2  
Operator: PPP Test Tech: \_\_\_\_\_  
Page Number: 1 of 2

## **Isokinetic Sampling Field Data Sheet**

Project Number: m2346w  
Client: PCC  
Plant: LPC - M.I. Waukegan OR

Date: 6/30/23  
Test Location: 9203 Inlet Counter  
Test Method: 29

Test Number: 2  
Operator: \_\_\_\_\_ Test Tech: \_\_\_\_\_  
Page Number: 2 of 2

3:15  
Flow  
lost  
for  
~2 min

**IMPIINGER WEIGHT SHEET**

PLANT: PCC STRUCTURAL

Scale ID Number S10-35

UNIT NO: INLET CENTER BH 9203

Scale Calibration Check Date: 6-30-23

LOCATION: INLET CENTER

Scale Calibration Check (see QS-6.05C for procedure)  
must be within  $\pm 0.5\text{g}$  of certified mass

DATE: 6-30-23

250 grams 250.0

TEST NO: #2

500 grams 500.1

METHOD: 29

750 grams 750.1

WEIGHED/MEASURED BY: Al

	FINAL WEIGHT	INITIAL WEIGHT	IMPIINGER	IMPIINGER
Circle One:	MLS / GRAMS	MLS / GRAMS	GAIN	CONTENTS
IMPIINGER 1	776.1	754.7		HgCl <sub>2</sub> /H <sub>2</sub> O <sub>2</sub>
IMPIINGER 2	760.0	746.3		HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>
IMPIINGER 3	630.0	624.4		Empty
IMPIINGER 4	763.7	769.2		KmnO <sub>4</sub>
IMPIINGER 5	742.1	740.9		KmnO <sub>4</sub>
IMPIINGER 6	900.4	889.1		SILICA
IMPIINGER 7				
IMPIINGER 8				

**IMPIINGERS**

FINAL TOTAL    INITIAL TOTAL    TOTAL IMPINGER GAIN

**SILICA**

FINAL TOTAL    INITIAL TOTAL    TOTAL SILICA GAIN

**Isokinetic Sampling Cover Sheet**

<b>Client:</b>	PCC Structural, Inc.	<b>Pitot Tube Cp:</b>	0.840
<b>Facility:</b>	Large Parts Campus Milwaukee, OR	<b>Probe Length (Feet):</b>	
<b>Test Location:</b>	9203 Inlet - South	<b>Probe Liner Material:</b>	Glass
<b>Project #:</b>	M232604	<b>Sample Plane:</b>	Hrztl. or Vert.
<b>Test Method(s):</b>	29	<b>Port Length ("):</b>	4
<b>Test Engineer:</b>	NCL	<b>Port Diameter ("):</b>	4
<b>Test Technician:</b>	PPP	<b>Port Type:</b>	Nipple
<b>Upstream Diameters:</b>	2.0	<b>Duct Shape:</b>	Circ or Rect.
<b>Downstream Diameters:</b>	78	<b>Diameter (Feet):</b>	3.0
<b># of Ports Sampled:</b>	2	<b>Length (Feet):</b>	—
<b># of Points per Port:</b>	12	<b>Width (Feet):</b>	—
<b>Source Condition:</b>	Normal	<b>Duct Area (Sq. Feet):</b>	7.069
<b>Diluent Model/SN:</b>	—	<b>Minutes per Point:</b>	20 (10/reading)
<b>Mid Gas ID/concentration:</b>	— /%CO <sub>2</sub> — %O <sub>2</sub>	<b>Total Traverse Points:</b>	24
<b>High Gas ID/concentration:</b>	— /%CO <sub>2</sub> — %O <sub>2</sub>	<b>Test Length (Min.):</b>	480
<b>Moisture Balance ID:</b>		<b>Train Type:</b>	Half Box

	R# 1	R# 2	R#
<b>Meter ID:</b>	CM8	CM8	
<b>Pitot ID:</b>	290	290	
<b>Filter ID:</b>	—	—	
<b>Filter Pre-Weight (g):</b>	—	—	
<b>Nozzle Diameter ("):</b>	.193	.193	
<b>Meter Cal Factor (Y):</b>	.984	.984	
<b>Meter Orifice Setting (DH):</b>	1.860	1.860	
<b>Nozzle Kit ID:</b>	Teflon	Teflon	
<b>Individual Nozzle ID:</b>			
<b>Pre Pitot Leak Check:</b>	✓ @ 4.5 "H <sub>2</sub> O	✓ @ 4.5 "H <sub>2</sub> O	@ "H <sub>2</sub> O
<b>Post Pitot Leak Check:</b>	✓ @ 4.5 "H <sub>2</sub> O	✓ @ 4.5 "H <sub>2</sub> O	@ "H <sub>2</sub> O
<b>Pre Nozzle Leak Check:</b>	.000 @ 19 "Hg	.000 @ 17 "Hg	@ "Hg
<b>Post Nozzle Leak Check:</b>	.000 @ 16 "Hg	.000 @ 15 "Hg	@ "Hg
<b>Barometric Pressure, "Hg:</b>	29.97	30.05 29.97	
<b>Static Pressure, "H<sub>2</sub>O:</b>	-3.7	-3.7	
<b>CO<sub>2</sub> %:</b>	—	—	
<b>O<sub>2</sub> %:</b>	—	—	

Comments:

## **Isokinetic Sampling Field Data Sheet**

Project Number: m232604  
Client: PCC  
Plant: LPC m.lwakic.0B

Date: 6/27/23 Test Number:  
Test Location: 9203 Intel - South Operator:  
Test Method: 29 Page Number:

WCC Test Tech: PPP

## **Isokinetic Sampling Field Data Sheet**

Project Number: m232604  
Client: Pcc  
Plant: Lpc Milwaukee OB

Date: 6/27/23 Test Number: 1  
Test Location: 9203 2nd St - South Operator: NCC Test Tech: PPP  
Test Method: 29 Page Number: 2 of 2

## IMPIINGER WEIGHT SHEET

PLANT: PCC STRUCTURALSScale ID Number 510-35UNIT NO: Baghouse 9203Scale Calibration Check Date: 6-27-23LOCATION: TINLET SOUTHScale Calibration Check (see QS-6.05C for procedure)  
must be within  $\pm 0.5$ g of certified massDATE: 6-27-23250 grams 250.0TEST NO: #1500 grams 500.1METHOD: M29750 grams 750.1WEIGHED/MEASURED BY: AB

	FINAL WEIGHT	INITIAL WEIGHT	IMPIINGER	IMPIINGER
Circle One:	MLS / GRAMS	MLS / GRAMS	GAIN	CONTENTS
IMPIINGER 1	732.7	720.3		O.W HNO3/H2O2
IMPIINGER 2	794.0	719.6		O.W HNO3/H2O2
IMPIINGER 3	625.5	623.2		Empty
IMPIINGER 4	768.0	779.1		KMNO4
IMPIINGER 5	734.1	737.2		KMNO4
IMPIINGER 6	888.7	837.2		SILICA
IMPIINGER 7				
IMPIINGER 8				

IMPIINGERS      FINAL TOTAL      INITIAL TOTAL      TOTAL IMPINGER GAIN

SILICA      FINAL TOTAL      INITIAL TOTAL      TOTAL SILICA GAIN

## **Isokinetic Sampling Field Data Sheet**

**Project Number:**

M 232604

Date:

6-30-2023 T

**Test Number:**

## Client:

PCC

**Test Location:**

9203 Tm 1-500 M

## Operator

Plant

### PCF - Milwaukee

#### Test Method:

M29

Page Number:

MFD Test Tech: NCC

# Isokinetic Sampling Field Data Sheet

Project Number:

M232604

Date:

6-30-2023

Test Number:

2

Client:

PCL

Test Location:

9003 Inlet South

Operator:

MFD

Test Tech:

NCC

Plant:

LPCF - Milwauke

Test Method:

M29

Page Number:

2 of 2

Port-Point #	Time	(ΔP)	X Orifice Setting (ΔH)	$K^1 = +1.440$ $1.476$	Stack Temp., °F	Meter Temp Inlet, °F	Meter Temp Outlet, °F	Pump Vacuum, "Hg	Probe Temp. °F	Filter Temp. °F	Impinger Well Temp. °F	Impinger Outlet Root, ΔP	K-Calc (Optional)		
													K = <del>1.40</del> <del>1.60</del>	x 10	
													J <sub>X</sub> Square	Meter Rate, Cubic Feet/Min.	Theoretical Meter Volume, (V <sub>m</sub> ) ft <sup>3</sup> , per point
2-1	1000	1.2	1.8	213.522	74	72	72	5	250	254	61	1.095	.745	7.449	—
1	1010	1.1	1.6	220.45	74	72	72	5	250	254	61	1.099	.713	7.132	220.971
2	1020	1.1	1.6	228.91	74	73	73	5	251	254	57	1.049	.713	7.132	228.103
2	1030	1.1	1.6	236.01	75	73	6	249	254	57	1.049	.713	7.132	235.235	
3	1040	1.0	1.5	242.75	75	74	5	252	254	55	1.000	.680	6.80	242.367	
3	1050	1.1	1.6	249.69	75	75	5	251	254	58	1.049	.713	7.132	249.167	
4	1100	1.2	1.8	256.99	77	75	5	250	254	58	1.095	.745	7.449	256.287	
4	1110	1.1	1.6	264.56	78	76	5	250	254	60	1.049	.713	7.132	263.736	
5	1120	1.3	1.9	271.52	80	77	5	252	254	56	1.140	.775	7.753	270.868	
5	1130	1.2	1.8	277.75	79	77	5	250	254	53	1.015	.745	7.449	278.621	
6	1140	1.1	1.6	285.63	81	78	5	251	254	51	1.049	.713	7.132	286.070	
6	1150	1.1	1.6	292.54	80	79	6	251	254	52	1.049	.713	7.132	293.202	
7	1200	1.0	1.5	299.79	80	81	6	247	254	52	1.000	.680	6.80	300.334	
7	1210	1.1	1.6	307.54	81	93	6	251	254	54	1.049	.713	7.132	307.134	
8	1220	1.2	1.8	315.72	81	85	6	251	254	53	1.095	.745	7.449	314.266	
8	1230	1.1	1.6	322.41	81	88	5	249	254	56	1.049	.713	7.132	321.715	
9	1240	1.1	1.6	329.31	82	89	5	251	254	55	1.049	.713	7.132	328.847	
9	1250	1.1	1.6	336.51	82	91	5	251	254	57	1.049	.713	7.132	335.967	
10	1300	1.1	1.6	343.78	82	93	5	252	254	56	1.049	.713	7.132	343.094	
10	1310	1.1	1.6	350.49	83	95	5	252	254	59	1.049	.713	7.132	350.231	
11	1320	1.3	1.9	356.52	83	96	5	250	254	57	1.140	.775	7.753	357.363	
11	1330			362.79											363.116
12	1340														
12	1350														
12	1400														

**IMPIINGER WEIGHT SHEET**

PLANT: PCC STRUCTURALS Scale ID Number 510-35  
 UNIT NO: BH 9203 Scale Calibration Check Date: 6-30-23  
 LOCATION: INLET SOUTH Scale Calibration Check (see QS-6.05C for procedure)  
 DATE: 6-30-23 must be within  $\pm 0.5$ g of certified mass  
 TEST NO: #2 250 grams 250.0  
 METHOD: M29 500 grams 500.0  
 WEIGHED/MEASURED BY: BT 750 grams 750.1

Circle One:	FINAL WEIGHT MLS / GRAMS	INITIAL WEIGHT MLS / GRAMS	IMPIINGER GAIN	IMPIINGER CONTENTS
IMPINGER 1	779.2	752.1		HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>
IMPINGER 2	764.3	752.1		HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>
IMPINGER 3	657.7	651.2		EMPTY
IMPINGER 4	776.9	782.1		KNO <sub>3</sub>
IMPINGER 5	764.1	761.1		KNO <sub>3</sub>
IMPINGER 6	868.8	802.1		Silica
IMPINGER 7				
IMPINGER 8				

IMPIINGERS      FINAL TOTAL      INITIAL TOTAL      TOTAL IMPINGER GAIN

SILICA      FINAL TOTAL      INITIAL TOTAL      TOTAL SILICA GAIN

**Isokinetic Sampling Cover Sheet**

Client:	PCC Structural Inc.		Pitot Tube Cp:	.84
Facility:	Large Parts Campus Milwaukee		Probe Length (Feet):	4
Test Location:	BH 9203 Inlet North		Probe Liner Material:	Glass
Project #:	M232604		Sample Plane:	(Hrz. or Vert.)
Test Method(s):	M0061		Port Length ("):	4
Test Engineer:	JX		Port Diameter ("):	4
Test Technician:	PPP		Port Type:	Nipple
Upstream Diameters:	22ft		Duct Shape:	(Circ) or Rect.
Downstream Diameters:	28ft		Diameter (Feet):	3
# of Ports Sampled:	2		Length (Feet):	
# of Points per Port:	12		Width (Feet):	
Source Condition:	Normal		Duct Area (Sq. Feet):	7.009
Diluent Model/SN:	N/A		Minutes per Point:	20
Mid Gas ID/concentration:	N/A	%CO <sub>2</sub>	Total Traverse Points:	34
High Gas ID/concentration:	N/A	%CO <sub>2</sub>	Test Length (Min.):	480
Moisture Balance ID:			Train Type:	Hot Box

R# 1

R#

R#

Meter ID:	CM39	CM39		
Pitot ID:	CM39-316	316		
Filter ID:	N/A	N/A		
Filter Pre-Weight (g):	N/A	N/A		
Nozzle Diameter ("):	.195	.195		
Meter Cal Factor (Y):	1.010	1.010		
Meter Orifice Setting (DH):	1.924	1.924		
Nozzle Kit ID:				
Individual Nozzle ID:				
Pre Pitot Leak Check:	0.000 @ 3.5 "H <sub>2</sub> O	0.000 @ 4 "H <sub>2</sub> O	@	"H <sub>2</sub> O
Post Pitot Leak Check:	0.000 @ 5 "H <sub>2</sub> O	0.000 @ 6 "H <sub>2</sub> O	@	"H <sub>2</sub> O
Pre Nozzle Leak Check:	0.000 @ 10 "Hg	0.000 @ 10 "Hg	@	"Hg
Post Nozzle Leak Check:	0.600 @ 10 "Hg	0.600 @ 10 "Hg	@	"Hg
Barometric Pressure, "Hg:	29.97	29.97		
Static Pressure, "H <sub>2</sub> O:	-4	-3.7		
CO <sub>2</sub> %:				
O <sub>2</sub> %:				

Comments:

## **Isokinetic Sampling Field Data Sheet**

Project Number: M232604  
Client: PCC Structural Inc.  
Plant: Milwaukee, WI

Date: 6/27/2023 Test Number:  
Test Location: BH91263 Inlet N. Operator:  
Test Method: M0061 Page Number:

1 Test Tech: JAS of 2 PPP

## **Isokinetic Sampling Field Data Sheet**

Project Number: M232604  
Client: PCC STRUCTURALS INC  
Plant: MILWAUKEE, OR

Date: 6/27/2023 Test Number:  
Test Location: BH 9103 Inlet N. Operator:  
Test Method: M0081 Page Number:

1  
JXJ Test Tech: PPP  
2 of 2

## **Isokinetic Sampling Field Data Sheet**

Project Number: M132604  
Client: PCL STRUCTURALS  
Plant: Milwaukee, WI

Date: 6/30 Test Number:  
Test Location: GH 9203 inlet N Operator:  
Test Method: 0001 Page Number:

J  
JXJ Test Tech: FJD1  
of 2

## **Isokinetic Sampling Field Data Sheet**

Project Number: M232604  
Client: PCC Structuralis  
Plant: Milwaukee, OR

Date: 6/30/23 Test Number:  
Test Location: BH9203 Inlet N. Operator:  
Test Method: 50/61 Page Number:

2  
jxj Test Tech: FJDJ  
2 of 2

**Isokinetic Sampling Cover Sheet**

<b>Client:</b>	PCC		<b>Pitot Tube Cp:</b>	O.S.I.
<b>Facility:</b>	LPC - Milwaukee, WI		<b>Probe Length (Feet):</b>	4
<b>Test Location:</b>	9203 - Tunnel Center		<b>Probe Liner Material:</b>	Clesis
<b>Project #:</b>	M232604		<b>Sample Plane:</b>	Hrzl. or Vert.
<b>Test Method(s):</b>	DOP		<b>Port Length ("):</b>	4
<b>Test Engineer:</b>	LSC		<b>Port Diameter ("):</b>	4
<b>Test Technician:</b>	PPF		<b>Port Type:</b>	Nipple
<b>Upstream Diameters:</b>			<b>Duct Shape:</b>	Circ. or Rect.
<b>Downstream Diameters:</b>			<b>Diameter (Feet):</b>	7.467
<b># of Ports Sampled:</b>	2		<b>Length (Feet):</b>	
<b># of Points per Port:</b>	12		<b>Width (Feet):</b>	
<b>Source Condition:</b>	Normal		<b>Duct Area (Sq. Feet):</b>	
<b>Diluent Model/SN:</b>			<b>Minutes per Point:</b>	200 / 10
<b>Mid Gas ID/concentration:</b>	—	/%CO <sub>2</sub> — %O <sub>2</sub>	<b>Total Traverse Points:</b>	24
<b>High Gas ID/concentration:</b>	—	/%CO <sub>2</sub> — %O <sub>2</sub>	<b>Test Length (Min.):</b>	450
<b>Moisture Balance ID:</b>			<b>Train Type:</b>	Silence

R# 1

R# 2

R#

<b>Meter ID:</b>	CMM	CMM	
<b>Pitot ID:</b>	287	289	
<b>Filter ID:</b>	—	—	
<b>Filter Pre-Weight (g):</b>	—	—	
<b>Nozzle Diameter ("):</b>	0.199	0.199	
<b>Meter Cal Factor (Y):</b>	1.000 ± 0.994 (S)	1.004 ± 0.994 (S)	
<b>Meter Orifice Setting (DH):</b>	1.833	1.833	
<b>Nozzle Kit ID:</b>			
<b>Individual Nozzle ID:</b>			
<b>Pre Pitot Leak Check:</b>	0.0 @ 3.6 "H <sub>2</sub> O	0.0 @ 3.3 "H <sub>2</sub> O	@ "H <sub>2</sub> O
<b>Post Pitot Leak Check:</b>	0.0 @ 4.0 "H <sub>2</sub> O	0.0 @ 3.6 "H <sub>2</sub> O	@ "H <sub>2</sub> O
<b>Pre Nozzle Leak Check:</b>	0.002 @ 18 "Hg	0.002 @ 18 "Hg	@ "Hg
<b>Post Nozzle Leak Check:</b>	0.002 @ 20 "Hg	0.004 @ 16 "Hg	@ "Hg
<b>Barometric Pressure, "Hg:</b>	29.97	29.97	
<b>Static Pressure, "H<sub>2</sub>O:</b>	-3.7	-3.5	
<b>CO<sub>2</sub> %:</b>	—		
<b>O<sub>2</sub> %:</b>	—		

**Comments:**

# Isokinetic Sampling Field Data Sheet

Project Number:

M232604

Client:

PCC

Plant:

LPC - Milwaukee, WI

Date:

6/27/23

Test Location:

9203 Inter-Center

Test Method:

OC1

Test Number:

1

Operator:

Test Tech: PPF

Page Number:

1 of 2

Port-Point #	Time	(ΔP)	Orifice Setting (ΔH)	Meter Volume (Vm) ft³, Actual	Stack Temp, °F	Meter Temp Inlet, °F	Meter Temp Outlet, °F	Pump Vacuum, "Hg	Probe Temp. °F	Filter Temp. °F	Impinger Outlet Well Temp. °F	Square Root, ΔP	K-Calcs (Optional)		
													K=	x 10	Theoretical Meter Volume, (Vm) ft³, per point
1-1	3:55	1.6	2.5	(21.033	63	56	54	10			57	1.205	0.716	9.162	
1	5:25	1.4	2.3	629.300	61	58	56	10			62	1.183	0.525	8.287	620.195
2	5:35	1.2	2.0	688.100	62	59	56	13			63	1.181	0.713	7.137	628.152
3	5:45	1.3	2.1	646.100	61	57	59	13			41	1.205	0.733	7.137	646.987
3	6:05	1.3	2.1	654.200	63	66	58	13			47	1.140	2.706	7.844	653.576
4	6:15	1.3	2.1	661.600	63	61	58	13			50	1.110	0.704	7.844	661.375
4	6:25	1.4	2.3	619.500	64	61	57	13			62	1.140	0.714	7.844	660.214
5	6:35	1.3	2.3	677.310	64	61	58	13			62	1.183	0.525	8.257	672.055
5	6:45	1.4	2.3	688.530	65	61	58	14			62	1.183	0.525	8.257	689.214
6	6:55	1.3	2.3	693.032	65	61	58	15			62	1.183	0.825	8.257	683.312
6	7:05	1.5	2.5	701.555	64	61	58	15			61	1.183	0.825	8.257	693.561
7	7:15	1.5	2.5	710.559	64	62	59	15			60	1.183	0.825	8.257	701.526
7	7:25	1.4	2.3	720.135	65	62	60	15			60	1.225	0.843	8.426	719.253
8	7:35	1.4	2.3	727.860	65	63	60	15			60	1.225	0.843	8.426	721.618
8	7:45	1.4	2.3	735.000	64	64	61	16			62	1.183	0.825	8.257	735.935
9	7:55	1.3	2.3	743.550	67	64	61	16			62	1.183	0.825	8.257	743.935
9	8:05	1.3	2.1	751.940	65	64	62	16			61	1.183	0.825	8.257	744.192
10	8:15	1.4	2.3	760.310	63	64	62	16			59	1.140	0.789	7.843	752.449
10	8:25	1.5	2.5	769.240	66	65	63	16			59	1.183	0.825	8.257	760.292
11	8:35	1.5	2.5	776.860	63	66	64	16			58	1.225	0.843	8.426	768.549
11	8:45	1.5	2.5	785.560	66	66	64	16			58	1.225	0.843	8.426	776.475
12	8:55	1.4	2.3	793.430	67	67	64	16			58	1.225	0.843	8.426	785.401
12	9:05	1.4	2.3	802.160	67	68	65	16			58	1.225	0.843	8.426	793.827
12	9:15	1.5	2.5	810.330	67	68	66	16			60	1.183	0.825	8.257	802.253
				817.880							61	1.225	0.843	8.426	810.500
															818.936

# Isokinetic Sampling Field Data Sheet

Project Number:

M232604

Client:

PCE

Plant:

LPC - milwaukee, WI

Date:

6/27/23

Test Location:

9203 Inlet - Central

Test Method:

CO<sub>2</sub>

Test Number:

Operator:

Page Number:

Test Tech: PPF

2 of 2

Port-Point #	Time	(ΔP)	1.6 <sup>2.6</sup> Orifice Setting (ΔH)	Meter Volume (V <sub>m</sub> ) ft <sup>3</sup> , Actual	Stack Temp, °F	Meter Temp Inlet, °F	Meter Temp Outlet, °F	Pump Vacuum, "Hg	Probe Temp. °F	Filter Temp. °F	Impinger Outlet Well Temp. °F	Square Root, ΔP	K-Calcs (Optional)		
													K=0.69 x 10 <sup>-3</sup>	Theoretical Meter Rate, Cubic Feet/ Min.	Theoretical Meter Volume, (V <sub>m</sub> ) ft <sup>3</sup> , per point
2-1	9:50	1.6	2.6	818.025	68	70	69	16			59	1.265	0.878	8.778	826.503
1	10:00	1.5	2.4	826.520	61	70	69	16			60	1.225	0.850	8.500	835.303
2	10:10	1.6	2.6	836.230	69	70	69	16			59	1.265	0.878	8.778	844.051
3	10:20	1.5	2.4	845.000	69	70	69	16			59	1.225	0.850	8.500	852.581
3	10:30	1.7	2.7	854.100	70	71	69	17			59	1.304	0.905	9.049	861.629
4	10:40	2.0	3.2	862.610	72	72	70	17			60	1.414	0.981	9.815	871.444
4	10:50	1.6	2.6	870.990	72	72	70	17			60	1.265	0.878	8.778	880.222
5	11:00	1.6	2.6	879.290	72	72	70	17			59	1.265	0.878	8.778	889.000
5	11:10	1.6	2.6	887.950	73	73	72	17			60	1.414	0.981	9.815	897.718
6	11:20	1.6	2.6	896.230	73	73	72	17			60	1.265	0.878	8.778	906.556
6	11:30	1.7	2.7	905.160	73	76	75	17			59	1.304	0.905	9.049	915.605
1	11:40	1.7	2.7	913.650	73	76	75	17			59	1.304	0.905	9.049	924.654
7	11:50	1.7	2.7	922.310	72	80	76	17			60	1.304	0.905	9.049	933.703
7	12:00	1.7	2.7	931.530	74	87	80	17			59	1.304	0.905	9.049	942.752
8	12:10	1.6	2.6	940.090	74	87	82	17			59	1.265	0.878	8.778	951.801
8	12:20	1.6	2.6	948.900	75	85	83	17			59	1.304	0.905	9.049	960.519
9	12:30	1.6	2.6	959.220	76	87	85	17			59	1.265	0.878	8.778	970.357
9	12:40	1.7	2.7	968.510	76	90	87	17			59	1.304	0.905	9.049	979.123
0	12:50	1.7	2.7	977.930	77	90	87	17			59	1.265	0.878	8.778	989.347
0	13:00	1.8	2.9	985.000	77	92	89	17			59	1.304	0.905	9.049	998.184
11	13:10	1.8	2.9	994.180	76	93	90	17			59	1.341	0.931	9.307	1006.233
11	13:20	1.8	2.9	1003.190	77	94	91	17			59	1.341	0.931	9.307	1005.540
12	13:30	1.6	2.6	1011.560	77	94	92	17			59	1.223	0.850	8.500	1014.847
12	13:40	1.5	2.4	1020.740	77	95	93	16			59	1.265	0.878	8.778	1023.347
13	13:50			1029.090							59	1.223	0.850	8.500	1032.125

## **Isokinetic Sampling Field Data Sheet**

Project Number: M232604  
Client: PCE  
Plant: LPER Milwaukee, OR

Date: 6/30/23  
Test Location: 9223 Inlet - Center  
Test Method: 0061

Test Number: 2  
Operator: PPP Test Tech: \_\_\_\_\_  
Page Number: 1 of 2

## **Isokinetic Sampling Field Data Sheet**

Project Number: M232604  
Client: PCC  
Plant: LFC - Milwaukee OR

Date: 6/30/23  
Test Location: 9203 Inlet Center  
Test Method: 0061

Test Number: 2  
Operator: \_\_\_\_\_ Test Tech: \_\_\_\_\_  
Page Number: 2 of 2

3-15  
last 10 s  
for  
~2 min

**Isokinetic Sampling Cover Sheet**

<b>Client:</b>	Pcc Structural, Inc.	<b>Pitot Tube Cp:</b>	0.840
<b>Facility:</b>	Large Park Campus Milwaukee, WI	<b>Probe Length (Feet):</b>	4
<b>Test Location:</b>	9203 Inlet - South	<b>Probe Liner Material:</b>	Glass
<b>Project #:</b>	M232604	<b>Sample Plane:</b>	Hrztl. or Vert
<b>Test Method(s):</b>	0061	<b>Port Length ("):</b>	4
<b>Test Engineer:</b>	NCC	<b>Port Diameter ("):</b>	4
<b>Test Technician:</b>	PPP	<b>Port Type:</b>	Wipple
<b>Upstream Diameters:</b>	2.0	<b>Duct Shape:</b>	Circ or Rect.
<b>Downstream Diameters:</b>	78.0	<b>Diameter (Feet):</b>	3.0
<b># of Ports Sampled:</b>	2	<b>Length (Feet):</b>	—
<b># of Points per Port:</b>	12	<b>Width (Feet):</b>	—
<b>Source Condition:</b>	Normal	<b>Duct Area (Sq. Feet):</b>	7.067
<b>Diluent Model/SN:</b>	—	<b>Minutes per Point:</b>	20 (16/second)
<b>Mid Gas ID/concentration:</b>	— /%CO <sub>2</sub> — %O <sub>2</sub>	<b>Total Traverse Points:</b>	24
<b>High Gas ID/concentration:</b>	— /%CO <sub>2</sub> — %O <sub>2</sub>	<b>Test Length (Min.):</b>	480
<b>Moisture Balance ID:</b>		<b>Train Type:</b>	H.A. B..

	R# 1	R# 2	R#
<b>Meter ID:</b>	CM10	CM10	
<b>Pitot ID:</b>	291	291	
<b>Filter ID:</b>	—	—	
<b>Filter Pre-Weight (g):</b>	—	—	
<b>Nozzle Diameter ("):</b>	.195	.195	
<b>Meter Cal Factor (Y):</b>	.990	.990	
<b>Meter Orifice Setting (DH):</b>	1.849	1.849	
<b>Nozzle Kit ID:</b>	Teflon	Teflon	
<b>Individual Nozzle ID:</b>			
<b>Pre Pitot Leak Check:</b>	✓ @ 4.5 "H <sub>2</sub> O	✓ @ 4.5 "H <sub>2</sub> O	@ "H <sub>2</sub> O
<b>Post Pitot Leak Check:</b>	✓ @ 4.5 "H <sub>2</sub> O	✓ @ 4.5 "H <sub>2</sub> O	@ "H <sub>2</sub> O
<b>Pre Nozzle Leak Check:</b>	.000 @ 21 "Hg	.600 @ 18 "Hg	@ "Hg
<b>Post Nozzle Leak Check:</b>	.000 @ 19 "Hg	.000 @ 16 "Hg	@ "Hg
<b>Barometric Pressure, "Hg:</b>	29.97	30.05 29.97	
<b>Static Pressure, "H<sub>2</sub>O:</b>	-3.7	-3.7	
<b>CO<sub>2</sub> %:</b>	—	—	
<b>O<sub>2</sub> %:</b>	—	—	

**Comments:**

# Isokinetic Sampling Field Data Sheet

Project Number:

M232604

Date:

6/27/23

Test Number:

1

Client:

PCC Structural's, Inc

Test Location:

9203 Inlet-South

Plant:

LPC Milwaukie, OR

Test Method:

0061

Operator:

NCCTest Tech: PPP1 of 2

Port-Point #	Time	X (ΔP)	Orifice Setting (ΔH)	Meter Volume (Vm) ft³, Actual	Stack Temp, °F	Meter Temp Outlet, °F	Pump Vacuum, "Hg	Probe Temp. °F	Filter Temp. °F	Impinger Well Temp. °F	K-Calcs (Optional)			
											K = <u>1.685</u>	x <u>10</u>	Theoretical Meter Rate, Cubic Feet/ Min.	Theoretical Meter Volume, (Vm) ft³, per point
											✓ Square Root, ΔP	Impinger Outlet Well Temp. °F	Meter Rate, Cubic Feet/ Min.	Theoretical Meter Volume, (Vm) ft³, total
1-1	515	1.3	2.0	35.151	65	59	59	11		61	1.140	.781	7.810	—
1	520	1.3	2.0	43.04	65	60	59	11		60	1.140	.781	7.810	43.961
2	525	1.3	2.0	50.84	65	61	59	11		60	1.140	.781	7.810	56.771
2	530	1.2	1.8	58.66	66	63	59	11		58	1.095	.750	7.504	58.561
3	535	1.2	1.8	66.15	66	63	60	11		57	1.095	.750	7.504	66.085
3	605	1.0	1.5	73.65	66	63	60	9		57	1.000	.685	6.850	73.589
4	645	1.0	1.5	80.51	66	64	60	9		57	1.000	.685	6.850	80.439
4	650	1.0	1.5	87.35	66	64	60	9		56	1.000	.685	6.850	87.289
5	655	1.2	1.8	94.22	66	65	61	10		56	1.095	.750	7.504	94.139
3	675	1.2	1.8	101.71	65	66	61	10		57	1.095	.750	7.504	101.643
6	655	1.0	1.5	109.23	65	66	62	9		58	1.000	.685	6.850	109.147
6	705	1.0	1.5	116.06	66	67	62	9		58	1.000	.685	6.850	116.087
7	715	1.0	1.5	122.92	66	67	63	9		57	1.000	.685	6.850	122.847
7	725	1.0	1.5	129.77	66	68	63	9		57	1.000	.685	6.850	129.697
8	735	1.0	1.5	136.63	66	68	63	10		58	1.000	.685	6.850	136.547
8	745	1.0	1.5	143.44	66	69	63	10		55	1.000	.685	6.850	143.397
9	765	1.1	1.7	150.32	66	69	64	10		57	1.049	.718	7.184	150.247
9	805	1.0	1.5	157.51	65	69	64	10		55	1.000	.685	6.850	157.433
10	815	1.0	1.5	166.31	66	69	64	10		61	1.000	.685	6.850	164.283
10	825	1.0	1.5	172.42	66	70	64	10		57	1.000	.685	6.850	171.153
11	835	1.1	1.7	179.23	67	71	65	10		57	1.049	.718	7.184	177.983
11	845	1.1	1.7	185.88	67	70	65	10		59	1.049	.718	7.184	185.167
12	855	1.1	1.7	192.12	69	71	66	10		62	1.049	.718	7.184	192.351
12	905	1.1	1.7	198.55	71	72	66	10		62	1.049	.718	7.184	199.535
915	—	—	—	206.777	—	—	—	—		—	—	—	—	Nick

## **Isokinetic Sampling Field Data Sheet**

**Project Number**

M 232604

Date:

6/27/23

### Test Number

## Client:

PCC

### Test Location

9 903 Inlets with Operators

Plants

LPC Milwaukee, OR

**Test Method:**

0061

Page Number

## **Isokinetic Sampling Field Data Sheet**

Project Number: M 232604  
Client: PCL  
Plant: LPC F - 1.1 w/w %

Date: 6-30-2023 Test Number:  
Test Location: 9903 InterSouth Operator:  
Test Method: 0061 Page Number:

2  
MTD Test Tech: NCC  
1 of 2

## **Isokinetic Sampling Field Data Sheet**

Project Number:

MZ32604

Date:

6-30-2023

### Test Number

三

Client:

80

### Test Location

### 3. Inlet Suction Operator

Plant-

1-PLC - MILWAAKEE

#### Test Method:

0061

Page Number

M-10

Test Tech: *Nce*

**Isokinetic Sampling Cover Sheet**

Client:	PEL Structural Inc.	Pitot Tube Cp:	
Facility:	Large Parts Campus Milwaukee OR	Probe Length (Feet):	3
Test Location:	BH9203 Outlet North	Probe Liner Material:	6Inss
Project #:	M232604	Sample Plane:	Horiz. or Vert.
Test Method(s):	29	Port Length ("":)	4.0
Test Engineer:	VTV	Port Diameter ("":)	4.0
Test Technician:	CIR 1	Port Type:	Flange
Upstream Diameters:	7.5	Duct Shape:	Circ or Rect.
Downstream Diameters:	72.0	Diameter (Feet):	2.873
# of Ports Sampled:	2	Length (Feet):	—
# of Points per Port:	12	Width (Feet):	—
Source Condition:	Normal	Duct Area (Sq. Feet):	6.305
Diluent Model/SN:	—	Minutes per Point:	20
Mid Gas ID/concentration:	— /%CO <sub>2</sub> %O <sub>2</sub>	Total Traverse Points:	24
High Gas ID/concentration:	— /%CO <sub>2</sub> %O <sub>2</sub>	Test Length (Min.):	480
Moisture Balance ID:		Train Type:	Anderson

	VTV R# 1	R# 2	R#
Meter ID:	LM1	LM1	
Pitot ID:	961	961	
Filter ID:			
Filter Pre-Weight (g):			
Nozzle Diameter ("":)	0.215	0.215	
Meter Cal Factor (Y):	1.003	1.003	
Meter Orifice Setting (DH):	1.570	1.570	
Nozzle Kit ID:	6Inss 1	6Inss 6	
Individual Nozzle ID:	31	31	
Pre Pitot Leak Check:	0 @ 5 "H <sub>2</sub> O	0 @ 5 "H <sub>2</sub> O	@ "H <sub>2</sub> O
Post Pitot Leak Check:	0 @ 5 "H <sub>2</sub> O	0 @ 5 "H <sub>2</sub> O	@ "H <sub>2</sub> O
Pre Nozzle Leak Check:	0 @ 15 "Hg	0 @ 10 "Hg	@ "Hg
Post Nozzle Leak Check:	0 @ 15 "Hg	0 @ 15 "Hg	@ "Hg
Barometric Pressure, "Hg:	29.97	29.97	
Static Pressure, "H <sub>2</sub> O:	0.5	0.5	
CO <sub>2</sub> %:	0	0	
O <sub>2</sub> %:	11	21	

Comments:

North

## **Isokinetic Sampling Field Data Sheet**

Project Number: M232604  
Client: PLC Structural  
Plant: LPC Milwaukee D

Date: 06/27/2023 Test Number:  
Test Location: BH 9203 outlet N Operator:  
Test Method: 29 Page Number:

1  
VTU Test Tech. LIR 1  
1 of 2

Port-Point #	Time	(ΔP)	Orifice Setting (ΔH)	Meter Volume (Vm) ft³, Actual	Stack Temp, °F	Meter Temp Inlet, °F	Meter Temp Outlet, °F	Pump Vacuum, "Hg	Probe Temp. °F	Filter Temp. °F	Impinger Outlet Well Temp. °F	K-Calcs (Optional)		
												K=	x	Theoretical Meter Volume, (Vm) ft³, per point
												Square Root, ΔP	Meter Rate, Cubic Feet/ Min.	Theoretical Meter Volume, (Vm) ft³, total
1-1	5:15	0.83	1.70	Ub.ub8	65	58	58	0	260	260	45			
1	5:25	0.85	1.70	54.230	67	62	58	0	260	260	48			
2	5:35	0.87	1.80	62.130	66	65	59	0	260	260	41			
2	5:45	1.09	2.00	70.160	67	68	69	0	260	262	49			
3	5:55	1.10	2.00	78.150	66	70	61	0	260	260	49			
3	6:05	1.10	2.00	86.410	67	72	63	2	258	260	50			
4	6:15	1.10	2.20	95.710	67	73	64	2	260	260	51			
4	6:25	1.30	2.60	104.260	67	74	65	3	252	260	51			
5	6:35	1.20	2.40	113.530	67	75	66	3	260	260	52			
5	6:45	1.21	2.40	122.830	67	76	67	4	260	260	54			
6	6:55	1.20	2.40	132.330	68	77	68	4	260	260	57			
6	7:05	1.20	2.40	141.870	69	78	69	4	250	260	59			
7	7:15	1.20	2.40	151.420	69	80	72	5	260	260	61			
7	7:25	1.20	2.40	160.470	70	83	74	5	250	260	62			
8	7:35	1.20	2.50	169.790	70	84	77	5	260	260	59			
8	7:45	1.20	2.50	179.560	69	84	78	4	260	260	52			
9	7:55	1.10	2.20	188.830	69	83	77	3	260	260	51			
9	8:05	1.10	2.30	197.79	67	82	77	3	250	260	53			
10	8:15	1.00	2.00	206.75	69	82	76	3	260	260	53			
10	8:25	1.00	2.00	215.530	69	81	74	2	260	260	50			
11	8:35	0.88	1.80	223.680	69	82	76	2	260	260	53			
11	8:45	0.88	1.80	232.330	71	83	77	3	250	260	56			
12	8:55	0.87	1.80	240.470	71	85	79	3	260	260	58			
12	9:05	0.88	1.80	248.220	74	88	81	2	250	260	61			
12	9:15	0.89	1.80	255.431	75	88	82	3	260	260	64			

North

## **Isokinetic Sampling Field Data Sheet**

Project Number: M13260

Date: 06/27/23

### Test Number

## Client:

## PIC Structure

#### Test Location:

26/27/23

### **Operators:**

Plant:

1-PG MEL-100012 DR

#### **Test Method:**

79

1

---

Test Tech: *1 P 1*

of 7

**IMPINGER WEIGHT SHEET**

PLANT: PCC STRUCTURES Scale ID Number S10-35

UNIT NO: Baghouse 9203 Scale Calibration Check Date: 6-27-23

LOCATION: OUTLET NORTH Scale Calibration Check (see QS-6.05C for procedure)

must be within  $\pm 0.5\text{g}$  of certified mass

DATE: 6-27-23 250 grams 250.0

TEST NO: #1 500 grams 500.1

METHOD: M29 750 grams 750.1

WEIGHED/MEASURED BY: AT

	FINAL WEIGHT	INITIAL WEIGHT	IMPIINGER	IMPIINGER
Circle One:	MLS / GRAMS	MLS / GRAMS	GAIN	CONTENTS
IMPIINGER 1	704.6	752.6		0.1N HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>
IMPIINGER 2	819.5	767.4		0.1N HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>
IMPIINGER 3	659.7	648.5		EMPTY
IMPIINGER 4	761.5	762.3		KMNO <sub>4</sub>
IMPIINGER 5	707.9	706.2		KMNO <sub>4</sub>
IMPIINGER 6	859.6	814.4		SILICA
IMPIINGER 7				
IMPIINGER 8				

IMPINGERS      FINAL TOTAL      INITIAL TOTAL      TOTAL IMPINGER GAIN

SILICA      FINAL TOTAL      INITIAL TOTAL      TOTAL SILICA GAIN

North

## **Isokinetic Sampling Field Data Sheet**

Project Number: M232604  
Client: PCL Structural Inc  
Plant: Milwaukee QR

Date: 06/30/2023 Test Number:  
Test Location: BH 9293 out 1st N Operator:  
Test Method: M29 Page Number:

UTV Test Tech: CPR 1  
1 of 2

North

## **Isokinetic Sampling Field Data Sheet**

Project Number: M23260

Date: 01/30/2023

**Test Number**

7

Client:

## PIC Structures

Test

06/30/2023

**Test Number**

Test

Plant-

## PIC Structures

Test

H9203 outlet

Page Number

V&V

Test Tech: CIR 1

2 of 1

### IMPIINGER WEIGHT SHEET

PLANT: PCC STRUCTURALS  
 Scale ID Number 510-35  
 UNIT NO: AT SOUTH OUTLET BH 9203  
 Scale Calibration Check Date: 6-30-23  
 LOCATION: No RTT at SOUTH OUTLET  
 Scale Calibration Check (see QS-6.05C for procedure)  
 must be within  $\pm 0.5$ g of certified mass  
 DATE: 6-30-23  
 250 grams 250.0  
 TEST NO: #2  
 500 grams 500.1  
 METHOD: M29  
 750 grams 750.1  
 WEIGHED/MEASURED BY: ft

Circle One:	FINAL WEIGHT MLS / GRAMS	INITIAL WEIGHT MLS / GRAMS	IMPIINGER GAIN	IMPIINGER CONTENTS
IMPINGER 1	756.3	766.1		HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>
IMPINGER 2	806.0	765.6		HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>
IMPINGER 3	675.3	651.5		Empty
IMPINGER 4	706.8	702.1		Krnay
IMPINGER 5	792.7	780.8		Krnay
IMPINGER 6	866.2	842.7		Silica
IMPINGER 7				
IMPINGER 8				

IMPINGERS      FINAL TOTAL      INITIAL TOTAL      TOTAL IMPINGER GAIN

SILICA      FINAL TOTAL      INITIAL TOTAL      TOTAL SILICA GAIN

**Isokinetic Sampling Cover Sheet**

Client:	PCC Structural Inc.		Pitot Tube Cp:		
Facility:	Large Parts Campus Milwaukee		Probe Length (Feet):	3	
Test Location:	BH 9203 Outlet South		Probe Liner Material:	Glass	
Project #:	M232604		Sample Plane:	(Hori. or Vert.)	
Test Method(s):	29		Port Length (""):	4.0	
Test Engineer:	VTV		Port Diameter (""):	4.0	
Test Technician:	(JIR)		Port Type:	Flange	
Upstream Diameters:	7.5		Duct Shape:	Circ. or Rect.	
Downstream Diameters:	72.0		Diameter (Feet):	2.873	
# of Ports Sampled:	2		Length (Feet):	—	
# of Points per Port:	12		Width (Feet):	—	
Source Condition:	Normal		Duct Area (Sq. Feet):	6.305	
Diluent Model/SN:	—		Minutes per Point:	20	
Mid Gas ID/concentration:	—	/%CO <sub>2</sub>	%O <sub>2</sub>	Total Traverse Points:	24
High Gas ID/concentration:	—	/%CO <sub>2</sub>	%O <sub>2</sub>	Test Length (Min.):	480
Moisture Balance ID:			Train Type:	Anderson	

	R# 1	R# 2	R#
Meter ID:	CM3U	CM3U	
Pitot ID:	U137	4037	
Filter ID:			
Filter Pre-Weight (g):			
Nozzle Diameter (""):	0.200	0.200	
Meter Cal Factor (Y):	1.003	1.003	
Meter Orifice Setting (DH):	1.758	1.758	
Nozzle Kit ID:	TN8 Glass	TN8 Glass	
Individual Nozzle ID:	31	36	
Pre Pitot Leak Check:	0 @ 5 "H <sub>2</sub> O	0 @ 5 "H <sub>2</sub> O	@ "H <sub>2</sub> O
Post Pitot Leak Check:	0 @ 5 "H <sub>2</sub> O	0 @ 5 "H <sub>2</sub> O	@ "H <sub>2</sub> O
Pre Nozzle Leak Check:	0 @ 15 "Hg	0 @ 10 "Hg	@ "Hg
Post Nozzle Leak Check:	0 @ 15 "Hg	0 @ 15 "Hg	@ "Hg
Barometric Pressure, "Hg:	29.97	29.97	
Static Pressure, "H <sub>2</sub> O:	0.5	0.5	
CO <sub>2</sub> %:	0	0	
O <sub>2</sub> %:	21	21	

Comments:

South

## **Isokinetic Sampling Field Data Sheet**

Project Number: M23260 u  
Client: PLL Structural  
Plant: LPL Milwaukee, WI

Date: 06/27/2023  
Test Location: BH9203 outlet S  
Test Method: 29

Test Number: 1  
Operator: UTV T  
Page Number: 1

1  
UTV Test Tech: CIRI  
1 of 2

Port-Point #	Time	(ΔP)	Orifice Setting (ΔH)	Meter Volume (Vm) ft³, Actual	Stack Temp, °F	Meter Temp Inlet, °F	Meter Temp Outlet, °F	Pump Vacuum, "Hg	Probe Temp. °F	Filter Temp. °F	Impinger Outlet Well Temp. °F	Square Root, ΔP	K-Calc (Optional)		
													K=	x	Theoretical Meter Volume, (Vm) ft³, per point
													Meter Rate, Cubic Feet/ Min.	Theoretical Meter Volume, (Vm) ft³, total	
1-1	5:15	1.70	2.70	70.013	68	59	59	7	250	250	43	VTV			
1	5:25	1.20	1.90	78.740	69	62	59	8	250	250	52	49			
2	5:35	1.30	2.10	87.350	69	66	60	7	250	250	54				
2	5:45	1.20	2.00	95.520	68	69	61	5	250	250	56				
3	5:55	1.30	2.20	103.430	68	71	62	6	250	250	55				
3	6:05	1.30	2.20	112.270	69	73	64	6	250	250	56				
4	6:15	1.30	2.20	120.420	69	73	65	7	250	250	56				
4	6:25	1.30	2.20	128.610	71	74	66	7	250	250	58				
5	6:35	1.30	2.20	136.220	70	75	66	8	250	250	58				
5	6:45	1.30	2.20	144.430	70	74	67	8	250	250	59				
6	6:55	1.30	2.20	153.520	70	75	67	8	250	250	60				
6	7:05	1.20	2.00	161.550	71	76	68	7	250	250	60				
7	7:15	1.20	2.00	169.120	72	74	70	7	250	250	60				
7	7:25	1.20	2.00	177.750	73	80	72	7	250	250	60				
8	7:35	1.10	1.90	185.820	74	81	75	7	250	250	55				
8	7:45	1.20	2.00	193.840	72	79	74	6	250	250	51				
9	7:55	1.10	1.90	201.920	71	78	73	6	250	250	50				
9	8:05	1.10	1.90	209.680	71	78	72	5	250	250	49				
10	8:15	0.89	1.50	217.620	71	77	72	6	250	250	51				
10	8:25	0.89	1.50	224.220	71	77	71	5	250	250	52				
11	8:35	0.77	1.30	230.910	71	78	71	5	250	250	52				
11	8:45	0.75	1.30	237.460	71	79	73	5	250	250	53				
12	8:55	0.73	1.20	243.730	74	81	75	5	250	250	55				
12	9:05	0.72	1.20	250.970	76	84	78	5	250	250	56				
9:15	0.73	1.20	256.150	76	84	78	5	250	250	56					

South

## **Isokinetic Sampling Field Data Sheet**

Project Number: M232604 Date: 06/27/2023 Test Number: 1  
Client: PCL Structural Inc. Test Location: BH9203 outlet S Operator: VTV Test Tech: CISI  
Plant: LPL Milwaukee DR Test Method: 29 Page Number: 2 of 2

**IMPINGER WEIGHT SHEET**

PLANT: PCC STRUCTURALS Scale ID Number 510-35  
 UNIT NO: Baghouse 9203 Scale Calibration Check Date: 6-27-25  
 LOCATION: OUTLET SOUTH Scale Calibration Check (see QS-6.05C for procedure)  
 must be within  $\pm 0.5$ g of certified mass  
 DATE: 6-27-23 250 grams 250.0  
 TEST NO: #1 500 grams 500.1  
 METHOD: M29 750 grams 750.1  
 WEIGHED/MEASURED BY: bf

	FINAL WEIGHT	INITIAL WEIGHT	IMPIINGER	IMPIINGER
Circle One:	MLS / GRAMS	MLS / GRAMS	GAIN	CONTENTS
IMPIINGER 1	681.5	720.8		0.1N HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>
IMPIINGER 2	723.1	722.4		0.1N HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>
IMPIINGER 3	666.4	644.2		EMPTY
IMPIINGER 4	796.9	771.4		Krnnoy
IMPIINGER 5	698.4	684.6		Krnnoy
IMPIINGER 6	913.3	867.8		SILICA
IMPIINGER 7				
IMPIINGER 8				

IMPINGERS      FINAL TOTAL      INITIAL TOTAL      TOTAL IMPINGER GAIN

SILICA      FINAL TOTAL      INITIAL TOTAL      TOTAL SILICA GAIN

South

## **Isokinetic Sampling Field Data Sheet**

Project Number: M232604  
Client: PCL Structural I  
Plant: Milwaukee OR

Date: 06/30/2023 Test Number:  
Test Location: BH 9203 - 2nd flr Operator:  
Test Method: M29 S-2014 Page Number:

2  
UTV Test Tech: LTR 1  
1 of 2

South

## **Isokinetic Sampling Field Data Sheet**

Project Number: M23260

Date: 06/30/2023

Test Number:

2

Client

### PIC Structures Test Location:

B+97.03 D+1.27 S

## Operator<sup>+</sup>

Test Tech: L.T.B. 1

Plant-

Milwaukee DR

#### Test Method:

MZ9

Page Number:

VTU

Test Tech: LIA 1

2 of

### IMPIINGER WEIGHT SHEET

PLANT: PCL STRUCTURALS

Scale ID Number S10-35

UNIT NO: BH 9203

Scale Calibration Check Date: 6-30-23

LOCATION: ~~NORTH~~ SOUTH OUTLET

Scale Calibration Check (see QS-6.05C for procedure)  
must be within  $\pm 0.5$  g of certified mass

DATE: 6-30-23

250 grams 250.0

TEST NO: H 2

500 grams 500.1

METHOD: M29

750 grams 750.1

WEIGHED/MEASURED BY: PF

Circle One:	FINAL WEIGHT MLS / GRAMS	INITIAL WEIGHT MLS / GRAMS	IMPIINGER GAIN	IMPIINGER CONTENTS
IMPIINGER 1	728.9	766.0		HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>
IMPIINGER 2	821.6	777.7		HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub>
IMPIINGER 3	531.6	507.2		EMPTY
IMPIINGER 4	692.3	689.0		KMNO <sub>4</sub>
IMPIINGER 5	580.0	570.0		KMNO <sub>4</sub>
IMPIINGER 6	842.4	821.5		SILICON
IMPIINGER 7				
IMPIINGER 8				

**IMPIINGERS**

FINAL TOTAL    INITIAL TOTAL    TOTAL IMPINGER GAIN

**SILICA**

FINAL TOTAL    INITIAL TOTAL    TOTAL SILICA GAIN

**Isokinetic Sampling Cover Sheet**

<b>Client:</b>	PCC Structural, Inc.	<b>Pitot Tube Cp:</b>	0.840
<b>Facility:</b>	Large Parts Campus Milwaukee, WI	<b>Probe Length (Feet):</b>	6.0
<b>Test Location:</b>	9203 outlet South North	<b>Probe Liner Material:</b>	Glass
<b>Project #:</b>	M232604	<b>Sample Plane:</b>	Horizontal or Vert.
<b>Test Method(s):</b>	ST 0061	<b>Port Length ("":)</b>	4.0
<b>Test Engineer:</b>	MPS	<b>Port Diameter ("":)</b>	4.0
<b>Test Technician:</b>	CJR	<b>Port Type:</b>	Flange
<b>Upstream Diameters:</b>	7.5	<b>Duct Shape:</b>	Circ or Rect.
<b>Downstream Diameters:</b>	72.0	<b>Diameter (Feet):</b>	2.333
<b># of Ports Sampled:</b>	2	<b>Length (Feet):</b>	—
<b># of Points per Port:</b>	12	<b>Width (Feet):</b>	—
<b>Source Condition:</b>	Normal	<b>Duct Area (Sq. Feet):</b>	6.305
<b>Diluent Model/SN:</b>	—	<b>Minutes per Point:</b>	20 (10/readings)
<b>Mid Gas ID/concentration:</b>	— /%CO <sub>2</sub> — %O <sub>2</sub>	<b>Total Traverse Points:</b>	24
<b>High Gas ID/concentration:</b>	— /%CO <sub>2</sub> — %O <sub>2</sub>	<b>Test Length (Min.):</b>	450
<b>Moisture Balance ID:</b>		<b>Train Type:</b>	Anderson

	R# 1	R# 2	R#
<b>Meter ID:</b>	CM 36	CM 36-CM 14	
<b>Pitot ID:</b>	1037	1037	
<b>Filter ID:</b>	—	—	
<b>Filter Pre-Weight (g):</b>	—	—	
<b>Nozzle Diameter ("":)</b>	.207	.207 .214	
<b>Meter Cal Factor (Y):</b>	1.001	1.001 1.001	
<b>Meter Orifice Setting (DH):</b>	1.945	1.945 1.646	
<b>Nozzle Kit ID:</b>	Glass	Glass	
<b>Individual Nozzle ID:</b>			
<b>Pre Pitot Leak Check:</b>	0 @ 5 "H <sub>2</sub> O	0 @ 5 "H <sub>2</sub> O	@ "H <sub>2</sub> O
<b>Post Pitot Leak Check:</b>	0 @ 5 "H <sub>2</sub> O	0 @ 5 "H <sub>2</sub> O	@ "H <sub>2</sub> O
<b>Pre Nozzle Leak Check:</b>	0 @ 15 "Hg	0 @ 15 "Hg	@ "Hg
<b>Post Nozzle Leak Check:</b>	0 @ 15 "Hg	0 @ 10 "Hg	@ "Hg
<b>Barometric Pressure, "Hg:</b>	29.97	29.97	
<b>Static Pressure, "H<sub>2</sub>O:</b>	.5	.5	
<b>CO<sub>2</sub> %:</b>	—	—	
<b>O<sub>2</sub> %:</b>	—	—	

**Comments:**

## **Isokinetic Sampling Field Data Sheet**

Project Number: m23264  
Client: FCC  
Plant: LPC - Milwaukee OR

Date: 6-27-23 Test Number:  
Test Location: 9203 Octavia Street Operator:  
Test Method: 29 North Page Number:

MPS 1 Test Tech: CJRI  
1 of 2

## **Isokinetic Sampling Field Data Sheet**

Project Number: M23264  
Client: PCE  
Plant: LPC-Milwaukee, WI

Date: 6-27-23 Test Number:  
Test Location: G203 - West - South Operator:  
Test Method: 29 North Page Number:

1  
NRS Test Tech: CJA1  
2 of 2

## **Isokinetic Sampling Field Data Sheet**

Project Number: M232604  
Client: PCC Structural  
Plant: Large Parts Campus Facility

Date: 6-30-23 Test Number:  
Test Location: NW BH9203 Outlet Operator:  
Test Method: ON61 Page Number:

2  
MPS Test Tech: JTM1  
1 of 2

### **Isokinetic Sampling Field Data Sheet**

Project Number: M232604  
Client: PCC Structural  
Plant: Large Parts Campus Facility

Date: 6-30-23 Test Number: 2  
Test Location: DH9203 Outlet No 10 Operator: MPS Test Tech: JTM1  
Test Method: OD61 Page Number: 2 of 2

**Isokinetic Sampling Cover Sheet**

<b>Client:</b>	Pee Structural, Inc.	<b>Pitot Tube Cp:</b>	0.840
<b>Facility:</b>	Large Parts Camp Milwaukee, WI	<b>Probe Length (Feet):</b>	6.0
<b>Test Location:</b>	9203 Outlet - South	<b>Probe Liner Material:</b>	Glass
<b>Project #:</b>	M232604	<b>Sample Plane:</b>	(Hrztl) or Vert.
<b>Test Method(s):</b>	0061	<b>Port Length ("):</b>	4.0
<b>Test Engineer:</b>	MPS	<b>Port Diameter ("):</b>	4.0
<b>Test Technician:</b>	CJRI	<b>Port Type:</b>	Flange
<b>Upstream Diameters:</b>	7.5	<b>Duct Shape:</b>	(Circ) or Rect.
<b>Downstream Diameters:</b>	72.0	<b>Diameter (Feet):</b>	2.833
<b># of Ports Sampled:</b>	2	<b>Length (Feet):</b>	—
<b># of Points per Port:</b>	12	<b>Width (Feet):</b>	—
<b>Source Condition:</b>	Normal	<b>Duct Area (Sq. Feet):</b>	6.305
<b>Diluent Model/SN:</b>	—	<b>Minutes per Point:</b>	20 (1st reading)
<b>Mid Gas ID/concentration:</b>	— /%CO <sub>2</sub> — %O <sub>2</sub>	<b>Total Traverse Points:</b>	24
<b>High Gas ID/concentration:</b>	— /%CO <sub>2</sub> — %O <sub>2</sub>	<b>Test Length (Min.):</b>	480
<b>Moisture Balance ID:</b>		<b>Train Type:</b>	Face Plate

R# 1

R# 2

R#

<b>Meter ID:</b>	CM22	CM22 CM40	
<b>Pitot ID:</b>	835	835	
<b>Filter ID:</b>	—	—	
<b>Filter Pre-Weight (g):</b>	—	—	
<b>Nozzle Diameter ("):</b>	.999 .210	.210.199	
<b>Meter Cal Factor (Y):</b>	+.889 .999	.999 .989	
<b>Meter Orifice Setting (DH):</b>	1.889	+.889 1.774	
<b>Nozzle Kit ID:</b>	Glass	Glass	
<b>Individual Nozzle ID:</b>	835		
<b>Pre Pitot Leak Check:</b>	0 @ 5 "H <sub>2</sub> O	0 @ 5 "H <sub>2</sub> O	@ "H <sub>2</sub> O
<b>Post Pitot Leak Check:</b>	0 @ 5 "H <sub>2</sub> O	0 @ 5 "H <sub>2</sub> O	@ "H <sub>2</sub> O
<b>Pre Nozzle Leak Check:</b>	0 @ 15 "Hg	0 @ 15 "Hg	@ "Hg
<b>Post Nozzle Leak Check:</b>	0 @ 15 "Hg	0 @ 10 "Hg	@ "Hg
<b>Barometric Pressure, "Hg:</b>	29.97	29.97	
<b>Static Pressure, "H<sub>2</sub>O:</b>	.5	.5	
<b>CO<sub>2</sub> %:</b>	—	—	
<b>O<sub>2</sub> %:</b>	—	—	

**Comments:**

## **Isokinetic Sampling Field Data Sheet**

Project Number: m23264  
Client: PCC  
Plant: LPC Milwaukee, WI

Date: 6-27-23  
Test Location: 9203 0-Block - Smith  
Test Method: OGL

Test Number: 1  
Operator: MRS Test Tech: GIB  
Page Number: 1 of 2

## **Isokinetic Sampling Field Data Sheet**

Project Number: m23264  
Client: PCC  
Plant: LFC - Milwaukee, WI

Date: 6-27-23 Test Number:  
Test Location: 9203 0.4th - South Operator:  
Test Method: 0061 Page Number:

MPS Test Tech: CJR  
2 of 2

### **Isokinetic Sampling Field Data Sheet**

Project Number: M232604  
Client: PCC Structural  
Plant: Large Parts Campus Facility

Date: 6-30-23 Test Number:  
Test Location: BH9203 outlet South Operator:  
Test Method: 0061 Page Number:

2  
MPS Test Tech: JTM  
1 of 2

## **Isokinetic Sampling Field Data Sheet**

Project Number: M232604  
Client: PCL Structural  
Plant: Large Parts Campus Facility

Date: 6-30-23  
Test Location: BH9203 Outlet South  
Test Method: 0061

Test Number: 2  
Operator: MPS Test Tech: JTA  
Page Number: 2 of 2

## **Appendix G - Calibration Data**

## **Procedures for Isokinetic Calibration**

### **Nozzles**

The nozzles are measured according to Method 5, Section 10.1

### **Dry Gas Meters**

The test meters are calibrated according to Method 5, Section 10.3 and 16.1. and "Procedures for Calibrating and Using Dry Gas Volume Meters as Calibration Standards" by P.R. Westlin and R.T. Shigehara, March 10, 1978.

### **Analytical Balance**

The accuracy of the analytical balance is checked with Class S, Stainless Steel Type 303 weights manufactured by F. Hopken and Son, Jersey City, New Jersey.

### **Temperature Sensing Devices**


The potentiometer and thermocouples are calibrated utilizing a NIST traceable millivolt source.

### **Pitot Tubes**

The "S" type pitot tubes utilized during this test program are manufactured according to the specification described and illustrated in the *Code of Federal Regulations*, Title 40, Part 60, Appendix A, Methods 1 and 2. The pitot tubes comply with the alignment specifications in Method 2, Section 10.1; and the pitot tube assemblies are in compliance with specifications in the same section.

These pitot tubes will have a wind tunnel calibrated CP calibrated as referenced to a standard type pitot.

## Dry Gas Meter/Control Module Calibration Diagram



Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM43	Date:	June 21, 2023
Standard Meter No.	16541852	Calibrated By:	MJD
Standard Meter (Y)	1.00440	Barometric Pressure:	29.42

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		21.956	79.225	76	76	78					
Initial		16.480	73.660	76	75	75					
Difference	1   0.20	5.476	5.565	76	76	77	76	21	13	0.988	1.727
Final		28.004	85.368	77	79	79					
Initial		22.067	79.343	76	78	78					
Difference	2   0.50	5.937	6.025	77	79	79	79	15	2	0.992	1.839
Final		34.604	92.082	77	80	80					
Initial		28.123	85.488	77	79	79					
Difference	3   0.70	6.481	6.594	77	80	80	80	13	36	0.990	1.768
Final		40.139	97.695	78	81	81					
Initial		34.788	92.256	77	80	80					
Difference	4   0.90	5.351	5.439	78	81	81	81	10	12	0.991	1.876
Final		45.492	103.110	78	82	82					
Initial		40.256	97.816	78	81	81					
Difference	5   1.20	5.236	5.294	78	82	82	82	8	32	0.997	1.829
Final		16.417	73.603	76	75	75					
Initial		10.579	67.764	76	74	74					
Difference	6   2.00	5.838	5.839	76	75	75	75	7	20	0.996	1.821
<u>Average</u>											
<b>0.992</b>											
<b>1.810</b>											

<b><i>Stack Temperature Sensor Calibration</i></b>			
Temperature ID :	100769	Name :	MJD
Ambient Temperature, °F :	79.5	Date :	June 21, 2023

<b><i>Temperature Calibrator</i></b>			
Model # :	CL23A	Certification Date:	May 2, 2023
Serial # :	T-285688	Expiration Date:	May 1, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b><i>Reference Source Temperature (° F)</i></b>	<b><i>Test Thermometer Temperature (° F)</i></b>	<b><i>Temperature Difference %</i></b>
0	0	0.0
250	249	0.1
600	600	0.0
1200	1198	0.1

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM43	Date:	July 17, 2023
Standard Meter No.	18654530	Calibrated By:	FB
Standard Meter (Y)	0.99520	Barometric Pressure:	29.23

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		71.056	90.828	79	77	77					
Initial		64.984	84.814	78	76	76					
Difference	1   0.20	6.072	6.014	79	77	77		77	23	47	1.001   1.825
Final		78.680	97.588	80	76	76					
Initial		72.065	90.937	79	75	75					
Difference	2   0.50	6.615	6.651	80	76	76		76	16	43	0.981   1.910
Final		84.966	104.940	81	76	76					
Initial		78.618	98.620	80	76	76					
Difference	3   0.70	6.348	6.320	81	76	76		76	13	3	0.990   1.774
Final		90.695	110.717	81	77	77					
Initial		85.013	105.184	81	76	76					
Difference	4   0.90	5.682	5.533	81	77	77		77	10	22	1.011   1.798
Final		91.756	111.836	81	76	76					
Initial		85.123	105.236	81	76	76					
Difference	5   1.20	6.633	6.600	81	76	76		76	9	59	0.988   1.633
Final		64.827	84.734	78	75	75					
Initial		58.833	78.740	77	75	75					
Difference	6   2.00	5.994	5.994	78	75	75		75	7	46	0.986   1.995

Average      **0.993**      **1.823**

<b>Stack Temperature Sensor Calibration</b>			
Temperature ID :	100769	Name :	FB
Ambient Temperature, °F :	78.6	Date :	July 17, 2023

<b>Temperature Calibrator</b>			
Model # :	CL23A	Certification Date:	May 18, 2023
Serial # :	T-285668	Expiration Date:	May 17, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b>Reference Source Temperature (°F)</b>	<b>Test Thermometer Temperature (°F)</b>	<b>Temperature Difference %</b>
0	0	0.0
250	249	0.1
600	600	0.0
1200	1198	0.1

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Ref. Temp., °F + 460

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM7	Date:	June 16, 2023
Standard Meter No.	18654530	Calibrated By:	FB
Standard Meter (Y)	0.99520	Barometric Pressure:	29.25

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		34.801	13.013	68	71	70					
Initial		28.891	7.009	67	69	69					
Difference	1   0.20	5.910	6.004	68	70	70	70	21	23	0.983	1.512
Final		41.680	20.015	68	74	72					
Initial		35.080	13.295	68	71	70					
Difference	2   0.50	6.600	6.720	68	73	71	72	15	3	0.983	1.499
Final		49.250	27.752	68	74	73					
Initial		43.571	21.945	68	74	72					
Difference	3   0.70	5.679	5.807	68	74	73	73	11	30	0.981	1.650
Final		65.535	44.155	68	74	74					
Initial		59.670	38.275	68	75	73					
Difference	4   0.90	5.865	5.880	68	75	74	74	10	0	1.002	1.502
Final		71.835	50.755	68	72	71					
Initial		65.926	44.744	68	73	73					
Difference	5   1.20	5.909	6.011	68	73	72	72	8	55	0.983	1.574
Final		28.609	106.730	68	71	68					
Initial		22.333	100.485	68	69	68					
Difference	6   2.00	6.276	6.245	68	70	68	69	7	3	0.997	1.462
<u>Average</u>											<b>0.988      1.533</b>

<b>Stack Temperature Sensor Calibration</b>			
Temperature ID :	100769	Name :	FB
Ambient Temperature, °F :	71.7	Date :	6/16/2023

<b>Temperature Calibrator</b>			
Model #:	CL23A	Certification Date:	May 18, 2022
Serial #:	T-285668	Expiration Date:	May 18, 2023

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b>Reference Source Temperature (° F)</b>	<b>Test Thermometer Temperature (° F)</b>	<b>Temperature Difference %</b>
0	2	0.2
250	248	0.2
600	599	0.1
1200	1203	0.3

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Ref. Temp., °F + 460

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM7	Date:	July 17, 2023
Standard Meter No.	18654530	Calibrated By:	FB
Standard Meter (Y)	0.99520	Barometric Pressure:	29.20

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		96.297	61.442	72	78	77					
Initial		90.556	55.692	72	78	76					
Difference	1   0.20	5.741	5.750	72	78	77	77	21	28	1.003	1.623
Final		103.178	68.465	72	79	77					
Initial		96.306	61.550	72	78	77					
Difference	2   0.50	6.872	6.915	72	79	77	78	15	56	0.998	1.558
Final		110.150	75.775	72	79	78					
Initial		103.334	68.826	73	78	77					
Difference	3   0.70	6.816	6.949	73	79	78	78	14	5	0.985	1.735
Final		117.696	83.278	72	80	78					
Initial		110.305	75.836	72	79	78					
Difference	4   0.90	7.391	7.442	72	80	78	79	12	38	0.999	1.522
Final		126.184	89.997	73	81	78					
Initial		118.742	82.425	73	80	78					
Difference	5   1.20	7.442	7.572	73	81	78	79	10	56	0.987	1.503
Final		90.554	55.597	72	80	72					
Initial		85.060	50.016	72	80	76					
Difference	6   2.00	5.494	5.581	72	80	74	77	6	44	0.984	1.744
<u>Average</u>											<b>0.993</b>
<u>1.614</u>											

<b><i>Stack Temperature Sensor Calibration</i></b>			
Temperature ID :	100679	Name :	FB
Ambient Temperature, °F :	78.1	Date :	July 17, 2023

<b><i>Temperature Calibrator</i></b>			
Model # :	CL23A	Certification Date:	May 18, 2023
Serial # :	T-285668	Expiration Date:	May 17, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b><i>Reference Source Temperature (° F)</i></b>	<b><i>Test Thermometer Temperature (° F)</i></b>	<b><i>Temperature Difference %</i></b>
0	0	0.0
250	249	0.1
600	597	0.3
1200	1200	0.0

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM8	Date:	June 6, 2023
Standard Meter No.	18654530	Calibrated By:	JVC
Standard Meter (Y)	0.99520	Barometric Pressure:	29.01

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		55.874	21.887	78	81	81					
Initial		50.824	16.785	77	80	80					
Difference	1   0.20	5.050	5.102	78	81	81	81	20	30	0.990	1.953
Final		61.234	27.301	79	83	83					
Initial		55.973	21.967	79	82	82					
Difference	2   0.50	5.261	5.334	79	83	83	83	13	15	0.987	1.883
Final		66.894	33.097	80	83	83					
Initial		61.306	27.409	80	83	83					
Difference	3   0.70	5.588	5.688	80	83	83	83	11	55	0.981	1.895
Final		72.970	39.272	79	82	82					
Initial		66.962	33.147	79	83	83					
Difference	4   0.90	6.008	6.125	79	83	83	83	11	0	0.980	1.791
Final		78.547	44.950	79	82	82					
Initial		73.047	39.364	79	81	81					
Difference	5   1.20	5.500	5.586	79	82	82	82	8	45	0.981	1.807
Final		50.732	16.687	80	81	81					
Initial		45.478	11.410	80	80	80					
Difference	6   2.00	5.254	5.277	80	81	81	81	6	30	0.987	1.831

Average      **0.984**      **1.860**

<b><i>Stack Temperature Sensor Calibration</i></b>			
Temperature ID :	100655	Name :	JVC
Ambient Temperature, °F :	80	Date :	June 6, 2023

<b><i>Temperature Calibrator</i></b>			
Model # :	CL23A	Certification Date:	May 2, 2023
Serial # :	T-314718	Expiration Date:	May 1, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b><i>Reference Source Temperature (° F)</i></b>	<b><i>Test Thermometer Temperature (° F)</i></b>	<b><i>Temperature Difference %</i></b>
0	2	0.4
250	251	0.1
600	598	0.2
1200	1196	0.2

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Meter Box Calibration

Dry Gas Meter Calibration Data

Dry Gas Meter No.	<u>CM8</u>	Date:	<u>July 10, 2023</u>
Standard Meter No.	<u>18654530</u>	Calibrated By:	<u>JVC</u>
Standard Meter (Y)	<u>0.99520</u>	Barometric Pressure:	<u>29.21</u>

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		49.841	95.391	78	82	82					
Initial		43.737	89.383	77	80	80					
Difference	1   0.20	6.104	6.008	78	81	81		81	22	33	1.017   1.605
Final		58.469	103.922	79	84	84					
Initial		50.018	95.565	79	82	82					
Difference	2   0.50	8.451	8.357	79	83	83		83	20	25	1.013   1.719
Final		65.925	11.283	80	85	85					
Initial		58.624	4.086	80	85	85					
Difference	3   0.70	7.301	7.197	80	85	85		85	14	57	1.017   1.729
Final		87.708	32.731	76	81	81					
Initial		79.603	24.749	76	80	80					
Difference	4   0.90	8.105	7.982	76	81	81		81	15	2	1.017   1.812
Final		95.741	40.664	76	82	82					
Initial		87.962	32.987	76	81	81					
Difference	5   1.20	7.779	7.677	76	82	82		82	12	24	1.016   1.781
Final		43.503	89.144	77	79	79					
Initial		35.589	81.389	77	78	78					
Difference	6   2.00	7.914	7.755	77	79	79		79	10	5	1.013   1.914
<u>Average</u>											
<b>1.015      1.760</b>											

<b><i>Stack Temperature Sensor Calibration</i></b>			
Temperature ID :	100655	Name :	JVC
Ambient Temperature, °F :	29.16	Date :	July 11, 2023

<b><i>Temperature Calibrator</i></b>			
Model # :	CL23A	Certification Date:	May 2, 2023
Serial # :	T-265668	Expiration Date:	May 1, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b><i>Reference Source Temperature (°F)</i></b>	<b><i>Test Thermometer Temperature (°F)</i></b>	<b><i>Temperature Difference %</i></b>
0	2	0.4
250	253	0.4
600	599	0.1
1200	1198	0.1

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM39	Date:	June 20, 2023
Standard Meter No.	366118	Calibrated By:	MJD
Standard Meter (Y)	1.00880	Barometric Pressure:	29.34

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		129.045	49.356	75	72	72					
Initial		123.488	43.842	72	72	72					
Difference	1   0.20	5.557	5.514	74	72	72		72	23	0	1.013   1.956
Final		135.858	56.152	77	73	73					
Initial		129.273	49.680	76	73	73					
Difference	2   0.50	6.585	6.472	77	73	73		73	17	18	1.018   1.988
Final		143.360	63.648	80	75	75					
Initial		136.015	56.412	78	74	74					
Difference	3   0.70	7.345	7.236	79	75	75		75	15	29	1.014   1.804
Final		164.014	84.406	80	75	75					
Initial		156.702	77.106	81	77	77					
Difference	4   0.90	7.312	7.300	81	76	76		76	13	57	1.000   1.905
Final		156.513	76.815	81	75	75					
Initial		151.033	71.428	80	74	74					
Difference	5   1.20	5.480	5.387	81	75	75		75	9	2	1.012   1.901
Final		123.244	43.788	72	71	71					
Initial		118.172	38.704	71	71	71					
Difference	6   2.00	5.072	5.084	72	71	71		71	6	43	1.000   1.991
<u>Average</u>											
1.010   1.924											

<b><i>Stack Temperature Sensor Calibration</i></b>			
Temperature ID :	100769	Name :	MJD
Ambient Temperature, °F :	76.6	Date :	June 20, 2023

1.0088

<b><i>Temperature Calibrator</i></b>			
Model #:	CL23A	Certification Date:	November 8, 2022
Serial #:	T-314718	Expiration Date:	November 8, 2023

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b><i>Reference Source Temperature (°F)</i></b>	<b><i>Test Thermometer Temperature (°F)</i></b>	<b><i>Temperature Difference %</i></b>
0	-1	
250	248	
600	587	1.2
1200	1199	

Ref. Temp., °F + 460

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM39	Date:	July 11, 2023
Standard Meter No.	18654530	Calibrated By:	JVC
Standard Meter (Y)	0.99520	Barometric Pressure:	29.17

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		40.732	88.488	75	77	77					
Initial		34.618	82.375	74	74	74					
Difference	1   0.20	6.114	6.113	75	76	76		76	24	52	0.997   1.946
Final		49.347	97.150	75	78	78					
Initial		40.904	88.657	75	77	77					
Difference	2   0.50	8.443	8.493	75	78	78		78	21	6	0.993   1.834
Final		70.827	18.739	76	79	79					
Initial		56.968	4.818	76	78	78					
Difference	3   0.70	13.859	13.921	76	79	79		79	29	50	0.994   1.908
Final		79.340	27.323	76	79	79					
Initial		70.974	18.904	76	78	78					
Difference	4   0.90	8.366	8.419	76	79	79		79	15	46	0.991   1.880
Final		89.705	37.732	76	80	80					
Initial		79.551	27.524	77	81	81					
Difference	5   1.20	10.154	10.208	77	81	81		81	16	34	0.994   1.876
Final		34.527	82.276	75	74	74					
Initial		27.291	75.156	74	74	74					
Difference	6   2.00	7.236	7.120	75	74	74		74	9	25	1.005   1.998
<u>Average</u>											
<b>0.996</b>											
<b>1.907</b>											

<b><i>Stack Temperature Sensor Calibration</i></b>			
Temperature ID :	100769	Name :	JVC
Ambient Temperature, °F :	81.6	Date :	July 11, 2023

<b><i>Temperature Calibrator</i></b>			
Model # :	CL23A	Certification Date:	May 2, 2023
Serial # :	T-265688	Expiration Date:	May 1, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b><i>Reference Source Temperature (°F)</i></b>	<b><i>Test Thermometer Temperature (°F)</i></b>	<b><i>Temperature Difference %</i></b>
0	1	0.2
250	246	0.6
600	598	0.2
1200	1201	0.1

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM11	Date:	June 20, 2023
Standard Meter No.	16541852	Calibrated By:	MJD
Standard Meter (Y)	1.00440	Barometric Pressure:	29.34

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		56.634	91.752	72	74	75					
Initial		51.219	86.234	73	74	75					
Difference	1   0.20	5.415	5.518	73	74	75	75	22	17	0.989	1.934
Final		64.294	99.546	74	75	75					
Initial		56.936	92.059	72	74	75					
Difference	2   0.50	7.358	7.487	73	75	75	75	18	38	0.989	1.833
Final		69.534	104.873	73	76	76					
Initial		64.495	99.745	74	75	75					
Difference	3   0.70	5.039	5.128	74	76	76	76	10	42	0.989	1.805
Final		76.751	12.198	74	78	77					
Initial		69.798	5.157	73	76	76					
Difference	4   0.90	6.953	7.041	74	77	77	77	13	1	0.996	1.800
Final		83.213	18.748	74	78	78					
Initial		77.051	12.571	74	78	77					
Difference	5   1.20	6.162	6.177	74	78	78	78	10	0	1.006	1.804
Final		51.056	86.057	71	72	74					
Initial		45.119	80.082	72	73	73					
Difference	6   2.00	5.937	5.975	72	73	74	73	7	30	0.996	1.821
<u>Average</u>											
<b>0.994</b>											
<b>1.833</b>											

<b><i>Stack Temperature Sensor Calibration</i></b>			
Temperature ID :	100769	Name :	MJD
Ambient Temperature, °F :	76.6	Date :	June 20, 2023

<b><i>Temperature Calibrator</i></b>			
Model # :	CL23A	Certification Date:	November 8, 2022
Serial # :	T-314718	Expiration Date:	November 8, 2023

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b><i>Reference Source Temperature (° F)</i></b>	<b><i>Test Thermometer Temperature (° F)</i></b>	<b><i>Temperature Difference %</i></b>
0	0.1	0.0
250	250	0.0
600	599	0.1
1200	1200	0.0

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM 11	Date:	August 15, 2023
Standard Meter No.	366118	Calibrated By:	DS
Standard Meter (Y)	0.99950	Barometric Pressure:	29.23

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		35.615	57.427	71	74	74					
Initial		30.125	51.938	71	73	73					
Difference	1   0.20	5.490	5.489	71	74	74		74	20	54	1.004
Final		41.822	63.603	71	75	75					
Initial		35.917	57.731	71	74	74					
Difference	2   0.50	5.905	5.872	71	75	75		75	14	30	1.010
Final		47.999	69.491	72	76	75					
Initial		42.755	64.136	72	75	75					
Difference	3   0.70	5.244	5.355	72	76	75		75	11	37	0.983
Final		53.800	75.578								
Initial		48.315	70.100	72	75	75					
Difference	4   0.90	5.485	5.478	72	75	75		75	10	20	1.004
Final		81.074	59.452	71	77	76					
Initial		75.899	54.178	72	76	76					
Difference	5   1.20	5.175	5.274	72	77	76		76	8	21	0.987
Final		29.681	51.504	71	73	73					
Initial		24.554	46.414	71	73	73					
Difference	6   2.00	5.127	5.090	71	73	73		73	6	25	1.005
<u>Average</u>											<b>0.999</b>
<u>1.806</u>											

<b><i>Stack Temperature Sensor Calibration</i></b>			
Temperature ID :	100769	Name :	DS
Ambient Temperature, °F :	73.1	Date :	August 15, 2023

<b><i>Temperature Calibrator</i></b>			
Model # :	CL23A	Certification Date:	August 15, 2023
Serial # :	T-314718	Expiration Date:	August 14, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b><i>Reference Source Temperature (°F)</i></b>	<b><i>Test Thermometer Temperature (°F)</i></b>	<b><i>Temperature Difference %</i></b>
0	0	0.0
250	249	0.1
600	597	0.3
1200	1196	0.2

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM 10	Date:	June 19, 2023
Standard Meter No.	16541852	Calibrated By:	BJE
Standard Meter (Y)	1.00440	Barometric Pressure:	29.24

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		44.766	37.633	78	81	81					
Initial		39.401	32.153	76	80	80					
Difference	1   0.20	5.365	5.480	77	81	81	81	21	45	0.989	1.894
Final		51.435	44.467	77	83	83					
Initial		45.244	38.123	77	82	82					
Difference	2   0.50	6.191	6.344	77	83	83	83	15	44	0.989	1.854
Final		58.487	51.642	78	83	83					
Initial		51.792	44.797	77	83	83					
Difference	3   0.70	6.695	6.845	78	83	83	83	14	33	0.991	1.900
Final		66.565	59.869	78	84	84					
Initial		58.924	52.072	78	83	83					
Difference	4   0.90	7.641	7.797	78	84	84	84	14	25	0.992	1.843
Final		73.515	66.956	78	84	84					
Initial		66.884	60.187	78	84	84					
Difference	5   1.20	6.631	6.769	78	84	84	84	10	42	0.992	1.795
Final		39.124	31.872	77	80	80					
Initial		31.143	23.761	77	80	80					
Difference	6   2.00	7.981	8.111	77	80	80	80	10	0	0.989	1.811
<u>Average</u>											
<b>0.990</b>											
<b>1.849</b>											

<b><i>Stack Temperature Sensor Calibration</i></b>			
Temperature ID :	100769	Name :	BJE
Ambient Temperature, °F :	81.3	Date :	July 22, 2023

<b><i>Temperature Calibrator</i></b>			
Model # :	CL23A	Certification Date:	June 5, 2023
Serial # :	T-285668	Expiration Date:	June 4, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b><i>Reference Source Temperature (° F)</i></b>	<b><i>Test Thermometer Temperature (° F)</i></b>	<b><i>Temperature Difference %</i></b>
0	-1	0.2
250	248	0.3
600	596	0.4
1200	1196	0.2

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM10	Date:	July 15, 2023
Standard Meter No.	18654530	Calibrated By:	JVC
Standard Meter (Y)	0.99520	Barometric Pressure:	29.10

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		61.495	82.545	76	82	82					
Initial		54.359	75.357	78	80	80					
Difference	1   0.20	7.136	7.188	77	81	81		81	24	10	0.995 1.351
Final		70.193	91.335	77	85	85					
Initial		61.705	82.745	77	82	82					
Difference	2   0.50	8.488	8.590	77	84	84		84	19	27	0.994 1.540
Final		79.256	100.533	77	84	84					
Initial		70.375	91.527	77	83	83					
Difference	3   0.70	8.881	9.006	77	84	84		84	17	20	0.992 1.564
Final		87.748	9.158	77	85	85					
Initial		79.488	0.765	77	84	84					
Difference	4   0.90	8.260	8.393	77	85	85		85	14	25	0.991 1.605
Final		95.456	16.984	77	85	85					
Initial		88.089	9.499	77	85	85					
Difference	5   1.20	7.367	7.485	77	85	85		85	10	59	0.991 1.560
Final		54.251	75.247	76	79	79					
Initial		45.240	66.238	77	79	79					
Difference	6   2.00	9.011	9.009	77	79	79		79	10	43	0.995 1.670
<u>Average</u>											
<b>0.993      1.548</b>											

<b><i>Stack Temperature Sensor Calibration</i></b>			
Temperature ID :	100769	Name :	JVC
Ambient Temperature, °F :	29.11	Date :	July 15, 2023

<b><i>Temperature Calibrator</i></b>			
Model # :	CL23A	Certification Date:	May 2, 2023
Serial # :	T-285688	Expiration Date:	May 1, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b><i>Reference Source Temperature (°F)</i></b>	<b><i>Test Thermometer Temperature (°F)</i></b>	<b><i>Temperature Difference %</i></b>
0	0	0.0
250	251	0.1
600	596	0.4
1200	1206	0.4

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM1	Date:	June 13, 2023
Standard Meter No.	16541852	Calibrated By:	JKM
Standard Meter (Y)	1.00440	Barometric Pressure:	28.96

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		36.438	109.068	66	71	70					
Initial		30.632	103.166	65	71	69					
Difference	1   0.20	5.806	5.902	66	71	70	70	20	59	0.996	1.483
Final		45.771	118.501	66	71	70					
Initial		36.552	109.189	66	71	70					
Difference	2   0.50	9.219	9.312	66	71	70	71	22	12	1.002	1.649
Final		54.535	127.309	67	72	70					
Initial		46.012	118.741	66	71	70					
Difference	3   0.70	8.523	8.568	67	72	70	71	16	30	1.005	1.494
Final		63.063	135.849	67	73	71					
Initial		54.788	127.564	67	72	70					
Difference	4   0.90	8.275	8.285	67	73	71	72	14	12	1.009	1.510
Final		70.832	143.664	67	74	71					
Initial		63.516	136.388	67	72	71					
Difference	5   1.20	7.316	7.276	67	73	71	72	11	35	1.016	1.712
Final		10.124	82.798	66	71	71					
Initial		4.584	77.151	66	71	70					
Difference	6   2.00	5.540	5.647	66	71	71	71	6	31	0.989	1.573
<u>Average</u>											
1.003      1.570											

<b><i>Stack Temperature Sensor Calibration</i></b>			
Temperature ID :	100769 CM1	Name :	JKM
Ambient Temperature, °F :	69.6	Date :	June 13, 2023

<b><i>Temperature Calibrator</i></b>			
Model # :	CL23A	Certification Date:	May 2, 2023
Serial # :	T-285668	Expiration Date:	May 2, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b><i>Reference Source Temperature (° F)</i></b>	<b><i>Test Thermometer Temperature (° F)</i></b>	<b><i>Temperature Difference %</i></b>
0	0	0.0
250	249	0.1
600	598	0.2
1200	1200	0.0

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM34	Date:	June 21, 2023
Standard Meter No.		Calibrated By:	MJD
Standard Meter (Y)	1.00880	Barometric Pressure:	29.42

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		91.552	42.169	72	80	72					
Initial		86.255	36.871	73	81	76					
Difference	1   0.20	5.297	5.298	73	81	74		77	20	25	1.017   1.669
Final		98.512	49.276	72	81	79					
Initial		92.011	42.645	72	80	77					
Difference	2   0.50	6.501	6.631	72	81	78		79	16	21	1.001   1.766
Final		105.074	56.090	72	84	80					
Initial		98.856	49.638	72	81	79					
Difference	3   0.70	6.218	6.452	72	83	80		81	13	24	0.987   1.809
Final		12.175	63.249	72	86	81					
Initial		5.240	56.151	72	84	80					
Difference	4   0.90	6.935	7.098	72	85	81		83	12	45	1.003   1.688
Final		18.048	69.248	73	87	82					
Initial		12.369	63.440	72	86	81					
Difference	5   1.20	5.679	5.808	73	87	82		84	9	9	1.005   1.728
Final		86.092	36.619	73	81	76					
Initial		80.260	30.740	73	77	75					
Difference	6   2.00	5.832	5.879	73	79	76		77	7	33	1.004   1.886
<u>Average</u>											
1.003   1.758											

<b><i>Stack Temperature Sensor Calibration</i></b>			
Temperature ID :	CM34	Name :	MJD
Ambient Temperature, °F :	78.2	Date :	June 21, 2023

<b><i>Temperature Calibrator</i></b>			
Model # :	CL23A	Certification Date:	May 18, 2023
Serial # :	T-285668	Expiration Date:	May 17, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b><i>Reference Source Temperature (° F)</i></b>	<b><i>Test Thermometer Temperature (° F)</i></b>	<b><i>Temperature Difference %</i></b>
0	-1	0.2
250	248	0.3
600	597	0.3
1200	1199	0.1

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM 34	Date:	August 15, 2023
Standard Meter No.	16541852	Calibrated By:	BJE
Standard Meter (Y)	1.00440	Barometric Pressure:	29.23

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		17.639	40.482	71	75	74					
Initial		12.555	35.372	71	74	74					
Difference	1   0.20	5.084	5.110	71	75	74	74	20	24	1.005	1.836
Final		23.530	46.279	71	75	75					
Initial		17.924	40.672	71	75	75					
Difference	2   0.50	5.606	5.607	71	75	75	75	14	29	1.011	1.900
Final		29.215	52.208								
Initial		23.919	46.899	72	76	75					
Difference	3   0.70	5.296	5.309	72	76	75	76	11	34	1.007	1.906
Final		34.078	57.879	72	77	76					
Initial		28.768	52.555	72	76	76					
Difference	4   0.90	5.310	5.324	72	77	76	76	10	15	1.007	1.912
Final		40.435	63.208	72	77	77					
Initial		35.284	58.065	72	74	74					
Difference	5   1.20	5.151	5.143	72	76	76	76	9	1	1.010	2.099
Final		12.308	35.117	71	75	74					
Initial		7.381	30.171	71	74	74					
Difference	6   2.00	4.927	4.946	71	75	74	74	6	24	1.002	1.924
<u>Average</u>											
<b>1.007</b>											
<b>1.930</b>											

<b><i>Stack Temperature Sensor Calibration</i></b>			
Temperature ID :	100769	Name :	BJE
Ambient Temperature, °F :	73.1	Date :	August 15, 2023

<b><i>Temperature Calibrator</i></b>			
Model # :	CL23A	Certification Date:	August 15, 2023
Serial # :	T-314718	Expiration Date:	August 14, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b><i>Reference Source Temperature (° F)</i></b>	<b><i>Test Thermometer Temperature (° F)</i></b>	<b><i>Temperature Difference %</i></b>
0	-1	0.2
250	248	0.3
600	597	0.3
1200	1199	0.1

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM36	Date:	June 6, 2023
Standard Meter No.	18654530	Calibrated By:	FB
Standard Meter (Y)	0.99520	Barometric Pressure:	29.28

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		127.513	71.923	76	75	75					
Initial		121.210	65.602	75	74	74					
Difference	1   0.20	6.303	6.321	76	75	75		75	24	6	0.990   1.723
Final		88.022	143.740	79	75	75					
Initial		81.448	137.180	78	75	75					
Difference	2   0.50	6.574	6.560	79	75	75		75	16	26	0.990   1.860
Final		151.239	95.610	79	75	75					
Initial		144.047	88.421	78	75	75					
Difference	3   0.70	7.192	7.189	79	75	75		75	15	10	0.987   1.853
Final		158.933	103.183	79	75	75					
Initial		151.690	95.954	78	75	75					
Difference	4   0.90	7.243	7.229	79	75	75		75	13	25	0.988   1.839
Final		166.496	110.304	80	75	75					
Initial		159.690	103.527	80	75	75					
Difference	5   1.20	6.806	6.777	80	75	75		75	11	21	0.987   1.998
Final		121.084	65.404	74	75	75					
Initial		115.045	59.455	74	74	74					
Difference	6   2.00	6.039	5.949	74	75	75		75	7	19	1.006   1.720
<u>Average</u>											
<b>0.991</b>											
<b>1.832</b>											

<b>Stack Temperature Sensor Calibration</b>			
Temperature ID :	100769	Name :	FB
Ambient Temperature, °F :	76.9	Date :	6/6/2023

<b>Temperature Calibrator</b>			
Model # :	CL23A	Certification Date:	May 2, 2023
Serial # :	T-285668	Expiration Date:	May 1, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b>Reference Source Temperature (° F)</b>	<b>Test Thermometer Temperature (° F)</b>	<b>Temperature Difference %</b>
0	0	0.0
250	248	0.2
600	598	0.2
1200	1202	0.2

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Ref. Temp., °F + 460

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM36	Date:	July 25, 2023
Standard Meter No.	18654530	Calibrated By:	FB
Standard Meter (Y)	0.99520	Barometric Pressure:	29.39

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		47.073	62.404	80	76	76					
Initial		41.417	56.825	79	76	76					
Difference	1   0.20	5.656	5.579	80	76	76		76	22	31	1.002   1.884
Final		53.665	68.335	81	76	76					
Initial		47.146	61.838	81	76	76					
Difference	2   0.50	6.519	6.497	81	76	76		76	15	46	0.988   1.748
Final		60.325	74.927	82	77	77					
Initial		53.746	68.525	82	77	77					
Difference	3   0.70	6.579	6.402	82	77	77		77	14	11	1.012   1.948
Final		67.255	81.385	83	77	77					
Initial		61.172	75.432	83	77	77					
Difference	4   0.90	6.083	5.953	83	77	77		77	11	39	1.003   1.984
Final		73.350	87.197	84	77	77					
Initial		67.348	81.388	84	77	77					
Difference	5   1.20	6.002	5.809	84	77	77		77	9	29	1.012   1.807
Final		41.327	56.842	79	76	76					
Initial		34.802	50.528	77	76	76					
Difference	6   2.00	6.525	6.314	78	76	76		76	8	29	1.020   1.998
<u>Average</u>											<b>1.006   1.895</b>

<b>Stack Temperature Sensor Calibration</b>			
Temperature ID :	100769	Name :	FB
Ambient Temperature, °F :	80.4	Date :	July 25, 2023

<b>Temperature Calibrator</b>			
Model #:	CL23A	Certification Date:	November 19, 2022
Serial #:	T-314718	Expiration Date:	November 19, 2023

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b>Reference Source Temperature (° F)</b>	<b>Test Thermometer Temperature (° F)</b>	<b>Temperature Difference %</b>
0	0	0.0
250	249	0.1
600	598	0.2
1200	1200	0.0

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Ref. Temp., °F + 460

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM14	Date:	June 21, 2023
Standard Meter No.	18654530	Calibrated By:	FB
Standard Meter (Y)	0.99520	Barometric Pressure:	29.41

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		126.550	71.373	76	82	81					
Initial		120.024	64.888	75	82	79					
Difference	1   0.20	6.526	6.485	76	82	80	81	23	31	1.011	1.505
Final		134.342	78.794	76	83	82					
Initial		126.788	71.322	76	82	81					
Difference	2   0.50	7.554	7.472	76	83	82	82	17	24	1.016	1.538
Final		141.132	86.470	76	84	82					
Initial		134.650	79.910	76	83	81					
Difference	3   0.70	6.482	6.560	76	84	82	83	13	30	0.994	1.758
Final		148.346	101.290	76	85	83					
Initial		141.240	94.083	77	84	83					
Difference	4   0.90	7.106	7.207	77	85	83	84	12	30	0.992	1.612
Final		155.782	101.290	76	84	84					
Initial		148.654	94.083	77	85	83					
Difference	5   1.20	7.128	7.207	77	85	84	84	11	4	0.995	1.674
Final		119.974	64.612	75	82	79					
Initial		113.905	58.535	75	81	79					
Difference	6   2.00	6.069	6.077	75	82	79	80	7	32	0.999	1.785
<u>Average</u>											<b>1.001      1.646</b>

<b>Stack Temperature Sensor Calibration</b>			
Temperature ID :	CM14	Name :	FB
Ambient Temperature, °F :	79	Date :	6/21/2023

<b>Temperature Calibrator</b>			
Model # :	CL23A	Certification Date:	May 2, 2023
Serial # :	T-285668	Expiration Date:	May 1, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b>Reference Source Temperature (° F)</b>	<b>Test Thermometer Temperature (° F)</b>	<b>Temperature Difference %</b>
0	-1	0.2
250	249	0.1
600	599	0.1
1200	1201	0.1

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Ref. Temp., °F + 460

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM 14	Date:	August 11, 2023
Standard Meter No.	16541852	Calibrated By:	BJE
Standard Meter (Y)	1.00440	Barometric Pressure:	29.10

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		69.420	45.989	78	83	82					
Initial		63.824	40.242	78	82	82					
Difference	1   0.20	5.596	5.747	78	83	82	82	20	24	0.985	1.539
Final		75.665	52.349	78	83	83					
Initial		69.665	46.222	78	83	83					
Difference	2   0.50	6.000	6.127	78	83	83	83	13	57	0.991	1.563
Final		81.421	58.203	78	84	83					
Initial		75.909	52.579	78	83	83					
Difference	3   0.70	5.512	5.624	78	84	83	83	11	4	0.992	1.631
Final		87.303	64.182	78	84	83					
Initial		81.583	58.365	78	84	83					
Difference	4   0.90	5.720	5.817	78	84	83	84	10	9	0.995	1.638
Final		93.405	70.368	78	83	83					
Initial		87.589	64.476	78	83	83					
Difference	5   1.20	5.816	5.892	78	83	83	83	9	10	0.998	1.724
Final		63.648	40.044	78	82	81					
Initial		57.701	34.053	78	81	81					
Difference	6   2.00	5.947	5.991	78	82	81	81	7	25	0.998	1.805
<u>Average</u>											<b>0.993</b>
<u>1.650</u>											

<b>Stack Temperature Sensor Calibration</b>			
Temperature ID :	100769	Name :	BJE
Ambient Temperature, °F :	79.3	Date :	August 11, 2023

<b>Temperature Calibrator</b>			
Model # :	CL23A	Certification Date:	August 11, 2023
Serial # :	T-314718	Expiration Date:	August 10, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b>Reference Source Temperature (°F)</b>	<b>Test Thermometer Temperature (°F)</b>	<b>Temperature Difference %</b>
0	2	0.4
250	255	0.7
600	607	0.7
1200	1214	0.8

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Ref. Temp., °F + 460

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM22	Date:	June 16, 2023
Standard Meter No.	366118	Calibrated By:	MJD
Standard Meter (Y)	1.00880	Barometric Pressure:	29.21

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		5.514	31.140	68	79	80					
Initial		0.362	25.781	68	76	77					
Difference	1   0.20	5.152	5.359	68	78	79		78	21	23	0.988   1.913
Final		11.274	37.089	68	80	80					
Initial		5.645	31.271	68	79	80					
Difference	2   0.50	5.629	5.818	68	80	80		80	14	30	0.997   1.836
Final		17.226	43.119	68	78	80					
Initial		11.516	37.339	68	80	80					
Difference	3   0.70	5.710	5.780	68	79	80		80	12	30	1.017   1.858
Final		23.075	49.246	68	80	80					
Initial		17.629	43.634	68	79	80					
Difference	4   0.90	5.446	5.612	68	80	80		80	10	33	0.998   1.869
Final		28.741	55.039	68	80	80					
Initial		23.265	49.429	68	80	80					
Difference	5   1.20	5.476	5.610	68	80	80		80	9	23	1.004   1.949
Final		98.789	24.175	68	74	76					
Initial		93.638	18.882	68	74	75					
Difference	6   2.00	5.151	5.293	68	74	76		75	6	44	0.989   1.909
<u>Average</u>											
<b>0.999</b>											
<b>1.889</b>											

<b>Stack Temperature Sensor Calibration</b>			
Temperature ID :	100769	Name :	MJD
Ambient Temperature, °F :	71.4	Date :	6/16/2023

<b>Temperature Calibrator</b>			
Model #:	CL23A	Certification Date:	May 18, 2022
Serial #:	T-285668	Expiration Date:	May 18, 2023

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b>Reference Source Temperature (° F)</b>	<b>Test Thermometer Temperature (° F)</b>	<b>Temperature Difference %</b>
0	-1	
250	249	
600	599	
1200	1203	

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Ref. Temp., °F + 460

Meter Box Calibration

**Dry Gas Meter Calibration Data**

Dry Gas Meter No.	CM22	Date:	July 14, 2023
Standard Meter No.	18654530	Calibrated By:	JVC
Standard Meter (Y)	0.99520	Barometric Pressure:	29.13

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		55.743	99.904	79	89	92					
Initial		49.969	94.031	78	86	88					
Difference	1   0.20	5.774	5.873	79	88	90	89	23	54	0.997	1.999
Final		63.794	8.138	79	89	93					
Initial		55.840	0.005	79	91	93					
Difference	2   0.50	7.954	8.133	79	90	93	92	20	13	0.995	1.879
Final		71.770	16.316	80	88	91					
Initial		63.928	8.272	79	92	93					
Difference	3   0.70	7.842	8.044	80	90	92	91	17	2	0.989	1.926
Final		80.199	24.988	81	91	92					
Initial		71.971	16.528	80	91	92					
Difference	4   0.90	8.228	8.460	81	91	92	92	15	42	0.985	1.917
Final		22.136	68.042	77	87	86					
Initial		14.621	60.331	77	84	85					
Difference	5   1.20	7.515	7.711	77	86	86	86	12	23	0.982	1.902
Final		49.832	93.892	78	80	86					
Initial		40.212	84.134	77	81	82					
Difference	6   2.00	9.620	9.758	78	81	84	82	12	32	0.985	1.997
<u>Average</u>											<b>0.989</b>
<u>1.937</u>											

<i>Temperature ID :</i>	100769	<i>Name :</i>	JVC
<i>Ambient Temperature, °F :</i>	80	<i>Date :</i>	July 15, 2023

<b>Temperature Calibrator</b>			
<i>Model # :</i>	CL23A	<i>Certification Date:</i>	May 2, 2023
<i>Serial # :</i>	T-285688	<i>Expiration Date:</i>	May 1, 2024

*Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)*

<b>Reference Source Temperature (°F)</b>	<b>Test Thermometer Temperature (°F)</b>	<b>Temperature Difference %</b>
0	2	0.4
250	253	0.4
600	598	0.2
1200	1196	0.2

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Ref. Temp., °F + 460

Meter Box Calibration

Dry Gas Meter Calibration Data

Dry Gas Meter No. CM40  
 Standard Meter No.   
 Standard Meter (Y) 1.00880

Date: June 20, 2023  
 Calibrated By: MJD  
 Barometric Pressure: 29.30

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		72.871	59.554	72	74	74					
Initial		67.887	54.489	74	72	72					
Difference	1   0.20	4.984	5.065	73	73	73		73	20	20	0.992 1.895
Final		80.039	66.891	72	74	74					
Initial		73.189	59.886	72	74	74					
Difference	2   0.50	6.850	7.005	72	74	74		74	16	42	0.989 1.683
Final		86.296	73.276	72	74	74					
Initial		80.436	67.283	72	75	75					
Difference	3   0.70	5.860	5.993	72	75	75		75	12	35	0.989 1.826
Final		92.013	79.122	72	75	75					
Initial		86.592	73.585	72	75	75					
Difference	4   0.90	5.421	5.537	72	75	75		75	10	6	0.991 1.766
Final		98.520	85.746	73	74	74					
Initial		92.584	79.690	72	75	75					
Difference	5   1.20	5.936	6.056	73	75	75		75	9	46	0.990 1.841
Final		43.635	29.693	74	75	75					
Initial		36.544	22.420	72	74	74					
Difference	6   2.00	7.091	7.273	73	75	75		75	8	30	0.981 1.632

Average 0.989 1.774

<b>Stack Temperature Sensor Calibration</b>			
Temperature ID :	100.769	Name :	FB
Ambient Temperature, °F :	76.9	Date :	6/6/2023

<b>Temperature Calibrator</b>			
Model # :	CL23A	Certification Date:	June 5, 2023
Serial # :	T-285668	Expiration Date:	June 4, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b>Reference Source Temperature (° F)</b>	<b>Test Thermometer Temperature (° F)</b>	<b>Temperature Difference %</b>
0	0	0.0
250	250	0.0
600	599	0.1
1200	1204	0.4

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Ref. Temp., °F + 460

Meter Box Calibration

Dry Gas Meter Calibration Data

Dry Gas Meter No.	CM40	Date:	July 14, 2023
Standard Meter No.	366118	Calibrated By:	DEJ
Standard Meter (Y)	1.00880	Barometric Pressure:	29.15

Run Number	Orifice Setting in H <sub>2</sub> O Chg (H)	Standard Meter Gas Volume vr	Dry Gas Meter Gas Volume vd	Standard Meter Temp. F° tr	Dry Gas Meter Inlet Temp. F° tdi	Dry Gas Meter Outlet Temp. F° tdo	Dry Gas Meter Avg. Temp. F° td	Time Min	Time Sec	Y	Chg (H)
Final		39.235	91.582	74	74	74					
Initial		33.060	85.286	75	73	73					
Difference	1   0.20	6.175	6.296	75	74	74	74	22	18	0.987	1.500
Final		46.321	98.781	76	74	74					
Initial		39.571	91.919	74	74	74					
Difference	2   0.50	6.750	6.862	75	74	74	74	16	5	0.989	1.634
Final		62.771	15.525	78	75	75					
Initial		56.460	9.103	78	75	75					
Difference	3   0.70	6.311	6.422	78	75	75	75	12	54	0.984	1.699
Final		71.124	24.026	79	76	76					
Initial		63.073	15.835	78	75	75					
Difference	4   0.90	8.051	8.191	79	76	76	76	14	54	0.984	1.793
Final		78.535	31.538	76	77	77					
Initial		71.377	24.280	76	77	77					
Difference	5   1.20	7.158	7.258	76	77	77	77	11	13	0.994	1.693
Final		24.406	76.077	75	73	73					
Initial		18.008	69.775	74	72	72					
Difference	6   2.00	6.398	6.302	75	73	73	73	8	10	1.015	1.877

Average      **0.992**      **1.699**

<b>Stack Temperature Sensor Calibration</b>			
Temperature ID :	100769	Name :	DEJ
Ambient Temperature, °F :	78.5	Date :	July 14, 2023

<b>Temperature Calibrator</b>			
Model # :	CL23A	Certification Date:	May 2, 2023
Serial # :	T-285668	Expiration Date:	May 1, 2024

Primary Standards Directly Traceable National Institute of Standards and Technology (NIST)

<b>Reference Source Temperature (°F)</b>	<b>Test Thermometer Temperature (°F)</b>	<b>Temperature Difference %</b>
0	1	0.2
250	253	0.4
600	602	0.2
1200	1205	0.3

$$\frac{(\text{Ref. Temp., } ^\circ\text{F} + 460) - (\text{Test Therm. Temp., } ^\circ\text{F} + 460)}{\text{Ref. Temp., } ^\circ\text{F} + 460} * 100 \leq 1.5 \%$$

Ref. Temp., °F + 460

## S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 288


Date: 6/14/2023

Inspectors Name: JLH

Type of Probe: (mark one)

M2	M5	M17
	X	

Probe Length: 4 ft.



Pitot tube assembly level? X yes \_\_\_\_\_ no

Pitot tube openings damaged? \_\_\_\_\_ yes (explain below) X no

$$a_1 = 0^\circ (\leq 10^\circ) \quad a_2 = 0^\circ (\leq 10^\circ) \quad z = A \sin \gamma = 0.000 \text{ (in.)}; (\leq 0.125 \text{ in.})$$

$$b_1 = 0^\circ (\leq 5^\circ) \quad b_2 = 0^\circ (\leq 5^\circ) \quad w = A \sin \theta = 0.00000 \text{ (in.)}; (\leq 0.03125 \text{ in.})$$

$$\gamma = 0^\circ \quad \theta = 0^\circ \quad A = 0.955 \text{ (in.)} \quad P_A = 0.487 \text{ (in.)}, P_B = 0.487 \text{ (in.)}, D_t = 0.375 \text{ (in.)}$$

Calibration required? \_\_\_\_\_ yes X no

## S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 289


Date: 7/20/2023

Inspectors Name: JAM

Type of Probe: (mark one)

M2	M5	M17
	X	

Probe Length: 4 ft.



Pitot tube assembly level? X yes \_\_\_\_\_ no

Pitot tube openings damaged? \_\_\_\_\_ yes (explain below) X no

$$a_1 = 1.5^\circ (\leq 10^\circ) \quad a_2 = 1.5^\circ (\leq 10^\circ) \quad z = A \sin \gamma = 0.008 \text{ (in.)}; (\leq 0.125 \text{ in.})$$

$$b_1 = 1.5^\circ (\leq 5^\circ) \quad b_2 = 0.5^\circ (\leq 5^\circ) \quad w = A \sin \theta = 0.00818 \text{ (in.)}; (\leq 0.03125 \text{ in.})$$

$$\gamma = 0.5^\circ \quad \theta = 0.5^\circ \quad A = 0.937 \text{ (in.)} \quad P_A = 0.469 \text{ (in.)}, P_B = 0.469 \text{ (in.)}, D_t = 0.375 \text{ (in.)}$$

Calibration required? \_\_\_\_\_ yes X no


S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 288

Date: 7/14/2023

Inspectors Name: EC

Type of Probe: (circle one) M2 M5 M17 Probe Length: 4 ft.



Pitot tube assembly level?  yes  no

Pitot tube openings damaged?  yes (explain below)  no

$$a_1 = \underline{2}^\circ (<10^\circ), \quad a_2 = \underline{6}^\circ (<10^\circ) \quad z = A \sin g = \underline{0.067} \text{ (in.)}; (<0.125 \text{ in.})$$

$$b_1 = \underline{0.5}^\circ (<5^\circ), \quad b_2 = \underline{1}^\circ (<5^\circ) \quad w = A \sin q = \underline{0.017} \text{ (in.)}; (<0.03125 \text{ in.})$$

$$\gamma = \underline{4}^\circ, \quad \theta = \underline{1}^\circ, \quad A = \underline{0.960} \text{ (in.)} \quad P_A = \underline{0.480} \text{ (in.)}, P_B = \underline{0.480} \text{ (in.)}, D_t = \underline{0.375} \text{ (in.)}$$

Calibration required?  yes  no

## S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 288


Date: 6/14/2023

Inspectors Name: JLH

Type of Probe: (mark one)

M2	M5	M17
X		

Probe Length: 4 ft.



Pitot tube assembly level? X yes    no

Pitot tube openings damaged?    yes (explain below) X no

$$a_1 = 0^\circ (\leq 10^\circ) \quad a_2 = 0^\circ (\leq 10^\circ) \quad z = A \sin \gamma = 0.000 \text{ (in.)}; (\leq 0.125 \text{ in.})$$

$$b_1 = 0^\circ (\leq 5^\circ) \quad b_2 = 0^\circ (\leq 5^\circ) \quad w = A \sin \theta = 0.00000 \text{ (in.)}; (\leq 0.03125 \text{ in.})$$

$$\gamma = 0^\circ \quad \theta = 0^\circ \quad A = 0.955 \text{ (in.)} \quad P_A = 0.487 \text{ (in.)}, P_B = 0.487 \text{ (in.)}, D_t = 0.375 \text{ (in.)}$$

Calibration required?    yes X no

## S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 291


Date: 6/14/2023

Inspectors Name: JLH

Type of Probe: (mark one)

M2	M5	M17
	X	

Probe Length: 4 ft.



Pitot tube assembly level? X yes    no

Pitot tube openings damaged?    yes (explain below) X no

$$a_1 = 0^\circ (\leq 10^\circ) \quad a_2 = 0^\circ (\leq 10^\circ) \quad z = A \sin \gamma = 0.000 \text{ (in.)}; (\leq 0.125 \text{ in.})$$

$$b_1 = 0^\circ (\leq 5^\circ) \quad b_2 = 0^\circ (\leq 5^\circ) \quad w = A \sin \theta = 0.00000 \text{ (in.)}; (\leq 0.03125 \text{ in.})$$

$$\gamma = 0^\circ \quad \theta = 0^\circ \quad A = 0.955 \text{ (in.)} \quad P_A = 0.487 \text{ (in.)}, P_B = 0.487 \text{ (in.)}, D_t = 0.375 \text{ (in.)}$$

Calibration required?    yes X no

## S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 291


Date: 7/7/2023

Inspectors Name: VJR

Type of Probe: (mark one)

M2	M5	M17
	X	

Probe Length: 4 ft.



Pitot tube assembly level? X yes    no

Pitot tube openings damaged?    yes (explain below) X no

$$a_1 = \underline{2}^\circ (\leq 10^\circ) \quad a_2 = \underline{1}^\circ (\leq 10^\circ) \quad z = A \sin \gamma = \underline{0.049} \text{ (in.)}; (\leq 0.125 \text{ in.})$$

$$b_1 = \underline{2}^\circ (\leq 5^\circ) \quad b_2 = \underline{2.5}^\circ (\leq 5^\circ) \quad w = A \sin \theta = \underline{0.00000} \text{ (in.)}; (\leq 0.03125 \text{ in.})$$

$$\gamma = \underline{3}^\circ \quad \theta = \underline{0}^\circ \quad A = \underline{0.940} \text{ (in.)} \quad P_A = \underline{0.470} \text{ (in.)}, P_B = \underline{0.470} \text{ (in.)}, D_t = \underline{0.375} \text{ (in.)}$$

Calibration required?    yes X no

## S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 290


Date: 6/14/2023

Inspectors Name: JLH

Type of Probe: (mark one)

M2	M5	M17
X		

Probe Length: 4 ft.



Pitot tube assembly level? X yes    no

Pitot tube openings damaged?    yes (explain below) X no

$$a_1 = \underline{0}^\circ (\leq 10^\circ) \quad a_2 = \underline{0}^\circ (\leq 10^\circ) \quad z = A \sin \gamma = \underline{0.000} \text{ (in.)}; (\leq 0.125 \text{ in.})$$

$$b_1 = \underline{0}^\circ (\leq 5^\circ) \quad b_2 = \underline{0}^\circ (\leq 5^\circ) \quad w = A \sin \theta = \underline{0.00000} \text{ (in.)}; (\leq 0.03125 \text{ in.})$$

$$\gamma = \underline{0}^\circ \quad \theta = \underline{0}^\circ \quad A = \underline{0.955} \text{ (in.)} \quad P_A = \underline{0.487} \text{ (in.)}, P_B = \underline{0.487} \text{ (in.)}, D_t = \underline{0.375} \text{ (in.)}$$

Calibration required?    yes X no


S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 290

Date: 7/13/2023

Inspectors Name: JTM

Type of Probe: (circle one) M2 **M5** M17 Probe Length: 4 ft.



Pitot tube assembly level?  yes  no

Pitot tube openings damaged?  yes (explain below)  no

$$a_1 = 5^\circ (< 10^\circ), \quad a_2 = 3^\circ (< 10^\circ) \quad z = A \sin g = 0.000 \text{ (in.)}; (< 0.125 \text{ in.})$$

$$b_1 = 0^\circ (< 5^\circ), \quad b_2 = 0^\circ (< 5^\circ) \quad w = A \sin q = 0.000 \text{ (in.)}; (< 0.03125 \text{ in.})$$

$$\gamma = 0^\circ, \theta = 0^\circ, A = 0.930 \text{ (in.)} \quad P_A = 0.465 \text{ (in.)}, P_B = 0.465 \text{ (in.)}, D_t = 0.375 \text{ (in.)}$$

Calibration required?  yes  no

## S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 316


Date: 6/13/2023

Inspectors Name: CST

Type of Probe: (circle one)

M2	M5	M17
X		

Probe Length: 4 ft.



Pitot tube assembly level? X yes \_\_\_\_\_ no

Pitot tube openings damaged? \_\_\_\_\_ yes (explain below) X no

$$a_1 = \underline{3.5}^\circ (\leq 10^\circ) \quad a_2 = \underline{0.5}^\circ (\leq 10^\circ) \quad z = A \sin \gamma = \underline{0.025} \text{ (in.)}; (\leq 0.125 \text{ in.})$$

$$b_1 = \underline{1.5}^\circ (\leq 5^\circ) \quad b_2 = \underline{1.5}^\circ (\leq 5^\circ) \quad w = A \sin \theta = \underline{0.02510} \text{ (in.)}; (\leq 0.03125 \text{ in.})$$

$$\gamma = \underline{1.5}^\circ \quad \theta = \underline{1.5}^\circ \quad A = \underline{0.959} \text{ (in.)} \quad P_A = \underline{0.480} \text{ (in.)}, P_B = \underline{0.480} \text{ (in.)}, D_t = \underline{0.375} \text{ (in.)}$$

Calibration required? \_\_\_\_\_ yes X no

## S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 316


Date: 7/19/2023

Inspectors Name: JAM

Type of Probe: (mark one)

M2	M5	M17
	X	

Probe Length: 4 ft.



Pitot tube assembly level? X yes \_\_\_\_\_ no

Pitot tube openings damaged? \_\_\_\_\_ yes (explain below) X no

$$a_1 = 3^\circ (\leq 10^\circ) \quad a_2 = 0.5^\circ (\leq 10^\circ) \quad z = A \sin \gamma = 0.033 \text{ (in.)}; (\leq 0.125 \text{ in.})$$

$$b_1 = 0.5^\circ (\leq 5^\circ) \quad b_2 = 1.5^\circ (\leq 5^\circ) \quad w = A \sin \theta = 0.00000 \text{ (in.)}; (\leq 0.03125 \text{ in.})$$

$$\gamma = 2^\circ \quad \theta = 0^\circ \quad A = 0.949 \text{ (in.)} \quad P_A = 0.475 \text{ (in.)}, P_B = 0.475 \text{ (in.)}, D_t = 0.375 \text{ (in.)}$$

Calibration required? \_\_\_\_\_ yes \_\_\_\_\_ no

## S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 312


Date: 5/31/2022

Inspectors Name: BWL

Type of Probe: (mark one)

M2	M5	M17
		<input checked="" type="checkbox"/>

Probe Length: 5 ft.



Pitot tube assembly level? X yes        no

Pitot tube openings damaged?        yes (explain below) X no

$$a_1 = \underline{3}^\circ (\leq 10^\circ) \quad a_2 = \underline{0}^\circ (\leq 10^\circ) \quad z = A \sin \gamma = \underline{0.049} \text{ (in.); } (\leq 0.125 \text{ in.})$$

$$b_1 = \underline{4}^\circ (\leq 5^\circ) \quad b_2 = \underline{3}^\circ (\leq 5^\circ) \quad w = A \sin \theta = \underline{0.00000} \text{ (in.); } (\leq 0.03125 \text{ in.})$$

$$\gamma = \underline{3}^\circ \quad \theta = \underline{0}^\circ \quad A = \underline{0.940} \text{ (in.)} \quad P_A = \underline{0.470} \text{ (in.), } P_B = \underline{0.470} \text{ (in.), } D_t = \underline{0.375} \text{ (in.)}$$

Calibration required?        yes X no

## S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 312


Date: 8/9/2023

Inspectors Name: JAM

Type of Probe: (mark one)

M2	M5	M17
	X	

Probe Length: 4 ft.



Pitot tube assembly level? X yes    no

Pitot tube openings damaged?    yes (explain below) X no

$$a_1 = \underline{3}^\circ (\leq 10^\circ) \quad a_2 = \underline{1.5}^\circ (\leq 10^\circ) \quad z = A \sin \gamma = \underline{0.025} \text{ (in.); } (\leq 0.125 \text{ in.})$$

$$b_1 = \underline{3}^\circ (\leq 5^\circ) \quad b_2 = \underline{1.5}^\circ (\leq 5^\circ) \quad w = A \sin \theta = \underline{0.00823} \text{ (in.); } (\leq 0.03125 \text{ in.})$$

$$\gamma = \underline{1.5}^\circ \quad \theta = \underline{0.5}^\circ \quad A = \underline{0.943} \text{ (in.)} \quad P_A = \underline{0.472} \text{ (in.), } P_B = \underline{0.472} \text{ (in.), } D_t = \underline{0.375} \text{ (in.)}$$

Calibration required?    yes X no

## S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 835


Date: 8/10/2022

Inspectors Name: JLH

Type of Probe: (circle one)

M2	M5	M17
X		

Probe Length: 3 ft.



Pitot tube assembly level? X yes    no

Pitot tube openings damaged?    yes (explain below) X no

$$a_1 = \underline{2}^\circ (\leq 10^\circ) \quad a_2 = \underline{5}^\circ (\leq 10^\circ) \quad z = A \sin \gamma = \underline{0.050} \text{ (in.); } (\leq 0.125 \text{ in.})$$

$$b_1 = \underline{1}^\circ (\leq 5^\circ) \quad b_2 = \underline{3}^\circ (\leq 5^\circ) \quad w = A \sin \theta = \underline{0.01651} \text{ (in.); } (\leq 0.03125 \text{ in.})$$

$$\gamma = \underline{3}^\circ \quad \theta = \underline{1}^\circ \quad A = \underline{0.946} \text{ (in.)} \quad P_A = \underline{0.473} \text{ (in.), } P_B = \underline{0.473} \text{ (in.), } D_t = \underline{0.375} \text{ (in.)}$$

Calibration required?    yes X no

## S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 4037


Date: 6/29/2022

Inspectors Name: TWM

Type of Probe: (circle one)

M2	M5	M17
X		

Probe Length: 8 ft.



Pitot tube assembly level? X yes    no

Pitot tube openings damaged?    yes (explain below) X no

$$a_1 = \underline{2}^\circ (\leq 10^\circ) \quad a_2 = \underline{4}^\circ (\leq 10^\circ) \quad z = A \sin \gamma = \underline{0.017} \text{ (in.); } (\leq 0.125 \text{ in.})$$

$$b_1 = \underline{1}^\circ (\leq 5^\circ) \quad b_2 = \underline{0}^\circ (\leq 5^\circ) \quad w = A \sin \theta = \underline{0.00000} \text{ (in.); } (\leq 0.03125 \text{ in.})$$

$$\gamma = \underline{1}^\circ \quad \theta = \underline{0}^\circ \quad A = \underline{0.956} \text{ (in.)} \quad P_A = \underline{0.478} \text{ (in.), } P_B = \underline{0.478} \text{ (in.), } D_t = \underline{0.375} \text{ (in.)}$$

Calibration required?    yes X no

## S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 4037


Date: 7/1/2021

Inspectors Name: AMS

Type of Probe: (circle one)

M2	M5	M17
X		

Probe Length: 8 ft.



Pitot tube assembly level? X yes    no

Pitot tube openings damaged?    yes (explain below) X no

$$a_1 = \underline{2}^\circ (\leq 10^\circ) \quad a_2 = \underline{4}^\circ (\leq 10^\circ) \quad z = A \sin \gamma = \underline{0.017} \text{ (in.)}; (\leq 0.125 \text{ in.})$$

$$b_1 = \underline{1}^\circ (\leq 5^\circ) \quad b_2 = \underline{0}^\circ (\leq 5^\circ) \quad w = A \sin \theta = \underline{0.00000} \text{ (in.)}; (\leq 0.03125 \text{ in.})$$

$$\gamma = \underline{1}^\circ \quad \theta = \underline{0}^\circ \quad A = \underline{0.956} \text{ (in.)} \quad P_A = \underline{0.478} \text{ (in.)}, P_B = \underline{0.478} \text{ (in.)}, D_t = \underline{0.375} \text{ (in.)}$$

Calibration required?    yes X no

## S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 1037


Date: 3/7/2023

Inspectors Name: JAM

Type of Probe: (circle one)

M2	M5	M17
	X	

Probe Length: 3 ft.



Pitot tube assembly level? X yes \_\_\_\_\_ no

Pitot tube openings damaged? \_\_\_\_\_ yes (explain below) X no

$$a_1 = 0.5^\circ (\leq 10^\circ) \quad a_2 = 3^\circ (\leq 10^\circ) \quad z = A \sin \gamma = 0.058 \text{ (in.)}; (\leq 0.125 \text{ in.})$$

$$b_1 = 2.5^\circ (\leq 5^\circ) \quad b_2 = 1.5^\circ (\leq 5^\circ) \quad w = A \sin \theta = 0.00000 \text{ (in.)}; (\leq 0.03125 \text{ in.})$$

$$\gamma = 3.5^\circ \quad \theta = 0^\circ \quad A = 0.947 \text{ (in.)} \quad P_A = 0.474 \text{ (in.)}, P_B = 0.474 \text{ (in.)}, D_t = 0.375 \text{ (in.)}$$

Calibration required? \_\_\_\_\_ yes X no

## S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 1037


Date: 8/9/2023

Inspectors Name: JAM

Type of Probe: (mark one)

M2	M5	M17
	X	

Probe Length: 3 ft.



Pitot tube assembly level? X yes \_\_\_\_\_ no

Pitot tube openings damaged? \_\_\_\_\_ yes (explain below) X no

$$a_1 = 1.5^\circ (\leq 10^\circ) \quad a_2 = 2.5^\circ (\leq 10^\circ) \quad z = A \sin \gamma = 0.066 \text{ (in.)}; (\leq 0.125 \text{ in.})$$

$$b_1 = 3.5^\circ (\leq 5^\circ) \quad b_2 = 3.5^\circ (\leq 5^\circ) \quad w = A \sin \theta = 0.00829 \text{ (in.)}; (\leq 0.03125 \text{ in.})$$

$$\gamma = 4^\circ \quad \theta = 0.5^\circ \quad A = 0.950 \text{ (in.)} \quad P_A = 0.475 \text{ (in.)}, P_B = 0.475 \text{ (in.)}, D_t = 0.375 \text{ (in.)}$$

Calibration required? \_\_\_\_\_ yes X no


S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 961

Date: 5/14/2021

Inspectors Name: JAM

Type of Probe: (circle one) M2  M5  M17 Probe Length: 10 ft.



Pitot tube assembly level?  yes  no

Pitot tube openings damaged?  yes (explain below)  no

$$a_1 = 1^\circ (< 10^\circ), \quad a_2 = 0.5^\circ (< 10^\circ) \quad z = A \sin g = 0.033 \text{ (in.)}; (< 0.125 \text{ in.})$$

$$b_1 = 1^\circ (< 5^\circ), \quad b_2 = 1.5^\circ (< 5^\circ) \quad w = A \sin q = 0.025 \text{ (in.)}; (< 0.03125 \text{ in.})$$

$$\gamma = 2^\circ, \quad \theta = 1.5^\circ, \quad A = 0.940 \text{ (in.)} \quad P_A = 0.470 \text{ (in.)}, \quad P_B = 0.470 \text{ (in.)}, \quad D_t = 0.375 \text{ (in.)}$$

Calibration required?  yes  no


S TYPE PITOT TUBE INSPECTION WORKSHEET

Pitot Tube No: 961

Date: 7/14/2023

Inspectors Name: JAM

Type of Probe: (circle one)  M2    M5    M17    Probe Length: 7 ft.



Pitot tube assembly level?  yes     no

Pitot tube openings damaged?  yes (explain below)     no

$$a_1 = \underline{1}^\circ (<10^\circ), \quad a_2 = \underline{1}^\circ (<10^\circ) \quad z = A \sin g = \underline{0.033} \text{ (in.)}; (<0.125 \text{ in.})$$

$$b_1 = \underline{1}^\circ (<5^\circ), \quad b_2 = \underline{1}^\circ (<5^\circ) \quad w = A \sin q = \underline{0.016} \text{ (in.)}; (<0.03125 \text{ in.})$$

$$\gamma = \underline{2}^\circ, \quad \theta = \underline{1}^\circ, \quad A = \underline{0.940} \text{ (in.)} \quad P_A = \underline{0.470} \text{ (in.)}, P_B = \underline{0.470} \text{ (in.)}, D_t = \underline{0.375} \text{ (in.)}$$

Calibration required?  yes     no


# Nozzle Calibration

Date: 1/27/2020

Nozzle ID No.: 888

Analyst: DPP

Material/Type: Glass



<u>0.200</u>	1
<u>0.199</u>	2
<u>0.199</u>	3
<u>0.198</u>	4

**Valid Data**

Average
<b>0.199</b>


# Nozzle Calibration

Date: 1/5/2020

Nozzle ID No.: 935

Analyst: RNS

Material/Type: Glass



<u>0.196</u>	1
<u>0.196</u>	2
<u>0.196</u>	3
<u>0.195</u>	4

**Valid Data**

<b>Average</b>
<b>0.196</b>


# Nozzle Calibration

Date: 4/13/2022

Nozzle ID No.: 71T-C

Analyst: AH1

Material/Type: Teflon



<u>0.200</u>	1
<u>0.201</u>	2
<u>0.200</u>	3
<u>0.200</u>	4

**Valid Data**

<b>Average</b>
<b>0.200</b>


# Nozzle Calibration

Date: 6/29/2018

Nozzle ID No.: #7

Analyst: EJP

Material/Type: Teflon



<u>0.210</u>	1
.	
<u>0.209</u>	2
<u>0.210</u>	3
<u>0.210</u>	4

**Valid Data**

<b>Average</b>
<b>0.210</b>


# Nozzle Calibration

Date: 4/13/2022

Nozzle ID No.: 71T-C

Analyst: AH1

Material/Type: Teflon



<u>0.200</u>	1
<u>0.201</u>	2
<u>0.200</u>	3
<u>0.200</u>	4

**Valid Data**

<b>Average</b>
<b>0.200</b>


# Nozzle Calibration

Date: 3/24/2021

Nozzle ID No.: 916

Analyst: RNS

Material/Type: Glass



<u>0.215</u>	1
<u>0.215</u>	2
<u>0.215</u>	3
<u>0.216</u>	4

**Valid Data**

<b>Average</b>
<b>0.215</b>

## **Appendix H - Laboratory Sample Analysis**

MOSTARDI PLATT

PROJECT: M232604  
PCC STRUCTURALS  
LPC – MILWAUKIE, OR

CLIENT # M050  
REPORT # 23-351

SUBMITTED BY:  
**CHESTER LabNet**  
12242 S.W. GARDEN PLACE  
TIGARD, OR 97223  
(503)624-2183/FAX (503)624-2653  
[www.ChesterLab.Net](http://www.ChesterLab.Net)

# **CHESTER LabNet**

12242 SW Garden Place ♦ Tigard, OR 97223-8246 ♦ USA  
Telephone 503-624-2183 ♦ Fax 503-624-2653 ♦ [www.chesterlab.net](http://www.chesterlab.net)

---

## **Case Narrative**

Date: August 24, 2023

### **General Information**

Client: Mostardi Platt  
Client Number: M050  
Report Number: 23-351  
Sample Description: Impinger Trains  
Sample Numbers: 23-S1834 – 23-S1949

### **Analysis**

Analytes: Al, Sb, As, Ba, Be, Cd, Cr, Co, Cu, Pb, Mn, Hg, Ni, P, Se, Ag, Tl, V, Zn, Hexavalent Chromium

Analytical Protocols: EPA Method 29 (8/2/17 version)  
SW-846 Method 0061 (revision 0, December 1996)

Analytical Notes: The petri dish for 23-S1904 contained a large amount of loose deposit. The filter and loose particulate were digested in separate vessels and then combined as one sample. That sample has more acid than the rest of the front half samples. The Co result for that samples was overscale using ICP-MS, but it matched the results as measured on the ICP-OES. The results for 23-S1904 may not be the most reliable because of the nature of the sample.

A low level LCS on one mercury run wasn't spiked because of an analyst error. The samples that were analyzed with that LL-LCS were the front half fractions for the second half samples starting with 23-S1874.

No problems were encountered during the Cr VI analysis. Results are not blank corrected.

QA/QC Review: All the data have been reviewed by the analysts performing the analyses and the project manager. All of the quality control and sample-specific information in this package is complete and meets or exceeds the minimum requirements for acceptability.

Comments: If you have any questions or concerns regarding this analysis, please feel free to contact the project manager.

Disclaimer:

This report shall not be reproduced, except in full, without the written approval of the laboratory. The results only represent that of the samples as received into the laboratory. All data are reported to the detection limit. Results <5x DL must be considered to have a higher degree of uncertainty associated with them. Due to the statistical process of detection limit determination, data in this report should not be used for statistical analysis as the data has been censored in such a manner as to bias statistical analyses high.

Paul D

Project Manager  
Paul Duda

8/24/23

Date

Lab ID: 23-S1834  
Client ID: 9203 N Inlet #1 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Inlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Aluminum, ICP	736.	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	21.4	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	1.26	0.050	µg/sample
Chromium, ICP	892.	0.200	µg/sample
Cobalt, ICP-MS	208.	0.125	µg/sample
Copper, ICP-MS	320.	0.250	µg/sample
Lead, ICP-MS	2.47	0.125	µg/sample
Manganese, ICP	16.5	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	6,520	0.750	µg/sample
Phosphorus, ICP	110.	5.00	µg/sample
Selenium, ICP-MS	1.05	0.500	µg/sample
Silver, ICP	1.14	0.500	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	2.53	0.075	µg/sample
Zinc, ICP	109.	0.750	µg/sample

---

Lab ID: 23-S1835  
Client ID: 9203 N Inlet #1 HNO3/H2O2  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Inlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Aluminum, ICP	55.8	4.71	µg/sample
Antimony, ICP-MS	< DL	0.628	µg/sample
Arsenic, ICP	< DL	1.10	µg/sample
Barium, ICP	4.45	0.078	µg/sample
Beryllium, ICP	< DL	0.031	µg/sample
Cadmium, ICP-MS	0.413	0.031	µg/sample
Chromium, ICP	12.6	0.126	µg/sample
Cobalt, ICP-MS	0.571	0.078	µg/sample
Copper, ICP	18.2	0.785	µg/sample
Lead, ICP	< DL	0.785	µg/sample
Manganese, ICP	13.3	0.047	µg/sample
Mercury, CVAA	0.336	0.0444	µg/sample
Nickel, ICP	18.0	0.471	µg/sample
Phosphorus, ICP	19.4	3.14	µg/sample
Selenium, ICP	11.7	2.36	µg/sample
Silver, ICP	0.812	0.314	µg/sample
Thallium, ICP	< DL	1.57	µg/sample
Vanadium, ICP	0.282	0.157	µg/sample
Zinc, ICP	44.0	0.471	µg/sample

---

Lab ID: 23-S1836  
Client ID: 9203 N Inlet #1 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Inlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00805	µg/sample

---

Lab ID: 23-S1837  
Client ID: 9203 N Inlet #1 KMnO4  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Inlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Mercury, CVAA	0.196	0.0233	µg/sample

---

Lab ID: 23-S1838  
Client ID: 9203 N Inlet #1 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Inlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Mercury, CVAA	0.102	0.0192	µg/sample

---

Lab ID: 23-S1839  
Client ID: 9203 N Inlet #2 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Inlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Aluminum, ICP	764.	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	6.66	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	0.265	0.050	µg/sample
Chromium, ICP	1,290	0.200	µg/sample
Cobalt, ICP-MS	315.	0.125	µg/sample
Copper, ICP-MS	396.	0.250	µg/sample
Lead, ICP-MS	1.15	0.125	µg/sample
Manganese, ICP	17.7	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	10,100	0.750	µg/sample
Phosphorus, ICP	109.	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	0.845	0.500	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	2.07	0.075	µg/sample
Zinc, ICP	141.	0.750	µg/sample

---

Lab ID: 23-S1840  
Client ID: 9203 N Inlet #2 HNO<sub>3</sub>/H<sub>2</sub>O<sub>2</sub>  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Inlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Aluminum, ICP	42.2	4.14	µg/sample
Antimony, ICP-MS	< DL	0.552	µg/sample
Arsenic, ICP	< DL	0.966	µg/sample
Barium, ICP	4.29	0.069	µg/sample
Beryllium, ICP	< DL	0.028	µg/sample
Cadmium, ICP-MS	0.328	0.028	µg/sample
Chromium, ICP	4.44	0.110	µg/sample
Cobalt, ICP-MS	0.600	0.069	µg/sample
Copper, ICP	2.99	0.690	µg/sample
Lead, ICP	0.882	0.690	µg/sample
Manganese, ICP	30.5	0.041	µg/sample
Mercury, CVAA	0.392	0.0315	µg/sample
Nickel, ICP	14.6	0.414	µg/sample
Phosphorus, ICP	19.4	2.76	µg/sample
Selenium, ICP	< DL	2.07	µg/sample
Silver, ICP	0.391	0.276	µg/sample
Thallium, ICP	< DL	1.38	µg/sample
Vanadium, ICP	0.161	0.138	µg/sample
Zinc, ICP	26.2	0.414	µg/sample

---

Lab ID: 23-S1841  
Client ID: 9203 N Inlet #2 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Inlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00814	µg/sample

---

Lab ID: 23-S1842  
Client ID: 9204 N Inlet #2 KMnO<sub>4</sub>  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Inlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	0.104	0.0214	µg/sample

---

Lab ID: 23-S1843  
Client ID: 9203 N Inlet #2 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Inlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0194	µg/sample

Lab ID: 23-S1844  
Client ID: 9203 C Inlet #1 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 Center Inlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Aluminum, ICP	783.	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	53.4	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	2.75	0.050	µg/sample
Chromium, ICP	670.	0.200	µg/sample
Cobalt, ICP-MS	136.	0.125	µg/sample
Copper, ICP-MS	324.	0.250	µg/sample
Lead, ICP-MS	1.94	0.125	µg/sample
Manganese, ICP	49.5	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	4,650	0.750	µg/sample
Phosphorus, ICP	147.	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	5.87	0.500	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	2.35	0.075	µg/sample
Zinc, ICP	642.	0.750	µg/sample

---

Lab ID: 23-S1845  
Client ID: 9203 C Inlet #1 HNO3/H2O2  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 Center Inlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Aluminum, ICP	42.6	3.39	µg/sample
Antimony, ICP-MS	< DL	0.452	µg/sample
Arsenic, ICP	< DL	0.791	µg/sample
Barium, ICP	4.41	0.056	µg/sample
Beryllium, ICP	< DL	0.023	µg/sample
Cadmium, ICP-MS	0.130	0.023	µg/sample
Chromium, ICP	73.4	0.090	µg/sample
Cobalt, ICP-MS	1.94	0.056	µg/sample
Copper, ICP	85.1	0.565	µg/sample
Lead, ICP	1.65	0.565	µg/sample
Manganese, ICP	69.1	0.034	µg/sample
Mercury, CVAA	0.217	0.0298	µg/sample
Nickel, ICP	211.	0.339	µg/sample
Phosphorus, ICP	22.6	2.26	µg/sample
Selenium, ICP	< DL	1.70	µg/sample
Silver, ICP	0.406	0.226	µg/sample
Thallium, ICP	< DL	1.13	µg/sample
Vanadium, ICP	0.526	0.113	µg/sample
Zinc, ICP	22.2	0.339	µg/sample

---

Lab ID: 23-S1846  
Client ID: 9203 C Inlet #1 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 Center Inlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00827	µg/sample

---

Lab ID: 23-S1847  
Client ID: 9203 C Inlet #1 KMnO4  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 Center Inlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Mercury, CVAA	0.163	0.0248	µg/sample

---

Lab ID: 23-S1848  
Client ID: 9203 C Inlet #1 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 Center Inlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0192	µg/sample

---

Lab ID: 23-S1849  
Client ID: 9203 C Inlet #2 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 Center Inlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Aluminum, ICP	899.	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	7.10	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	0.994	0.050	µg/sample
Chromium, ICP	1,360	0.200	µg/sample
Cobalt, ICP-MS	44.6	0.125	µg/sample
Copper, ICP-MS	776.	0.250	µg/sample
Lead, ICP-MS	1.33	0.125	µg/sample
Manganese, ICP	80.3	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	7,850	0.750	µg/sample
Phosphorus, ICP	112.	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	1.23	0.500	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	3.87	0.075	µg/sample
Zinc, ICP	155.	0.750	µg/sample

---

Lab ID: 23-S1850  
Client ID: 9203 C Inlet #2 HNO<sub>3</sub>/H<sub>2</sub>O<sub>2</sub>  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 Center Inlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Aluminum, ICP	37.5	4.32	µg/sample
Antimony, ICP-MS	< DL	0.576	µg/sample
Arsenic, ICP	< DL	1.01	µg/sample
Barium, ICP	5.55	0.072	µg/sample
Beryllium, ICP	< DL	0.029	µg/sample
Cadmium, ICP-MS	0.177	0.029	µg/sample
Chromium, ICP	2.33	0.115	µg/sample
Cobalt, ICP-MS	0.763	0.072	µg/sample
Copper, ICP	3.37	0.720	µg/sample
Lead, ICP	< DL	0.720	µg/sample
Manganese, ICP	49.9	0.043	µg/sample
Mercury, CVAA	0.570	0.0341	µg/sample
Nickel, ICP	11.1	0.432	µg/sample
Phosphorus, ICP	19.0	2.88	µg/sample
Selenium, ICP	< DL	2.16	µg/sample
Silver, ICP	1.35	0.288	µg/sample
Thallium, ICP	< DL	1.44	µg/sample
Vanadium, ICP	0.184	0.144	µg/sample
Zinc, ICP	34.4	0.432	µg/sample

---

Lab ID: 23-S1851  
Client ID: 9203 C Inlet #2 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 Center Inlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00866	µg/sample

---

Lab ID: 23-S1852  
Client ID: 9203 C Inlet #2 KMnO<sub>4</sub>  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 Center Inlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	0.236	0.0240	µg/sample

---

Lab ID: 23-S1853  
Client ID: 9203 C Inlet #2 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 Center Inlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0196	µg/sample

Analysis performed by: **CHESTER LabNet**

Lab ID: 23-S1854  
Client ID: 9203 S Inlet #1 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Inlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Aluminum, ICP	828.	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	3.61	2.50	µg/sample
Barium, ICP	43.4	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	5.84	0.050	µg/sample
Chromium, ICP	2,640	0.200	µg/sample
Cobalt, ICP-MS	44.4	0.125	µg/sample
Copper, ICP-MS	292.	0.250	µg/sample
Lead, ICP-MS	1.18	0.125	µg/sample
Manganese, ICP	30.2	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	8,120	0.750	µg/sample
Phosphorus, ICP	108.	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	3.77	0.500	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	5.46	0.075	µg/sample
Zinc, ICP	109.	0.750	µg/sample

---

Lab ID: 23-S1855  
Client ID: 9203 S Inlet #1 HNO3/H2O2  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Inlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Aluminum, ICP	31.6	3.81	µg/sample
Antimony, ICP-MS	< DL	0.508	µg/sample
Arsenic, ICP	< DL	0.889	µg/sample
Barium, ICP	3.74	0.064	µg/sample
Beryllium, ICP	< DL	0.025	µg/sample
Cadmium, ICP-MS	0.241	0.025	µg/sample
Chromium, ICP	1.25	0.102	µg/sample
Cobalt, ICP-MS	0.234	0.064	µg/sample
Copper, ICP	1.23	0.635	µg/sample
Lead, ICP	< DL	0.635	µg/sample
Manganese, ICP	22.3	0.038	µg/sample
Mercury, CVAA	0.305	0.0328	µg/sample
Nickel, ICP	1.41	0.381	µg/sample
Phosphorus, ICP	19.2	2.54	µg/sample
Selenium, ICP	< DL	1.90	µg/sample
Silver, ICP	0.269	0.254	µg/sample
Thallium, ICP	< DL	1.27	µg/sample
Vanadium, ICP	< DL	0.127	µg/sample
Zinc, ICP	79.1	0.381	µg/sample

Lab ID: 23-S1856  
Client ID: 9203 S Inlet #1 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Inlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00814	µg/sample

---

Lab ID: 23-S1857  
Client ID: 9203 S Inlet #1 KMnO4  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Inlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Mercury, CVAA	0.106	0.0232	µg/sample

---

Lab ID: 23-S1858  
Client ID: 9203 S Inlet #1 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Inlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0191	µg/sample

---

Lab ID: 23-S1859  
Client ID: 9203 S Inlet #2 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Inlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Aluminum, ICP	1,160	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	10.5	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	6.72	0.050	µg/sample
Chromium, ICP	4,890	0.200	µg/sample
Cobalt, ICP-MS	54.9	0.125	µg/sample
Copper, ICP-MS	680.	0.250	µg/sample
Lead, ICP-MS	1.14	0.125	µg/sample
Manganese, ICP	106.	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	20,400	0.750	µg/sample
Phosphorus, ICP	124.	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	2.69	0.500	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	6.64	0.075	µg/sample
Zinc, ICP	275.	0.750	µg/sample

---

Lab ID: 23-S1860  
Client ID: 9203 S Inlet #2 HNO<sub>3</sub>/H<sub>2</sub>O<sub>2</sub>  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Inlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Aluminum, ICP	34.2	3.36	µg/sample
Antimony, ICP-MS	0.636	0.448	µg/sample
Arsenic, ICP	< DL	0.784	µg/sample
Barium, ICP	5.13	0.056	µg/sample
Beryllium, ICP	< DL	0.022	µg/sample
Cadmium, ICP-MS	0.093	0.022	µg/sample
Chromium, ICP	3.37	0.090	µg/sample
Cobalt, ICP-MS	0.881	0.056	µg/sample
Copper, ICP	1.99	0.560	µg/sample
Lead, ICP	0.968	0.560	µg/sample
Manganese, ICP	167.	0.034	µg/sample
Mercury, CVAA	0.318	0.0332	µg/sample
Nickel, ICP	15.8	0.336	µg/sample
Phosphorus, ICP	20.2	2.24	µg/sample
Selenium, ICP	< DL	1.68	µg/sample
Silver, ICP	< DL	0.224	µg/sample
Thallium, ICP	< DL	1.12	µg/sample
Vanadium, ICP	0.395	0.112	µg/sample
Zinc, ICP	26.7	0.336	µg/sample

---

Lab ID: 23-S1861  
Client ID: 9203 S Inlet #2 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Inlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00792	µg/sample

---

Lab ID: 23-S1862  
Client ID: 9203 S Inlet #2 KMnO<sub>4</sub>  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Inlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	0.167	0.0156	µg/sample

---

Lab ID: 23-S1863  
Client ID: 9203 S Inlet #2 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Inlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0196	µg/sample

---

Analysis performed by: **CHESTER LabNet**

12242 SW Garden Place ♦ Tigard, OR 97223 ♦ (503) 624-2183 ♦ [www.chesterlab.net](http://www.chesterlab.net)  
Project No. M232604B Rev. 1 262 of 340 ©Mostardi Platt  
Baghouse 9203

Lab ID: 23-S1864  
Client ID: 9203 N Outlet #1 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Outlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Aluminum, ICP	506.	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	5.52	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	0.270	0.050	µg/sample
Chromium, ICP	5.57	0.200	µg/sample
Cobalt, ICP-MS	0.689	0.125	µg/sample
Copper, ICP-MS	1.54	0.250	µg/sample
Lead, ICP-MS	0.328	0.125	µg/sample
Manganese, ICP	4.80	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	33.4	0.750	µg/sample
Phosphorus, ICP	86.4	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	< DL	0.500	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	0.110	0.075	µg/sample
Zinc, ICP	10.6	0.750	µg/sample

---

Lab ID: 23-S1865  
Client ID: 9203 N Outlet #1 HNO3/H2O2  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Outlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Aluminum, ICP	61.1	3.48	µg/sample
Antimony, ICP-MS	< DL	0.464	µg/sample
Arsenic, ICP	< DL	0.812	µg/sample
Barium, ICP	4.45	0.058	µg/sample
Beryllium, ICP	< DL	0.023	µg/sample
Cadmium, ICP-MS	0.126	0.023	µg/sample
Chromium, ICP	0.945	0.093	µg/sample
Cobalt, ICP-MS	0.201	0.058	µg/sample
Copper, ICP	2.15	0.580	µg/sample
Lead, ICP	1.53	0.580	µg/sample
Manganese, ICP	47.2	0.035	µg/sample
Mercury, CVAA	0.712	0.0258	µg/sample
Nickel, ICP	1.01	0.348	µg/sample
Phosphorus, ICP	18.6	2.32	µg/sample
Selenium, ICP	< DL	1.74	µg/sample
Silver, ICP	< DL	0.232	µg/sample
Thallium, ICP	< DL	1.16	µg/sample
Vanadium, ICP	< DL	0.116	µg/sample
Zinc, ICP	12.7	0.348	µg/sample

Lab ID: 23-S1866  
Client ID: 9203 N Outlet #1 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Outlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00790	µg/sample

---

Lab ID: 23-S1867  
Client ID: 9203 N Outlet #1 KMnO4  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Outlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Mercury, CVAA	0.816	0.0237	µg/sample

---

Lab ID: 23-S1868  
Client ID: 9203 N Outlet #1 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Outlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Mercury, CVAA	0.0801	0.0193	µg/sample

---

Lab ID: 23-S1869  
Client ID: 9203 N Outlet #2 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Outlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Aluminum, ICP	508.	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	2.92	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	0.210	0.050	µg/sample
Chromium, ICP	13.8	0.200	µg/sample
Cobalt, ICP-MS	6.87	0.125	µg/sample
Copper, ICP-MS	1.50	0.250	µg/sample
Lead, ICP-MS	0.318	0.125	µg/sample
Manganese, ICP	2.74	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	43.8	0.750	µg/sample
Phosphorus, ICP	80.0	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	< DL	0.500	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	0.090	0.075	µg/sample
Zinc, ICP	11.4	0.750	µg/sample

---

Lab ID: 23-S1870  
Client ID: 9203 N Outlet #2 HNO<sub>3</sub>/H<sub>2</sub>O<sub>2</sub>  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Outlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Aluminum, ICP	24.2	3.54	µg/sample
Antimony, ICP-MS	< DL	0.472	µg/sample
Arsenic, ICP	< DL	0.826	µg/sample
Barium, ICP	3.49	0.059	µg/sample
Beryllium, ICP	< DL	0.024	µg/sample
Cadmium, ICP-MS	0.028	0.024	µg/sample
Chromium, ICP	1.62	0.094	µg/sample
Cobalt, ICP-MS	0.696	0.059	µg/sample
Copper, ICP	< DL	0.590	µg/sample
Lead, ICP	< DL	0.590	µg/sample
Manganese, ICP	19.2	0.035	µg/sample
Mercury, CVAA	0.535	0.0233	µg/sample
Nickel, ICP	4.09	0.354	µg/sample
Phosphorus, ICP	21.4	2.36	µg/sample
Selenium, ICP	< DL	1.77	µg/sample
Silver, ICP	< DL	0.236	µg/sample
Thallium, ICP	< DL	1.18	µg/sample
Vanadium, ICP	< DL	0.118	µg/sample
Zinc, ICP	5.06	0.354	µg/sample

---

Lab ID: 23-S1871  
Client ID: 9203 N Outlet #2 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Outlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	0.0222	0.00971	µg/sample

---

Lab ID: 23-S1872  
Client ID: 9203 N Outlet #2 KMnO<sub>4</sub>  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Outlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	0.275	0.0256	µg/sample

---

Lab ID: 23-S1873  
Client ID: 9203 N Outlet #2 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 North Outlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0200	µg/sample

Analysis performed by: **CHESTER LabNet**

12242 SW Garden Place ♦ Tigard, OR 97223 ♦ (503) 624-2183 ♦ [www.chesterlab.net](http://www.chesterlab.net)  
Project No. M232604B Rev. 1 265 of 340 ©Mostardi Platt  
Baghouse 9203

Lab ID: 23-S1874  
Client ID: 9203 S Outlet #1 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Outlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Aluminum, ICP	535.	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	12.2	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	0.474	0.050	µg/sample
Chromium, ICP	3.02	0.200	µg/sample
Cobalt, ICP-MS	0.322	0.125	µg/sample
Copper, ICP-MS	1.58	0.250	µg/sample
Lead, ICP-MS	0.494	0.125	µg/sample
Manganese, ICP	2.64	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	6.35	0.750	µg/sample
Phosphorus, ICP	84.0	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	< DL	0.500	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	0.142	0.075	µg/sample
Zinc, ICP	15.6	0.750	µg/sample

---

Lab ID: 23-S1875  
Client ID: 9203 S Outlet #1 HNO3/H2O2  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Outlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Aluminum, ICP	17.4	4.29	µg/sample
Antimony, ICP-MS	< DL	0.572	µg/sample
Arsenic, ICP	< DL	1.00	µg/sample
Barium, ICP	4.13	0.072	µg/sample
Beryllium, ICP	< DL	0.029	µg/sample
Cadmium, ICP-MS	0.089	0.029	µg/sample
Chromium, ICP	1.23	0.114	µg/sample
Cobalt, ICP-MS	0.172	0.072	µg/sample
Copper, ICP	13.6	0.715	µg/sample
Lead, ICP	< DL	0.715	µg/sample
Manganese, ICP	1.62	0.043	µg/sample
Mercury, CVAA	0.283	0.0233	µg/sample
Nickel, ICP	0.593	0.429	µg/sample
Phosphorus, ICP	17.6	2.86	µg/sample
Selenium, ICP	3.51	2.14	µg/sample
Silver, ICP	< DL	0.286	µg/sample
Thallium, ICP	< DL	1.43	µg/sample
Vanadium, ICP	< DL	0.143	µg/sample
Zinc, ICP	16.7	0.429	µg/sample

Lab ID: 23-S1876  
Client ID: 9203 S Outlet #1 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Outlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00828	µg/sample

---

Lab ID: 23-S1877  
Client ID: 9203 S Outlet #1 KMnO4  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Outlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Mercury, CVAA	0.145	0.0275	µg/sample

---

Lab ID: 23-S1878  
Client ID: 9203 S Outlet #1 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Outlet  
Sample Date: 6/27/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0192	µg/sample

---

Lab ID: 23-S1879  
Client ID: 9203 S Outlet #2 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Outlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Aluminum, ICP	521.	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	4.11	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	0.076	0.050	µg/sample
Chromium, ICP	32.3	0.200	µg/sample
Cobalt, ICP-MS	13.4	0.125	µg/sample
Copper, ICP-MS	1.66	0.250	µg/sample
Lead, ICP-MS	0.328	0.125	µg/sample
Manganese, ICP	2.59	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	82.1	0.750	µg/sample
Phosphorus, ICP	88.8	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	< DL	0.500	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	0.121	0.075	µg/sample
Zinc, ICP	14.8	0.750	µg/sample

---

Analysis performed by: **CHESTER LabNet**

12242 SW Garden Place ♦ Tigard, OR 97223 ♦ (503) 624-2183 ♦ [www.chesterlab.net](http://www.chesterlab.net)  
Project No. M232604B Rev. 1 267 of 340 ©Mostardi Platt  
Baghouse 9203

Lab ID: 23-S1880  
Client ID: 9203 S Outlet #2 HNO<sub>3</sub>/H<sub>2</sub>O<sub>2</sub>  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Outlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Aluminum, ICP	27.7	3.78	µg/sample
Antimony, ICP-MS	0.540	0.504	µg/sample
Arsenic, ICP	< DL	0.882	µg/sample
Barium, ICP	4.03	0.063	µg/sample
Beryllium, ICP	< DL	0.025	µg/sample
Cadmium, ICP-MS	0.077	0.025	µg/sample
Chromium, ICP	1.32	0.101	µg/sample
Cobalt, ICP-MS	0.315	0.063	µg/sample
Copper, ICP	0.841	0.630	µg/sample
Lead, ICP	< DL	0.630	µg/sample
Manganese, ICP	90.6	0.038	µg/sample
Mercury, CVAA	0.489	0.0257	µg/sample
Nickel, ICP	2.31	0.378	µg/sample
Phosphorus, ICP	20.6	2.52	µg/sample
Selenium, ICP	2.60	1.89	µg/sample
Silver, ICP	< DL	0.252	µg/sample
Thallium, ICP	< DL	1.26	µg/sample
Vanadium, ICP	< DL	0.126	µg/sample
Zinc, ICP	14.7	0.378	µg/sample

---

Lab ID: 23-S1881  
Client ID: 9203 S Outlet #2 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Outlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0107	µg/sample

---

Lab ID: 23-S1882  
Client ID: 9203 S Outlet #2 KMnO<sub>4</sub>  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Outlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	0.110	0.0154	µg/sample

---

Lab ID: 23-S1883  
Client ID: 9203 S Outlet #2 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 9203 South Outlet  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0161	µg/sample

---

Analysis performed by: **CHESTER LabNet**

12242 SW Garden Place ♦ Tigard, OR 97223 ♦ (503) 624-2183 ♦ [www.chesterlab.net](http://www.chesterlab.net)  
Project No. M232604B Rev. 1 268 of 340 ©Mostardi Platt  
Baghouse 9203

Lab ID: 23-S1884  
Client ID: 9256 Inlet #1 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Inlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Aluminum, ICP	3,090	7.50	µg/sample
Antimony, ICP-MS	1.07	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	7.90	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	0.111	0.050	µg/sample
Chromium, ICP	88.7	0.200	µg/sample
Cobalt, ICP-MS	2.60	0.125	µg/sample
Copper, ICP-MS	329.	0.250	µg/sample
Lead, ICP-MS	8.79	0.125	µg/sample
Manganese, ICP	748.	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	121.	0.750	µg/sample
Phosphorus, ICP	93.5	5.00	µg/sample
Selenium, ICP-MS	0.634	0.500	µg/sample
Silver, ICP	0.733	0.500	µg/sample
Thallium, ICP-MS	0.102	0.100	µg/sample
Vanadium, ICP-MS	1.18	0.075	µg/sample
Zinc, ICP	109.	0.750	µg/sample

---

Lab ID: 23-S1885  
Client ID: 9256 Inlet #1 HNO3/H2O2  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Inlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Aluminum, ICP	61.1	3.72	µg/sample
Antimony, ICP-MS	< DL	0.496	µg/sample
Arsenic, ICP	< DL	0.868	µg/sample
Barium, ICP	10.7	0.062	µg/sample
Beryllium, ICP	< DL	0.025	µg/sample
Cadmium, ICP-MS	0.124	0.025	µg/sample
Chromium, ICP	10.3	0.099	µg/sample
Cobalt, ICP-MS	0.956	0.062	µg/sample
Copper, ICP	11.4	0.620	µg/sample
Lead, ICP	< DL	0.620	µg/sample
Manganese, ICP	43.3	0.037	µg/sample
Mercury, CVAA	0.543	0.0359	µg/sample
Nickel, ICP	60.7	0.372	µg/sample
Phosphorus, ICP	27.7	2.48	µg/sample
Selenium, ICP	< DL	1.86	µg/sample
Silver, ICP	0.345	0.248	µg/sample
Thallium, ICP	< DL	1.24	µg/sample
Vanadium, ICP	< DL	0.124	µg/sample
Zinc, ICP	11.4	0.372	µg/sample

---

Lab ID: 23-S1886  
Client ID: 9256 Inlet #1 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Inlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00818	µg/sample

---

Lab ID: 23-S1887  
Client ID: 9256 Inlet #1 KMnO4  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Inlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Mercury, CVAA	0.778	0.0234	µg/sample

---

Lab ID: 23-S1888  
Client ID: 9256 Inlet #1 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Inlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Mercury, CVAA	0.0532	0.0196	µg/sample

---

Lab ID: 23-S1889  
Client ID: 9256 Inlet #2 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Inlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Aluminum, ICP	3,010	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	21.0	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	0.484	0.050	µg/sample
Chromium, ICP	103.	0.200	µg/sample
Cobalt, ICP-MS	4.02	0.125	µg/sample
Copper, ICP-MS	417.	0.250	µg/sample
Lead, ICP-MS	4.92	0.125	µg/sample
Manganese, ICP	411.	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	211.	0.750	µg/sample
Phosphorus, ICP	102.	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	1.14	0.500	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	1.71	0.075	µg/sample
Zinc, ICP	96.8	0.750	µg/sample

---

Lab ID: 23-S1890  
Client ID: 9256 Inlet #2 HNO3/H2O2  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Inlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Aluminum, ICP	57.6	3.33	µg/sample
Antimony, ICP-MS	0.543	0.444	µg/sample
Arsenic, ICP	< DL	0.777	µg/sample
Barium, ICP	9.83	0.056	µg/sample
Beryllium, ICP	< DL	0.022	µg/sample
Cadmium, ICP-MS	0.105	0.022	µg/sample
Chromium, ICP	3.70	0.089	µg/sample
Cobalt, ICP-MS	0.463	0.056	µg/sample
Copper, ICP	1.92	0.555	µg/sample
Lead, ICP	< DL	0.555	µg/sample
Manganese, ICP	24.0	0.033	µg/sample
Mercury, CVAA	0.334	0.0354	µg/sample
Nickel, ICP	21.1	0.333	µg/sample
Phosphorus, ICP	23.2	2.22	µg/sample
Selenium, ICP	< DL	1.66	µg/sample
Silver, ICP	< DL	0.222	µg/sample
Thallium, ICP	< DL	1.11	µg/sample
Vanadium, ICP	< DL	0.111	µg/sample
Zinc, ICP	31.3	0.333	µg/sample

---

Lab ID: 23-S1891  
Client ID: 9256 Inlet #2 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Inlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00809	µg/sample

---

Lab ID: 23-S1892  
Client ID: 9256 Inlet #2 KMnO4  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Inlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Mercury, CVAA	0.164	0.0229	µg/sample

---

Lab ID: 23-S1893  
Client ID: 9256 Inlet #2 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Inlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0198	µg/sample

Lab ID: 23-S1894  
Client ID: 9256 Outlet #1 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Outlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Aluminum, ICP	516.	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	10.3	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	0.620	0.050	µg/sample
Chromium, ICP	1.92	0.200	µg/sample
Cobalt, ICP-MS	0.566	0.125	µg/sample
Copper, ICP-MS	0.994	0.250	µg/sample
Lead, ICP-MS	0.328	0.125	µg/sample
Manganese, ICP	1.57	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	12.1	0.750	µg/sample
Phosphorus, ICP	83.6	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	< DL	0.500	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	0.122	0.075	µg/sample
Zinc, ICP	13.5	0.750	µg/sample

---

Lab ID: 23-S1895  
Client ID: 9256 Outlet #1 HNO3/H2O2  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Outlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Aluminum, ICP	22.3	3.42	µg/sample
Antimony, ICP-MS	< DL	0.456	µg/sample
Arsenic, ICP	< DL	0.798	µg/sample
Barium, ICP	5.53	0.057	µg/sample
Beryllium, ICP	< DL	0.023	µg/sample
Cadmium, ICP-MS	0.105	0.023	µg/sample
Chromium, ICP	2.30	0.091	µg/sample
Cobalt, ICP-MS	0.145	0.057	µg/sample
Copper, ICP	4.28	0.570	µg/sample
Lead, ICP	< DL	0.570	µg/sample
Manganese, ICP	7.49	0.034	µg/sample
Mercury, CVAA	0.488	0.0284	µg/sample
Nickel, ICP	1.42	0.342	µg/sample
Phosphorus, ICP	28.3	2.28	µg/sample
Selenium, ICP	2.55	1.71	µg/sample
Silver, ICP	< DL	0.228	µg/sample
Thallium, ICP	< DL	1.14	µg/sample
Vanadium, ICP	< DL	0.114	µg/sample
Zinc, ICP	21.2	0.342	µg/sample

---

Lab ID: 23-S1896  
Client ID: 9256 Outlet #1 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Outlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00822	µg/sample

---

Lab ID: 23-S1897  
Client ID: 9256 Outlet #1 KMnO4  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Outlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Mercury, CVAA	0.160	0.0267	µg/sample

---

Lab ID: 23-S1898  
Client ID: 9256 Outlet #1 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Outlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0196	µg/sample

---

Lab ID: 23-S1899  
Client ID: 9256 Outlet #2 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Outlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Aluminum, ICP	528.	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	4.61	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	1.01	0.050	µg/sample
Chromium, ICP	26.9	0.200	µg/sample
Cobalt, ICP-MS	7.77	0.125	µg/sample
Copper, ICP-MS	1.95	0.250	µg/sample
Lead, ICP-MS	0.553	0.125	µg/sample
Manganese, ICP	2.29	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	99.5	0.750	µg/sample
Phosphorus, ICP	86.3	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	< DL	1.00	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	0.140	0.075	µg/sample
Zinc, ICP	8.92	0.750	µg/sample

---

Lab ID: 23-S1900  
Client ID: 9256 Outlet #2 HNO<sub>3</sub>/H<sub>2</sub>O<sub>2</sub>  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Outlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Aluminum, ICP	31.8	3.99	µg/sample
Antimony, ICP-MS	< DL	0.532	µg/sample
Arsenic, ICP	< DL	0.931	µg/sample
Barium, ICP	4.43	0.066	µg/sample
Beryllium, ICP	< DL	0.027	µg/sample
Cadmium, ICP-MS	0.035	0.027	µg/sample
Chromium, ICP	5.41	0.106	µg/sample
Cobalt, ICP-MS	0.374	0.066	µg/sample
Copper, ICP	4.29	0.665	µg/sample
Lead, ICP	< DL	0.665	µg/sample
Manganese, ICP	24.7	0.040	µg/sample
Mercury, CVAA	0.424	0.0280	µg/sample
Nickel, ICP	31.0	0.399	µg/sample
Phosphorus, ICP	22.1	2.66	µg/sample
Selenium, ICP	< DL	2.00	µg/sample
Silver, ICP	< DL	0.266	µg/sample
Thallium, ICP	< DL	1.33	µg/sample
Vanadium, ICP	< DL	0.133	µg/sample
Zinc, ICP	12.3	0.399	µg/sample

---

Lab ID: 23-S1901  
Client ID: 9256 Outlet #2 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Outlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00836	µg/sample

---

Lab ID: 23-S1902  
Client ID: 9256 Outlet #2 KMnO<sub>4</sub>  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Outlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Mercury, CVAA	0.158	0.0251	µg/sample

---

Lab ID: 23-S1903  
Client ID: 9256 Outlet #2 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 9256 Outlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0194	µg/sample

Lab ID: 23-S1904  
Client ID: 8901 Inlet #1 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Inlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Aluminum, ICP	9,940	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	8.92	2.50	µg/sample
Barium, ICP	50.9	0.125	µg/sample
Beryllium, ICP-MS	0.226	0.050	µg/sample
Cadmium, ICP-MS	2.68	0.050	µg/sample
Chromium, ICP	145,000	0.200	µg/sample
Cobalt, ICP-MS	80,800	0.125	µg/sample
Copper, ICP-MS	48.8	0.250	µg/sample
Lead, ICP-MS	7.13	0.125	µg/sample
Manganese, ICP	78.6	0.075	µg/sample
Mercury, CVAA	0.0281	0.0219	µg/sample
Nickel, ICP	341,000	0.750	µg/sample
Phosphorus, ICP	368.	5.00	µg/sample
Selenium, ICP-MS	2.07	0.500	µg/sample
Silver, ICP	85.8	1.00	µg/sample
Thallium, ICP-MS	0.101	0.100	µg/sample
Vanadium, ICP-MS	70.6	0.075	µg/sample
Zinc, ICP	2,470	0.750	µg/sample

---

Lab ID: 23-S1905  
Client ID: 8901 Inlet #1 HNO3/H2O2  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Inlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Aluminum, ICP	58.3	3.30	µg/sample
Antimony, ICP-MS	< DL	0.440	µg/sample
Arsenic, ICP	< DL	0.770	µg/sample
Barium, ICP	5.54	0.055	µg/sample
Beryllium, ICP	< DL	0.022	µg/sample
Cadmium, ICP-MS	0.114	0.022	µg/sample
Chromium, ICP	5.86	0.088	µg/sample
Cobalt, ICP-MS	2.90	0.055	µg/sample
Copper, ICP	2.01	0.550	µg/sample
Lead, ICP	1.14	0.550	µg/sample
Manganese, ICP	59.5	0.033	µg/sample
Mercury, CVAA	0.407	0.0385	µg/sample
Nickel, ICP	20.1	0.330	µg/sample
Phosphorus, ICP	24.8	2.20	µg/sample
Selenium, ICP	1.97	1.65	µg/sample
Silver, ICP	0.426	0.220	µg/sample
Thallium, ICP	< DL	1.10	µg/sample
Vanadium, ICP	< DL	0.110	µg/sample
Zinc, ICP	28.8	0.330	µg/sample

Lab ID: 23-S1906  
Client ID: 8901 Inlet #1 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Inlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00853	µg/sample

---

Lab ID: 23-S1907  
Client ID: 8901 Inlet #1 KMnO4  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Inlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Mercury, CVAA	0.191	0.0178	µg/sample

---

Lab ID: 23-S1908  
Client ID: 8901 Inlet #1 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Inlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0196	µg/sample

---

Lab ID: 23-S1909  
Client ID: 8901 Inlet #2 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Inlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Aluminum, ICP	1,370	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	10.5	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	0.348	0.050	µg/sample
Chromium, ICP	2,840	0.200	µg/sample
Cobalt, ICP-MS	1,150	0.125	µg/sample
Copper, ICP-MS	4.94	0.250	µg/sample
Lead, ICP-MS	1.21	0.125	µg/sample
Manganese, ICP	25.8	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	8,120	0.750	µg/sample
Phosphorus, ICP	98.1	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	4.77	1.00	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	3.84	0.075	µg/sample
Zinc, ICP	83.1	0.750	µg/sample

---

Lab ID: 23-S1910  
Client ID: 8901 Inlet #2 HNO3/H2O2  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Inlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Aluminum, ICP	27.9	3.33	µg/sample
Antimony, ICP-MS	< DL	0.444	µg/sample
Arsenic, ICP	< DL	0.777	µg/sample
Barium, ICP	6.58	0.056	µg/sample
Beryllium, ICP	< DL	0.022	µg/sample
Cadmium, ICP-MS	0.068	0.022	µg/sample
Chromium, ICP	3.43	0.089	µg/sample
Cobalt, ICP-MS	1.20	0.056	µg/sample
Copper, ICP	1.05	0.555	µg/sample
Lead, ICP	1.25	0.555	µg/sample
Manganese, ICP	296.	0.033	µg/sample
Mercury, CVAA	0.332	0.0341	µg/sample
Nickel, ICP	8.23	0.333	µg/sample
Phosphorus, ICP	22.2	2.22	µg/sample
Selenium, ICP	< DL	1.66	µg/sample
Silver, ICP	< DL	0.222	µg/sample
Thallium, ICP	< DL	1.11	µg/sample
Vanadium, ICP	< DL	0.111	µg/sample
Zinc, ICP	16.2	0.333	µg/sample

---

Lab ID: 23-S1911  
Client ID: 8901 Inlet #2 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Inlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00814	µg/sample

---

Lab ID: 23-S1912  
Client ID: 8901 Inlet #2 KMnO4  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Inlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Mercury, CVAA	0.210	0.0258	µg/sample

---

Lab ID: 23-S1913  
Client ID: 8901 Inlet #2 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Inlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0195	µg/sample

Lab ID: 23-S1914  
Client ID: 8901 Outlet #1 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Outlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Aluminum, ICP	555.	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	6.83	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	1.03	0.050	µg/sample
Chromium, ICP	117.	0.200	µg/sample
Cobalt, ICP-MS	3.55	0.125	µg/sample
Copper, ICP-MS	5.01	0.250	µg/sample
Lead, ICP-MS	0.822	0.125	µg/sample
Manganese, ICP	9.89	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	104.	0.750	µg/sample
Phosphorus, ICP	88.4	5.00	µg/sample
Selenium, ICP-MS	2.17	0.500	µg/sample
Silver, ICP	13.1	1.00	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	0.812	0.075	µg/sample
Zinc, ICP	16.2	0.750	µg/sample

---

Lab ID: 23-S1915  
Client ID: 8901 Outlet #1 HNO3/H2O2  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Outlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Aluminum, ICP	21.5	4.05	µg/sample
Antimony, ICP-MS	< DL	0.540	µg/sample
Arsenic, ICP	< DL	0.945	µg/sample
Barium, ICP	3.51	0.068	µg/sample
Beryllium, ICP	< DL	0.027	µg/sample
Cadmium, ICP-MS	0.071	0.027	µg/sample
Chromium, ICP	1.82	0.108	µg/sample
Cobalt, ICP-MS	0.276	0.068	µg/sample
Copper, ICP	1.36	0.675	µg/sample
Lead, ICP	0.709	0.675	µg/sample
Manganese, ICP	25.8	0.040	µg/sample
Mercury, CVAA	0.240	0.0271	µg/sample
Nickel, ICP	2.14	0.405	µg/sample
Phosphorus, ICP	26.5	2.70	µg/sample
Selenium, ICP	< DL	2.02	µg/sample
Silver, ICP	< DL	0.270	µg/sample
Thallium, ICP	< DL	1.35	µg/sample
Vanadium, ICP	< DL	0.135	µg/sample
Zinc, ICP	22.1	0.405	µg/sample

---

Analysis performed by: **CHESTER LabNet**

12242 SW Garden Place ♦ Tigard, OR 97223 ♦ (503) 624-2183 ♦ [www.chesterlab.net](http://www.chesterlab.net)  
Project No. M232604B Rev. 1 278 of 340 ©Mostardi Platt  
Baghouse 9203

Lab ID: 23-S1916  
Client ID: 8901 Outlet #1 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Outlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00822	µg/sample

---

Lab ID: 23-S1917  
Client ID: 8901 Outlet #1 KMnO4  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Outlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Mercury, CVAA	0.160	0.0254	µg/sample

---

Lab ID: 23-S1918  
Client ID: 8901 Outlet #1 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Outlet  
Sample Date: 6/28/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0194	µg/sample

---

Lab ID: 23-S1919  
Client ID: 8901 Outlet #2 Filter & Probe  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Outlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Aluminum, ICP	534.	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	4.18	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	0.068	0.050	µg/sample
Chromium, ICP	8.93	0.200	µg/sample
Cobalt, ICP-MS	1.53	0.125	µg/sample
Copper, ICP-MS	3.14	0.250	µg/sample
Lead, ICP-MS	0.369	0.125	µg/sample
Manganese, ICP	4.18	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	26.7	0.750	µg/sample
Phosphorus, ICP	86.8	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	< DL	1.00	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	0.104	0.075	µg/sample
Zinc, ICP	14.2	0.750	µg/sample

---

Lab ID: 23-S1920  
Client ID: 8901 Outlet #2 HNO<sub>3</sub>/H<sub>2</sub>O<sub>2</sub>  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Outlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Aluminum, ICP	36.0	3.99	µg/sample
Antimony, ICP-MS	< DL	0.532	µg/sample
Arsenic, ICP	< DL	0.931	µg/sample
Barium, ICP	3.37	0.066	µg/sample
Beryllium, ICP	< DL	0.027	µg/sample
Cadmium, ICP-MS	0.093	0.027	µg/sample
Chromium, ICP	2.03	0.106	µg/sample
Cobalt, ICP-MS	0.530	0.066	µg/sample
Copper, ICP	1.96	0.665	µg/sample
Lead, ICP	< DL	0.665	µg/sample
Manganese, ICP	31.4	0.040	µg/sample
Mercury, CVAA	0.266	0.0282	µg/sample
Nickel, ICP	2.36	0.399	µg/sample
Phosphorus, ICP	21.0	2.66	µg/sample
Selenium, ICP	< DL	2.00	µg/sample
Silver, ICP	< DL	0.266	µg/sample
Thallium, ICP	< DL	1.33	µg/sample
Vanadium, ICP	< DL	0.133	µg/sample
Zinc, ICP	21.3	0.399	µg/sample

---

Lab ID: 23-S1921  
Client ID: 8901 Outlet #2 Empty Imp  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Outlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00814	µg/sample

---

Lab ID: 23-S1922  
Client ID: 8901 Outlet #2 KMnO<sub>4</sub>  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Outlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Mercury, CVAA	0.173	0.0253	µg/sample

---

Lab ID: 23-S1923  
Client ID: 8901 Outlet #2 HCl Rinse  
Site: PCC Structural: LPC-Milwaukie  
Source: 8901 Outlet  
Sample Date: 6/29/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0194	µg/sample

Lab ID: 23-S1924  
Client ID: Filter Blank  
Site: PCC Structural: LPC-Milwaukie  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Aluminum, ICP	495.	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	3.75	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	< DL	0.050	µg/sample
Chromium, ICP	1.06	0.200	µg/sample
Cobalt, ICP-MS	0.445	0.125	µg/sample
Copper, ICP-MS	< DL	0.250	µg/sample
Lead, ICP-MS	0.150	0.125	µg/sample
Manganese, ICP	0.870	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	1.58	0.750	µg/sample
Phosphorus, ICP	79.2	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	< DL	1.00	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	< DL	0.075	µg/sample
Zinc, ICP	4.29	0.750	µg/sample

---

Lab ID: 23-S1925  
Client ID: 0.1N HNO3 Blank  
Site: PCC Structural: LPC-Milwaukie  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Aluminum, ICP	< DL	7.50	µg/sample
Antimony, ICP-MS	< DL	1.00	µg/sample
Arsenic, ICP-MS	< DL	2.50	µg/sample
Barium, ICP	1.09	0.125	µg/sample
Beryllium, ICP-MS	< DL	0.050	µg/sample
Cadmium, ICP-MS	< DL	0.050	µg/sample
Chromium, ICP	< DL	0.200	µg/sample
Cobalt, ICP-MS	0.412	0.125	µg/sample
Copper, ICP-MS	< DL	0.250	µg/sample
Lead, ICP-MS	< DL	0.125	µg/sample
Manganese, ICP	0.428	0.075	µg/sample
Mercury, CVAA	< DL	0.0219	µg/sample
Nickel, ICP	< DL	0.750	µg/sample
Phosphorus, ICP	< DL	5.00	µg/sample
Selenium, ICP-MS	< DL	0.500	µg/sample
Silver, ICP	< DL	1.00	µg/sample
Thallium, ICP-MS	< DL	0.100	µg/sample
Vanadium, ICP-MS	< DL	0.075	µg/sample
Zinc, ICP	< DL	0.750	µg/sample

Lab ID: 23-S1926  
Client ID: HNO<sub>3</sub>/H<sub>2</sub>O<sub>2</sub> Blank  
Site: PCC Structural: LPC-Milwaukie  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Aluminum, ICP	12.1	3.78	µg/sample
Antimony, ICP-MS	< DL	0.504	µg/sample
Arsenic, ICP	< DL	0.882	µg/sample
Barium, ICP	4.59	0.063	µg/sample
Beryllium, ICP	< DL	0.025	µg/sample
Cadmium, ICP-MS	< DL	0.025	µg/sample
Chromium, ICP	0.375	0.101	µg/sample
Cobalt, ICP-MS	0.086	0.063	µg/sample
Copper, ICP	< DL	0.630	µg/sample
Lead, ICP	< DL	0.630	µg/sample
Manganese, ICP	0.735	0.038	µg/sample
Mercury, CVAA	0.274	0.0172	µg/sample
Nickel, ICP	< DL	0.378	µg/sample
Phosphorus, ICP	21.3	2.52	µg/sample
Selenium, ICP	< DL	1.89	µg/sample
Silver, ICP	< DL	0.252	µg/sample
Thallium, ICP	< DL	1.26	µg/sample
Vanadium, ICP	< DL	0.126	µg/sample
Zinc, ICP	0.929	0.378	µg/sample

---

Lab ID: 23-S1927  
Client ID: DI Water Blank  
Site: PCC Structural: LPC-Milwaukie  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.00849	µg/sample

---

Lab ID: 23-S1928  
Client ID: KMnO<sub>4</sub>/H<sub>2</sub>SO<sub>4</sub> Blank  
Site: PCC Structural: LPC-Milwaukie  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	0.0430	0.00836	µg/sample

---

Lab ID: 23-S1929  
Client ID: 8N HCl Blank  
Site: PCC Structural: LPC-Milwaukie  
Sample Date: 6/30/23

Analyte	Result	DL	Units
Mercury, CVAA	< DL	0.0192	µg/sample

---

Lab ID: 23-S1930  
Client ID: 9203 N Inlet #1 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 9203 North Inlet  
Sample Date: 6/27/23  
Sample Volume: 315. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	261.	0.010	82.3	0.0032

Lab ID: 23-S1931  
Client ID: 9203 N Inlet #2 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 9203 North Inlet  
Sample Date: 6/30/23  
Sample Volume: 285. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	348.	0.010	99.2	0.0028

Lab ID: 23-S1932  
Client ID: 9203 C Inlet #1 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 9203 Center Inlet  
Sample Date: 6/27/23  
Sample Volume: 320. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	638.	0.010	204.	0.0032

Lab ID: 23-S1933  
Client ID: 9203 C Inlet #2 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 9203 Center Inlet  
Sample Date: 6/30/23  
Sample Volume: 310. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	303.	0.010	94.0	0.0031

Lab ID: 23-S1934  
Client ID: 9203 S Inlet #1 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 9203 South Inlet  
Sample Date: 6/27/23  
Sample Volume: 360. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	136.	0.010	49.1	0.0036

Lab ID: 23-S1935  
Client ID: 9203 S Inlet #2 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 9203 South Inlet  
Sample Date: 6/30/23  
Sample Volume: 275. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	97.1	0.010	26.7	0.0028

Lab ID: 23-S1936  
Client ID: 9203 N Outlet #1 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 9203 North Outlet  
Sample Date: 6/27/23  
Sample Volume: 430. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	2.19	0.010	0.941	0.0043

Lab ID: 23-S1937  
Client ID: 9203 N Outlet #2 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 9203 North Outlet  
Sample Date: 6/30/23  
Sample Volume: 590. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	7.82	0.010	4.61	0.0059

Lab ID: 23-S1938  
Client ID: 9203 S Outlet #1 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 9203 South Outlet  
Sample Date: 6/27/23  
Sample Volume: 520. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	3.79	0.010	1.97	0.0052

Lab ID: 23-S1939  
Client ID: 9203 S Outlet #2 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 9203 South Outlet  
Sample Date: 6/30/23  
Sample Volume: 445. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	5.14	0.010	2.29	0.0044

Lab ID: 23-S1940  
Client ID: 9256 Inlet #1 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 9256 Inlet  
Sample Date: 6/28/23  
Sample Volume: 300. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	5.87	0.010	1.76	0.0030

Lab ID: 23-S1941  
Client ID: 9256 Inlet #2 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 9256 Inlet  
Sample Date: 6/29/23  
Sample Volume: 365. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	4.72	0.010	1.72	0.0036

Lab ID: 23-S1942  
Client ID: 9256 Outlet #1 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 9256 Outlet  
Sample Date: 6/28/23  
Sample Volume: 375. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	17.1	0.010	6.40	0.0038

Lab ID: 23-S1943  
Client ID: 9256 Outlet #2 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 9256 Outlet  
Sample Date: 6/29/23  
Sample Volume: 335. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	2.49	0.010	0.834	0.0034

Lab ID: 23-S1944  
Client ID: 8901 Inlet #1 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 8901 Inlet  
Sample Date: 6/28/23  
Sample Volume: 350. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	43.2	0.010	15.1	0.0035

Lab ID: 23-S1945  
Client ID: 8901 Inlet #2 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 8901 Inlet  
Sample Date: 6/29/23  
Sample Volume: 290. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	4.40	0.010	1.28	0.0029

Lab ID: 23-S1946  
Client ID: 8901 Outlet #1 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 8901 Outlet  
Sample Date: 6/28/23  
Sample Volume: 355. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	20.0	0.010	7.11	0.0036

Lab ID: 23-S1947  
Client ID: 8901 Outlet #2 0061  
Site: PCC Structural: LPC - Milwaukie  
Source: 8901 Outlet  
Sample Date: 6/29/23  
Sample Volume: 325. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	9.50	0.010	3.09	0.0032

Lab ID: 23-S1948  
Client ID: 0.5M KOH Reagent Blank  
Site: PCC Structural: LPC - Milwaukie  
Sample Date: 6/30/23  
Sample Volume: 295. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	0.432	0.010	0.127	0.0030

Lab ID: 23-S1949  
Client ID: DI Reagent Blank  
Site: PCC Structural: LPC - Milwaukie  
Sample Date: 6/30/23  
Sample Volume: 103. mL

Analyte	µg/L		µg/sample	
	Conc.	DL	Conc.	DL
Cr VI	0.0250	0.010	0.0026	0.0010

# QA/QC Report

Client Name: Mostardi Platt  
Project Number: M050  
Analytical Technique: ICP-OES  
Instrument: Perkin Elmer Optima 8300  
Sample Description: EPA Method 29 Front Half  
Report Number: 23-351

## Blank Data

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Ag	ICB	< DL	2.00
Ag	Meth_Blk	< DL	2.00
Ag	CCB	< DL	2.00
Ag	CCB	< DL	2.00
Ag	ICB	< DL	2.00
Ag	CCB	< DL	2.00
Al	ICB	< DL	30.0
Al	Meth_Blk	< DL	30.0
Al	CCB	< DL	30.0
Al	CCB	< DL	30.0
Al	CCB	< DL	30.0
Ba	ICB	< DL	0.500
Ba	Meth_Blk	< DL	0.500
Ba	CCB	< DL	0.500
Ba	CCB	< DL	0.500
Cr	ICB	< DL	0.800
Cr	Meth_Blk	< DL	0.800
Cr	CCB	< DL	0.800
Cr	CCB	< DL	0.800
Cr	CCB	< DL	0.800
Cr	ICB	< DL	0.800
Cr	CCB	< DL	0.800
Cr	CCB	< DL	0.800
Mn	ICB	< DL	0.300
Mn	Meth_Blk	< DL	0.300
Mn	CCB	< DL	0.300
Mn	CCB	< DL	0.300
Ni	ICB	< DL	3.00
Ni	Meth_Blk	< DL	3.00
Ni	CCB	< DL	3.00
Ni	CCB	< DL	3.00
Ni	CCB	< DL	3.00
Ni	ICB	< DL	3.00
Ni	CCB	< DL	3.00
Ni	CCB	< DL	3.00

## QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: ICP-OES  
 Instrument: Perkin Elmer Optima 8300  
 Sample Description: EPA Method 29 Front Half  
 Report Number: 23-351

### **Blank Data (continued)**

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Ni	CCB	< DL	3.00
P	ICB	< DL	20.0
P	Meth_Blk	< DL	20.0
P	CCB	< DL	20.0
P	CCB	< DL	20.0
Zn	ICB	< DL	3.00
Zn	Meth_Blk	< DL	3.00
Zn	CCB	< DL	3.00
Zn	CCB	< DL	3.00
Zn	CCB	< DL	3.00
Zn	ICB	< DL	3.00
Zn	CCB	< DL	3.00
Zn	CCB	< DL	3.00
Zn	CCB	< DL	3.00

ICB: Initial Calibration Blank CCB: Continuing Calibration Blank

\*: Sample Media Blank (SM\_Blk) concentration in µg/filter

Method Blank is in control if Method Blank results are <10% of sample results

### **Calibration QC**

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Ag	ICV	2500.	2518.	100.7
Ag	LL-CCV	10.00	9.283	92.8
Ag	LL-LCS	9.000	9.376	104.2
Ag	CCV	2500.	2363.	94.5
Ag	CCV	2500.	2292.	91.7
Ag	ICV	2500.	2516.	100.6
Ag	LL-CCV	10.00	7.793	77.9
Ag	CCV	2500.	2472.	98.9
Al	ICV	2500.	2501.	100.0
Al	LL-CCV	150.0	149.3	99.5
Al	LL-LCS	75.00	87.87	117.2
Al	CCV	2500.	2609.	104.4
Al	CCV	2500.	2616.	104.6
Al	CCV	2500.	2589.	103.6

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-CCV Limits: 60% - 140% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

## QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: ICP-OES  
 Instrument: Perkin Elmer Optima 8300  
 Sample Description: EPA Method 29 Front Half  
 Report Number: 23-351

### Calibration QC (continued)

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Al	CCV	2500.	2581.	103.2
Ba	ICV	2500.	2529.	101.2
Ba	LL-CCV	2.500	2.871	114.8
Ba	LL-LCS	1.500	1.725	115.0
Ba	CCV	2500.	2600.	104.0
Ba	CCV	2500.	2607.	104.3
Ba	CCV	2500.	2572.	102.9
Cr	ICV	2500.	2476.	99.0
Cr	LL-CCV	4.000	4.566	114.2
Cr	LL-LCS	2.000	2.208	110.4
Cr	CCV	2500.	2542.	101.7
Cr	CCV	2500.	2509.	100.4
Cr	CCV	2500.	2499.	100.0
Cr	ICV	2500.	2459.	98.4
Cr	LL-CCV	4.000	4.661	116.5
Cr	CCV	2500.	2449.	98.0
Cr	CCV	2500.	2449.	98.0
Cr	CCV	2500.	2469.	98.8
Mn	ICV	2500.	2552.	102.1
Mn	LL-CCV	1.500	1.698	113.2
Mn	LL-LCS	1.000	1.114	111.4
Mn	CCV	2500.	2623.	104.9
Mn	CCV	2500.	2591.	103.6
Mn	CCV	2500.	2572.	102.9
Ni	ICV	2500.	2426.	97.0
Ni	LL-CCV	15.00	15.34	102.3
Ni	LL-LCS	6.000	5.478	91.3
Ni	CCV	2500.	2476.	99.0
Ni	CCV	2500.	2430.	97.2
Ni	CCV	2500.	2435.	97.4
Ni	ICV	2500.	2396.	95.8
Ni	LL-CCV	15.00	14.94	99.6
Ni	CCV	2500.	2419.	96.8
Ni	CCV	2500.	2419.	96.8
Ni	CCV	2500.	2419.	96.8
P	ICV	2500.	2508.	100.3
P	LL-CCV	100.0	108.7	108.7

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-CCV Limits: 60% - 140% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

## QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: ICP-OES  
 Instrument: Perkin Elmer Optima 8300  
 Sample Description: EPA Method 29 Front Half  
 Report Number: 23-351

### Calibration QC (continued)

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
P	LL-LCS	75.00	70.68	94.2
P	CCV	2500.	2548.	101.9
P	CCV	2500.	2550.	102.0
P	CCV	2500.	2569.	102.8
Zn	ICV	2500.	2517.	100.7
Zn	LL-CCV	15.00	16.53	110.2
Zn	LL-LCS	6.000	6.847	114.1
Zn	CCV	2500.	2582.	103.3
Zn	CCV	2500.	2545.	101.8
Zn	CCV	2500.	2537.	101.5
Zn	ICV	2500.	2501.	100.0
Zn	LL-CCV	15.00	17.60	117.3
Zn	CCV	2500.	2482.	99.3
Zn	CCV	2500.	2484.	99.4
Zn	CCV	2500.	2509.	100.4

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-CCV Limits: 60% - 140% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

### Replicate Data

Analyte	Sample ID	Sample Conc. µg/L	Replicate Conc. µg/L	RPD
Ag	23-S1834	4.58	3.13	37.6 *
Al	23-S1834	2940	3020	2.65
Ba	23-S1834	85.4	85.1	0.43
Cr	23-S1834	3570	3560	0.28
Mn	23-S1834	65.9	65.6	0.46
Ni	23-S1834	26100	26200	0.42
P	23-S1834	441.	440.	0.16
Zn	23-S1834	435.	434.	0.07

RPD =  $\{(sample-replicate)/[(sample+replicate)/2]\} \times 100$

N/C: RPD is not calculated when sample or replicate is below detection limit

Replicate Limit: 20% RPD

\*: per EPA CLP protocol, control limits do not apply if sample and/or replicate concentration is less than 5x the detection limit

# QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: ICP-OES  
 Instrument: Perkin Elmer Optima 8300  
 Sample Description: EPA Method 29 Front Half  
 Report Number: 23-351

## Laboratory Control Sample/Matrix Post Spike Analysis

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Ag	LCS	< 2	2550.	2500	102.
Ag	LCS-Duplicate	< 2	2579.	2500	103.
Ag	23-S1839	3.379	2536.	2500	101.
Al	kv:LL-CCV	149.3	2677.	2500	101.
Al	kv:LL-CCV	149.3	2697.	2500	102.
Al	23-S1839	3054.	8240.	5000	104.
Ba	LCS	< 0.5	2506.	2500	100.
Ba	LCS-Duplicate	< 0.5	2532.	2500	101.
Ba	23-S1839	26.65	2493.	2500	98.7
Cr	LCS	< 0.8	2572.	2500	103.
Cr	LCS-Duplicate	< 0.8	2562.	2500	102.
Cr	23-S1839	5172.	9513.	5000	86.8
Mn	LCS	< 0.3	2640.	2500	106.
Mn	LCS-Duplicate	< 0.3	2629.	2500	105.
Mn	23-S1839	70.99	2550.	2500	99.2
Ni	LCS	< 3	2575.	2500	103.
Ni	LCS-Duplicate	< 3	2597.	2500	104.
Ni	23-S1839	40250	84290	50000	88.1
P	LCS	< 20	2693.	2500	108.
P	LCS-Duplicate	< 20	2678.	2500	107.
P	23-S1839	437.3	3008.	2500	103.
Zn	LCS	< 3	2746.	2500	110.
Zn	LCS-Duplicate	< 3	2726.	2500	109.
Zn	23-S1839	565.9	3120.	2500	102.

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

## LCS Duplicate Data

Analyte	Sample ID	Original Conc. µg/L	Replicate Conc. µg/L	RPD
Ag	LCS-Duplicate	2550.	2579.	1.13
Al	LCS-Duplicate	2677.	2697.	0.74
Ba	LCS-Duplicate	2506.	2532.	1.03
Cr	LCS-Duplicate	2572.	2562.	0.39
Mn	LCS-Duplicate	2640.	2629.	0.42
Ni	LCS-Duplicate	2575.	2597.	0.85
P	LCS-Duplicate	2693.	2678.	0.56
Zn	LCS-Duplicate	2746.	2726.	0.73

RPD = {(sample-duplicate)/[(sample+duplicate)/2]}x100

Duplicate Limit: 20% RPD

# QA/QC Report

Client Name: Mostardi Platt  
Project Number: M050  
Analytical Technique: ICP-MS  
Instrument: Agilent 7850  
Sample Description: EPA Method 29 Front Half  
Report Number: 23-351

## Blank Data

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
As	ICB	< DL	1.00
As	CCB	< DL	1.00
As	Meth_Blk	< 10	1.00
As	CCB	< DL	1.00
As	CCB	< DL	1.00
As	CCB	< DL	1.00
Be	ICB	< DL	0.020
Be	CCB	< DL	0.020
Be	Meth_Blk	< 0.2	0.020
Be	CCB	< DL	0.020
Be	CCB	< DL	0.020
Be	CCB	< DL	0.020
Cd	ICB	< DL	0.020
Cd	CCB	< DL	0.020
Cd	Meth_Blk	< 0.2	0.020
Cd	CCB	< DL	0.020
Cd	CCB	< DL	0.020
Cd	CCB	< DL	0.020
Co	ICB	< DL	0.050
Co	CCB	< DL	0.050
Co	Meth_Blk	0.923	0.050
Co	CCB	< DL	0.050
Co	CCB	< DL	0.050
Co	CCB	< DL	0.050
Co	CCB	< DL	0.050
Cu	ICB	< DL	0.100
Cu	CCB	< DL	0.100
Cu	Meth_Blk	< 1	0.100
Cu	CCB	< DL	0.100
Cu	CCB	< DL	0.100
Cu	CCB	< DL	0.100
Pb	ICB	< DL	0.050
Pb	CCB	< DL	0.050
Pb	Meth_Blk	< 0.5	0.050
Pb	CCB	< DL	0.050

## **QA/QC Report**

Client Name: Mostardi Platt  
Project Number: M050  
Analytical Technique: ICP-MS  
Instrument: Agilent 7850  
Sample Description: EPA Method 29 Front Half  
Report Number: 23-351

### **Blank Data (continued)**

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Pb	CCB	< DL	0.050
Pb	CCB	< DL	0.050
Pb	CCB	< DL	0.050
Sb	ICB	< DL	0.400
Sb	CCB	< DL	0.400
Sb	Meth_Blk	< 4	0.400
Sb	CCB	< DL	0.400
Sb	CCB	< DL	0.400
Sb	CCB	< DL	0.400
Se	ICB	< DL	0.200
Se	CCB	< DL	0.200
Se	Meth_Blk	< 2	0.200
Se	CCB	< DL	0.200
Se	CCB	< DL	0.200
Se	CCB	< DL	0.200
Se	CCB	< DL	0.200
Tl	ICB	< DL	0.040
Tl	CCB	< DL	0.040
Tl	Meth_Blk	< 0.4	0.040
Tl	CCB	< DL	0.040
Tl	CCB	< DL	0.040
Tl	CCB	< DL	0.040
V	ICB	< DL	0.030
V	CCB	< DL	0.030
V	Meth_Blk	< 0.3	0.030
V	CCB	< DL	0.030
V	CCB	< DL	0.030
V	CCB	< DL	0.030

ICB: Initial Calibration Blank CCB: Continuing Calibration Blank

\*: Sample Media Blank (SM\_Blk) concentration in µg/filter

Method Blank is in control if Method Blank results are <10% of sample results

# QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: ICP-MS  
 Instrument: Agilent 7850  
 Sample Description: EPA Method 29 Front Half  
 Report Number: 23-351

## Calibration QC

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
As	ICV	100.0	100.3	100.3
As	CCV	100.0	97.45	97.4
As	LL-LCS	20.00	25.02	125.1
As	CCV	100.0	95.55	95.6
As	CCV	100.0	94.68	94.7
As	CCV	100.0	95.66	95.7
As	CCV	100.0	95.83	95.8
Be	ICV	100.0	98.34	98.3
Be	CCV	100.0	95.78	95.8
Be	LL-LCS	0.500	0.505	101.0
Be	CCV	100.0	100.3	100.3
Be	CCV	100.0	102.2	102.2
Be	CCV	100.0	103.6	103.6
Be	CCV	100.0	101.1	101.1
Cd	ICV	100.0	98.99	99.0
Cd	CCV	100.0	96.14	96.1
Cd	LL-LCS	1.500	1.411	94.1
Cd	CCV	100.0	96.66	96.7
Cd	CCV	100.0	98.84	98.8
Cd	CCV	100.0	97.83	97.8
Cd	CCV	100.0	96.16	96.2
Co	ICV	100.0	99.22	99.2
Co	CCV	100.0	97.70	97.7
Co	LL-LCS	1.500	2.519	167.9
Co	CCV	100.0	99.13	99.1
Co	CCV	100.0	100.1	100.1
Co	CCV	100.0	100.1	100.1
Co	CCV	100.0	97.19	97.2
Cu	ICV	100.0	101.9	101.9
Cu	CCV	100.0	99.80	99.8
Cu	LL-LCS	15.00	15.26	101.7
Cu	CCV	100.0	100.2	100.2
Cu	CCV	100.0	101.4	101.4
Cu	CCV	100.0	102.1	102.1
Cu	CCV	100.0	98.39	98.4
Pb	ICV	100.0	100.8	100.8
Pb	CCV	100.0	98.03	98.0

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-CCV Limits: 60% - 140% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

# QA/QC Report

Client Name: Mostardi Platt  
Project Number: M050  
Analytical Technique: ICP-MS  
Instrument: Agilent 7850  
Sample Description: EPA Method 29 Front Half  
Report Number: 23-351

## Calibration QC (continued)

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Pb	LL-LCS	15.00	14.19	94.6
Pb	CCV	100.0	96.09	96.1
Pb	CCV	100.0	97.32	97.3
Pb	CCV	100.0	95.65	95.6
Pb	CCV	100.0	95.43	95.4
Sb	ICV	100.0	99.17	99.2
Sb	CCV	100.0	95.90	95.9
Sb	LL-LCS	15.00	14.77	98.5
Sb	CCV	100.0	94.52	94.5
Sb	CCV	100.0	94.60	94.6
Sb	CCV	100.0	94.14	94.1
Sb	CCV	100.0	93.52	93.5
Se	ICV	100.0	99.65	99.6
Se	CCV	100.0	94.86	94.9
Se	LL-LCS	25.00	26.62	106.5
Se	CCV	100.0	93.45	93.4
Se	CCV	100.0	91.20	91.2
Se	CCV	100.0	91.73	91.7
Se	CCV	100.0	93.50	93.5
Tl	ICV	100.0	100.8	100.8
Tl	CCV	100.0	98.70	98.7
Tl	LL-LCS	30.00	28.87	96.2
Tl	CCV	100.0	96.86	96.9
Tl	CCV	100.0	99.48	99.5
Tl	CCV	100.0	97.49	97.5
Tl	CCV	100.0	97.72	97.7
V	ICV	100.0	100.3	100.3
V	CCV	100.0	98.62	98.6
V	LL-LCS	3.000	3.019	100.6
V	CCV	100.0	97.61	97.6
V	CCV	100.0	98.39	98.4
V	CCV	100.0	98.43	98.4
V	CCV	100.0	97.36	97.4

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-CCV Limits: 60% - 140% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

# QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: ICP-MS  
 Instrument: Agilent 7850  
 Sample Description: EPA Method 29 Front Half  
 Report Number: 23-351

## Replicate Data

Analyte	Sample ID	Sample Conc. µg/L	Replicate Conc. µg/L	RPD
As	23-S1834	< 10	< 10	N/C *
Be	23-S1834	< 0.2	< 0.2	N/C *
Cd	23-S1834	5.03	4.84	3.83
Co	23-S1834	834.	813.	2.48
Cu	23-S1834	1280	1260	1.81
Pb	23-S1834	9.87	9.78	0.97
Sb	23-S1834	< 4	< 4	N/C *
Se	23-S1834	4.18	3.88	7.39
Tl	23-S1834	< 0.4	< 0.4	N/C *
V	23-S1834	10.1	9.69	4.20

$$RPD = \{[(sample - replicate) / ((sample + replicate) / 2)]\} \times 100$$

N/C: RPD is not calculated when sample or replicate is below detection limit

Replicate Limit: 20% RPD

\*: per EPA CLP protocol, control limits do not apply if sample and/or replicate concentration is less than 5x the detection limit

## Laboratory Control Sample/Matrix Post Spike Analysis

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
As	LCS	< 10	2339.	2500	93.6
As	LCS-Duplicate	< 10	2353.	2500	94.1
As	23-S1839	< 10	904.5	1000	90.4
Be	LCS	< 0.2	2422.	2500	96.9
Be	LCS-Duplicate	< 0.2	2418.	2500	96.7
Be	23-S1839	< 0.2	932.9	1000	93.3
Cd	LCS	< 0.2	2401.	2500	96.0
Cd	LCS-Duplicate	< 0.2	2396.	2500	95.8
Cd	23-S1839	1.060	941.9	1000	94.1
Co	LCS	0.923	2531.	2500	101.
Co	LCS-Duplicate	0.923	2497.	2500	99.8
Co	23-S1839	1259.	2208.	1000	94.9
Cu	LCS	< 1	2557.	2500	102.
Cu	LCS-Duplicate	< 1	2514.	2500	101.
Cu	23-S1839	1582.	2539.	1000	95.7
Pb	LCS	< 0.5	2436.	2500	97.4
Pb	LCS-Duplicate	< 0.5	2432.	2500	97.3
Pb	23-S1839	4.594	930.3	1000	92.6

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

## QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: ICP-MS  
 Instrument: Agilent 7850  
 Sample Description: EPA Method 29 Front Half  
 Report Number: 23-351

### **Laboratory Control Sample/Matrix Post Spike Analysis (continued)**

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Sb	LCS	< 4	2333.	2500	93.3
Sb	LCS-Duplicate	< 4	2331.	2500	93.2
Sb	23-S1839	< 4	900.3	1000	90.0
Se	LCS	< 2	2337.	2500	93.5
Se	LCS-Duplicate	< 2	2328.	2500	93.1
Se	23-S1839	< 2	872.8	1000	87.3
Tl	LCS	< 0.4	2445.	2500	97.8
Tl	LCS-Duplicate	< 0.4	2430.	2500	97.2
Tl	23-S1839	< 0.4	945.1	1000	94.5
V	LCS	< 0.3	2417.	2500	96.7
V	LCS-Duplicate	< 0.3	2408.	2500	96.3
V	23-S1839	8.290	958.2	1000	95.0

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

### **LCS Duplicate Data**

Analyte	Sample ID	Original Conc. µg/L	Replicate Conc. µg/L	RPD
As	LCS-Duplicate	2339.	2353.	0.60
Be	LCS-Duplicate	2422.	2418.	0.17
Cd	LCS-Duplicate	2401.	2396.	0.21
Co	LCS-Duplicate	2531.	2497.	1.35
Cu	LCS-Duplicate	2557.	2514.	1.70
Pb	LCS-Duplicate	2436.	2432.	0.16
Sb	LCS-Duplicate	2333.	2331.	0.09
Se	LCS-Duplicate	2337.	2328.	0.39
Tl	LCS-Duplicate	2445.	2430.	0.62
V	LCS-Duplicate	2417.	2408.	0.37

RPD =  $\{(sample-duplicate)/[(sample+duplicate)/2]\} \times 100$

Duplicate Limit: 20% RPD

# QA/QC Report

Client Name: Mostardi Platt  
Project Number: M050  
Analytical Technique: ICP-OES  
Instrument: Perkin Elmer Optima 8300  
Sample Description: EPA Method 29 Back Half  
Report Number: 23-351

## Blank Data

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Ag	ICB	< DL	2.00
Ag	Meth_Blk	< DL	2.00
Ag	CCB	< DL	2.00
Ag	CCB	< DL	2.00
Ag	CCB	< DL	2.00
Al	ICB	< DL	30.0
Al	Meth_Blk	< DL	30.0
Al	CCB	< DL	30.0
Al	CCB	< DL	30.0
As	ICB	< DL	7.00
As	Meth_Blk	< DL	7.00
As	CCB	< DL	7.00
As	CCB	< DL	7.00
As	CCB	< DL	7.00
Ba	ICB	< DL	0.500
Ba	Meth_Blk	< DL	0.500
Ba	CCB	< DL	0.500
Ba	CCB	< DL	0.500
Be	ICB	< DL	0.200
Be	Meth_Blk	< DL	0.200
Be	CCB	< DL	0.200
Be	CCB	< DL	0.200
Cr	ICB	< DL	0.800
Cr	Meth_Blk	< DL	0.800
Cr	CCB	< DL	0.800
Cr	CCB	< DL	0.800
Cu	ICB	< DL	5.00
Cu	Meth_Blk	< DL	5.00
Cu	CCB	< DL	5.00
Cu	CCB	< DL	5.00
Mn	ICB	< DL	0.300
Mn	Meth_Blk	< DL	0.300
Mn	CCB	< DL	0.300
Mn	CCB	< DL	0.300

## **QA/QC Report**

Client Name: Mostardi Platt  
Project Number: M050  
Analytical Technique: ICP-OES  
Instrument: Perkin Elmer Optima 8300  
Sample Description: EPA Method 29 Back Half  
Report Number: 23-351

### **Blank Data (continued)**

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Mn	CCB	< DL	0.300
Ni	ICB	< DL	3.00
Ni	Meth_Blk	< DL	3.00
Ni	CCB	< DL	3.00
Ni	CCB	< DL	3.00
P	ICB	< DL	20.0
P	Meth_Blk	< DL	20.0
P	CCB	< DL	20.0
P	CCB	< DL	20.0
Pb	ICB	< DL	5.00
Pb	Meth_Blk	< DL	5.00
Pb	CCB	< DL	5.00
Pb	CCB	< DL	5.00
Se	ICB	< DL	15.0
Se	Meth_Blk	< DL	15.0
Se	CCB	< DL	15.0
Se	CCB	< DL	15.0
Se	CCB	< DL	15.0
Tl	ICB	< DL	10.0
Tl	Meth_Blk	< DL	10.0
Tl	CCB	< DL	10.0
Tl	CCB	< DL	10.0
Tl	CCB	< DL	10.0
V	ICB	< DL	1.00
V	Meth_Blk	< DL	1.00
V	CCB	< DL	1.00
V	CCB	< DL	1.00
V	CCB	< DL	1.00
Zn	ICB	< DL	3.00
Zn	Meth_Blk	3.39	3.00
Zn	CCB	< DL	3.00
Zn	CCB	< DL	3.00
Zn	CCB	< DL	3.00

ICB: Initial Calibration Blank CCB: Continuing Calibration Blank

\*: Sample Media Blank (SM\_Blk) concentration in µg/filter

Method Blank is in control if Method Blank results are <10% of sample results

## QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: ICP-OES  
 Instrument: Perkin Elmer Optima 8300  
 Sample Description: EPA Method 29 Back Half  
 Report Number: 23-351

### Calibration QC

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Ag	ICV	2500.	2496.	99.8
Ag	LL-CCV	10.00	9.577	95.8
Ag	LL-LCS	9.000	8.402	93.4
Ag	CCV	2500.	2469.	98.8
Ag	CCV	2500.	2416.	96.6
Ag	CCV	2500.	2277.	91.1
Al	ICV	2500.	2555.	102.2
Al	LL-CCV	150.0	152.2	101.5
Al	LL-LCS	75.00	142.9	190.5
Al	CCV	2500.	2550.	102.0
Al	CCV	2500.	2511.	100.4
Al	CCV	2500.	2515.	100.6
As	ICV	2500.	2513.	100.5
As	LL-CCV	35.00	32.90	94.0
As	LL-LCS	20.00	17.68	88.4
As	CCV	2500.	2525.	101.0
As	CCV	2500.	2546.	101.8
As	CCV	2500.	2550.	102.0
Ba	ICV	2500.	2557.	102.3
Ba	LL-CCV	2.500	2.669	106.8
Ba	LL-LCS	1.500	1.598	106.5
Ba	CCV	2500.	2540.	101.6
Ba	CCV	2500.	2531.	101.2
Ba	CCV	2500.	2552.	102.1
Be	ICV	2500.	2527.	101.1
Be	LL-CCV	1.000	1.006	100.6
Be	LL-LCS	0.500	0.372	74.4
Be	CCV	2500.	2523.	100.9
Be	CCV	2500.	2509.	100.4
Be	CCV	2500.	2498.	99.9
Cr	ICV	2500.	2488.	99.5
Cr	LL-CCV	4.000	4.593	114.8
Cr	LL-LCS	2.000	1.992	99.6
Cr	CCV	2500.	2505.	100.2
Cr	CCV	2500.	2508.	100.3
Cr	CCV	2500.	2538.	101.5
Cu	ICV	2500.	2392.	95.7

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-CCV Limits: 60% - 140% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

## QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: ICP-OES  
 Instrument: Perkin Elmer Optima 8300  
 Sample Description: EPA Method 29 Back Half  
 Report Number: 23-351

### Calibration QC (continued)

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Cu	LL-CCV	25.00	27.31	109.2
Cu	LL-LCS	15.00	15.24	101.6
Cu	CCV	2500.	2416.	96.6
Cu	CCV	2500.	2416.	96.6
Cu	CCV	2500.	2457.	98.3
Mn	ICV	2500.	2566.	102.6
Mn	LL-CCV	1.500	1.721	114.7
Mn	LL-LCS	1.000	1.383	138.3
Mn	CCV	2500.	2586.	103.4
Mn	CCV	2500.	2586.	103.4
Mn	CCV	2500.	2621.	104.8
Ni	ICV	2500.	2443.	97.7
Ni	LL-CCV	15.00	15.68	104.5
Ni	LL-LCS	6.000	5.931	98.8
Ni	CCV	2500.	2450.	98.0
Ni	CCV	2500.	2456.	98.2
Ni	CCV	2500.	2461.	98.4
P	ICV	2500.	2527.	101.1
P	LL-CCV	100.0	105.7	105.7
P	LL-LCS	75.00	66.59	88.8
P	CCV	2500.	2510.	100.4
P	CCV	2500.	2462.	98.5
P	CCV	2500.	2460.	98.4
Pb	ICV	2500.	2455.	98.2
Pb	LL-CCV	25.00	26.88	107.5
Pb	LL-LCS	15.00	14.07	93.8
Pb	CCV	2500.	2415.	96.6
Pb	CCV	2500.	2418.	96.7
Pb	CCV	2500.	2415.	96.6
Se	ICV	2500.	2475.	99.0
Se	LL-CCV	75.00	81.05	108.1
Se	LL-LCS	30.00	32.14	107.1
Se	CCV	2500.	2460.	98.4
Se	CCV	2500.	2427.	97.1
Se	CCV	2500.	2400.	96.0
Tl	ICV	2500.	2472.	98.9
Tl	LL-CCV	50.00	53.14	106.3

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-CCV Limits: 60% - 140% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

## QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: ICP-OES  
 Instrument: Perkin Elmer Optima 8300  
 Sample Description: EPA Method 29 Back Half  
 Report Number: 23-351

### Calibration QC (continued)

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Tl	LL-LCS	30.00	29.80	99.3
Tl	CCV	2500.	2491.	99.6
Tl	CCV	2500.	2498.	99.9
Tl	CCV	2500.	2498.	99.9
V	ICV	2500.	2465.	98.6
V	LL-CCV	5.000	4.878	97.6
V	LL-LCS	3.000	2.567	85.6
V	CCV	2500.	2417.	96.7
V	CCV	2500.	2417.	96.7
V	CCV	2500.	2442.	97.7
Zn	ICV	2500.	2530.	101.2
Zn	LL-CCV	15.00	16.58	110.5
Zn	LL-LCS	6.000	8.323	138.7
Zn	CCV	2500.	2551.	102.0
Zn	CCV	2500.	2546.	101.8
Zn	CCV	2500.	2582.	103.3

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-CCV Limits: 60% - 140% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

### Replicate Data

Analyte	Sample ID	Sample Conc. µg/L	Replicate Conc. µg/L	RPD
Ag	23-S1835	5.17	4.54	13.0 *
Al	23-S1835	355.	362.	1.95
As	23-S1835	< 7	< 7	N/C *
Ba	23-S1835	28.3	28.4	0.11
Be	23-S1835	< 0.2	< 0.2	N/C *
Cr	23-S1835	80.0	80.6	0.73
Cu	23-S1835	116.	115.	0.78
Mn	23-S1835	84.4	84.8	0.50
Ni	23-S1835	115.	114.	0.79
P	23-S1835	123.	126.	1.93
Pb	23-S1835	< 5	< 5	N/C *
Se	23-S1835	74.3	82.9	10.9 *
Tl	23-S1835	< 10	< 10	N/C *

RPD =  $\{(sample-replicate)/[(sample+replicate)/2]\} \times 100$

N/C: RPD is not calculated when sample or replicate is below detection limit

Replicate Limit: 20% RPD

\*: per EPA CLP protocol, control limits do not apply if sample and/or replicate concentration is less than 5x the detection limit

# QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: ICP-OES  
 Instrument: Perkin Elmer Optima 8300  
 Sample Description: EPA Method 29 Back Half  
 Report Number: 23-351

## Replicate Data (continued)

Analyte	Sample ID	Sample Conc. µg/L	Replicate Conc. µg/L	RPD
V	23-S1835	1.80	1.80	0.28 *
Zn	23-S1835	280.	266.	5.13

$$RPD = \{(\text{sample}-\text{replicate})/[(\text{sample}+\text{replicate})/2]\} \times 100$$

N/C: RPD is not calculated when sample or replicate is below detection limit

Replicate Limit: 20% RPD

\*: per EPA CLP protocol, control limits do not apply if sample and/or replicate concentration is less than 5x the detection limit

## Laboratory Control Sample/Matrix Post Spike Analysis

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Ag	LCS	< 2	2285.	2500	91.4
Ag	LCS-Duplicate	< 2	2285.	2500	91.4
Ag	23-S1840	2.831	2214.	2500	88.4
Al	kv:LL-CCV	152.2	2566.	2500	96.6
Al	kv:LL-CCV	152.2	2395.	2500	89.7
Al	23-S1840	305.7	2536.	2500	89.2
As	LCS	< 7	2377.	2500	95.1
As	LCS-Duplicate	< 7	2403.	2500	96.1
As	23-S1840	< 7	2274.	2500	91.0
Ba	LCS	< 0.5	2462.	2500	98.5
Ba	LCS-Duplicate	< 0.5	2461.	2500	98.4
Ba	23-S1840	31.12	2373.	2500	93.7
Be	LCS	< 0.2	2398.	2500	95.9
Be	LCS-Duplicate	< 0.2	2449.	2500	98.0
Be	23-S1840	< 0.2	2290.	2500	91.6
Cr	LCS	< 0.8	2419.	2500	96.8
Cr	LCS-Duplicate	< 0.8	2428.	2500	97.1
Cr	23-S1840	32.21	2354.	2500	92.9
Cu	LCS	< 5	2322.	2500	92.9
Cu	LCS-Duplicate	< 5	2324.	2500	93.0
Cu	23-S1840	21.66	2253.	2500	89.3
Mn	LCS	< 0.3	2479.	2500	99.2
Mn	LCS-Duplicate	< 0.3	2488.	2500	99.5
Mn	23-S1840	221.1	2584.	2500	94.5
Ni	LCS	< 3	2352.	2500	94.1
Ni	LCS-Duplicate	< 3	2385.	2500	95.4

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

# QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: ICP-OES  
 Instrument: Perkin Elmer Optima 8300  
 Sample Description: EPA Method 29 Back Half  
 Report Number: 23-351

## **Laboratory Control Sample/Matrix Post Spike Analysis (continued)**

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Ni	23-S1840	105.8	2362.	2500	90.2
P	LCS	< 20	2367.	2500	94.7
P	LCS-Duplicate	< 20	2382.	2500	95.3
P	23-S1840	140.6	2378.	2500	89.5
Pb	LCS	< 5	2314.	2500	92.6
Pb	LCS-Duplicate	< 5	2361.	2500	94.4
Pb	23-S1840	6.394	2208.	2500	88.1
Se	LCS	< 15	2385.	2500	95.4
Se	LCS-Duplicate	< 15	2420.	2500	96.8
Se	23-S1840	< 15	2238.	2500	89.5
Tl	LCS	< 10	2354.	2500	94.2
Tl	LCS-Duplicate	< 10	2395.	2500	95.8
Tl	23-S1840	< 10	2233.	2500	89.3
V	LCS	< 1	2366.	2500	94.6
V	LCS-Duplicate	< 1	2423.	2500	96.9
V	23-S1840	1.165	2313.	2500	92.5
Zn	LCS	3.387	2414.	2500	96.4
Zn	LCS-Duplicate	3.387	2452.	2500	97.9
Zn	23-S1840	190.1	2477.	2500	91.5

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

## **LCS Duplicate Data**

Analyte	Sample ID	Original Conc. µg/L	Replicate Conc. µg/L	RPD
Ag	LCS-Duplicate	2285.	2285.	0.00
Al	LCS-Duplicate	2566.	2395.	6.89
As	LCS-Duplicate	2377.	2403.	1.09
Ba	LCS-Duplicate	2462.	2461.	0.04
Be	LCS-Duplicate	2398.	2449.	2.10
Cr	LCS-Duplicate	2419.	2428.	0.37
Cu	LCS-Duplicate	2322.	2324.	0.09
Mn	LCS-Duplicate	2479.	2488.	0.36
Ni	LCS-Duplicate	2352.	2385.	1.39
P	LCS-Duplicate	2367.	2382.	0.63
Pb	LCS-Duplicate	2314.	2361.	2.01
Se	LCS-Duplicate	2385.	2420.	1.46
Tl	LCS-Duplicate	2354.	2395.	1.73
V	LCS-Duplicate	2366.	2423.	2.38
Zn	LCS-Duplicate	2414.	2452.	1.56

$$RPD = \{(sample-duplicate)\}/[(sample+duplicate)/2]\times100$$

Duplicate Limit: 20% RPD

## QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: ICP-MS  
 Instrument: Agilent 7850  
 Sample Description: EPA Method 29 Back Half  
 Report Number: 23-351

### **Blank Data**

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Cd	ICB	< DL	0.020
Cd	Meth_Blk	< 0.2	0.020
Cd	CCB	< DL	0.020
Cd	CCB	< DL	0.020
Cd	CCB	< DL	0.020
Co	ICB	< DL	0.050
Co	Meth_Blk	1.51	0.050
Co	CCB	< DL	0.050
Co	CCB	< DL	0.050
Sb	ICB	< DL	0.400
Sb	Meth_Blk	< 4	0.400
Sb	CCB	< DL	0.400
Sb	CCB	< DL	0.400
Sb	CCB	< DL	0.400

ICB: Initial Calibration Blank CCB: Continuing Calibration Blank

\*: Sample Media Blank (SM\_Blk) concentration in µg/filter

Method Blank is in control if Method Blank results are <10% of sample results

### **Calibration QC**

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Cd	ICV	100.0	98.99	99.0
Cd	LL-LCS	1.500	1.393	92.9
Cd	CCV	100.0	97.69	97.7
Cd	CCV	100.0	96.14	96.1
Cd	CCV	100.0	96.66	96.7
Co	ICV	100.0	99.22	99.2
Co	LL-LCS	1.500	2.933	195.5
Co	CCV	100.0	98.79	98.8
Co	CCV	100.0	97.70	97.7
Co	CCV	100.0	99.13	99.1
Sb	ICV	100.0	99.17	99.2
Sb	LL-LCS	15.00	13.90	92.7
Sb	CCV	100.0	97.78	97.8
Sb	CCV	100.0	95.90	95.9

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-CCV Limits: 60% - 140% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

# QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: ICP-MS  
 Instrument: Agilent 7850  
 Sample Description: EPA Method 29 Back Half  
 Report Number: 23-351

## Calibration QC (continued)

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Sb	CCV	100.0	94.52	94.5

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-CCV Limits: 60% - 140% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

## Replicate Data

Analyte	Sample ID	Sample Conc. µg/L	Replicate Conc. µg/L	RPD
Cd	23-S1835	2.63	2.44	7.45
Co	23-S1835	3.64	3.55	2.53
Sb	23-S1835	< 4	< 4	N/C *

RPD =  $\{(sample-replicate)/[(sample+replicate)/2]\} \times 100$

N/C: RPD is not calculated when sample or replicate is below detection limit

Replicate Limit: 20% RPD

\*: per EPA CLP protocol, control limits do not apply if sample and/or replicate concentration is less than 5x the detection limit

## Laboratory Control Sample/Matrix Post Spike Analysis

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Cd	LCS	< 0.2	2422.	2500	96.9
Cd	LCS-Duplicate	< 0.2	2415.	2500	96.6
Cd	23-S1840	2.380	912.9	1000	91.1
Co	LCS	1.506	2430.	2500	97.1
Co	LCS-Duplicate	1.506	2455.	2500	98.1
Co	23-S1840	4.348	929.6	1000	92.5
Sb	LCS	< 4	2404.	2500	96.2
Sb	LCS-Duplicate	< 4	2338.	2500	93.5
Sb	23-S1840	< 4	916.5	1000	91.6

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

## LCS Duplicate Data

Analyte	Sample ID	Original Conc. µg/L	Replicate Conc. µg/L	RPD
Cd	LCS-Duplicate	2422.	2415.	0.29
Co	LCS-Duplicate	2430.	2455.	1.02
Sb	LCS-Duplicate	2404.	2338.	2.78

RPD =  $\{(sample-duplicate)/[(sample+duplicate)/2]\} \times 100$

Duplicate Limit: 20% RPD

## QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: Cold Vapor Atomic Absorption  
 Instrument: Nippon 3320A CVAA  
 Sample Description: EPA Method 29  
 Report Number: 23-351

### Blank Data

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Hg	ICB	< DL	0.007
Hg	MB_FH	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007

ICB: Initial Calibration Blank CCB: Continuing Calibration Blank

\*: Sample Media Blank (SM\_Blk) concentration in µg/filter

Method Blank is in control if Method Blank results are <10% of sample results

### Calibration QC

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Hg	ICV	5.00	5.06	101.1
Hg	LL-LCS	0.020	0.023	115.0
Hg	LL-LCS	0.020	0.021	105.0
Hg	CCV	5.00	5.06	101.2
Hg	CCV	5.00	5.13	102.6
Hg	CCV	5.00	5.05	101.0
Hg	CCV	5.00	5.10	102.0
Hg	CCV	5.00	5.18	103.7
Hg	CCV	5.00	5.14	102.8

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

### Duplicate Data

All samples analyzed in duplicate. The reported concentrations are the average of the two measurements.

### Laboratory Control Sample/Matrix Spike Analysis

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Hg	23-S1343	< 0.007	5.03	5.00	101.

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

## **QA/QC Report**

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: Cold Vapor Atomic Absorption  
 Instrument: Nippon 3320A CVAA  
 Sample Description: EPA Method 29  
 Report Number: 23-351

### **Blank Data**

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Hg	ICB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007

ICB: Initial Calibration Blank CCB: Continuing Calibration Blank

\*: Sample Media Blank (SM\_Blk) concentration in µg/filter

Method Blank is in control if Method Blank results are <10% of sample results

### **Calibration QC**

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Hg	ICV	5.00	5.23	104.6
Hg	LL-LCS	0.020	0.022	110.0
Hg	CCV	5.00	5.40	108.0
Hg	CCV	5.00	5.21	104.3
Hg	CCV	5.00	5.22	104.3
Hg	CCV	5.00	5.19	103.7
Hg	CCV	5.00	5.19	103.8
Hg	CCV	5.00	5.16	103.2

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

### **Duplicate Data**

All samples analyzed in duplicate. The reported concentrations are the average of the two measurements.

### **Laboratory Control Sample/Matrix Spike Analysis**

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Hg	23-S1840	0.087	5.28	5.00	104.
Hg	23-S1880	0.133	5.24	5.00	102.

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

## **QA/QC Report**

Client Name: Mostardi Platt  
Project Number: M050  
Analytical Technique: Cold Vapor Atomic Absorption  
Instrument: Nippon 3320A CVAA  
Sample Description: EPA Method 29  
Report Number: 23-351

### **Blank Data**

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Hg	ICB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007

ICB: Initial Calibration Blank CCB: Continuing Calibration Blank

\*: Sample Media Blank (SM\_Blk) concentration in µg/filter

Method Blank is in control if Method Blank results are <10% of sample results

### **Calibration QC**

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Hg	ICV	5.00	5.08	101.7
Hg	LL-LCS	0.020	0.018	90.0
Hg	CCV	5.00	5.02	100.5
Hg	CCV	5.00	5.02	100.4
Hg	CCV	5.00	5.05	101.0
Hg	CCV	5.00	5.22	104.3
Hg	CCV	5.00	5.05	101.0

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

### **Duplicate Data**

All samples analyzed in duplicate. The reported concentrations are the average of the two measurements.

# **QA/QC Report**

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: Cold Vapor Atomic Absorption  
 Instrument: Nippon 3320A CVAA  
 Sample Description: EPA Method 29  
 Report Number: 23-351

## **Blank Data**

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Hg	ICB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007

ICB: Initial Calibration Blank CCB: Continuing Calibration Blank

\*: Sample Media Blank (SM\_Blk) concentration in µg/filter

Method Blank is in control if Method Blank results are <10% of sample results

## **Calibration QC**

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Hg	ICV	5.00	5.09	101.7
Hg	LL-LCS	0.020	0.023	115.0
Hg	CCV	5.00	5.07	101.4
Hg	CCV	5.00	5.06	101.1
Hg	CCV	5.00	5.06	101.3

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

## **Duplicate Data**

All samples analyzed in duplicate. The reported concentrations are the average of the two measurements.

## **Laboratory Control Sample/Matrix Spike Analysis**

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Hg	23-S1872	0.075	5.20	5.00	103.

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

# **QA/QC Report**

Client Name: Mostardi Platt  
Project Number: M050  
Analytical Technique: Cold Vapor Atomic Absorption  
Instrument: Nippon 3320A CVAA  
Sample Description: EPA Method 29  
Report Number: 23-351

## **Blank Data**

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Hg	ICB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007

ICB: Initial Calibration Blank CCB: Continuing Calibration Blank

\*: Sample Media Blank (SM\_Blk) concentration in µg/filter

Method Blank is in control if Method Blank results are <10% of sample results

## **Calibration QC**

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Hg	ICV	5.00	5.08	101.7
Hg	LL-LCS	0.020	0.018	90.0
Hg	CCV	5.00	5.16	103.1
Hg	CCV	5.00	5.15	103.0

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

## **Duplicate Data**

All samples analyzed in duplicate. The reported concentrations are the average of the two measurements.

## **Laboratory Control Sample/Matrix Spike Analysis**

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Hg	23-S1907	0.075	5.13	5.00	101.

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

# **QA/QC Report**

Client Name: Mostardi Platt  
Project Number: M050  
Analytical Technique: Cold Vapor Atomic Absorption  
Instrument: Nippon 3320A CVAA  
Sample Description: EPA Method 29  
Report Number: 23-351

## **Blank Data**

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Hg	ICB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007

ICB: Initial Calibration Blank CCB: Continuing Calibration Blank

\*: Sample Media Blank (SM\_Blk) concentration in µg/filter

Method Blank is in control if Method Blank results are <10% of sample results

## **Calibration QC**

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Hg	ICV	5.00	5.05	101.0
Hg	LL-LCS	0.020	0.021	105.0
Hg	CCV	5.00	4.97	99.4
Hg	CCV	5.00	4.94	98.8
Hg	CCV	5.00	4.97	99.4

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

## **Duplicate Data**

All samples analyzed in duplicate. The reported concentrations are the average of the two measurements.

## **Laboratory Control Sample/Matrix Spike Analysis**

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Hg	23-S1886	< 0.007	4.99	5.00	99.8

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

# **QA/QC Report**

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: Cold Vapor Atomic Absorption  
 Instrument: Nippon 3320A CVAA  
 Sample Description: EPA Method 29  
 Report Number: 23-351

## **Blank Data**

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Hg	ICB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007

ICB: Initial Calibration Blank CCB: Continuing Calibration Blank

\*: Sample Media Blank (SM\_Blk) concentration in µg/filter

Method Blank is in control if Method Blank results are <10% of sample results

## **Calibration QC**

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Hg	ICV	5.00	5.01	100.3
Hg	LL-LCS	0.020	0.021	105.0
Hg	CCV	5.00	5.07	101.5
Hg	CCV	5.00	5.07	101.4

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

## **Duplicate Data**

All samples analyzed in duplicate. The reported concentrations are the average of the two measurements.

## **Laboratory Control Sample/Matrix Spike Analysis**

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Hg	23-S1838	0.037	5.10	5.00	101.

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

# **QA/QC Report**

Client Name: Mostardi Platt  
Project Number: M050  
Analytical Technique: Cold Vapor Atomic Absorption  
Instrument: Nippon 3320A CVAA  
Sample Description: EPA Method 29  
Report Number: 23-351

## **Blank Data**

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Hg	ICB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007

ICB: Initial Calibration Blank CCB: Continuing Calibration Blank

\*: Sample Media Blank (SM\_Blk) concentration in µg/filter

Method Blank is in control if Method Blank results are <10% of sample results

## **Calibration QC**

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Hg	ICV	5.00	5.33	106.6
Hg	LL-LCS	0.020	0.024	120.0
Hg	CCV	5.00	5.27	105.4
Hg	CCV	5.00	5.31	106.2
Hg	CCV	5.00	5.20	104.0

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

## **Duplicate Data**

All samples analyzed in duplicate. The reported concentrations are the average of the two measurements.

## **Laboratory Control Sample/Matrix Spike Analysis**

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Hg	23-S1888	0.019	5.31	5.00	106.

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

## QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: Cold Vapor Atomic Absorption  
 Instrument: Nippon 3320A CVAA  
 Sample Description: EPA Method 29  
 Report Number: 23-351

### **Blank Data**

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Hg	ICB	< DL	0.007
Hg	MB_FH	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007

ICB: Initial Calibration Blank CCB: Continuing Calibration Blank

\*: Sample Media Blank (SM\_Blk) concentration in µg/filter

Method Blank is in control if Method Blank results are <10% of sample results

### **Calibration QC**

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Hg	ICV	5.00	5.03	100.5
Hg	LL-LCS	0.020	0.014	70.0
Hg	CCV	5.00	5.08	101.5
Hg	CCV	5.00	5.08	101.7

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

### **Duplicate Data**

All samples analyzed in duplicate. The reported concentrations are the average of the two measurements.

### **Laboratory Control Sample/Matrix Spike Analysis**

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Hg	LCS	< 0.007	4.61	5.00	92.2
Hg	LCS-Duplicate	< 0.007	4.58	5.00	91.6
Hg	23-S1834	< 0.007	5.11	5.00	102.

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

### **LCS Duplicate Data**

Analyte	Sample ID	Original Conc. µg/L	Replicate Conc. µg/L	RPD
Hg	LCS-Duplicate	4.61	4.58	0.70

RPD = {(sample-duplicate)/[(sample+duplicate)/2]}x100

Duplicate Limit: 20% RPD

# **QA/QC Report**

Client Name: Mostardi Platt  
Project Number: M050  
Analytical Technique: Cold Vapor Atomic Absorption  
Instrument: Nippon 3320A CVAA  
Sample Description: EPA Method 29  
Report Number: 23-351

## **Blank Data**

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Hg	ICB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007
Hg	CCB	< DL	0.007

ICB: Initial Calibration Blank CCB: Continuing Calibration Blank

\*: Sample Media Blank (SM\_Blk) concentration in µg/filter

Method Blank is in control if Method Blank results are <10% of sample results

## **Calibration QC**

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Hg	ICV	5.00	5.05	100.9
Hg	LL-LCS	0.020	< 0.007	ND
Hg	CCV	5.00	5.06	101.2
Hg	CCV	5.00	5.06	101.3
Hg	CCV	5.00	5.39	107.8

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

## **Duplicate Data**

All samples analyzed in duplicate. The reported concentrations are the average of the two measurements.

## **Laboratory Control Sample/Matrix Spike Analysis**

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Hg	23-S1874	< 0.007	5.17	5.00	103.

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

## QA/QC Report

Client Name: Mostardi Platt  
 Project Number: M050  
 Analytical Technique: Ion Chromatography-PCR  
 Instrument: Aquion Cr VI IC (1)  
 Sample Description: SW-846 Method 0061  
 Report Number: 23-351

### **Blank Data**

Analyte	Sample ID	Measured Conc. µg/L	DL Conc. µg/L
Cr VI	ICB	< DL	0.010
Cr VI	CCB	< DL	0.010
Cr VI	CCB	< DL	0.010
Cr VI	CCB	< DL	0.010
Cr VI	CCB	< DL	0.010

ICB: Initial Calibration Blank CCB: Continuing Calibration Blank

### **Calibration QC**

Analyte	Sample ID	Standard Conc. µg/L	Measured Conc. µg/L	Percent Recovery
Cr VI	ICV	0.500	0.529	105.8
Cr VI	LL-LCS	0.030	0.048	160.0
Cr VI	CCV	0.500	0.527	105.4
Cr VI	CCV	0.500	0.528	105.6
Cr VI	CCV	0.500	0.537	107.4
Cr VI	CCV	0.500	0.533	106.6

ICV: Initial Calibration Verification CCV: Continuing Calibration Verification

Calibration Verification Limits: 90% - 110% Recovery

Low Level-LCS Limits: 50% - 150% Recovery

LL-LCS results are insignificant if sample results are >10x LL-LCS concentration

### **Duplicate Data**

Analyte	Sample ID	Sample Conc. µg/L	Duplicate Conc. µg/L	RPD
Cr VI	23-S1930	261.	266.	1.71

RPD =  $\{(sample-duplicate)/[(sample+duplicate)/2]\} \times 100$

Duplicate Limit: 20% RPD

N/C: RPD is not calculated when sample or duplicate is below detection limit

\*: per EPA CLP protocol, control limits do not apply if sample and/or duplicate concentration is less than 5x the detection limit

### **Laboratory Control Sample/Matrix Spike Analysis**

Analyte	Sample ID	Sample Conc. µg/L	Spike Conc. µg/L	Spike Amount µg/L	Percent Recovery
Cr VI	23-S1931	348.	620.	250.	109.

LCS Limit: 80% - 120% Recovery

Spike Limit: 75% - 125% Recovery

\*: per EPA CLP protocol, control limits do not apply if spike concentration is less than 25% of the sample concentration

**CHESTER LABNET**  
**SOURCE SAMPLE RECEIPT CHECKLIST**

Client	Mostardi Platt	Date	6/30/2023
# Runs	18 + blanks	Report #	23-351

Package intact? hand delivered

Chain-of-Custody form inspected

- CoC present with samples?
- CoC indicates analytical methodology to be used? (eg M29, etc.)
- Has CoC been signed by client?
- Custody release date and time noted on CoC?

/	
/	
EPA 29, 0061	!!
No	
/	

All sample containers inspected

- Does number of samples match number on CoC form?
- Do all sample ID numbers match those on the CoC form?
- Did client mark sample volumes prior to shipment?
- Sample temperature recorded?
- Are the sample containers intact?
- If present, Audit Sample intact?
- Are signs of leakage present?

✓	
✓	!!
✓	!!
No	
✓ See 0061	!!
✓	!!
n/a	!!
No	*

Chain-of-Custody form signed and dated by CLN ✓

Corrective actions

- Client contacted due to mismatching sample ID numbers
- Client contacted due to broken sample container(s)
- Client contacted due to leaking sample container(s)
- Client contacted for verification of methodology?
- Corrective actions documented?
- Corrective actions accomplished?

-	
-	
-	
✓	
✓	
✓	

*Items marked !! shall be addressed prior to any analytical work being started.*

*Items marked \* shall be noted in case narrative upon reporting of results to client.*

Signed Pcl DL

Notes Called Eric to confirm analytes - CrVI only for 0061 samples. Cu should be on M29 list of metals.

---



---



---

Chain-of-Custody Form						
Project Number: M232604			Date Results Required:			
Client: PCC Structural			TAT Required:			
Plant/Test Location: LPC – Milwaukie, OR			Project Supervisor: EE			
Sample Number	Sample Date	Sample Point Identification		# of Conts	Sub Lab	Analysis Required
001	6/27/23	9203 North Inlet #1 M29 – Filter and 0.1N HNO <sub>3</sub> probe wash		2		M29*
002	6/27/23	9203 North Inlet #1 M29 – HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub> imps, 0.1N Rinse of empty imp, KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub> Imps, HCl Rinse		4		M29*
003	6/30/23	9203 North Inlet #2 M29 – Filter and 0.1N HNO <sub>3</sub> probe wash		2		M29*
004	6/30/23	9203 North Inlet #2 M29 – HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub> imps, 0.1N Rinse of empty imp, KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub> Imps, HCl Rinse		4		M29*
005	6/27/23	9203 Center Inlet #1 M29 – Filter and 0.1N HNO <sub>3</sub> probe wash		2		M29*
006	6/27/23	9203 Center Inlet #1 M29 – HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub> imps, 0.1N Rinse of empty imp, KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub> Imps, HCl Rinse		4		M29*
007	6/30/23	9203 Center Inlet #2 M29 – Filter and 0.1N HNO <sub>3</sub> probe wash		2		M29*
008	6/30/23	9203 Center Inlet #2 M29 – HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub> imps, 0.1N Rinse of empty imp, KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub> Imps, HCl Rinse		4		M29*
009	6/27/23	9203 South Inlet #1 M29 – Filter and 0.1N HNO <sub>3</sub> probe wash		2		M29*
010	6/27/23	9203 South Inlet #1 M29 – HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub> imps, 0.1N Rinse of empty imp, KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub> Imps, HCl Rinse		4		M29*
011	6/30/23	9203 South Inlet #2 M29 – Filter and 0.1N HNO <sub>3</sub> probe wash		2		M29*
012	6/30/23	9203 South Inlet #2 M29 – HNO <sub>3</sub> /H <sub>2</sub> O <sub>2</sub> imps, 0.1N Rinse of empty imp, KMnO <sub>4</sub> /H <sub>2</sub> SO <sub>4</sub> Imps, HCl Rinse		4		M29*
013	6/27/23	9203 North Outlet #1 M29 – Filter and 0.1N HNO <sub>3</sub> probe wash		2		M29*

# mostardi platt

014	6/27/23	9203 North Outlet #1 M29 – HNO3/H2O2 imps, 0.1N Rinse of empty imp, KMnO4/H2SO4 Imps, HCl Rinse	4		M29*	
015	6/30/23	9203 North Outlet #2 M29 – Filter and 0.1N HNO3 probe wash	2		M29*	
016	6/30/23	9203 North Outlet #2 M29 – HNO3/H2O2 imps, 0.1N Rinse of empty imp, KMnO4/H2SO4 Imps, HCl Rinse	4		M29*	
017	6/27/23	9203 South Outlet #1 M29 – Filter and 0.1N HNO3 probe wash	2		M29*	
018	6/27/23	9203 South Outlet #1 M29 – HNO3/H2O2 imps, 0.1N Rinse of empty imp, KMnO4/H2SO4 Imps, HCl Rinse	4		M29*	
019	6/30/23	9203 South Outlet #2 M29 – Filter and 0.1N HNO3 probe wash	2		M29*	
020	6/30/23	9203 South Outlet #2 M29 – HNO3/H2O2 imps, 0.1N Rinse of empty imp, KMnO4/H2SO4 Imps, HCl Rinse	4		M29*	
021	6/28/23	9256 Inlet #1 M29 – Filter and 0.1N HNO3 probe wash	2		M29*	
022	6/28/23	9256 Inlet #1 M29 – HNO3/H2O2 imps, 0.1N Rinse of empty imp, KMnO4/H2SO4 Imps, HCl Rinse	4		M29*	
023	6/29/23	9256 Inlet #2 M29 – Filter and 0.1N HNO3 probe wash	2		M29*	
024	6/29/23	9256 Outlet #2 M29 – HNO3/H2O2 imps, 0.1N Rinse of empty imp, KMnO4/H2SO4 Imps, HCl Rinse	4		M29*	
025	6/28/23	9256 Outlet #1 M29 – Filter and 0.1N HNO3 probe wash	2		M29*	
026	6/28/23	9256 Outlet #1 M29 – HNO3/H2O2 imps, 0.1N Rinse of empty imp, KMnO4/H2SO4 Imps, HCl Rinse	4		M29*	
027	6/29/23	9256 Outlet #2 M29 – Filter and 0.1N HNO3 probe wash	2		M29*	
028	6/29/23	9256 Outlet #2 M29 – HNO3/H2O2 imps, 0.1N Rinse of empty imp, KMnO4/H2SO4 Imps, HCl Rinse	4		M29*	
029	6/28/23	8901 Inlet #1 M29 – Filter and 0.1N HNO3 probe wash	2		M29*	

# mostardi platt

030	6/28/23	8901 Inlet #1 M29 – HNO3/H2O2 imps, 0.1N Rinse of empty imp, KMnO4/H2SO4 Imps, HCl Rinse	4		M29*	
031	6/29/23	8901 Inlet #2 M29 – Filter and 0.1N HNO3 probe wash	2		M29*	
032	6/29/23	8901 Outlet #2 M29 – HNO3/H2O2 imps, 0.1N Rinse of empty imp, KMnO4/H2SO4 Imps, HCl Rinse	4		M29*	
033	6/28/23	8901 Outlet #1 M29 – Filter and 0.1N HNO3 probe wash	2		M29*	
034	6/28/23	8901 Outlet #1 M29 – HNO3/H2O2 imps, 0.1N Rinse of empty imp, KMnO4/H2SO4 Imps, HCl Rinse	4		M29*	
035	6/29/23	8901 Outlet #2 M29 – Filter and 0.1N HNO3 probe wash	2		M29*	
036	6/29/23	8901 Outlet #2 M29 – HNO3/H2O2 imps, 0.1N Rinse of empty imp, KMnO4/H2SO4 Imps, HCl Rinse	4		M29*	
037	6/27/23	9203 North Inlet #1 0061 0.5M KOH	1		0061	23-5 1930
038	6/30/23	9203 North Inlet #2 0061 0.5M KOH	1		0061	1931
039	6/27/23	9203 Center Inlet #1 0061 0.5M KOH	1		0061	1932
040	6/30/23	9203 Center Inlet #2 0061 0.5M KOH	1		0061	1933
041	6/27/23	9203 South Inlet #1 0061 0.5M KOH	1		0061	1934
042	6/30/23	9203 South Inlet #2 0061 0.5M KOH	1		0061	1935
043	6/27/23	9203 North Outlet #1 0061 0.5M KOH	1		0061	1936
044	6/30/23	9203 North Outlet #2 0061 0.5M KOH	1		0061	1937
045	6/27/23	9203 South Outlet #1 0061 0.5M KOH	1		0061	1938
046	6/30/23	9203 South Outlet #2 0061 0.5M KOH	1		0061	1939
047	6/28/23	9256 Inlet #1 0061 0.5M KOH	1		0061	1940
048	6/29/23	9256 Inlet #2 0061 0.5M KOH	1		0061	1941
049	6/28/23	9256 Outlet #1 0061 0.5M KOH	1		0061	1942
050	6/29/23	9256 Outlet #2 0061 0.5M KOH	1		0061	1943
051	6/28/23	8901 Inlet #1 0061 0.5M KOH	1		0061	1944
052	6/29/23	8901 Inlet #2 0061 0.5M KOH	1		0061	1945

# mostardi platt

053	6/28/23	8901 Outlet #1 0061 0.5M KOH	1		0061	23-S 1946
054	6/29/23	8901 Outlet #2 0061 0.5M OKH	1		0061	1947
055	6/30/23	0.1N HNO3 Reagent Blank	1		M29*	
056	6/30/23	DI Water Reagent Blank	1		M29*	
057	6/30/23	HNO3/H2O2 Reagent Blank	1		M29*	
058	6/30/23	KMnO4/H2SO4 Reagent Blank	1		M29*	
059	6/30/23	8N HCl Reagent Blank	1		M29*	
060	6/30/23	Filter Blank	3		M29*	
061	6/30/23	0.5M KOH Reagent Blank	1		0061	23-S 1948
062	6/30/23	DI Reagent Blank	1		0061	1949
Delivered to Lab by: Date/Time:		Received by:  6.30.23 ©1815	Date/Time:	Processed by: Date/Time:		

Laboratory Notes: \*M29 target metals include: Aluminum, Arsenic, Antimony, Barium, Beryllium, Cadmium, Chromium, Cobalt, Lead, Manganese, Mercury, Nickel, Phosphorous, Selenium, Silver, Thallium, Vanadium, Zinc.

0061 rec'd temp. 6°C

23-S1834	9203 N Inlet #1 Filter & Probe	23-S1884	9256 Inlet #1 Filter & Probe
23-S1835	9203 N Inlet #1 HNO3/H2O2	23-S1885	9256 Inlet #1 HNO3/H2O2
23-S1836	9203 N Inlet #1 Empty Imp	23-S1886	9256 Inlet #1 Empty Imp
23-S1837	9203 N Inlet #1 KMnO4	23-S1887	9256 Inlet #1 KMnO4
23-S1838	9203 N Inlet #1 HCl Rinse	23-S1888	9256 Inlet #1 HCl Rinse
23-S1839	9203 N Inlet #2 Filter & Probe	23-S1889	9256 Inlet #2 Filter & Probe
23-S1840	9203 N Inlet #2 HNO3/H2O2	23-S1890	9256 Inlet #2 HNO3/H2O2
23-S1841	9203 N Inlet #2 Empty Imp	23-S1891	9256 Inlet #2 Empty Imp
23-S1842	9204 N Inlet #2 KMnO4	23-S1892	9256 Inlet #2 KMnO4
23-S1843	9203 N Inlet #2 HCl Rinse	23-S1893	9256 Inlet #2 HCl Rinse
23-S1844	9203 C Inlet #1 Filter & Probe	23-S1894	9256 Outlet #1 Filter & Probe
23-S1845	9203 C Inlet #1 HNO3/H2O2	23-S1895	9256 Outlet #1 HNO3/H2O2
23-S1846	9203 C Inlet #1 Empty Imp	23-S1896	9256 Outlet #1 Empty Imp
23-S1847	9203 C Inlet #1 KMnO4	23-S1897	9256 Outlet #1 KMnO4
23-S1848	9203 C Inlet #1 HCl Rinse	23-S1898	9256 Outlet #1 HCl Rinse
23-S1849	9203 C Inlet #2 Filter & Probe	23-S1899	9256 Outlet #2 Filter & Probe
23-S1850	9203 C Inlet #2 HNO3/H2O2	23-S1900	9256 Outlet #2 HNO3/H2O2
23-S1851	9203 C Inlet #2 Empty Imp	23-S1901	9256 Outlet #2 Empty Imp
23-S1852	9203 C Inlet #2 KMnO4	23-S1902	9256 Outlet #2 KMnO4
23-S1853	9203 C Inlet #2 HCl Rinse	23-S1903	9256 Outlet #2 HCl Rinse
23-S1854	9203 S Inlet #1 Filter & Probe	23-S1904	8901 Inlet #1 Filter & Probe
23-S1855	9203 S Inlet #1 HNO3/H2O2	23-S1905	8901 Inlet #1 HNO3/H2O2
23-S1856	9203 S Inlet #1 Empty Imp	23-S1906	8901 Inlet #1 Empty Imp
23-S1857	9203 S Inlet #1 KMnO4	23-S1907	8901 Inlet #1 KMnO4
23-S1858	9203 S Inlet #1 HCl Rinse	23-S1908	8901 Inlet #1 HCl Rinse
23-S1859	9203 S Inlet #2 Filter & Probe	23-S1909	8901 Inlet #2 Filter & Probe
23-S1860	9203 S Inlet #2 HNO3/H2O2	23-S1910	8901 Inlet #2 HNO3/H2O2
23-S1861	9203 S Inlet #2 Empty Imp	23-S1911	8901 Inlet #2 Empty Imp
23-S1862	9203 S Inlet #2 KMnO4	23-S1912	8901 Inlet #2 KMnO4
23-S1863	9203 S Inlet #2 HCl Rinse	23-S1913	8901 Inlet #2 HCl Rinse
23-S1864	9203 N Outlet #1 Filter & Probe	23-S1914	8901 Outlet #1 Filter & Probe
23-S1865	9203 N Outlet #1 HNO3/H2O2	23-S1915	8901 Outlet #1 HNO3/H2O2
23-S1866	9203 N Outlet #1 Empty Imp	23-S1916	8901 Outlet #1 Empty Imp
23-S1867	9203 N Outlet #1 KMnO4	23-S1917	8901 Outlet #1 KMnO4
23-S1868	9203 N Outlet #1 HCl Rinse	23-S1918	8901 Outlet #1 HCl Rinse
23-S1869	9203 N Outlet #2 Filter & Probe	23-S1919	8901 Outlet #2 Filter & Probe
23-S1870	9203 N Outlet #2 HNO3/H2O2	23-S1920	8901 Outlet #2 HNO3/H2O2
23-S1871	9203 N Outlet #2 Empty Imp	23-S1921	8901 Outlet #2 Empty Imp
23-S1872	9203 N Outlet #2 KMnO4	23-S1922	8901 Outlet #2 KMnO4
23-S1873	9203 N Outlet #2 HCl Rinse	23-S1923	8901 Outlet #2 HCl Rinse
23-S1874	9203 S Outlet #1 Filter & Probe	23-S1924	Filter Blank
23-S1875	9203 S Outlet #1 HNO3/H2O2	23-S1925	0.1N HNO3 Blank
23-S1876	9203 S Outlet #1 Empty Imp	23-S1926	HNO3/H2O2 Blank
23-S1877	9203 S Outlet #1 KMnO4	23-S1927	DI Water Blank
23-S1878	9203 S Outlet #1 HCl Rinse	23-S1928	KMnO4/H2SO4 Blank
23-S1879	9203 S Outlet #2 Filter & Probe	23-S1929	8N HCl Blank
23-S1880	9203 S Outlet #2 HNO3/H2O2		
23-S1881	9203 S Outlet #2 Empty Imp		
23-S1882	9203 S Outlet #2 KMnO4		
23-S1883	9203 S Outlet #2 HCl Rinse		

## **RAW DATA**

Available upon request

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Inlet West**

**Test Method: 29**

<b>Source Condition:</b>		<b>Batch Process</b>	
		<b>Run 1</b>	<b>Run 2</b>
<b>Identify Analyte:</b>	Aluminum (Al)		
<b>Molecular Weight:</b>	26.98	ADL	ADL
<b>ug (net) collected:</b>		752.21	765.89
<b>Identify Analyte:</b>	Antimony (Sb)		
<b>Molecular Weight:</b>	121.76	BDL	BDL
<b>ug (net) collected:</b>		1.628	1.552
<b>Identify Analyte:</b>	Arsenic (As)		
<b>Molecular Weight:</b>	74.92	BDL	BDL
<b>ug (net) collected:</b>		3.6	3.496
<b>Identify Analyte:</b>	Barium (Ba)		
<b>Molecular Weight:</b>	137.33	ADL	ADL
<b>ug (net) collected:</b>		21.1	6.2
<b>Identify Analyte:</b>	Beryllium (Be)		
<b>Molecular Weight:</b>	9.01	BDL	BDL
<b>ug (net) collected:</b>		0.081	0.078
<b>Identify Analyte:</b>	Cadmium (Cd)		
<b>Molecular Weight:</b>	112.41	ADL	ADL
<b>ug (net) collected:</b>		1.673	0.593
<b>Identify Analyte:</b>	Chromium (Cr)		
<b>Molecular Weight:</b>	52	ADL	ADL
<b>ug (net) collected:</b>		903.165	1293
<b>Identify Analyte:</b>	Cobalt (Co)		
<b>Molecular Weight:</b>	58.93	ADL	ADL
<b>ug (net) collected:</b>		208.571	314.657
<b>Identify Analyte:</b>	Copper (Cu)		
<b>Molecular Weight:</b>	63.55	ADL	ADL
<b>ug (net) collected:</b>		338.2	398.99

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Inlet West**

**Test Method: 29**

Source Condition:		Batch Process	
		Run 1	Run 2
Identify Analyte:	Lead (Pb)		
Molecular Weight:	207.2	DLL	ADL
ug (net) collected:		3.105	1.882
Identify Analyte:	Manganese (Mn)		
Molecular Weight:	54.94	ADL	ADL
ug (net) collected:		27.767	46.167
Identify Analyte:	Mercury (Hg)		
Molecular Weight:	200.59	DLL	DLL
ug (net) collected:		0.66395	0.54544
Identify Analyte:	Nickel (Ni)		
Molecular Weight:	58.69	ADL	ADL
ug (net) collected:		6536.42	10113.2
Identify Analyte:	Phosphorus (P)		
Molecular Weight:	30.97	ADL	ADL
ug (net) collected:		116.75	115.75
Identify Analyte:	Selenium (Se)		
Molecular Weight:	78.96	ADL	BDL
ug (net) collected:		12.75	2.57
Identify Analyte:	Silver (Ag)		
Molecular Weight:	107.87	ADL	ADL
ug (net) collected:		1.952	1.236
Identify Analyte:	Thallium (Tl)		
Molecular Weight:	204.38	BDL	BDL
ug (net) collected:		1.67	1.48
Identify Analyte:	Vanadium (V)		
Molecular Weight:	50.94	ADL	ADL
ug (net) collected:		2.812	2.231
Identify Analyte:	Zinc (Zn)		
Molecular Weight:	65.38	ADL	ADL
ug (net) collected:		147.781	161.981

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Inlet Center**

**Test Method: 29**

<b>Source Condition:</b>		<b>Batch Process</b>	
		<b>Run 1</b>	<b>Run 2</b>
<b>Identify Analyte:</b>	Aluminum (Al)		
<b>Molecular Weight:</b>	26.98	ADL	ADL
<b>ug (net) collected:</b>		784.32	889.675
<b>Identify Analyte:</b>	Antimony (Sb)		
<b>Molecular Weight:</b>	121.76	BDL	BDL
<b>ug (net) collected:</b>		1.452	1.576
<b>Identify Analyte:</b>	Arsenic (As)		
<b>Molecular Weight:</b>	74.92	BDL	BDL
<b>ug (net) collected:</b>		3.291	3.51
<b>Identify Analyte:</b>	Barium (Ba)		
<b>Molecular Weight:</b>	137.33	ADL	ADL
<b>ug (net) collected:</b>		53.06	7.9
<b>Identify Analyte:</b>	Beryllium (Be)		
<b>Molecular Weight:</b>	9.01	BDL	BDL
<b>ug (net) collected:</b>		0.073	0.079
<b>Identify Analyte:</b>	Cadmium (Cd)		
<b>Molecular Weight:</b>	112.41	ADL	ADL
<b>ug (net) collected:</b>		2.88	1.171
<b>Identify Analyte:</b>	Chromium (Cr)		
<b>Molecular Weight:</b>	52	ADL	ADL
<b>ug (net) collected:</b>		741.965	1360.895
<b>Identify Analyte:</b>	Cobalt (Co)		
<b>Molecular Weight:</b>	58.93	ADL	ADL
<b>ug (net) collected:</b>		136.997	44.42
<b>Identify Analyte:</b>	Copper (Cu)		
<b>Molecular Weight:</b>	63.55	ADL	ADL
<b>ug (net) collected:</b>		409.1	779.37

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Inlet Center**

**Test Method: 29**

<b>Source Condition:</b>		<b>Batch Process</b>	
		<b>Run 1</b>	<b>Run 2</b>
<b>Identify Analyte:</b>	Lead (Pb)		
<b>Molecular Weight:</b>	207.2	ADL	DLL
<b>ug (net) collected:</b>		3.44	1.87
<b>Identify Analyte:</b>	Manganese (Mn)		
<b>Molecular Weight:</b>	54.94	ADL	ADL
<b>ug (net) collected:</b>		116.567	128.167
<b>Identify Analyte:</b>	Mercury (Hg)		
<b>Molecular Weight:</b>	200.59	DLL	DLL
<b>ug (net) collected:</b>		0.42937	0.85616
<b>Identify Analyte:</b>	Nickel (Ni)		
<b>Molecular Weight:</b>	58.69	ADL	ADL
<b>ug (net) collected:</b>		4859.42	7859.52
<b>Identify Analyte:</b>	Phosphorus (P)		
<b>Molecular Weight:</b>	30.97	ADL	ADL
<b>ug (net) collected:</b>		156.82	118.35
<b>Identify Analyte:</b>	Selenium (Se)		
<b>Molecular Weight:</b>	78.96	BDL	BDL
<b>ug (net) collected:</b>		2.2	2.66
<b>Identify Analyte:</b>	Silver (Ag)		
<b>Molecular Weight:</b>	107.87	ADL	ADL
<b>ug (net) collected:</b>		6.276	2.58
<b>Identify Analyte:</b>	Thallium (Tl)		
<b>Molecular Weight:</b>	204.38	BDL	BDL
<b>ug (net) collected:</b>		1.23	1.54
<b>Identify Analyte:</b>	Vanadium (V)		
<b>Molecular Weight:</b>	50.94	ADL	ADL
<b>ug (net) collected:</b>		2.876	4.054
<b>Identify Analyte:</b>	Zinc (Zn)		
<b>Molecular Weight:</b>	65.38	ADL	ADL
<b>ug (net) collected:</b>		658.981	184.11

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Inlet East**

**Test Method: 29**

<b>Source Condition:</b>		<b>Batch Process</b>	
		<b>Run 1</b>	<b>Run 2</b>
<b>Identify Analyte:</b>	Aluminum (Al)		
<b>Molecular Weight:</b>	26.98	ADL	ADL
<b>ug (net) collected:</b>		816.62	1134.49
<b>Identify Analyte:</b>	Antimony (Sb)		
<b>Molecular Weight:</b>	121.76	BDL	DLL
<b>ug (net) collected:</b>		1.508	1.636
<b>Identify Analyte:</b>	Arsenic (As)		
<b>Molecular Weight:</b>	74.92	DLL	BDL
<b>ug (net) collected:</b>		4.499	3.284
<b>Identify Analyte:</b>	Barium (Ba)		
<b>Molecular Weight:</b>	137.33	ADL	ADL
<b>ug (net) collected:</b>		42.39	10.88
<b>Identify Analyte:</b>	Beryllium (Be)		
<b>Molecular Weight:</b>	9.01	BDL	BDL
<b>ug (net) collected:</b>		0.075	0.072
<b>Identify Analyte:</b>	Cadmium (Cd)		
<b>Molecular Weight:</b>	112.41	ADL	ADL
<b>ug (net) collected:</b>		6.081	6.813
<b>Identify Analyte:</b>	Chromium (Cr)		
<b>Molecular Weight:</b>	52	ADL	ADL
<b>ug (net) collected:</b>		2639.815	4891.935
<b>Identify Analyte:</b>	Cobalt (Co)		
<b>Molecular Weight:</b>	58.93	ADL	ADL
<b>ug (net) collected:</b>		43.777	54.838
<b>Identify Analyte:</b>	Copper (Cu)		
<b>Molecular Weight:</b>	63.55	ADL	ADL
<b>ug (net) collected:</b>		293.23	681.99

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Inlet East**

**Test Method: 29**

<b>Source Condition:</b>		<b>Batch Process</b>	
		<b>Run 1</b>	<b>Run 2</b>
<b>Identify Analyte:</b>	Lead (Pb)		
<b>Molecular Weight:</b>	207.2	DLL	ADL
<b>ug (net) collected:</b>		1.665	1.958
<b>Identify Analyte:</b>	Manganese (Mn)		
<b>Molecular Weight:</b>	54.94	ADL	ADL
<b>ug (net) collected:</b>		50.467	270.967
<b>Identify Analyte:</b>	Mercury (Hg)		
<b>Molecular Weight:</b>	200.59	DLL	DLL
<b>ug (net) collected:</b>		0.46014	0.53442
<b>Identify Analyte:</b>	Nickel (Ni)		
<b>Molecular Weight:</b>	58.69	ADL	ADL
<b>ug (net) collected:</b>		8119.83	20414.22
<b>Identify Analyte:</b>	Phosphorus (P)		
<b>Molecular Weight:</b>	30.97	ADL	ADL
<b>ug (net) collected:</b>		114.55	131.54
<b>Identify Analyte:</b>	Selenium (Se)		
<b>Molecular Weight:</b>	78.96	BDL	BDL
<b>ug (net) collected:</b>		2.4	2.18
<b>Identify Analyte:</b>	Silver (Ag)		
<b>Molecular Weight:</b>	107.87	ADL	DLL
<b>ug (net) collected:</b>		4.039	2.914
<b>Identify Analyte:</b>	Thallium (Tl)		
<b>Molecular Weight:</b>	204.38	BDL	BDL
<b>ug (net) collected:</b>		1.37	1.22
<b>Identify Analyte:</b>	Vanadium (V)		
<b>Molecular Weight:</b>	50.94	ADL	ADL
<b>ug (net) collected:</b>		5.587	7.035
<b>Identify Analyte:</b>	Zinc (Zn)		
<b>Molecular Weight:</b>	65.38	ADL	ADL
<b>ug (net) collected:</b>		182.881	296.481

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Outlet West**

**Test Method: 29**

<b>Source Condition:</b>		<b>Batch Process</b>	
		<b>Run 1</b>	<b>Run 2</b>
<b>Identify Analyte:</b>	Aluminum (Al)		
<b>Molecular Weight:</b>	26.98	ADL	ADL
<b>ug (net) collected:</b>		538.745	505.59
<b>Identify Analyte:</b>	Antimony (Sb)		
<b>Molecular Weight:</b>	121.76	BDL	BDL
<b>ug (net) collected:</b>		1.464	1.472
<b>Identify Analyte:</b>	Arsenic (As)		
<b>Molecular Weight:</b>	74.92	BDL	BDL
<b>ug (net) collected:</b>		3.312	3.326
<b>Identify Analyte:</b>	Barium (Ba)		
<b>Molecular Weight:</b>	137.33	ADL	DDL
<b>ug (net) collected:</b>		5.22	2.62
<b>Identify Analyte:</b>	Beryllium (Be)		
<b>Molecular Weight:</b>	9.01	BDL	BDL
<b>ug (net) collected:</b>		0.073	0.074
<b>Identify Analyte:</b>	Cadmium (Cd)		
<b>Molecular Weight:</b>	112.41	ADL	ADL
<b>ug (net) collected:</b>		0.396	0.238
<b>Identify Analyte:</b>	Chromium (Cr)		
<b>Molecular Weight:</b>	52	ADL	ADL
<b>ug (net) collected:</b>		5.08	13.985
<b>Identify Analyte:</b>	Cobalt (Co)		
<b>Molecular Weight:</b>	58.93	BDL	ADL
<b>ug (net) collected:</b>		0.183	6.623
<b>Identify Analyte:</b>	Copper (Cu)		
<b>Molecular Weight:</b>	63.55	ADL	DLL
<b>ug (net) collected:</b>		3.69	2.09

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Outlet West**

**Test Method: 29**

Source Condition:		Batch Process	
		Run 1	Run 2
Identify Analyte:	Lead (Pb)		
Molecular Weight:	207.2	DLL	DLL
ug (net) collected:		1.708	0.758
Identify Analyte:	Manganese (Mn)		
Molecular Weight:	54.94	ADL	ADL
ug (net) collected:		49.967	19.907
Identify Analyte:	Mercury (Hg)		
Molecular Weight:	200.59	DLL	DLL
ug (net) collected:		1.6379	0.8741
Identify Analyte:	Nickel (Ni)		
Molecular Weight:	58.69	ADL	ADL
ug (net) collected:		32.86	46.31
Identify Analyte:	Phosphorus (P)		
Molecular Weight:	30.97	ADL	ADL
ug (net) collected:		92.35	88.68
Identify Analyte:	Selenium (Se)		
Molecular Weight:	78.96	BDL	BDL
ug (net) collected:		2.24	2.27
Identify Analyte:	Silver (Ag)		
Molecular Weight:	107.87	BDL	BDL
ug (net) collected:		0.732	0.736
Identify Analyte:	Thallium (Tl)		
Molecular Weight:	204.38	BDL	BDL
ug (net) collected:		1.26	1.28
Identify Analyte:	Vanadium (V)		
Molecular Weight:	50.94	DLL	DLL
ug (net) collected:		0.226	0.208
Identify Analyte:	Zinc (Zn)		
Molecular Weight:	65.38	ADL	ADL
ug (net) collected:		18.081	11.241

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Outlet East**

**Test Method: 29**

<b>Source Condition:</b>		<b>Batch Process</b>	
		<b>Run 1</b>	<b>Run 2</b>
<b>Identify Analyte:</b>	Aluminum		
<b>Molecular Weight:</b>	26.98	ADL	ADL
<b>ug (net) collected:</b>		524.65	521.265
<b>Identify Analyte:</b>	Antimony (Sb)		
<b>Molecular Weight:</b>	121.76	BDL	DLL
<b>ug (net) collected:</b>		1.572	1.54
<b>Identify Analyte:</b>	Arsenic (As)		
<b>Molecular Weight:</b>	74.92	BDL	BDL
<b>ug (net) collected:</b>		3.5	3.382
<b>Identify Analyte:</b>	Barium (Ba)		
<b>Molecular Weight:</b>	137.33	ADL	DLL
<b>ug (net) collected:</b>		11.58	3.39
<b>Identify Analyte:</b>	Beryllium (Be)		
<b>Molecular Weight:</b>	9.01	BDL	BDL
<b>ug (net) collected:</b>		0.079	0.075
<b>Identify Analyte:</b>	Cadmium (Cd)		
<b>Molecular Weight:</b>	112.41	ADL	ADL
<b>ug (net) collected:</b>		0.563	0.153
<b>Identify Analyte:</b>	Chromium (Cr)		
<b>Molecular Weight:</b>	52	ADL	ADL
<b>ug (net) collected:</b>		2.815	32.165
<b>Identify Analyte:</b>	Cobalt (Co)		
<b>Molecular Weight:</b>	58.93	DLL	ADL
<b>ug (net) collected:</b>		0.211	12.772
<b>Identify Analyte:</b>	Copper (Cu)		
<b>Molecular Weight:</b>	63.55	ADL	ADL
<b>ug (net) collected:</b>		15.18	92.503

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Outlet East**

**Test Method: 29**

<b>Source Condition:</b>		<b>Batch Process</b>	
		<b>Run 1</b>	<b>Run 2</b>
<b>Identify Analyte:</b>	Lead (Pb)		
<b>Molecular Weight:</b>	207.2	DLL	DLL
<b>ug (net) collected:</b>		1.059	0.808
<b>Identify Analyte:</b>	Manganese (Mn)		
<b>Molecular Weight:</b>	54.94	ADL	ADL
<b>ug (net) collected:</b>		2.227	91.157
<b>Identify Analyte:</b>	Mercury (Hg)		
<b>Molecular Weight:</b>	200.59	DLL	DLL
<b>ug (net) collected:</b>		0.21768	0.5531
<b>Identify Analyte:</b>	Nickel (Ni)		
<b>Molecular Weight:</b>	58.69	ADL	ADL
<b>ug (net) collected:</b>		5.363	82.83
<b>Identify Analyte:</b>	Phosphorus (P)		
<b>Molecular Weight:</b>	30.97	ADL	ADL
<b>ug (net) collected:</b>		88.95	96.72
<b>Identify Analyte:</b>	Selenium (Se)		
<b>Molecular Weight:</b>	78.96	DLL	DLL
<b>ug (net) collected:</b>		4.01	3.1
<b>Identify Analyte:</b>	Silver (Ag)		
<b>Molecular Weight:</b>	107.87	BDL	BDL
<b>ug (net) collected:</b>		0.786	0.752
<b>Identify Analyte:</b>	Thallium (Tl)		
<b>Molecular Weight:</b>	204.38	BDL	BDL
<b>ug (net) collected:</b>		1.53	1.36
<b>Identify Analyte:</b>	Vanadium (V)		
<b>Molecular Weight:</b>	50.94	DLL	DLL
<b>ug (net) collected:</b>		0.285	0.247
<b>Identify Analyte:</b>	Zinc (Zn)		
<b>Molecular Weight:</b>	65.38	DLL	DLL
<b>ug (net) collected:</b>		27.081	24.281

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Inlet**

**Test Method: 0061**

**Source Condition:**

**Batch Process**

**Run 1      Run 2**

**Identify Analyte:** Hexavalent Chromium (Cr+6)

**Molecular Weight:** 52

**ug (net) collected:** 204

ADL

ADL

94

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Inlet East**

**Test Method: 0061**

**Source Condition:**

**Batch Process**

**Run 1      Run 2**

**Identify Analyte:** Hexavalent Chromium (Cr+6)

**Molecular Weight:** 52

**ug (net) collected:** 49.1      26.7

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Inlet West**

**Test Method: 0061**

**Source Condition:**

**Batch Process**

**Run 1      Run 2**

**Identify Analyte:** Hexavalent Chromium (Cr+6)

**Molecular Weight:** 52

**ug (net) collected:** 82.3      99.2

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Outlet East**

**Test Method: 0061**

**Source Condition:**

**Batch Process**

**Run 1      Run 2**

**Identify Analyte:** Hexavalent Chromium (Cr+6)

**Molecular Weight:** 52

**ug (net) collected:**

ADL      ADL

1.97      2.29

**Client: PCC Structural, Inc.**

**Facility: Large Parts Campus Facility - Milwaukie, OR**

**Test Location: BH9203 Outlet West**

**Test Method: 0061**

**Source Condition:**

**Batch Process**

**Run 1      Run 2**

**Identify Analyte:** Hexavalent Chromium (Cr+6)

**Molecular Weight:** 52

**ug (net) collected:**

ADL      ADL

0.941      4.61

**END OF THE REPORT**