



CITY of THE DALLES

313 COURT STREET
THE DALLES, OREGON 97058

(541) 296-5481
FAX (541) 296-6906

April 22, 2024

**ADDENDUM #3
THE DALLES MUNICIPAL WI-FI ASSESSMENT
PROJECT NO. 2024-005**

The City of The Dalles is providing this Addendum to clarify the April 3, 2024, Request for Proposals for **Project No. 2024-005 THE DALLES MUNICIPAL WI-FI ASSESSMENT (RFP)**.

This Addendum provides clarifications to the RFP by openly answering questions the City has received on its substance. *None of these responses have resulted in any amendments to the existing solicitation or form of contract.*

- **Q1: What is the voltage of the existing light poles with photocells?**

A: Northern Wasco PUD's light poles lights are able to accept 120, 208, 240, 277 or 480 volts depending on the voltage available at the location of the light. The most common voltage the lights are connected to is 120 volts.

Pursuant to OAR 137-049-0250, you are not required to provide written acknowledgment of this addendum's receipt when you submit your bid.

CITY OF THE DALLES, OR

Ann Moorhead
Special Projects Coordinator
City of The Dalles

Project No. 2024-005 THE DALLES MUNICIPAL WI-FI ASSESSMENT