



Water Department Monthly Report

Month/ Year: **July, 2021**

Hours of Operation: **679.7**

Rainfall (inches): **0.00**

Water (gal)			
Total Treated:	46,578,000		Total Discharge:
	2,781,190		
Daily Average:	1,502,516		Daily Average:
	89,716		
Maximum Day:	1,876,000		Max . Dcg. Day:
	1,599,980		
Minimum Day:	982,000		Min. Dcg Day:
	30,000		

Chemicals (lbs.)	
825-B(ACH): 1,388.51	Soda Ash(Na ₂ CO ₃): 687.09
Chlorine(NaOCl): 708.00	FA Polymer: 15.69

Treated Water Averages	
Turbidity(NTU): 0.043	Cl ₂ Residual(mg/l): 0.99
pH: 7.83	Temperature(C): 21.2

Sampling		
BACT: 10	TOC: 0	Nitrate: 0
Alkalinity: 0	DBP: 0	VOC: 0
Other: DEQ Backwash Samples: 2		

Notes:
