



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 09/01/2022
Received: 08/23/2022
Sampled By: Ryan Hepler
Work Order: 2235011

C **Molalla, City of**
L Attn: Ryan Hepler
I PO Box 248
E Molalla OR, 97038
N Phone: (503) 829-5408
T

Project: 3rd Qtr samples
Project # : N/A
PWSID # : 4100534

Sampling Location: Filter effluent, Raw water
Sample Matrix: Drinking Water

Lab Number

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
2235011-01	Sample Name: Filter effluent TOC WTP-A Filtered Sampled: 8/23/22 8:15						
<i>Inorganics</i>							
Total Organic Carbon	2920	SM5310-C	mg/L	ND	0.50	-	08/30/22 21:46
2235011-02	Sample Name: Raw Water TOC CH-A Raw Sampled: 8/23/22 8:20						
<i>Inorganics</i>							
Total Organic Carbon	2920	SM5310-C	mg/L	0.92	0.50	-	08/30/22 22:25
2235011-03	Sample Name: Raw Water Alkalinity CH-A Raw Sampled: 8/23/22 8:20						
<i>Inorganics</i>							
Alkalinity (CaCO3)	1067	EPA 310.1	mg/L	39	2	-	08/23/22 14:30

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.