



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

Reported: 06/03/2022  
Received: 05/17/2022  
Sampled By: Ryan Hepler  
Work Order: 2137043

**C** **Molalla, City of**  
**L** Attn: Ryan Hepler  
**I** PO Box 248  
**E** Molalla OR, 97038  
**N** Phone: (503) 829-5408  
**T**

**Project:** 2nd Qtr samples  
Project # : N/A  
PWSID # : 4100534

Sampling Location: Filter effluent, Raw Water  
Sample Matrix: Drinking Water

**Lab Number**

	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
<b>2137043-01</b>	<b>Sample Name:</b> Filter effluent TOC WTP-A Filterd <b>Sampled:</b> 5/17/22 11:40						
<i>Inorganics</i>							
Total Organic Carbon	2920	SM5310-C	mg/L	ND	0.50	-	05/19/22 16:10
<b>2137043-02</b>	<b>Sample Name:</b> Raw Water TOC - CH-A Raw <b>Sampled:</b> 5/17/22 11:30						
<i>Inorganics</i>							
Total Organic Carbon	2920	SM5310-C	mg/L	0.57	0.50	-	05/19/22 16:10
<b>2137043-03</b>	<b>Sample Name:</b> Raw Water Alkalinity - CH-A Raw <b>Sampled:</b> 5/17/22 11:30						
<i>Inorganics</i>							
Alkalinity (CaCO3)	1067	EPA 310.1	mg/L	19	2	-	05/26/22 12:30

**ND** = None detected at the MRL      **MRL** = Minimum Reporting Limit      **MCL** = Maximum Contamination Limit

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.