



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 11/11/2022
Received: 11/01/2022
Sampled By: Ryan Hepler
Work Order: 2305043

**C
L
I
E
N
T**
Molalla, City of
Attn: Ryan Hepler
PO Box 248
Molalla OR, 97038
Phone: (503) 829-5408

Project: 4th Quarter DBP's
Project # : N/A
PWSID # : 4100534

Sampling Location: 921 Meadowlawn Pl. , 12424 Toliver Rd
Sample Matrix: Drinking Water

Lab Number	Sample Name	Sampled: 11/1/22 8:45	Sample Composition: Treated Distribution				
2305043-01	921 Meadowlawn PI						

Haloacetic Acids	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date
A <i>Dibromoacetic Acid</i>		SM 6251B	mg/L	ND	0.0010		11/07/2022
A <i>Dichloroacetic Acid</i>		SM 6251B	mg/L	0.0082	0.0010		11/07/2022
A <i>Monobromoacetic Acid</i>		SM 6251B	mg/L	ND	0.0010		11/07/2022
A <i>Monochloroacetic Acid</i>		SM 6251B	mg/L	ND	0.0020		11/07/2022
A <i>Trichloroacetic Acid</i>		SM 6251B	mg/L	0.0125	0.0010		11/07/2022
Total HAA5	2456	SM 6251B	mg/L	0.0207		0.060	
Trihalomethanes	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date
A <i>Chloroform</i>		EPA 524.2	mg/L	0.0197	0.0010		11/08/2022
A <i>Bromodichloromethane</i>		EPA 524.2	mg/L	0.0019	0.0010		11/08/2022
A <i>Dibromochloromethane</i>		EPA 524.2	mg/L	ND	0.0010		11/08/2022
A <i>Bromoform</i>		EPA 524.2	mg/L	ND	0.0010		11/08/2022
Total THM	2950	EPA 524.2	mg/L	0.0216		0.080	

Lab Number	Sample Name	Sampled: 11/1/22 8:45	Sample Composition: Treated Distribution				
2305043-02	12424 Toliver Rd						


Haloacetic Acids	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date
A <i>Dibromoacetic Acid</i>		SM 6251B	mg/L	ND	0.0010		11/08/2022
A <i>Dichloroacetic Acid</i>		SM 6251B	mg/L	0.0088	0.0010		11/08/2022
A <i>Monobromoacetic Acid</i>		SM 6251B	mg/L	ND	0.0010		11/08/2022
A <i>Monochloroacetic Acid</i>		SM 6251B	mg/L	ND	0.0020		11/08/2022
A <i>Trichloroacetic Acid</i>		SM 6251B	mg/L	0.0136	0.0010		11/08/2022
Total HAA5	2456	SM 6251B	mg/L	0.0223		0.060	
Trihalomethanes	Code	Method	Units	Result	MRL	EPA MCL	Analysis Date
A <i>Chloroform</i>		EPA 524.2	mg/L	0.0209	0.0010		11/08/2022
A <i>Bromodichloromethane</i>		EPA 524.2	mg/L	0.0019	0.0010		11/08/2022
A <i>Dibromochloromethane</i>		EPA 524.2	mg/L	ND	0.0010		11/08/2022
A <i>Bromoform</i>		EPA 524.2	mg/L	ND	0.0010		11/08/2022
Total THM	2950	EPA 524.2	mg/L	0.0228		0.080	

Maximum Contaminant Level: Total THM = 0.080 mg/L, Total HAA5 = 0.060 mg/L

ND = None detected MRL = Minimum Reporting Limit MCL = Maximum Contaminant Limit

A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Notes

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.
All procedures for this report are in accordance with NELAP standards.