

Andy Peters

From: Andy Peters
Sent: Monday, June 15, 2020 10:52 AM
To: 'PINNEY Mike'
Cc: Gerald Fisher
Subject: BOD5 results

Mike, we have results from the BOD5 tests that went in 6/10/20:

Influent: 152 mg/L
Effluent: 33 mg/L
Pond 1: 13 mg/L
Pond 2: 9 mg/L

Another round of bottles is due out tomorrow 6/16/20. To help explain these numbers we'll be taking additional samples between processes in the coming days.

Respectfully,

Andy Peters

City of Molalla
Public Works Operations Supervisor
(503) 829-6855 x220
Cell: 503-793-0507
apeters@cityofmolalla.com
117 N Molalla Ave
Molalla, OR 97038