

Lab Test Id	CreatedBy	DateCreated	Notes
201	kbatridge	10/7/2020	Pond 1 BOD and CBOD all failed from D.O. change less then 2.0 mg/L Pond 2 BOD was 48
199	jclifton	9/30/2020	Pond #1= all BOD fail Pond #2 = 60 Mg/L BOD
195	kbatridge	9/16/2020	pond 1 BOD ave. 32 Pond 2 BOD ave. failed at sample dilutions 30,40,50 mL
193	jclifton	9/9/2020	Pond 1 25 mg/l Pond 2 37 mg/l
191	kbatridge	9/2/2020	Pond #1 30 Mg/l Pond #2 34 Mg/l
189	kbatridge	8/26/2020	Pond # 1 18 Mg/L BOD Pond #2 23 Mg/L BOD
188	jclifton	8/20/2020	Pond 1 , 2 are filtered and seeded Pond 1 BOD: 8.7 mg/l Pond 2 BOD 5.5 mg/l
187	jclifton	8/19/2020	Pond 1, 2 are filtered with no seed. Pond #1 BOD: 7 mg/l Pond #2 BOD: 10 mg/l
186	operator	8/13/2020	Pond #1 unseeded BOD: 9.5 mg/l Pond #2 unseeded BOD: 9.5 mg/l
185	kbatridge	8/12/2020	Pond 1 and Pond 2 are seeded Pond 1: 9 mg/L Pond 2: 13 mg/L
181	jclifton	7/29/2020	Pond 1 & Pond 2 are not seeded Pond 1 10.8 mg/L Pond 2 14 mg/L
180	operator	7/23/2020	Pond 1,2 were seeded pond 1 11 mg/L pond 2 11 mg/L
179	operator	7/22/2020	Pond # 1 12 Mg/L Pond # 2 16 Mg/l After Filters 14 Mg/l
178	kbatridge	7/16/2020	Pond 1 & 2 samples NOT seeded Pond #1 13 Mg/L Pond #2 11 Mg/l
177	kbatridge	7/15/2020	Pond 1 & 2 samples NOT seeded Pond 1 -13.5 mg/L Pond 2 - 12 mg/L
176	jclifton	7/9/2020	Pond 1 , 2 are not seeded POND 1 BOD: 10.9 mg/l POND 2 BOD: 9.6 mg/l ALL Effluent BOD samples failed due to near total oxygen depletion
175	jclifton	7/8/2020	Pond 1 , 2 are not seeded
174	jclifton	7/2/2020	Pond 1 & 2 are not seeded Pond 1 - 13 mg/L Pond 2 - 9 mg/L
173	jclifton	7/1/2020	Pond 1,2 are not seeded Pond 1 - 14 mg/L Pond 2 - 11 mg/L
171	kbatridge	6/24/2020	Pond 1 seeded BOD ave. 9.8 mg/L Pond2 seeded BOD ave. 14 mg/L
172	kbatridge	6/25/2020	Pond #1 12 Mg/L BOD Pond #2 12 Mg/L BOD
169	operator	6/17/2020	Grab samples : pond # 1 (10 mg/L) Pond #2 (10 mg/L). EFF not seeded showed same results as seeded.
167	operator	6/11/2020	Pond # 1>>> 11 Mg/l BOD Pond # 2>>> 9 Mg/ BOD C.O.D Pond #1 37.0 Mg/l Pond #2 42.0 Mg/l Effluent 57.9 Mg/l
166	operator	6/10/2020	Pond #1>>>13 Mg/l BOD Pond #2 >>> 9 Mg/l BOD
163	operator	6/1/2020	EPS irrigation Eff. EFF BOD FAIL/ POND #1 12MG/L BOD POND #2 9 Mg/L BOD
161	kbatridge	5/22/2020	Pond #1 BOD = 11Mg/L Pond #2 BOD = 13Mg/L
160	jclifton	5/21/2020	POND #1 BOD 11Mg/L POND #2 BOD 9 Mg/L
159	kbatridge	5/15/2020	POND #1 BOD 9 MG/L