

PERMITTEE NAME/ADDRESS:

NAME: James Miller, G-I Holdings Inc.

ADDRESS: One Campus Drive  
Parsippany, NJ 07054

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

## DISCHARGE MONITORING REPORT (DMR)

PERMIT NUMBER

DISCHARGE NUMBER


FACILITY: GAF/Mattel Site Groundwater Treatment System

LOCATION: 8585 SW Hall Blvd  
Beaverton, OR

## MONITORING PERIOD

FROM 24 | 05 | 01 TO 24 | 05 | 31

NO DISCHARGE ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNIT				
Flow (discharge)	SAMPLE MEASUREMENT		6,706,618	Gallons this period	146	150	155	Gallons per minute	0	1/30	N/A	
	PERMIT REQUIREMENT				----	----	----					
Temperature	SAMPLE MEASUREMENT						11.20	°C	0	1/30	Grab	
	PERMIT REQUIREMENT				----	----	----					
pH	SAMPLE MEASUREMENT						7.42	pH units	0	1/30	Grab	
	PERMIT REQUIREMENT				6	----	9					
Phosphate	SAMPLE MEASUREMENT						ND (100)	µg/L	0	1/90	Grab	
	PERMIT REQUIREMENT				----	----	130					
Trichloroethene (TCE)	SAMPLE MEASUREMENT						2.03	µg/L	0	1/90	Grab	
	PERMIT REQUIREMENT				----	----	50					
Other VOCs	SAMPLE MEASUREMENT						0.470	µg/L	0	1/90	Grab	
	PERMIT REQUIREMENT				----	----	70					
Free (WAD) Cyanide (Weak Acid Dissociable)	SAMPLE MEASUREMENT						ND (5.0)	µg/L	0	1/30	Grab	
	PERMIT REQUIREMENT				----	----	5.2					
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		<small>I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.</small>					TELEPHONE		DATE			
James Miller									(470) 599-7019		24   06   10	
TYPED OR PRINTED							SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE NUMBER		YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

ND = Not detected above laboratory reporting limit.