



May 31, 2024

Oregon Department of Environmental Quality (DEQ)
700 NE Multnomah Street
Portland, OR 97232

Re: Seismic Vulnerability Assessment, Seaport Midstream Partners, LLC, Portland Terminal

To Whom It May Concern,

Attached please find the Seismic Vulnerability Assessment for the SeaPort Midstream Partners, LLC Portland Terminal located at 9930 NW St. Helens Rd, Portland, OR 97231. This document is submitted in response to *Rule 340-300-0003 Seismic Vulnerability Assessment Requirements and Timeline*. This assessment has been prepared by SGH Consultants and has been reviewed by Seaport Midstream Partners LLC.

We look forward to working productively with Oregon DEQ on the *Fuel Tank Seismic Stability Rules* as we move into subsequent phases of the program.

Regards,

Karl H. Bernard
Vice President Terminal Operations
Seaport Midstream Partners, LLC



SEISMIC VULNERABILITY ASSESSMENT OF THE SEAPORT MIDSTREAM PARTNERS PORTLAND TERMINAL


SeaPort Midstream Partners, LLC
Portland Terminal
Portland, OR
May 2024



EXPIRES: 06/30/25

PE Stamp applies to
Report Body and
Appendix C

SGH Project 247052



PREPARED FOR
SeaPort Midstream Partners, LLC
9930 N.W. St. Helens Rd.
Portland, OR 97231

PREPARED BY
Simpson Gumpertz & Heger Inc.
1999 Harrison Street, Suite 2400
Oakland, CA 94612
o: 415.495.3700

EXECUTIVE SUMMARY

SeaPort Midstream Partners, LLC (SMP) has contracted Simpson Gumpertz & Heger Inc. (SGH) to perform a Seismic Vulnerability Assessment of the SeaPort Midstream Partners Portland Terminal to comply with the new "Fuel Tank Seismic Stability Rules" (Rules) recently adopted by the Oregon Department of Environmental Quality (DEQ). This report presents the geotechnical, structural, and safety assessments performed. Key vulnerability findings are summarized below and discussed in further detail in this report.

Items are categorized as Moderate or High Risk based on the full consideration of hazards, including earthquake induced ground deformations. For High Risk items, mitigations should be considered using an As Low As Reasonably Practicable (ALARP) risk reduction philosophy. For Moderate Risk items, further evaluation is recommended to determine if mitigation is necessary. For example, this may include detailed engineering calculations to quantify the seismic capacity of specific, existing components.

Table E-1 - Summary of High Risk Items

North Tank Farm	South Tank Farm	Biodiesel Tank Farm	Butane Storage, Water Separators, & Dock	Safety Systems & Buildings
Containment Walls	Containment Walls	Containment Walls	Sheet Pile Wall	Water Main
Tank Foam System			Dock	Foam System
			Dock Piping	Deluge System
			Oil Water Separator	
			Storm Water Separator	

Table E-2 - Summary of Moderate Risk Items

North Tank Farm	South Tank Farm	Biodiesel Tank Farm	Butane Storage, Water Separators, & Dock
Piping	Piping	Piping	Piping
Tank 1			Fire Pump
Tank 5			
Tank 6			
Tank 8			
Tank 11			
Tank 24			
Tank 25			

Geotechnical

We have determined a peak ground acceleration (PGA_M) of 0.49g for the ASCE 7-16 DLE event.

The sheet pile wall design estimates lateral displacements on the order 1½ ft, though the toe is in liquefiable material and the design does not appear to include inertial seismic forces. It is unclear at this time if the FLAC analysis considers the potential for deep-seated seismic deformations occurring below the wall. Future investigations should include a detailed review and validation of the sheet pile wall’s FLAC analysis to understand the original assumptions, including considerations for global stability due to the deep-seated liquefiable soil and considerations for inertial seismic forces, and to confirm the sheet pile wall’s expected lateral displacement.

The estimated seismically-induced vertical ground deformations vary from 2 in. to 18 in. at the site, with the potential for larger vertical deformations if large lateral deformations occur due to the performance of the sheet pile wall. Our structural and safety assessments considered these potential displacements.

Structural

Many of the tanks in the North Tank Farm have a Moderate Risk due to their flammable contents and a higher Life Safety severity. Additionally, Tank 1 is riveted, and Tanks 5, 6, 8, and 11 are Moderate Risk due to a higher Likelihood of damage driven by an over-constrained condition with stairs or piping, as shown in the example photos below. Tanks 24 and 25 are rated Moderate due to a high H/D ratio, even considering them half full.

Pipelines are rated Moderate throughout the terminal due to differential displacements from vertical settlement and the anticipated pipe stresses. At the dock, pipelines are rated High due to a higher consequence of damage and spill directly into the river. Additionally, the dock piping is likely to experience high stresses due to its supported condition on the wharf and the higher soil displacements estimated at the river front.

The containment walls are rated High due to their importance in containing spills and the uncertainty in their capacity to withstand seismic loads due to their age and construction.



Figure E-1: Example Over-Constrained Conditions

Safety

The water supply is rated as a High Risk seismic vulnerability. The facility relies on municipal water as its only source for firewater and for foam distribution. It is highly unlikely municipal water will be available following the DLE considered by the Rules.

Since the foam system, fire pump, and deluge systems are dependent on municipal water, which is unlikely to be available following the DLE, and the consequence of these systems being unavailable, these items are deemed a High Risk.

Power is needed for the electric fire / foam pump, MOVs, and facility lighting. However, the diesel fire / foam pump can continue operating even during a loss of municipal power . Since it is very likely that power will be lost following an earthquake, we determined that loss of power is a Medium Risk item.

Table of Contents

EXECUTIVE SUMMARY

CONTENTS		Page
1.	INTRODUCTION	3
1.1	Background	3
1.2	Scope of Work	4
1.3	Assessment Boundaries	5
1.4	Assessment Criteria	5
1.5	Limitations	6
2.	FACILITY DESCRIPTION	7
2.1	North Tank Farm	8
2.2	South Tank Farm	9
2.3	Biodiesel Tank Farm	10
2.4	Butane Storage, Water Separators, and Dock	10
2.5	Loading Racks	12
2.6	Buildings	12
3.	GEOTECHNICAL ASSESSMENT	14
3.1	Site Conditions	14
3.2	Seismic Hazard Evaluation	15
3.3	Seismically-Induced Ground Deformations	16
4.	STRUCTURAL ASSESSMENT	18
4.1	Walkdown Assessment	18
4.2	Likelihood of Spill from Seismic Structural Damage	19
5.	SAFETY ASSESSMENT	21
5.1	Spill Containment Systems, Equipment and Procedures	21
5.1.1	Seismic Vulnerabilities	26
5.2	Fire Control and Suppression Systems	26
5.2.1	Seismic Vulnerabilities	27
5.3	Emergency Response Equipment	27
5.3.1	Seismic Vulnerabilities	29
5.4	Safety and Operating Conditions	29
5.4.1	Seismic Vulnerabilities	29
5.5	Terminal Staffing, Monitoring, and Response	29
5.5.1	Seismic Vulnerabilities	29
6.	RISK ASSESSMENT	30

7.	FINDINGS	34
	7.1 Geotechnical	35
	7.2 Structural	36
	7.3 Safety	37
8.	REFERENCES	38

APPENDIX

Appendix A – Site Plan and Inventory
Appendix B – Geotechnical Assessment
Appendix C – Risk Assessment

1. INTRODUCTION

SeaPort Midstream Partners, LLC (SMP) has contracted Simpson Gumpertz & Heger Inc. (SGH) to perform a Seismic Vulnerability Assessment of the SeaPort Midstream Partners Portland Terminal to comply with the new "Fuel Tank Seismic Stability Rules" (Rules) recently adopted by the Oregon Department of Environmental Quality (DEQ). This report summarizes that assessment.

1.1 Background

The DEQ developed the Rules to address the risks related to a Cascadia Subduction Zone earthquake impacting large capacity fuel handling facilities in Columbia, Lane, and Multnomah counties in Oregon. Rule 340-300-0003 specifies the requirements and timeline to perform a Seismic Vulnerability Assessment. The Seismic Vulnerability Assessment is a detailed, facility-wide, site-specific evaluation of the risk of seismically induced damage and secondary effects to a facility and environment when subjected to a Design Level Earthquake (DLE). The Rules require that, for the purposes of this study, the DLE be determined in accordance with ASCE 7-16. This results in a very large earthquake (with a moment magnitude greater than 9.0) representing the Cascadia Megathrust fault, as described further in Section 3.2.

Rule 340-300-0002(18) defines the "Performance Objective" as limiting structural damage resulting in a spill exceeding the Maximum Allowable Uncontained Spill (MAUS) when the facility experiences DLE ground motions. Rule 340-300-0002 defines the maximum uncontained quantity of spill as one barrel (42 gal) or less for each tank or associated equipment, by reference to the reportable volumes in Oregon Law OAR 340-142.

Rule 340-300-0003 specifies the following elements be included in the Seismic Vulnerability Assessment:

- Description of facility components in terms of construction, age, inspection, maintenance, and operations.
- Summary of currently implemented spill prevention and mitigation measures and their ability to achieve the Performance Objective.

- Definition of the DLE.
- Evaluation of the potential for a spill exceeding the MAUS during the DLE for all components in the facility
- Evaluation of the potential for liquefaction, lateral spreading, and settlement seismically induced
- Evaluation of the safety of operating conditions, safe shutdown procedures, and potential spills
- Evaluation of the availability and integrity of automated sprinkler systems and sufficient supplies of firefighting foam and other emergency response equipment located in seismically resilient locations accessible after an earthquake to mitigate the risk of fire and explosions following an earthquake
- Evaluation of fire control measures such as firewalls surrounding the facility to limit fire spreading into surrounding communities
- Evaluation of the availability of day and night onsite personnel trained in emergency response and able to respond in the event of an earthquake

1.2 Scope of Work

The scope of work consisted of the following assessments consistent with Rule 340-300-0003(6)(a-c):

- Geotechnical Assessment including:
 - Site conditions assessment
 - Seismic hazard evaluation
 - Geotechnical evaluation
- Structural Assessment
- Safety Assessment including:
 - Fire control and suppression systems evaluation
 - Spill containment system evaluation
 - Evaluation of onsite emergency equipment, operational safety measures, and personnel availability

1.3 Assessment Boundaries

The team considered possible scenarios due to earthquakes that may realistically occur and result in an uncontained spill, uncontrolled fire, explosion, or toxic release at the terminal.

The following items were excluded from the scope of this study:

- Failures due to non-earthquake-related causes
- Life-safety considerations that are not directly caused by a spill that occurs due to an earthquake (e.g. life-safety concerns from occupants of a building that collapses)

1.4 Assessment Criteria

Rule 340-300-0002(4) lists codes and standards for use in this assessment. This list includes ASCE 7 for seismic design criteria, building structures, piping and pipe racks, and secondary containment, ASCE 41 for existing buildings, API 650 and API 653 for tanks, and ASCE 61 for piers, wharves, and waterfront structures. As permitted by Rule 340-300-0002(4)(h), the team considers "other applicable standards" to include:

- "Guidance for California Accidental Release Prevention (CalARP) Program Seismic Assessments," prepared for the Unified Program Agency (UPA) Subcommittee of the Region I Local Emergency Planning Committee (LEPC), January 2019, also referred to as the "CalARP Seismic Guidance Document".
- California Building Code (CBC) Chapter 34F, otherwise known as Marine Oil Terminal Engineering and Maintenance Standards (MOTEMS), 2022.
- "Seismic Evaluation and Design of Petrochemical and Other Industrial Facilities, 3rd Edition, American Society of Civil Engineers (ASCE), 2020.

The CalARP Seismic Guidance Document has a long history, being widely used within the industry for assessing existing chemical and process facilities that contain hazardous materials. Further, MOTEMS is considered the most appropriate code document for assessment of operational procedures and seismic performance at existing oil terminals. Both of these documents also reference the ASCE document noted above. That document is widely used throughout the industry and is frequently accepted by building officials for its interpretation of building code provisions as specifically relevant to typical structures and systems found in

petrochemical and industrial facilities.

1.5 Limitations

SGH has performed the professional services for this project using the degree of care and skill ordinarily exercised under similar circumstances by reputable engineers practicing in the structural and earthquake engineering fields in this or similar localities. SGH makes no other warranty, expressed or implied, as to the professional advice included in this report. We have prepared this report for SMP to be used solely for the purposes of satisfying the requirements of the DEQ Rules. We have not prepared the report for use by other parties and the report may not contain sufficient information for purposes of other parties or for other uses. The recommendations resulting from this assessment rely on information provided by SMP to SGH, including soils reports, drawings, and specifications. SGH makes no warranty as to the accuracy and correctness of any information provided by SMP.

Please note that addressing vulnerabilities identified in our report may reduce the risk, but does not guarantee or assure that a release will not occur in an earthquake. All parties should recognize the lack of complete assurance connected with seismic evaluations, especially of existing facilities. Uncertainties exist associated with material properties and structural behavior (uncertainties that are typically larger for existing facilities than new designs), as well as large uncertainties associated with earthquake motion in terms of amplitude, frequency content, direction, and duration. All parties should also recognize that seismic assessments such as those performed in this review require the significant application of professional experience and engineering judgment. Some amount of uncertainty and variation will always exist with respect to the interpretation of data, notwithstanding the exercise of due professional care.

This assessment emphasized identification of vulnerabilities and not conformance to building codes for new design. We further note that conformance to new design codes does not eliminate seismic risk, and industry standards for seismic evaluation of existing facilities consistently have been developed with the intent of reducing risk, and not for compliance with new design codes.

2. FACILITY DESCRIPTION

The SeaPort Midstream Partners Portland Terminal is located at 9930 NW St. Helens Road in Portland, Oregon. The terminal has a 125-foot dock with dolphins and catwalks along the Willamette River. The facility consists of three tank farms, the dock, a butane storage area, an offload area, loading racks, and several buildings. See Figure 2-1 for the vicinity plan of the SeaPort Midstream Partners Portland Terminal. See Figure 2-2 for the aerial plan of the facility.



Figure 2-1: Vicinity Plan of SeaPort Midstream Partners Portland Terminal



Figure 2-2: Aerial Plan of SeaPort Midstream Partners Portland Terminal

2.1 North Tank Farm

The North Tank Farm consists of one combustible fuel tank, seven flammable fuel tanks, four additive tanks, and one groundwater remediation tank. There are thirteen total tanks in the containment area. There is one tank with a diameter larger than 120 ft, while the remainder of tanks have a diameter less than 80 ft. The tanks vary from large-diameter squat tanks to small-diameter tanks with a high aspect ratio (height divided by diameter, H/D). Several pumps and the truck loading rack manifold are located within the tank farm. Pipes interconnect the tanks and penetrate the containment walls, leading to the adjacent truck loading racks. The containment consists primarily of reinforced concrete walls and one earthen ramp on the river side of the tank farm. The approximate gross area within the containment is 127,317 square ft. Containment volume of the North Tank Farm, per the SPCC, is about 6,947,712 gallons (about 165,400 barrels). See Figure 2-3 for an aerial view of the North Tank Farm.



Figure 2-3: Aerial Plan of North Tank Farm

2.2 South Tank Farm

The South Tank Farm consists of six combustible fuel tanks, one process water fuel tank, and two additive tanks. There are nine total tanks in the containment area. There is one tank with a diameter larger than 100 ft, while the remainder of the tanks have a diameter of less than 80 ft. The tanks vary from large-diameter squat tanks to small-diameter tanks with a high aspect ratio (height divided by diameter, H/D). Several pumps and other mechanical equipment are located within the tank farm. Pipes interconnect the tanks and penetrate the containment walls. The containment consists primarily of reinforced concrete walls and one earthen ramp on the river side of the tank farm. The approximate gross area within the containment is 99,992 square ft. Containment volume of the South Tank Farm, per the SPCC is 4,822,841 gallons (114,830 bbls). See Figure 2-4 for an aerial view of the South Tank Farm.



Figure 2-4: Aerial of South Tank Farm and Biodiesel Tank Farm

2.3 Biodiesel Tank Farm

The Biodiesel Tank Farm has four additive tanks, one combustible fuel, and two process water tanks within the containment area. All seven tanks have a diameter of 30 ft. All four additive tanks are out of service. Several pumps and other mechanical equipment are located within the tank farm. Pipes interconnect the tanks and lead out of the tank farm via pipe bridges over the containment walls. The containment consists primarily of reinforced concrete walls. The approximate gross area within the containment is 15,790 square ft. Containment volume of the Biodiesel Tank Farm, per the SPCC, is 335,165 gallons (7,980 bbls). See Figure 2-4 for an aerial view of the Biodiesel Tank Farm.

2.4 Butane Storage, Water Separators, and Dock

The dock was rebuilt in 1993 primarily using concrete. It consists of a 125 ft long loading platform with two breasting dolphins on either side. The loading platform and dolphins are connected by

catwalks. A 115 ft long trestle supporting pipelines connects the loading platform to land. Piping runs above and below the trestle deck to shore.

The Oil Water Separator is located south of the trestle. The Storm Water Separator is located adjacent to the northeast corner of the North Tank Farm.

The Butane Storage is located southwest of the Truck Loading Rack. The Butane Storage is an approximately 140-ft long horizontal tank supported on reinforced concrete piers constructed circa 2014. Piping from the tank runs to the north to the Truck Loading Rack. See Figure 2-5 for an aerial view of the dock, water separators, and Butane Storage.



Figure 2-5: Aerial of Water Separators, Butane Storage, and Dock

2.5 Loading Racks

The SeaPort Midstream Partners Portland Terminal has one truck loading rack and one rail unloading rack. They are used for loading product on trucks and unloading rail cars. The rail unloading rack is southwest of the South Tank Farm. The truck loading rack is located between the tank farms. The loading racks consist of steel framed construction. See Figure 2-6 for an aerial view of the Loading Racks.



Figure 2-6: Aerial of Loading Racks

2.6 Buildings

The following lists the occupied buildings at the SeaPort Midstream Partners Portland Terminal.

- Guardshack
- Truck Shop
- Boiler House
- Office
- SIMOPS
- Warehouse
- QAQC

The primary construction for these buildings is concrete or masonry walls with light-framed roofs. None of these buildings, or the unoccupied buildings or structures, store or contain fuels. We have listed the buildings in the risk assessment (Section 6).

A plot plan and inventory are provided in Appendix A.

3. GEOTECHNICAL ASSESSMENT

A geotechnical assessment was performed to provide input for the Seismic Vulnerability Assessment. The assessment included consideration of existing site-specific geotechnical information and other existing data. The full geotechnical assessment, performed by Gannett Fleming Inc. (Gannett Fleming), is included in Appendix B.

3.1 Site Conditions

The terminal is located on the east side of NW St. Helens Road east of the foothills of the Tualatin Mountains along the western shoreline of the Willamette River as shown in Figure 1. The site is relatively flat at roughly elevation 35 ft (NAVD88). Bathymetric survey data collected by the United States Army Corps of Engineers indicate the waterfront slope is roughly 70 ft high.

An anchored sheet pile wall was constructed along the waterfront circa 2009 to replace a concrete cantilever seawall constructed in the 1940s due to progressive structural failure. Sheet pile wall drawings indicate the existing wall is located on the waterside of the 1940s seawall, with a pile tip elevation of about -7 ft (NAVD88) and two rows of tiebacks.

The site is underlain by various amounts of fill materials placed during site development. Regional geologic mapping indicates the site is underlain by young Quaternary alluvium comprised of river and stream deposits of silt, sand, clay, and peat of present flood-plains. The alluvium is largely confined to the ancient incised Willamette River channel, which includes the current channel and the adjacent alluvial plains. The mapping suggests the alluvium is underlain by Columbia River basalt at depth.

The previous borings by others indicate subsurface conditions which generally consist of fill, stream deposits, alluvial deposits, and bedrock, consistent with published geologic maps. The fill primarily consists of loose to dense sands with varying amounts of silt and gravel, often containing debris such as brick, asphalt, glass, and wood. The stream deposits are comprised of medium dense to dense sands interlayered with silts. Alluvial deposits underlying the stream deposits are comprised of fine-grained and sandy soils. Columbia River basalt was encountered in the west

portion of the site at a depth of about 40 ft and at about 70 ft below the ground surface adjacent to the sheet pile wall.

Shallow groundwater was encountered in the onshore borings at depths ranging from about 1 to 13 ft. Groundwater evaluations at the site indicate the groundwater depth near the sheet pile wall is about 30 ft, which is likely influenced by the groundwater extraction wells at this location. Fluctuations in groundwater levels likely occur due to variations in the Willamette River water level, rainfall, underground drainage patterns, groundwater extraction, regional influence, and other factors.

3.2 Seismic Hazard Evaluation

We have evaluated seismic hazards including ground shaking, liquefaction, lateral spreading, and seismic densification. A summary of our conclusions regarding the potential for liquefaction and lateral spreading is provided below.

As required by the Rules, we developed seismic design parameters in accordance with the 2016 American Society of Civil Engineers (ASCE) Standard 7-16 (ASCE 7-16): Minimum Design Loads for Buildings and Other Structures (ASCE 2016) for the purposes of evaluating liquefaction potential and lateral spreading. Based on the existing geotechnical data, the site can be characterized as Site Class D in conformance with ASCE 7-16. Using the ASCE 7 Hazard Tool, we calculated a maximum considered earthquake geometric mean (MCEG) peak ground acceleration adjusted for site class (PGA_M) of 0.49g, corresponding to a moment magnitude (M_w) of 9.3 on the Cascadia Megathrust fault, which governs the seismic hazard at the site.

The results of our evaluation indicate the potential for liquefaction is high during the design earthquake. Related effects include ground surface settlements, sediment ejecta and settlement from ground loss. In addition to settlement from reconsolidation and sediment ejecta, liquefaction-induced foundation settlement can occur when shear-induced deformations driven by cyclic loading occur due to ratcheting and bearing capacity types of movement caused by soil structure interaction (SSI).

Liquefied soils will directly impact the sheet pile wall's seismic performance. Liquefied soils have a decreased shear strength and will increase the lateral loads on the sheet pile wall compared to their non-liquefied state. The decreased shear strength also may reduce the capacity of the tieback anchors.

Lateral spreading is a phenomenon where a soil mass moves laterally on liquefied soil down a gentle slope or toward a free face, such as the adjacent Willamette River channel. Displacement occurs in response to gravitational and earthquake-induced forces acting on soils within and above the liquefied layer. If the sheet pile wall is effective at limiting lateral deformations to this magnitude, we expect the ground deformation to reduce in magnitude with increasing distance from the waterfront slope.

During lateral spreading, surface layers commonly break into large blocks, which progressively migrate toward a free face. This development of ground fissures can promote ground loss for sediment ejecta and increase the likelihood of associated settlement.

3.3 Seismically-Induced Ground Deformations

We have developed preliminary estimates of vertical and lateral seismically-induced ground deformations to approximate the range of movements expected at the site.

The sheet pile wall designers used borings collected to conduct a two-dimensional analyses using the computer program FLAC (Fast Lagrangian Analysis of Continua). The FLAC analyses included static and post-seismic analysis of stresses and deformation of the sheet piles wall. The post-seismic analysis considered the reduced strength of the soils due to liquefaction, but did not appear to consider seismic inertial forces. The post-seismic stability analyses indicated up to about 1½ ft of horizontal displacement at the top of the sheet pile wall.

The sheet pile wall has a relatively shallow embedment below the riverbed and is underlain by liquefiable soils. It is unclear to what extent the previous FLAC analysis considered the potential for deep-seated seismic deformations occurring below the wall, which may result in the

translation/rotation of the wall and tiebacks behaving as a unit. If this is the case, potentially larger deformations than previously estimated may be realized and extend to substantial distances landward of the sheet pile wall.

Future investigations should include a detailed review and validation of the sheet pile wall's FLAC analysis to understand the original assumptions, including considerations for global stability due to the deep-seated liquefiable soil and considerations for inertial seismic forces, and to confirm the sheet pile wall's expected lateral displacement.

Large deformations may be experienced on the waterside of the sheet pile wall as a result of flow-type failure. In this case, masses of ground may travel long distances (likely more than 5 ft) in the form of liquefied flows or blocks of ground riding on liquefied flows.

The primary mechanisms of liquefaction-induced settlement are reconsolidation (estimated as 2 to 6 in.), localized ejecta-induced settlements (up to 12 in.), and shear-induced foundation settlement (not estimated). Combined, the total estimated vertical ground deformation, with free-field conditions, ranges from 2 to 18 in. We note that this estimate does not incorporate any vertical deformations associated with lateral displacement of the sheet pile wall.

4. STRUCTURAL ASSESSMENT

Rule 340-300-0003(6)(b) identifies that a structural assessment is to be performed for all onsite structures where damage could result in a potential release of fuel.

The key structural assessment consisted of a walkdown evaluation of the entire facility, supplemented by limited reviews of available drawings and other documentation, such as tank inventory tables.

Our evaluation is based on the "expected" or "most likely" conditions at the time of an earthquake rather than the worst-case or conditions that might be considered for new design. This includes consideration of existing deterioration or damage and any modifications made since construction, as observed during the walkdown.

Considering the variability of tank operation (i.e., tanks are filled or emptied over days, weeks, or months) and input from SMP regarding the likely fill heights based on actual operating procedures, a reasonably conservative assumption for all tanks is that they are half full.

4.1 Walkdown Assessment

The walkdown assessment is a primarily visual review that considers the actual conditions of each installation in a systematic, methodical manner. The engineers performing the review investigate potential seismic vulnerabilities, focusing on proven failure modes from past earthquake experience, basic engineering principles, and engineering judgment. The walkdown review emphasizes the primary seismic load-resisting elements and the potential areas of weakness due to design, construction, modification practices, historical deterioration, or existing damage. A special emphasis is placed on details that may have been designed without consideration of seismic loads.

This walkdown assessment approach is widely used within industry, and in particular is used in California for assessing existing chemical and process facilities that contain hazardous materials. The approach is documented in the CalARP Seismic Guidance Document, which recommends that

the walkdown follow the guidance provided by the American Society of Civil Engineers (ASCE) in their document, "*Guidelines for Seismic Evaluation and Design of Petrochemical Facilities*, 2nd Edition", published by ASCE, 2011. We also considered that document, as well as the 3rd Edition, published in 2020.

Our walkdown assessment considered the likely response due to ground shaking (inertial effects), as well as the likely damage due to liquefaction and lateral spreading associated with the DLE.

4.2 Likelihood of Spill from Seismic Structural Damage

We assigned a judgment-based, qualitative likelihood of spill to each structure, tank, and other installation within the terminal based on our walkdown assessment and associated document review.

For storage tanks, we have taken into consideration the historical performance of storage tanks regardless of whether designed to modern code requirements, emphasizing those details that have been proven by experience to increase the likelihood of damage that could lead to a spill. For this assessment, we considered criteria such as tank construction (i.e. riveted versus welded), whether the tank is anchored (anchored tanks historically perform very well), the aspect ratio of the tank (fill height to diameter ratio), and whether any piping, stairs, or other attachments are restrained in a manner that would over-constrain movement of the tank and cause stress concentrations or damage to attached piping.

For containment walls, the likelihood of structural failure in a seismic event is based on the type of containment (i.e. concrete wall versus soil berm), liner details, depth of wall foundations, geometries (i.e. width and toe), reinforcing details, and era of construction. We also considered the present condition as well as modifications made to containment walls, such as penetrations or reinforcing buttresses, if applicable.

For buildings and other building-like structures, we first considered whether damage to the structure would result directly in an uncontained spill, uncontrolled fire, or explosion or would

damage a critical safety or control system, leading to the same effect. Buildings that do not store fuel products (such as the office building) or contain critical safety systems were screened from further assessment. For structures that contain products or critical systems within the scope of these rules, we considered the structure system, visible condition, and era of construction to determine a qualitative likelihood of damage that could lead to a spill.

We first determined a likelihood of spill due to earthquake-induced structural damage, without any consideration of the geotechnical ground displacements associated with liquefaction and lateral spreading. We then adjusted likelihood scores for individual elements, considering the estimated ground displacements within the geographic area where the equipment is located and the specifics of that structure (such as aspect ratio and foundation type). For example, significant ground displacement will increase the likelihood for overturning on unanchored tanks with a high aspect ratio, so we increased the Likelihood category accordingly.

5. SAFETY ASSESSMENT

We reviewed the fire systems and procedures, oil spill containment systems and procedures, and other emergency systems that would be affected by a major earthquake.

We also performed a walkdown of the site, met with the operators and held discussions, and participated in the risk assessment discussed in Section 6.

We considered realistic general earthquake effects that are likely to occur in the DLE, such as:

- Shaking of the entire facility simultaneously without prior warning.
- Lengthy duration of shaking (15 seconds or longer).
- Loss of grid power.
- Loss of municipal water.
- Off-site emergency services may not be available due to infrastructure problems (bridges and highways) or regional needs for the general community.
- Unpredictable human response.

5.1 Spill Containment Systems, Equipment and Procedures

This section addresses Rule 340-300-0003(6)(c)(B) and Rule 340-300-0003(1)(d).

Primary Containment and Maintenance Procedures for Bulk Storage

All bulk storage tanks in the facility are constructed of steel and meet American Petroleum Institute (API) standards for oil storage tank construction. In addition, bulk storage tanks are operated according to API 650 or 653 and are inspected in accordance with industry standards, including:

- API Standard 653 for atmospheric storage tanks with a capacity of 50,000 or more.
- Steel Tank Institute (STI) Standard SP001 for atmospheric storage tanks for storage tanks with a capacity of 50,000 or less.
- API Standard 510 for pressurized storage vessels.

Inspection intervals for all oil storage tanks have been established based on the referenced industry standards, including the daily inspection of each tank for signs of corrosion or leaks. Tank bottom inspections, including visual and ultrasonic inspections, are performed when a tank is removed from service.

Similarly, 55 gallon drums and totes are inspected regularly by terminal personnel.

There are no underground, partially underground or portable storage tanks in use at the terminal.

Double bottoms to provide secondary containment have been installed on gasoline Tanks 1, 2, 3, 4, 5, 8, 12, and 13. Tanks without double bottoms have been equipped with a cathodic protection system for corrosion control.

The Terminal has several design and operational measures in place to prevent spills caused by overfilling tanks. Operationally, the Terminal is always manned during any active cargo movement. In addition, all tank volume capacities are checked prior to start of transfer operations to ensure sufficient volume is available for receipt of cargo.

All gasoline and distillate tanks are equipped with electronic tank gauging systems set to trigger high level alarms at the Terminal control room as well as throughout the facility. The electronic gauging system is protected by UPS so it continues to monitor tank levels even in the case of loss of municipal power. The electronic gauging system and high level alarm is tested monthly.

Maintenance and Operation of Terminal Piping

The majority of the piping at the SMP Terminal is located above ground. Any piping located underground is placed inside concrete pipe trenches. All piping to be placed underground is wrapped, coated and protected by a cathodic protection system to mitigate corrosion. In addition, buried piping that is exposed is inspected for deterioration.

The Terminal follows API 570 standards for inspection and testing of piping systems, including the regular inspection of piping, valves and flanges for leaks or signs of deterioration. Any leaks are repaired immediately.

Secondary Spill Containment Systems and Response Procedures

Both the North Tank Farm and the South Tank Farm are protected by a secondary spill containment system composed of concrete walls and an earthen floor covered with gravel. In contrast, the secondary containment for the Biodiesel Tank Farm includes an impervious asphalt floor. According to the SPCC, the earthen floor for both the North Tank Farm and the South Tank Farm has been studied and determined adequately impervious to provide containment until clean up takes place.

The North Tank Farm, the South Tank Farm, and the Biodiesel Tank Farm all have sufficient secondary containment capacity to contain a spill from the largest tank inside the area, plus an allowance for a 25-year, 24-hour storm.

Rainwater in the North and South Tank Farms is collected and sent to the north Oil Water Separator (OWS) by way of catch basins. The catch basins are normally left closed except when discharging ponded stormwater.

The truck loading lane area is protected by a 6-in curb and is sloped to form a retention basin which drains to a lift station that pumps into the oily water tank. If the lift pump fails, the lift station is designed to overflow to the Oil Water Separator (OWS).

At the dock area, the hose connection manifold is protected by a curbed concrete area that forms secondary spill containment for the flexible hoses used to transfer cargo to vessels.

The Rail car unloading stations are all protected by drain pans that drain to a 10-inch drain header and then to a spur sump.

Most of the terminal piping is located aboveground and inside diked tank farm areas or in concrete lined, below grade pipeways. Underground piping to truck loading rack, dock and rail car unloading areas is either installed in a concrete trench or else equipped with protective wrapping and coating for corrosion control.

Terminal spill containment equipment includes a spill response boat and spill containment boom located in the terminal boathouse. This is in addition to the permanent boom located in-water. In addition, the terminal has 1,000 feet of stored containment boom as well as 10 bales of sorbent pads.

Lastly, the four out-of-service additive tanks in the Biodiesel Tank Farm could be available in short order if needed for emergency spill response.

Summary of Current Spill Prevention and Mitigation Measures

Tank design and maintenance is in accordance with industry standards. In addition, the terminal provides secondary storage for all oil stored on site.

The terminal Facility Response Plan (FRP) outlines spill response procedures. The first person on scene functions as the person-in-charge until relieved by an authorized supervisor who will assume position of Incident Commander (IC). Transfer of command takes place as more senior management responds to the incident.

The Initial Response Checklist Identifies the following steps:

- Treat all spill material as potentially hazardous.
- Notify Terminal Manager
- Sound alarm, warn other personnel.
- Stop product flows, if safe to do so. Activate Emergency Shutdown as appropriate.
- Remove potential ignition sources.

Terminal Management (Qualified Individual) Initial Response Checklist includes the following steps:

- Evaluate Severity, Impact, Safety Concerns and Response Requirements.
- Assume Role of Incident Commander
- Confirm Safety aspects at site, including need for special protective equipment, sources of ignition and potential need for evacuation.
- Activate local response team and primary response contractors and as the situation demands.
- Coordinate / activate additional spill response contractors as the situation demands.
- Make Internal Notifications
- Notify corporate contacts to complete regulatory agency notifications as needed.
- Proceed to spill site and coordinate response and clean-up operations.
- Complete USCG ICS 201 Incident Briefing Document is complete as soon as possible.
- Direct containment, dispersion and / or clean-up operations in accordance with the Product Specific Response Considerations provided inside the FRP.

The Local Response Personnel procedures are summarized below:

- Assigned personnel respond to discharge from Facility as situation demands
- Perform response / clean-up operations as directed or coordinated by the Incident Commander.
- Assist as directed at the spill site.

For the person acting as IC, the general Initial Response Actions are summarized as follows:

- Identify Hazards
- Sound Alarm

- Identify Hot Zones, Evacuate if Necessary
- Shut Down or Contain
 - **If transferring Tank Vessel to Terminal:** the terminal notifies vessel that the transfer is being shut down. The Terminal PIC will activate the emergency shutdown switch and close the valve closest to the dock.
 - **If transferring Terminal to Tank Vessel:** The Terminal PIC activates the shutdown switch at the dock, shutting down all operations at the Terminal. The PIC then shuts down the manual valves at the dock. Valves on the interior of the tank farms are motorized, and will be closed remotely.

5.1.1 Seismic Vulnerabilities

Tanks are susceptible to damage following an earthquake from shaking or differential displacements.

Similarly, piping is susceptible to damage from differential displacements of supports and anchor points.

If tanks or piping are damaged in an earthquake, the concrete containment walls that form part of the secondary containment are critical in controlling the spill and its associated environmental and safety hazards. These walls are also susceptible to damage during an earthquake. From a safety standpoint, loss of containment for a spill would potentially spread the life safety hazards over a larger area, including fire and exposure to hazardous materials.

5.2 Fire Control and Suppression Systems

This section addresses Rule 340-300-0003(6)(c)(A) and Rule 340-300-0003(1)(i).

The terminal fire control system includes a fire main fed from a municipal source that feeds a series of fire hydrants, hoses, nozzles, and fire monitors. The terminal has two booster pumps, both fed from a municipal connection, to increase water pressure throughout the terminal and to inject foam into specific tanks. One booster pump is electric and depends on municipal power, but the second is diesel and can continue to operate even with a complete loss of municipal power.

The terminal truck loading lanes are protected by an automatic foam deluge / sprinkler system that automatically dispenses foam over the truck lanes upon sensing a fire. The foam deluge / sprinkler system can also be manually actuated from locations near the loading lanes.

The terminal foam system can also supply a sub-surface foam injection system into terminal tanks.

In addition, the Terminal is equipped with handheld and wheeled extinguishers located throughout the facility.

The Biodiesel Tank Farm is protected by containment walls that are only 2.5 feet tall, which may not be tall enough to provide adequate protection from radiant heat due to a pool fire. However, most of the tanks inside the Lube Oil Tank Farm are either out of service or used to store process water, with only one tank used to store combustible cargo. For this reason, it was determined that there is a decreased chance of a pool fire and no concerns noted by the audit team.

The rest of the terminal is protected by containment walls that can function as firewalls to limit the spread of fire.

5.2.1 Seismic Vulnerabilities

The firewater system and foam distribution system rely on municipal water, which might not be available following an earthquake.

Containment walls, which can also act as firewalls, are susceptible to damage during an earthquake.

5.3 Emergency Response Equipment

This section addresses Rule 340-300-0003(6)(c)(C) and Rule 340-300-0003(1)(h).

Automated Sprinkler Systems

The tank truck loading lanes are protected by a sprinkler / deluge foam system that automatically starts upon detecting a fire. The deluge system can also be activated manually.

Firefighting Foam

The terminal tank foam system includes 1,300 gallons of foam and can provide 1200 gpm of firewater / foam concentrate to the tank foam systems. The truck rack foam system is equipped with 600 gallons of foam and can deliver 1200 gpm of fire water / foam concentrate via the deluge system.

The foam system was reviewed and approved by the Authority Having Jurisdiction as part of a recent project.

The terminal is equipped with two booster pumps, one diesel and the other electric, to ensure adequate pressure and flow is available for the firewater and foam system.

Spill Response Kits

The terminal has spill response kits strategically located throughout the Terminal, as well as storage containers to store spill waste.

Power and Communications

The terminal is equipped with a radio repeater located on the Main Office that extends range and facilitates communication and emergency coordination by way of handheld, two-way radios. However, the radios can make direct radio-to-radio calls, and continue to function even if the repeater loses power.

In addition, the terminal is equipped with Emergency Shutdown stations at the Loading Rack, the Terminal Office and inside the Dock House which can all be used to secure a cargo transfer operation remotely and quickly.

5.3.1 Seismic Vulnerabilities

The firewater system and foam distribution system rely on municipal water, which might not be available following an earthquake.

Remotely actuated Emergency Shutdown systems, including the fire detection and automatic deluge system at the truck loading rack, depend on municipal power to operate, which may not be available following an earthquake.

5.4 Safety and Operating Conditions

This section addresses Rule 340-300-0003(1)(g).

Terminal operating conditions, safe shutdown procedures and preparedness for potential spills are consistent with industry best-practices, and no concerns were noted by the audit team.

The terminal is equipped with Emergency Shutdown actuation stations that can help secure transfers at the Loading Rack and at the Dock.

Yard lighting is not equipped with emergency backup power, and relies solely on municipal power.

5.4.1 Seismic Vulnerabilities

Remotely actuated Emergency Shutdown systems depend on municipal power to operate, which may not be available following an earthquake.

Terminal yard lighting depends on municipal power to operate, which may not be available following an earthquake.

5.5 Terminal Staffing, Monitoring, and Response

The terminal is staffed 24 hours a day, 7 days a week.

5.5.1 Seismic Vulnerabilities

None identified.

6. RISK ASSESSMENT

We used a critical systems risk assessment process to identify, prioritize, and assess the seismic vulnerabilities of critical equipment, structures, and procedures during a DLE event. This analysis considered the performance of critical systems during and after the DLE event, and how their seismic vulnerabilities impact the prevention and containment of oil spills.

This risk assessment was in the form of a workshop including terminal operations and safety specialists, along with structural/seismic engineering specialists who understand the historic seismic performance of systems in earthquakes. With this experience we can consider realistic damage and failure scenarios rather than assessing strict conformance to current codes for new design. See Appendix C for a list of attendees.

The team considered possible scenarios due to earthquakes that could realistically occur and result in an uncontained spill, uncontrolled fire, explosion, or toxic release at the terminal. The workshop was used to risk rank and prioritize the criticality of various structures and systems during and following a seismic event in terms of the likelihood and consequences of a potential release of fuel from a spill caused by a DLE event.

The risk ranking was done through a risk matrix approach, using the risk matrices shown in Figures 6-1 and 6-2 for Environmental and Life-Safety risks, respectively.

We assigned structures and equipment a Likelihood of damage in a DLE that could lead to a spill, with ratings of 1 to 5 from "Very Unlikely" to "Very Likely", as defined in Appendix C. During the workshop, we assigned a Severity rating from A to E, from the least severe environmental or life-safety consequences to the most severe.

The Severity rating considered potential spill volumes, secondary containment mechanisms, operational or other safeguards that are in place, type of contents (i.e. flammability or combustibility of contents), and criticality of the component in emergency response. The potential

impact on public health and safety are also considered within the Life Safety severity. For example, the spill of a more volatile substance has a higher Life Safety consequence due to its fire potential.

We use the Severity and Likelihood to assign each item two risk ranking matrix scores. The environmental score relates to the quantity of spill and its impact on, or extent into, the neighboring community. The life-safety score relates to life-safety consequences that occur directly as a result of the spill.

For most items, the scores are specific to that item (e.g. based on an individual tank's Likelihood of structural failure and Severity of consequences). For secondary containment walls, the score considers all the tanks, piping, and other fuel storage within that area. If likelihood of structural failure is 'Possible' or more likely, then the severity score is based on the worst of any given tank or piping within that area. If the likelihood of structural failure is considered Very Unlikely or Unlikely, then the severity is based on the volume of potential overtopping using an expected probable volume of spill for tanks within that containment.

We also assigned two sets of scores, representing vulnerability with and without the considerations of geotechnical soil displacements. This is to inform the terminal of relative risks associated with the global liquefaction and lateral spreading hazard versus those associated with ground shaking.

We provide the complete risk assessment, including a table of all items and resulting risk assessment scores in Appendix C.

Risk Assessment Matrix - Environmental

		LIKELIHOOD					
		1	2	3	4	5	
Environmental Consequences		Very Unlikely	Unlikely	Possible	Likely	Very Likely	
SEVERITY	A	No release.	A1	A2	A3	A4	A5
	B	Release within secondary containment and no offsite impact.	B1	B2	B3	B4	B5
	C	Release exceeds secondary containment, but no offsite impact.	C1	C2	C3	C4	C5
	D	Minor offsite release.	D1	D2	D3	D4	D5
	E	Major offsite release.	E1	E2	E3	E4	E5

- High Risk -- Mitigations to be considered using ALARP (As Low as Reasonably Practicable)
- Moderate Risk -- Further evaluation recommended to determine if mitigation is necessary
- Low Risk -- No mitigations recommended

Figure 6-1 – Environmental Risk Assessment Matrix

Risk Assessment Matrix - Life Safety

		LIKELIHOOD					
		1	2	3	4	5	
		Very Unlikely	Unlikely	Possible	Likely	Very Likely	
Life-Safety Consequences							
SEVERITY	A	Minor / First Aid Injury No Impact on Public	A1	A2	A3	A4	A5
	B	Injury With Medical Treatment No Impact on Public	B1	B2	B3	B4	B5
	C	Serious Injury / Partial Disability Limited Impact on Public	C1	C2	C3	C4	C5
	D	Single Fatality / Serious Injury Impact on Public	D1	D2	D3	D4	D5
	E	Multiple Fatalities / Serious Injuries Significant Impact on Public	E1	E2	E3	E4	E5

- High Risk -- Mitigations to be considered using ALARP (As Low as Reasonably Practicable)
- Moderate Risk -- Further evaluation recommended to determine if mitigation is necessary
- Low Risk -- No mitigations recommended

Figure 6-2 – Life-Safety Risk Assessment Matrix

7. FINDINGS

Based upon the geotechnical, structural, and safety assessments as described herein, we have identified the key vulnerability findings as summarized below.

Items are categorized as Moderate or High Risk based on the full consideration of hazards, including earthquake induced ground deformations. Although the Likelihood of a spill may increase as a result of ground deformations, severity of consequences are typically the same. Thus, the risk categorization (or color) does not necessarily change due to the addition of ground deformations. Where the with- and without- ground deformation score results in a difference in categorization, the without ground deformation categorization is also indicated.

For High Risk items, mitigations should be considered using As Low As Reasonably Practicable (ALARP) risk reduction philosophy. For Moderate Risk items, further evaluation is recommended to determine if mitigation is necessary. For example, this may include detailed engineering calculations to quantify the seismic capacity of specific, existing components.

Table 7-1 - Summary of High Risk Items

North Tank Farm	South Tank Farm	Biodiesel Tank Farm	Butane Storage, Water Separators, & Dock	Safety Systems & Buildings
Containment Walls	Containment Walls	Containment Walls	Sheet Pile Wall	Water Main
Tank Foam System			Dock	Foam System
			Dock Piping	Deluge System
			Oil Water Separator ¹	
			Storm Water Separator ¹	

1. These items are Moderate Risk without consideration of ground deformation and elevated to High with ground deformation due to increased Likelihood of damage.

Table 7-2 - Summary of Moderate Risk Items

North Tank Farm	South Tank Farm	Biodiesel Tank Farm	Butane Storage, Water Separators, & Dock
Piping ¹	Piping ¹	Piping ¹	Piping ¹
Tank 1			Fire Pump
Tank 5			
Tank 6			
Tank 8			
Tank 11			
Tank 24			
Tank 25			

1. All piping (except at the dock) is Moderate with ground deformations due to Likelihood. Non-flammable product piping is Low Risk without ground displacements. Piping for flammable fuels are Moderate Risk with- or without- ground deformation due to Life Safety Severity.

7.1 Geotechnical

We have determined a peak ground acceleration (PGA_M) of 0.49g for the ASCE 7-16 DLE event.

The sheet pile wall design estimates lateral displacements on the order 1½ ft, though the toe is in liquefiable material and the design does not appear to include inertial seismic forces. It is unclear at this time if the FLAC analysis considers the potential for deep-seated seismic deformations occurring below the wall. Future investigations should include a detailed review and validation of the sheet pile wall’s FLAC analysis to understand the original assumptions, including considerations for global stability due to the deep-seated liquefiable soil and considerations for inertial seismic forces, and to confirm the sheet pile wall’s expected lateral displacement.

The estimated seismically-induced vertical ground deformations vary from 2 in. to 18 in. at the site, with the potential for larger vertical deformations if large lateral deformations occur due to the performance of the sheet pile wall. Our structural and safety assessments considered these potential displacements.

7.2 Structural

Many of the tanks in the North Tank Farm have a Moderate Risk due to their flammable contents and a higher Life Safety severity. Additionally, Tank 1 is riveted, and Tanks 5, 6, 8, and 11 are Moderate Risk due to a higher Likelihood of damage driven by an over-constrained condition with stairs or piping, as shown in the example photos below. Tanks 24 and 25 are rated Moderate due to a high H/D ratio, even considering them half full.

Pipelines are rated Moderate throughout the terminal due to differential displacements from vertical settlement and the anticipated pipe stresses. At the dock, pipelines are rated High due to a higher consequence of damage and spill directly into the river. Additionally, the dock piping is likely to experience high stresses due to its supported condition on the wharf and the higher soil displacements estimated at the river front.

The containment walls are rated High due to their importance in containing spills and the uncertainty in their capacity to withstand seismic loads due to their age and construction.



Figure 7-1: Example Over-Constrained Conditions

Left: Short pipe run to u-bolt at Tank 5

Right: Anchored stair handrail at Tank 11

7.3 Safety

The water supply is rated as a High Risk seismic vulnerability. The facility relies on municipal water as its only source for firewater and for foam distribution. It is highly unlikely municipal water will be available following the DLE considered by the Rules.

Since the foam system, fire pump, and deluge systems are dependent on municipal water, which is unlikely to be available following the DLE, and the consequence of these systems being unavailable, these items are deemed a High Risk.

Power is needed for the electric fire / foam pump, MOVs, and facility lighting. However, the diesel fire / foam pump can continue operating even during a loss of municipal power . Since it is very likely that power will be lost following an earthquake, we determined that loss of power is a Medium Risk item.

8. REFERENCES

1. API Standard 570 "Piping Inspection Code: Inspection, Repair, Alteration and Rerating of In-Service Piping Systems, American Petroleum Institute (API)," 5th Edition, 2024.
2. API Standard 650 "Welded Tanks for Oil Storage, American Petroleum Institute (API)," 13th Edition, 2020.
3. API Standard 653 "Tank Inspection, Repair, Alteration and Reconstruction, American Petroleum Institute (API)," 5th Edition, 2020.
4. ASCE 7-16 "Minimum Design Loads and Associated Criteria for Buildings and Other Structures, American Society of Civil Engineers (ASCE), Structural Engineering Institute (SEI)," 2016.
5. ASCE 41-17 "Seismic Evaluation and Retrofit of Existing Buildings, American Society of Civil Engineers (ASCE), Structural Engineering Institute (SEI)," 2017.
6. ASCE 61-14 "Seismic Design of Piers and Wharves, American Society of Civil Engineers (ASCE), Coasts, Oceans, Ports & Rivers Institute, (COPRI)," 2014.
7. California Building Code (CBC) Chapter 31F, "Marine Oil Terminal Engineering and Maintenance Standards" (MOTEMS), 2022.
8. "Fuel Tank Stability Rules," Division 300, State of Oregon Department of Environmental Quality (DEQ), 2023.
9. "Guidance for California Accidental Release Prevention (CalARP) Program Seismic Assessments." Prepared for the Unified Program Agency (UPA) Subcommittee of the Region I Local Emergency Planning Committee (LEPC) by the CalARP Program Seismic Guidance Committee, January 2019.
10. "Guidelines for Seismic Evaluation and Design of Petrochemical Facilities," Task Committee on Seismic Evaluation and Design of Petrochemical Facilities, American Society of Civil Engineers (ASCE), 1997, 2nd Edition, 2011, and 3rd Edition, 2020.
11. SeaPort Midstream Partners Terminal Portland SPCC, "Spill Prevention, Control, and Countermeasure Plan, Portland Terminal," AECOM, July, 2022.
12. STI Standard SP001 "Standard for the Inspection of Aboveground Storage Tanks, Steel Tank Institute (STI)," 6th Edition, 2018.
13. TLP Management Services LLC Portland Terminal FRC, "Facility Response Plan / Oil Spill Contingency Plan," Response Management Associates Inc., July, 2021.

Appendix A

Site Plans & Inventory

ALTA/ACSM LAND TITLE SURVEY

SW 1/4, SEC. 2, T. 1 N., R. 1 W., W.M.
MULTNOMAH, OREGON

CHECKED BY: KWS
DRAWING NAME: 1504501_ALTA.DWG
SHEET: 2 OF 5

DRAWN BY: CMH
SCALE: 1" = 100'
DATE: 03/17/2016
JOB NUMBER: 15-045-01




SHEET TITLE:
ALTA/ACSM LAND TITLE SURVEY
CLIENT:
BP PIPELINES & LOGISTICS
PORTLAND, OREGON

PACIFIC GEOMATIC SERVICES, INC.
LAND SURVEYING & MAPPING SERVICES
QUALITY SERVICE - CREATIVE SOLUTIONS
6806 216TH STREET SW, STE. 304
MOUNTLAKE TERRACE, WA 98043
PHONE: (425) 775-5620 FAX: (425) 775-2849
WEB: www.pacgeom.com

PGS / INC

REV.	DESCRIPTION	BY	DATE
1	CLARIFIED THE DEPICTION OF STATE RIGHT-OF-WAY. REVISOR SURVEY NOTE 10.	JMM	03/28/2016

REVISIONS



FOUND 4 1/4" BRASS DISK ON 6"x6" CONC. MONUMENT IN CASE AT FINISH GRADE STAMPED "TIN R/W WC 801.70 WLY OF SE COR OF S. RICHARDS DLC NORTH LINE GEO J. WATTS D/LC 1964 (HELD) POINT NO. 1154 PER SN 59683 VISITED 12/01/2015

SITE INFORMATION
SITE ADDRESS: 9930 NW ST. HELENS ROAD
PORTLAND, OR 97231

MULTNOMAH COUNTY PROPERTY ID NUMBERS
PARCELS I & V (EAST OF R.R. R/W): R498331
PARCELS I & V (WEST OF R.R. R/W): R323771
PARCELS II, IV & IV-XII: R323779
PARCEL III: R323758

PARCEL AREAS
PARCEL I: 371,770 ± SQFT (8.53 ± ACRES)
INCLUDE PORTION OF W/R AND AREA EXTENDS TO HARBOR LINE AS ESTABLISHED BY US ARMY CORPS OF ENGINEERS.
PARCEL II, IV, IV-XII: 122,770 SQFT (2.82 ACRES)
PARCEL III: 58,519 SQFT (1.34 ACRES)
PARCEL V: 376,470 ± SQFT (8.64 ± ACRES)

LEGEND:
● MONUMENT SET (5/8" REBAR AND 2" ALUMINUM CAP UNLESS NOTED)
⊕ MONUMENT FOUND (AS NOTED)
○ PROP. CORNER FOUND (AS NOTED)

03/20/2016
REGISTERED PROFESSIONAL LAND SURVEYOR
KENNETH W. SWINDAMAN
#02759
RENEWS 06/30/2016



POINT NO. 1181 PER SN 59683 VISITED 12/01/2015

ALTA/ACSM LAND TITLE SURVEY

SW 1/4, SEC. 2, T. 1 N., R. 1 W., W.M.
MULTNOMAH, OREGON

LEGEND:

- | | | | |
|---------|-------------------------------|-------|---------------------------|
| ⊕ | MONUMENT FOUND (AS NOTED) | EH | ELECTRIC HANDHOLE |
| ○ | PROP. CORNER FOUND (AS NOTED) | EB | ELECTRIC JUNCTION BOX |
| R/W | RIGHT OF WAY | ⊕ | LUMINAIRE |
| (M) | MEASURED DISTANCE | ☆ | YARD LIGHT |
| (C) | CALCULATED DISTANCE | ○ | UTILITY POLE |
| (P) | PLAT DISTANCE | ⊖ | GUY ANCHOR |
| ○ | SANITARY SEWER MANHOLE | — x — | FENCE |
| ⊕ | CATCH BASIN (CB) | — c — | BURIED COMMUNICATION LINE |
| ⊕ | STORM DRAIN MANHOLE | WCR | WHEELCHAIR RAMP |
| SDCO | STORM DRAIN CLEANOUT | CONC | CONCRETE |
| ⊕ | WATER VALVE | CC | CONCRETE CURB |
| ⊕ | FIRE HYDRANT | EOA | EDGE OF ASPHALT |
| FDC | FIRE DEPARTMENT CONNECTION | • | BOLLARD |
| ⊕ | WATER METER | — | SIGN POST |
| Piv | POST-INDICATOR VALVE | ⊕ | MONITORING WELL |
| — GAS — | BURIED GAS LINE | SE(#) | SPECIAL EXCEPTION (#) |
| ⊕ | GAS VALVE | OHW | OVERHEAD WIRE |
| COMM | COMMUNICATIONS VAULT | | |



U.S. HWY 30 (COLUMBIA RIVER HWY)
PER ODOT DRAWING NO. 11B-7-47
NAMED US30: NW McNAMEE RD-NW
BRIDGE AVE SECTION DATED 8/6/2015.

03/28/2016
REGISTERED
PROFESSIONAL
LAND SURVEYOR
Kenneth W. Swindaman
OREGON
JULY 10, 1996
KENNETH W. SWINDAMAN
802769
RENEWS 06/20/2016

CHECKED BY: KWS	DRAWING NAME: 1504501_ALTA.DWG
DRAWN BY: CMH	DATE: 03/17/2016
SCALE: 1" = 30'	JOB NUMBER: 15-045-01
SHEET: 3 OF 5	

SHEET TITLE:
ALTA/ACSM LAND TITLE SURVEY
CLIENT:
BP PIPELINES & LOGISTICS
PORTLAND, OREGON

PACIFIC GEOMATIC SERVICES, INC.
LAND SURVEYING & MAPPING SERVICES
QUALITY SERVICE - CREATIVE SOLUTIONS
6808 216TH STREET SW, STE. 304
MOUNTLAKE TERRACE, WA 98043
PHONE: (425) 778-9620 FAX: (425) 775-2849
WEB: www.pacificgeomatic.com
PGS / INC



REV.	DESCRIPTION	BY	DATE
1	CLARIFIED THE DEPICTION OF STATE RIGHT-OF-WAY. REVISED SURVEY NOTE 10.	JNM	03/28/2016

ALTA/ACSM LAND TITLE SURVEY

SW 1/4, SEC. 2, T. 1 N., R. 1 W., W.M.
MULTNOMAH, OREGON

LEGEND:

- | | | | |
|-------|-------------------------------|-------|---------------------------|
| ⊕ | MONUMENT FOUND (AS NOTED) | ⊕ | ELECTRIC HANDHOLE |
| ○ | PROP. CORNER FOUND (AS NOTED) | ⊕ | ELECTRIC JUNCTION BOX |
| R/W | RIGHT OF WAY | ⊕ | LUMINAIRE |
| (M) | MEASURED DISTANCE | ☆ | YARD LIGHT |
| (C) | CALCULATED DISTANCE | ○ | UTILITY POLE |
| (P) | PLAT DISTANCE | — | GUY ANCHOR |
| ⊕ | SANITARY SEWER MANHOLE | — x | FENCE |
| ⊕ | CATCH BASIN (CB) | — C | BURIED COMMUNICATION LINE |
| ⊕ | STORM DRAIN MANHOLE | WCR | WHEELCHAIR RAMP |
| ⊕ | STORM DRAIN CLEANOUT | CONC | CONCRETE |
| ⊕ | WATER VALVE | CC | CONCRETE CURB |
| ⊕ | FIRE HYDRANT | EOA | EDGE OF ASPHALT |
| ⊕ | FIRE DEPARTMENT CONNECTION | • | BOLLARD |
| ⊕ | WATER METER | ⊕ | SIGN POST |
| PIV | POST-INDICATOR VALVE | ⊕ | MONITORING WELL |
| — GAS | BURIED GAS LINE | ⊕ | METAL STAIRCASE (TYP) |
| ⊕ | GAS VALVE | SE(#) | SPECIAL EXCEPTION (#) |
| ⊕ | COMMUNICATIONS VAULT | OHW | OVERHEAD WIRE |




03/28/2016
REGISTERED
PROFESSIONAL
LAND SURVEYOR
Kenneth W. Swindaman
OREGON
JULY 10, 1998
KENNETH W. SWINDAMAN
#02758
RENEWS 06/20/2016

CHECKED BY: KWS		DRAWING NAME: 1504501_ALTA.DWG	
DRAWN BY: CMH		DATE: 03/17/2016	
SCALE: 1" = 30'		JOB NUMBER: 15-045-01	
SHEET TITLE: ALTA/ACSM LAND TITLE SURVEY		SHEET: 4 OF 5	
CLIENT: BP PIPELINES & LOGISTICS PORTLAND, OREGON			
PACIFIC GEOMATIC SERVICES, INC. LAND SURVEYING & MAPPING SERVICES QUALITY SERVICE - CREATIVE SOLUTIONS 6808 216TH STREET SW, STE. 304 MOUNTLAKE TERRACE, WA 98043 PHONE: (425) 778-8620 FAX: (425) 775-2849 WEB: www.pacgeom.com			
PGS / INC 			
REVISIONS 1. CLARIFIED THE DEPICTION OF STATE RIGHT-OF-WAY. REVISED SURVEY NOTE 10.			
REV.	BY	DATE	
1	JMM	03/28/2016	

ALTA/ACSM LAND TITLE SURVEY

SW 1/4, SEC. 2, T. 1 N., R. 1 W., W.M.
MULTNOMAH, OREGON




U.S. HWY 30 (COLUMBIA RIVER HWY)

03/20/2016
REGISTERED
PROFESSIONAL
LAND SURVEYOR
KENNETH W. SWINDAMAN
#2789
RENEWS 06/20/2016


LEGEND:

- | | | | | | |
|------|-------------------------------|------------------|----------------------------|-------|---------------------------|
| ⊕ | MONUMENT FOUND (AS NOTED) | ⊗ | WATER VALVE | ○ | UTILITY POLE |
| ○ | PROP. CORNER FOUND (AS NOTED) | ⊗ _{FDC} | FIRE HYDRANT | ⊖ | GUY ANCHOR |
| R/W | RIGHT OF WAY | ⊗ | FIRE DEPARTMENT CONNECTION | — x — | FENCE |
| (M) | MEASURED DISTANCE | ⊗ | WATER METER | — c — | BURIED COMMUNICATION LINE |
| (C) | CALCULATED DISTANCE | PIV* | POST-INDICATOR VALVE | WCR | WHEELCHAIR RAMP |
| (P) | PLAT DISTANCE | — GAS — | BURIED GAS LINE | CONC | CONCRETE |
| ○ | SANITARY SEWER MANHOLE | ⊙ | GAS VALVE | CC | CONCRETE CURB |
| ⊞ | CATCH BASIN (CB) | ⊗ | ELECTRIC HANDHOLE | EOA | EDGE OF ASPHALT |
| ⊞ | STORM DRAIN MANHOLE | ⊗ | ELECTRIC JUNCTION BOX | • | BOLLARD |
| SDCO | STORM DRAIN CLEANOUT | ⊗ | LUMINAIRE | — | SIGN POST |
| | | ☆ | YARD LIGHT | ⊗ | MONITORING WELL |
| | | | | ⊗ | COMMUNICATIONS VAULT |
| | | | | ⊞ | METAL STAIRCASE (TYP) |
| | | | | SE(#) | SPECIAL EXCEPTION (#) |
| | | | | OHW | OVERHEAD WIRE |



CHECKED BY: KWS	DRAWING NAME: 1504501_ALTA.DWG	SHEET: 5 OF 5	
			DRAWN BY: CMH
SHEET TITLE: ALTA/ACSM LAND TITLE SURVEY		CLIENT: BP PIPELINES & LOGISTICS PORTLAND, OREGON	
PACIFIC GEOMATIC SERVICES, INC. LAND SURVEYING & MAPPING SERVICES QUALITY SERVICE - CREATIVE SOLUTIONS 6808 216TH STREET SW, STE. 304 MOUNTLAKE TERRACE, WA 98043 PHONE: (206) 835-6600 FAX: (206) 775-0849 WEB: www.pacificgeom.com			
REV.	DESCRIPTION	BY	DATE
1	CLARIFIED THE DEPICTION OF STATE RIGHT-OF-WAY. REVISED SURVEY NOTE 10.	JNM	03/28/2016


EVACUATION DIAGRAM



1. FOR PIPING SMALLER THAN 4" SEE ENLARGED PIPING PLANS
2. IN THE EVENT THE PRIMARY MUSTER POINT IS EITHER UNAVAILABLE OR INACCESSIBLE, THE DOCK MAY BE USED AS A SECONDARY MUSTER POINT.

LEGEND

	ABOVE GRADE GASOLINE LINE		CHAINLINK FENCE
	UNDERGROUND GASOLINE LINE		EARTH DIKE
	ABOVE GRADE DIESEL LINE		
	UNDERGROUND DIESEL LINE		
	ABOVE GRADE ETHANOL LINE		
	UNDERGROUND ETHANOL LINE		
	ABOVE GRADE BIODIESEL LINE		



ENGINEERING CONTRACTOR:
ANVIL CORPORATION
 BELLINGHAM, WA.
 Anvil project: BE9561
 AutoCAD file: 10110968
 Last edit: 10/30/07 08:25

LEGEND

MUSTER POINT

EVACUATION ROUTE

SECONDARY MUSTER POINT

Edited by: JADS of RJA
2/4/08

REVISION SECTION		AFIC	DIAG. NO.	BY	CHK	APR
0	8/8/03	ISSUED FOR 2003 COMPLIANCE	M833	N/A	RR	PT BM
1	4/05	UPDATED PER 2005 SPCC WALKDOWN	1698	N/A	PT	BM JP
2	9/08	UPDATED PER 2005 SPCC WALKDOWN	1733	N/A	PT	BM WN
3	10/25/07	UPDATED FOR BIODIESEL EQUIPMENT INSTALLATION	1802	N/A	DL	DA MI

TLP Management Services LLC

PORTLAND TERMINAL

DRAWING NO. _____ REVISION _____



Boat House

Dock House

Dock

Storm Water Separator

QAQC

Warehouse

Oil Water Separator

Storage

Tank 25
THIRD PARTY
ADDITIVE

TK 13
ETH

TK 12
ETH

TK 7
PREM

TK 11
ULR
H/L RVP

Biodiesel
Tank
Farm

TK 43
WATER

TK 42
O O S

TK 44
WATER

TK 19
WATER

TK 21
Additive

TK 1
ULR
9# + RVP

North Tank
Farm

TK 6
ULR
9# + RVP

TK 8
PREM

SIMOPS
Office

TK 41
O O S

TK 45
O O S

TK 40
O O S

TK 46
BIO

TK 10
ULSD #2

TK 17
ULSD #2

TK 15
BIO

South Tank
Farm

TK 14
ULSD #2

TK 3
ULSD#2

TK 4
ULR
H/L RVP

TK 2
WATER

TANK 24 BP
RACK
ADDITIVE

TK 5
ULR
H/L RVP

Truck Loading Rack

KINDER MORGAN 8" TO EUGENE

TO VALVES ALONG
ENTRANCE ROAD

KINDER MORGAN 8" TRANSFER LINE

TO VALVES ALONG
ENTRANCE ROAD

Truck Loading
Rack Manifold

KINDER MORGAN 8" TO / FROM WILLBRIDGE PUMP STATION

Rail Unloading Rack

Truck Shop

Boiler House

Butane tank


OLY RECEIVING LINES
14" GASOLINE
14" DIESEL

© 2018 Google

Guardshack

FIGURE 1.3

SITE PLAN / DRAINAGE DIAGRAM



BIO DIESEL TANK FARM		
TANK	PRODUCT	SAFE FILL CAP(BBLS)
40	NOT AVAILABLE	NOT APPLICABLE
41	*	4,983
42	*	4,983
43	*	4,983
44	*	4,983
45	NOT AVAILABLE	NOT APPLICABLE
46	BIO DIESEL	3273

* AVAILABLE FOR STORM WATER

CATHODIC PROTECTION RECTIFIER	
LOCATION	VOLUME
OUTSIDE NORTH TANK FARM	116 GALS
OUTSIDE SOUTH TANK FARM	116 GALS


* MARINE TRANSFER PIPING/ VALVES DESIGNATION	
1	= DIESEL FUELS
2	= BIODIESEL FUELS
3	= GASOLINES
4	= ETHANOL

STORM WATER DISCHARGE	
DRAINAGE AREA	DESCRIPTION OF DRAINAGE
	DRAINAGE TO TANK-19
	GRAVITY DRAINAGE TO NORTH OIL/WATER SEPARATOR
	IMPOUNDED STORM WATER, RELEASED TO NORTH OIL/WATER SEPARATOR (AFTER OBSERVATION)
	GROUND SURFACE IS PERVIOUS
	DRAINAGE TO SANITARY SEWER SYSTEM
	STORM WATER MONITORING LOCATION
	SPILL KIT

- LEGEND:
- MH = MANHOLE
 - CB = CATCH BASIN
 - BARRIER WELLS
 - WD = WATER DRAW
 - WP = WELL PUMP
 - RCP = OIL FILLED CATHODIC PROTECTION RECTIFIER
 - = USCG/EPA JURISDICTIONAL VALVE *

- SURFACE DRAINAGE
- STORM WATER
- SANITARY SEWER
- PROCESS OILY WATER
- GROUND WATER
- TREATED WATER

- NOTES:
- 1.) ALL PIPING IS SHOWN UNDERGROUND. FOR ABOVEGROUND PIPING (SEE 10110968)
 - 2.) ELEVATION DATUM IS CITY OF PORTLAND, BASED ON CITY OF PORTLAND BENCH MARK No. 1426 = EL. 32.25' (SEE DWG PO-P-93113)
 - 3.) COORDINATES ARE BASED ON THE OUTSIDE OF THE NORTH WALL OF THE NORTH TANK FARM DIKE
 WEST END N.6000.00 EAST END N. 6000.00
 E.10000.00 E.374.99
 (SEE DWG PO-P-93112)



REFERENCE DRAWINGS		REVISION SECTION							
DWG NO.	DESCRIPTION	REV.	DATE	REVISIONS	AFC	DIAG. NO.	BY	CHK	APR
		7	2/12	UPDATED PER 2011 SPCC WALKDOWN	3098	N/A	DL	TA	TA
		8	11/20/12	PER CITY OF PORTLAND STORMWATER INSPECTION	N/A	N/A	WM	TM	TM
		9	09/18/14	UPDATED PER SWPCP	N/A	N/A	WMM	WS	WS
		3	9/06	UPDATED PER 2006 SPCC WALKDOWN	1733	N/A	PT	BM	WN
		4	12/06	IDENTIFIED OUTFALL AREAS	1733	N/A	PT	BM	BD
		5	5/08	UPDATED PER 2007 SPCC WALKDOWN	N/A	N/A	BN	PT	TA
		6	2/22/11	SWPCP UPDATES - AECOM ENVIRONMENTAL	N/A	N/A	AECOM	DV	TA

OLD DWG NO:

TLP Management Services LLC

PORTLAND ENVIRONMENTAL COMPLIANCE

TANK FARM - GENERAL SITE PLAN

SCALE: 1"=40'
 DRAWING NO. PO-2-G-10110969
 TYPE:3 SUBTYPE:71
 REVISION 9

HAZARD IDENTIFICATION TANKS (Tank = any container that stores oil)							
Tank Number	Substance Stored (Oil & Haz. Substance)	Normal Working Capacity (Gallons)	Maximum Shell Capacity (Gallons)	Tank Type (ie. floating roof, fixed roof, etc.)	Year Built	Failure / Cause (Record cause and date of any Tank failure which has resulted in a loss of tank contents)	Containment Capacity (Gallons)
NORTH TANK FARM							
1	Gasoline	4,184,712	4,479,168	Internal Floating Roof	Pre-1940	None	5,443,801
2	Groundwater (Remediation)	N/A	1,231,000	Internal Floating Roof	1957	None	
3	Diesel	1,505,448	1,584,366	Internal Floating Roof	1957	None	
4	Gasoline	939,918	1,105,860	Internal Floating Roof	1957	None	
5	Gasoline	741,300	895,314	Internal Floating Roof	1957	None	
6	Gasoline	803,040	1,014,384	Internal Floating Roof	1957	None	
7	Gasoline	450,492	648,018	Internal Floating Roof	1957	None	
8	Gasoline	616,938	790,272	Internal Floating Roof	1957	None	
11	Gasoline	1,129,926	1,354,122	Internal Floating Roof	Pre-1940	None	
12	Ethanol	561,204	605,346	Internal Floating Roof	1961	None	
13	Ethanol	559,482	602,994	Internal Floating Roof	1961	None	
24	Gasoline Additive	15,960	20,286	Fixed Roof	1970	None	
25	Gasoline Additive	15,960	20,241	Fixed Roof	1966	None	
SOUTH TANK FARM							
9	Diesel	2,161,404	2,295,636	Fixed Roof	Pre-1940	None	3,622,080
10	Diesel	931,980	1,008,840	Fixed Roof	Pre-1940	None	
14	Diesel	1,046,388	1,121,736	Fixed Roof	Pre-1940	None	
15	Biodiesel	743,400	804,972	Fixed Roof	Pre-1940	None	
17	Diesel	3,125,472	3,329,340	Fixed Roof	Pre-1940	None	
18	Diesel	1,046,262	1,104,726	Fixed Roof	Pre-1940	None	
19	Oily Waste Water	184,000	198,828	Internal Floating Roof	1961	None	
21	Gasoline Additive	204,960	220,080	Fixed Roof	1961	None	

HAZARD IDENTIFICATION TANKS (Cont'd) (Tank = any container that stores oil)							
Tank Number	Substance Stored (Oil & Haz. Substance)	Normal Working Capacity (Gallons)	Maximum Shell Capacity (Gallons)	Tank Type (ie. floating roof, fixed roof, etc.)	Year Built	Failure / Cause (Record cause and date of any Tank failure which has resulted in a loss of tank contents)	Containment Capacity (Gallons)
BIODIESEL TANKS							
40	Unavailable	0	209,286	Fixed Roof	1954	None	261,874
41	Permanently Closed	0	209,286	Fixed Roof	1954	None	
42	Permanently Closed	0	209,286	Fixed Roof	1954	None	
43	Out of Service	0	209,286	Fixed Roof	1954	None	
44	Out of Service	0	209,286	Fixed Roof	1954	None	
45	Unavailable	0	209,286	Fixed Roof	1954	None	
46	Biodiesel	125,571	221,970	Fixed Roof	1954	None	
OUTSIDE TANK FARM							
23	Diesel Lubricity Additive	2,100	2,100	Horizontal Tank	2005	None	2,148
26	Diesel Conductivity Additive	N/A	300	Tote	NA	None	2,148
27	Diesel Conductivity Additive	N/A	300	Tote	N/A	None	N/A
T101	Butane	N/A	90,000	Horizontal Tank	2017	None	N/A
N/A	Diesel Lubricity Additive	N/A	300	Tote in Storage Shed	N/A	None	450
N/A	Diesel Red Dye	N/A	300 (2)	Tote in Storage Shed	N/A	None	450

(Note: Tanks 40 & 45 empty - open to provide SPCC required containment. Tanks 41 & 42 empty, slotted and permanently closed. Tanks 43 & 44 empty in reserve status for backup stormwater containment if needed.)

Appendix B

Geotechnical Assessment



155 Grand Avenue
Suite 504
Oakland, CA 94612
P 510.701.2266

gannettfleming.com

May 29, 2024

SGH Project No. 247052.00-TMPO / Gannett Fleming Project No. 078231

Julie A. Galbraith
Senior Project Manager
Simpson Gumpertz & Heger Inc.
1999 Harrison Street, Suite 2400
Oakland, CA 94612

**Re: Technical Memorandum
Preliminary Geotechnical Assessment
SeaPort Midstream Partners Portland Terminal – Seismic Vulnerability Assessment
Portland, Oregon**

Dear Ms. Galbraith:

At your request, Gannett Fleming, Inc. (Gannett Fleming) has prepared this technical memorandum summarizing our preliminary geotechnical assessment in support of the Seismic Vulnerability Assessment of the Seaport Midstream Partners Portland Terminal located at 9930 NW St. Helens Road in Portland, Oregon. We performed our assessment in general accordance with the scope of services per our agreement with Simpson Gumpertz & Heger Inc. (SGH) dated March 29, 2024. The following provides a summary of the results of our assessment based on an evaluation of existing geotechnical data for the site.

PROJECT BACKGROUND

The site is located along the west shoreline of the Willamette River, with primary improvements comprised of over two dozen fuel storage tanks, a wharf, product transfer pipelines, and associated facilities. A Seismic Vulnerability Assessment of the terminal will be required in accordance with the State of Oregon Department of Environmental Quality (DEQ) Division 300 Fuel Tank Seismic Stability Rules, Oregon Administrative Rules 340-300-0000 (Rules). The Rules require a Seismic Vulnerability Assessment be performed to evaluate the risk of seismically-induced impacts including liquefaction, settlement, lateral spreading, and ground failures. The objective of such an assessment is to identify any risk mitigation measures that may be necessary. SGH is leading the Seismic Vulnerability Assessment with geotechnical input provided by Gannett Fleming.

OBJECTIVE AND SCOPE OF SERVICES

The purpose of our geotechnical assessment is to provide input in support of the Seismic Vulnerability Assessment. In accordance with our agreement with SGH dated March 29, 2024, our assessment considers



existing site-specific geotechnical information and other existing data. The scope of our services included the following.

- Review of existing information and subsurface characterization considering geotechnical data for the site.
- Preliminary seismic hazards evaluation considering liquefaction triggering/cyclic degradation based on existing geotechnical data.
- Preliminary assessment of mechanisms contributing to vertical and lateral ground surface deformations.
- Qualitative evaluation of the potential effects of ground deformations on fuel storage tanks and associated facilities.
- Preparation of this memorandum.

SITE CONDITIONS

The terminal is located on the east side of NW St. Helens Road east of the foothills of the Tualatin Mountains along the western shoreline of the Willamette River as shown in Figure 1. The site is relatively flat at roughly elevation 35 feet (NAVD88). Terminal improvements include steel fuel storage tanks about 30 to 140 feet in diameter, a wharf, a waterfront sheet pile bulkhead wall (sheet pile wall), pumps, pipelines, secondary containment walls, a truck loading rack, and associated facilities. Bathymetric survey data collected by the United States Army Corps of Engineers indicate the waterfront slope is roughly 70 feet high. An aerial image of the terminal is presented in Figure 2.

We understand an anchored sheet pile wall was constructed along the waterfront circa 2009 to replace a concrete cantilever seawall constructed in the 1940s due to progressive structural failure. Sheet pile wall drawings prepared by URS dated March 2009 indicate the wall is located on the waterside of the 1940s seawall, with a pile tip elevation of about -7 feet (NAVD88) and two rows of tiebacks (URS 2009).

PREVIOUS STUDIES

Several previous geotechnical investigations have been performed at the site. These included geotechnical borings completed by URS Corporation (URS) in July/August of 2003 and October/November of 2004 as summarized in a Final Geotechnical Report prepared by URS dated April 12, 2006 (URS 2006). Five soil borings were completed as part of the 2003 investigation, with nineteen soil borings completed for the 2004 investigation. The data from the URS geotechnical investigations were considered as part of our geotechnical assessment. Subsurface cross sections including Standard Penetration Test (SPT) blow count (N value) data presented in a Final Geotechnical Analyses Report by URS dated April 1, 2007, are included as Appendix A of this memorandum (URS 2007). These data were referred to as part of a two-dimensional analyses completed using the computer program FLAC (Fast Lagrangian Analysis of Continua) in support of the existing sheet pile wall design. The FLAC analyses included static and post-seismic analysis of stresses and deformation of the sheet piles wall. The post-seismic analysis considered the reduced strength of the soils due to liquefaction, but did not consider seismic inertial forces. The post-seismic stability analyses, indicated up to about 1 ½ feet of horizontal displacement at the top of the sheet pile wall.

In addition to previous geotechnical studies, we understand that several groundwater monitoring and extraction wells have been installed at the site as part of a groundwater capture system related to remedial measures.

SUBSURFACE CONDITIONS

The site is underlain by various amounts of fill materials placed during site development. Regional geologic mapping indicates the site is underlain by young Quaternary alluvium comprised of river and stream deposits of silt, sand, clay, and peat of present floodplains (Schlicker, H.G., et al. 1967). The alluvium is largely confined to the ancient incised Willamette River channel, which includes the current channel and the adjacent floodplains. The mapping suggests the alluvium is underlain by Columbia River basalt at depth.

The previous borings by URS completed in July/August of 2003 and October/November of 2004 indicate subsurface conditions encountered that are generally consistent with site development and regional geology. The borings indicate subsurface soils are generally comprised of fill, stream deposits, alluvial deposits, and bedrock. The fill materials vary in thickness from about 15 to 35 feet, with greater thickness adjacent to the existing seawall and lesser thickness on the west side of the site. The fill primarily consists of loose to dense sands with varying amounts of silt and gravel, often containing debris such as brick, asphalt, glass, and wood. Stream deposits underlying the fill near the center of the site range in thickness from about 2 to 10 feet and are generally comprised of medium dense to dense sands interlayered with silts. These soils are interpreted to have been deposited in a historic stream channel originating from the adjacent Tualatin Mountains. Alluvial deposits underlying the fill and stream deposits are comprised of fine-grained and sandy sands. The fine-grained alluvium encountered is up to about 18 feet thick and generally consist of soft to very stiff silts and lean clays interlayered with sands deposited by successive historic flood events. The Sandy alluvium underlying the fine-grained alluvial and/or stream deposits primarily consist of loose to dense relatively clean to silty sands. The sandy alluvial deposits are up to about 20 feet thick and are underlain by basalt bedrock. Columbia River basalt was encountered in the west portion of the site at a depth of about 40 feet and at about 70 feet below the ground surface adjacent to the sheet pile wall.

Groundwater

Shallow groundwater was encountered in the borings by URS at depths ranging from about 1 to 13 feet. Groundwater evaluations at the site indicate the groundwater depth near the sheet pile wall is about 30 feet, which is likely influenced by the groundwater extraction wells at this location. Fluctuations in groundwater levels likely occur due to variations in the Willamette River water level, rainfall, underground drainage patterns, groundwater extraction, regional influence, and other factors.

SEISMIC HAZARDS ASSESSMENT

We have evaluated seismic hazards including liquefaction, lateral spreading, and seismic densification. As part of this, we have developed design earthquake ground motions for the purposes of our assessment. A summary of design earthquake ground motions and our conclusions regarding the potential for liquefaction and lateral spreading is provided below.

Design Earthquake Ground Motions

We developed seismic design parameters in accordance with the 2016 American Society of Civil Engineers (ASCE) Standard 7-16 (ASCE 7-16): Minimum Design Loads for Buildings and Other Structures (ASCE 2016) for the purposes of evaluating liquefaction potential and lateral spreading. Considering the existing geotechnical data and depth to bedrock, the site can be characterized as Site Class D. Using the ASCE 7 Hazard Tool, we calculated a maximum considered earthquake geometric mean (MCE_G) peak ground acceleration adjusted for site class (PGA_M) of 0.49g, corresponding to a moment magnitude (M_w) of 9.3 on the Cascadia Megathrust fault, which governs the seismic hazard at the site. Note this dominant magnitude

is slightly more conservative than the M_w 9.0 scenario noted in Chapter 99 of the Oregon Laws; however, we expect the difference in results of liquefaction and lateral spreading analysis to not vary significantly given the high magnitude of either event.

Liquefaction

Using the empirical procedure developed by Boulanger and Idriss (2014), we evaluated the potential for saturated soil deposits to liquefy. Field (uncorrected) Standard Penetration Test (SPT) blow counts within the various strata are shown on the geologic profile included in Appendix A. Our analysis accounts for the liquefaction potential of sands and post-cyclic behavior of silt-rich soil with consideration to data from published studies of Willamette River Silt (Dickenson, et al. 2022) as well as the potential for seismic densification (seismic settlement of sands above the groundwater table). We considered a PGA_M of 0.49g and a moment magnitude (M_w) of 9.3.

The results of our evaluation indicate the potential for liquefaction is high considering the design earthquake. This is consistent with previous assessments by URS (URS 2007). Excess pore-water pressures generated during liquefaction will cause ground settlement as the pore pressures dissipate (referred to as reconsolidation). In addition, excess pore pressures will result in strength loss, which can lead to lateral spreading and other effects such as floatation of underground structures and increased lateral pressures on submerged retaining walls. The primary mechanisms of liquefaction-induced ground settlement are reconsolidation (seismic settlement of soils below the groundwater table), ejecta-induced, and shear-induced deformation. In addition, sands above the groundwater table can undergo seismic densification resulting in ground settlement. We summarize our assessment of seismic densification and the effects of liquefaction including ground settlement, floatation of underground structures, and increased lateral pressures below, which is followed by our evaluation of lateral spreading in a subsequent section of this memorandum.

Seismic Densification and Reconsolidation Settlement

Considering the generally shallow groundwater conditions at the site, the risk of seismically-induced settlement resulting from the densification of sands above the groundwater table is low. However, a considerable amount of liquefaction-induced settlement from reconsolidation can occur. The seismically-induced ground deformations summarized in a subsequent section of this memorandum are based on the approaches developed by Tokimatsu and Seed (1987) and Ishihara and Yoshimine (1992).

Ejecta-Induced Settlement

Based on our evaluation of the potential for surface effects, we conclude there is a high likelihood of ground surface disruption following liquefaction given the relatively thin non-liquefiable soil (crust) overlying relatively thick liquefiable soil. Surface effects can occur as water is forced to the ground surface when the dissipation of excess pore-water pressures in the liquefied soil exceeds the resistance of the overlying non-liquefiable crust. This can lead to sediment ejecta and settlement from ground loss as the expelled pore-water carries sand particles to the ground surface through volcano-like vents (referred to as sand boils). Ground surface disruption associated with lateral spreading tends to increase the likelihood of sediment ejecta. Our assessment of ejecta-induced settlement considers a review of case histories, such as those summarized by Mijic, et al. (2002), and professional experience including post-earthquake observations.

Shear-Induced Settlement

In addition to settlement from reconsolidation and sediment ejecta, liquefaction-induced foundation settlement can occur when shear-induced deformations driven by cyclic loading occur due to ratcheting and bearing capacity types of movement caused by soil structure interaction (SSI). The amount of foundation settlement in response to the design earthquake depends on the seismic bearing pressures imposed by the structure, foundation dimensions, and liquefied soil strengths. We anticipate settlement would be most significant where the thickness of non-liquefiable crust beneath the foundation is the lowest. While shear-induced foundation settlement is difficult to predict and would need to be evaluated on a case-by-case basis, we expect that up to about 1 foot or more of shear-induced foundation settlement could occur.

Floatation of Underground Structures

Underground structures including underground tanks, vaults, and manholes may be susceptible to floatation due to liquefaction. This can occur as the soil liquefies and loses shear resistance against the uplift force from the buoyancy of the underground structure. The magnitude of uplift displacement depends on the depth of the structure as well as the duration and intensity of earthquake ground motions and is difficult to predict. This would need to be further evaluated for specific underground structures if needed.

Increased Lateral Pressures on Retaining Walls

Liquefied soils will impose increased lateral loads on submerged retaining walls such as the existing sheet pile bulkhead wall. This is due to the reduction in shear strength resulting from liquefaction. Decreased shear strength may also reduce the capacity of tieback anchors. These effects will need to be considered as part of further evaluation of retaining walls.

Lateral Spreading

Lateral spreading is a phenomenon where a soil mass moves laterally on liquefied soil down a gentle slope or toward a free face, such as the adjacent Willamette River channel, due to reduced soil strengths and earthquake-induced forces acting on soils within and above the liquefied layer (seismic inertial loading). As noted in the 2007 URS report, relatively lateral ground deformations may be experienced following the liquefaction of soils behind the sheet pile wall, with estimates of up to about 1 ½ of horizontal wall displacement based on FLAC analyses (URS 2007). If the wall is effective at limiting lateral deformations to this magnitude, we would expect lower ground deformations with greater distance landward of the wall.

The sheet pile wall has a relatively shallow embedment below the riverbed and is underlain by liquefiable soils. It is unclear to what extent the previous FLAC analysis considered the potential for deep-seated (global) seismic deformations occurring below the wall. Slope deformation occurring below the wall may result in the translation/rotation of the wall and tiebacks behaving as a unit. If this is the case, potentially larger deformations than previously estimated may be realized and extend to substantial distances landward of the sheet pile wall. In any case, large deformations may be experienced on the waterside of the sheet pile wall as a result of unlimited strain development leading to flow-type failure. In this case, masses of ground may travel long distances (likely more than 5 feet) in the form of liquefied flows or blocks of ground riding on liquefied flows. Lateral spreading in this area will impose kinematic lateral loads on the wharf pile foundations where soil movements occur relative to the piles.

Seismically-Induced Ground Deformations

As indicated previously, the primary mechanisms of liquefaction-induced settlement are reconsolidation, ejecta-induced, and shear-induced deformation. In addition, sands above the groundwater table can undergo seismic densification resulting in ground settlement. We have developed preliminary estimates of vertical seismically-induced ground deformations to approximate the range of movements expected at the site as summarized Table 1 below. These estimates do not consider shear-induced foundation settlements discussed previously.

Table 1: Seismically-Induced Vertical Settlement

Mechanism	Probable Approximate Vertical Settlement Range¹ (inches)
Densification	< 1/2
Reconsolidation	2 to 6
Ejecta-Induced ²	Up to 12 (locally near ejecta)
All the Above	2 to 18

1. The estimated vertical ground deformations consider free-field conditions. Additional settlement of tanks and other structures may occur due to shear-induced foundation settlement as discussed previously.
2. Ground loss from sediment ejecta is highly variable and difficult to estimate.

It should be noted that lateral spreading also results in ground settlement, which can be as much as about one-third to one-half of the magnitude of lateral displacement. The vertical component of lateral deformation in the onshore portions of the site will depend on the seismic performance of the sheet pile wall, which will need to be evaluated further as discussed below. Large vertical deformations may be experienced on the waterside of the sheet pile wall due to flow slide failure.

CONCLUSIONS

As discussed herein, there are various liquefaction-induced mechanisms that could impact the terminal infrastructure. The most significant risk is related to lateral spreading on the waterside of the sheet pile wall, where the potential for flow slide failure exists. This can result in impacts on the facilities in this area including kinematic loading on piles supporting the wharf. Where seismically-induced ground deformations are not acceptable, potential mitigation measures could be considered. The potential for lateral spreading on the waterside of a shoreline buttress and potential kinematic load impacts on the existing wharf should be assessed as part of any remedial measures. Settlement and other foundation impacts could be mitigated by structural improvements/strengthening of shallow foundations, deep foundations, and/or ground improvement to make them less susceptible to vertical ground deformations.

An evaluation of the seismic performance of the sheet pile wall is critical to the understanding of the seismic hazard. Future investigations should focus on an assessment of lateral displacement considering the seismic performance of the wall including global stability. This would include a detailed review and validation of the FLAC model and analysis completed by URS, supplemented by simplified Newmark deformation and additional FLAC analyses. In addition, any future investigations should include the collection of data in support of developing remedial measures or further evaluating the performance of specific structures.

LIMITATIONS

This report has been prepared for the sole use of SGH and SeaPort Midstream Partners, and is specific to the conditions at the site as described herein. The opinions, conclusions, and recommendations contained in this report are based upon information obtained from existing geotechnical data, experience, and engineering judgment, and have been formulated in accordance with generally accepted geotechnical practices at the time this report was prepared; no other warranty is expressed or implied. In addition, the conclusions and recommendations presented in this report are based on interpretations of the subsurface conditions encountered in widely spaced explorations. Actual conditions may vary. If subsurface conditions encountered in the field differ from those described in this report, Gannett Fleming should be consulted to determine if changes to the conclusions presented herein or supplemental recommendations are required.


The opinions presented in this report are valid as of the date of this report. Changes in the condition of a site can occur with the passage of time, whether due to natural processes or the works of man. In addition, changes in applicable standard of practice can occur, whether from legislation or the broadening of knowledge. Accordingly, this report may be invalidated, wholly or partially, by changes outside of Gannett Fleming's control. In any case, this report should not be relied upon after a period of three years without prior review and approval by Gannett Fleming.

CLOSING


We appreciate the opportunity to collaborate with you on this important project. Please contact us if you have any questions.

Sincerely,

Gannett Fleming, Inc.



Benjamin Serna, PE
Principal Engineer



R. William Rudolph
Senior Consultant

Attachments: Figures
Appendix A – Existing Data

REFERENCES

ASCE, 2016, ASCE Standard (7-16), Minimum Design Loads and Associated Criteria for Buildings and Other Structures, 2016.

Beeson, M.H., Tolan, T.L., and Madin, I.P., 1991, Geologic Map of the Portland Quadrangle, Multnomah and Washington Counties, Oregon, and Clark County, Washington, Geological Map Series 75, 1:24,000.

Boulanger, R.W., and Idriss, I.M., 2014, CPT and SPT Based Liquefaction Triggering Procedures, Report No. UCD/CGM-14/01, Department of Civil and Environmental Engineering, University of California, Davis, USA.

Dickenson, S.E., Khosravifar, A., Beaty, M., Bock, J., Moug, D., Schlechter, S., and Six, J., 2022, Cyclic and Post-Cyclic Behavior of Silt-Rich, Transitional Soils of the Pacific Northwest: A Database for Geo-professionals in Practice and Research, August 2022.

Ishihara, K., and Yoshimine, M., 1992, Evaluation of Settlements in Sand Deposits Following Liquefaction During Earthquakes, *Soils and Foundations*, Volume 32, No. 1.

Mijic, Z., Bray, J.D., and Sjoerd van Ballegooy, 2022, Evaluation of Liquefaction Ejecta Case Histories in Christchurch, Geo-Congress 2022 Proceedings.

Tokimatsu, K., and Seed, H.B., 1987, Evaluation of Settlements in Sands due to Earthquake Shaking, *Journal of Geotechnical Engineering*, Volume 113, No. 8.


Schlicker, H.G., and Deacon, R.J., 1967, Engineering Geology of the Tualatin Valley Region, Oregon Department of Geology and Mineral Industries, Bulletin 60, 1:48,000.

URS Corporation, 2006, Final Geotechnical Report, Proposed Seawall Replacement, BP Terminal 22, Linnton, Oregon, April 12, 2006.

URS Corporation, 2007, Final Geotechnical Analyses Report, Proposed Seawall Replacement, BP Terminal 22, Linnton, Oregon, April 1, 2007.


URS Corporation, 2009, Revetment Removal Record Revision, BP West Coast Products, LLC, Terminal 22, Portland, Oregon, March 2009.

FIGURES



\n\p\figs\23\EnvSci\IP\Projects\07078231_TransMontaigne_Portland\MXD\Figures\Memo1_VicinityMap.mxd.mtc.c. 4/30/2024

Base map: Esri, 2024. Aerial imagery: USDA-NAIP, 2022.

	SITE VICINITY PLAN SeaPort Midstream Partners Portland Terminal Preliminary Geotechnical Assessment Portland, Oregon			FIGURE 1
	Date: 4/30/2024	By: M. Ticci	Scale: 1:250,000	Project No: 078231

WILLAMETTE RIVER

WHARF

EXISTING SHEET PILE WALL

SITE BOUNDARY (APPROXIMATE)

NORTH TANK FARM


LUBE OIL TANK FARM

SOUTH TANK FARM

TRUCK LOADING RACK

Aerial Imagery: Google, May 2021.

Imagery: USDA-NAIP, 2022.



SITE PLAN
SeaPort Midstream Partners Portland Terminal
Preliminary Geotechnical Assessment
Portland, Oregon

FIGURE
2

Date: 5/2/2024



By: M. Ticci

Scale: 1:1,200

Project No: 078231


\\cph623\env\sc\l\Projects\078231_TransMontaigne_Portland\MXD\Figures\Memo2_SitePlan.mxd, 5/2/2024, mticc

APPENDIX A – EXISTING DATA



LEGEND

- APPROXIMATE PROPERTY BOUNDARY
- CONCRETE TANK DIKE WALL FENCE
- GB-1 2003 URS GEOTECHNICAL BORING
- SC-17 2004 URS GEOTECHNICAL BORING
- SWGP-1 2005 URS GEOPROBE
- IW-4 MONITORING/RECOVERY WELL
- MW-13 PIEZOMETER
- P-13 02-2001 GEOPROBE
- GP-21 URS GEOPROBE
- GP-6 URS GEOPROBE
- VW-03 MOBIL MONITORING WELL
- KMW-09 MOBIL SOIL SAMPLE
- SC-2 LNAPL RECON WELL
- CMT-1 HART CROWSER GEOTECHNICAL BORING
- DW1 WELL




SITE PLAN

BP
APRIL 2007
38476256


TERMINAL 22
LINNTON, OREGON

FIGURE 1.2






- SANDY FILL WITH SILT AND WOOD DEBRIS
- FINE-GRAINED ALLUVIAL DEPOSITS
- STREAM DEPOSITS
- SANDY ALLUVIAL DEPOSITS
- BASE OF EXISTING SEAWALL
- BASE OF PROPOSED SHEET PILE WALL



C:\p0478231\22T_Sheet_Pile_Sewer\0000_Traffic\Geotechnical\Phase 1 - Final Section Report\CAD\Figure 2.1.DWG User: jerry Plot: 4/18/07 11:05am Last Saved: 4/01/2007 11:15am


		JOB No. 38478258		DESIGNED	PROJ. MANAGER	URS	BP TERMINAL 22T	9930 NW ST HELENS ROAD PORTLAND, OREGON		Geologic Cross Section Profile 2-2'		DRAWING NUMBER Figure 2.1	
		SCALE: As Noted	DRAWN BY: SPB	APPROVED BY						CAD FILE NUMBER			
				CHECKED BY	DATE: APRIL 2007	111 SW Columbia, Suite 1500 Portland, Oregon 97201-5814 (tel) 503-222-7200 (fax) 503-222-4292 www.urscorp.com				SHEET: 1 OF 1		REV. A	
No.	DATE	BY	REVISION										



D:\31470331_22T_Sheet_Pile_Seawall\31470331_Technical\Geotechnical\Phase II - Final Geotech Report\CAD\Figure 2.2.DWG User: jerry Protocad: Apr 08, 2007 - 11:26am User: jerry Protocad: Apr 08, 2007 - 12:39pm


JOB No. 38476256		DESIGNED:	PRCA. ENGINEER.	URS	BP TERMINAL 22T	9930 NW ST HELENS ROAD PORTLAND, OREGON	Cross Section A and Potential Excavation Units	DRAWING NUMBER: Figure 2.2	
SCALE: As Noted		DRAWN BY SPB	APPROVED BY:					CAD FILE NUMBER:	
		CHECKED BY:	DATE: APRIL 2007					SHEET: 1 OF 1	REV. A
No.	DATE	BY	REVISION	111 SW Columbia, Suite 1500 Portland, Oregon 97201-5850 (tel) 503-222-7200 (fax) 503-222-4292 www.urscorp.com					

D:\31470331_221_31471_P14_Sheet_P14_Sheet1.dwg User: jerry Date: 4/28/07 11:20am Plot Size: 11.25in x 17.25in



URS 111 SW Columbia, Suite 1500 Portland, Oregon 97201-5850 (tel) 503-222-7200 (fax) 503-222-4292 www.urscorp.com		BP TERMINAL 22T 9930 NW ST HELENS ROAD PORTLAND, OREGON		DRAWING NUMBER: Figure 2.3 CAD FILE NUMBER: SHEET: 1 OF 1 REV: A	
JOB No. 38476256	DESIGNED: SPB	PROJ. ENGINEER: [Blank]	APPROVED BY: [Blank]	CROSS SECTION B AND POTENTIAL EXCAVATION UNITS	
SCALE: As Noted	CHECKED BY: [Blank]	DATE: APRIL 2007	No. DATE BY REVISION		

D:\31470331_22T_Sheet_P14_Section\31470331_Technical\Geotechnical\Phase II - Final Geotech Report\CAD\Figure 2.4.DWG User: jerry Photo: Apr 08, 2007 - 11:30am Last Saved: Apr 01, 2007 - 12:42pm



No.	DATE	BY	REVISION

JOB No. 38476256	DESIGNED:	PRCA ENGINEER:
SCALE: As Noted	DRAWN BY SPB	APPROVED BY:
	CHECKED BY:	DATE: APRIL 2007


URS
 111 SW Columbia, Suite 1500
 Portland, Oregon 97201-5850
 (tel) 503-222-7200
 (fax) 503-222-4292
 www.urscorp.com

BP TERMINAL 22T
9930 NW ST HELENS ROAD
PORTLAND, OREGON

Cross Section C and
Potential Excavation Units

DRAWING NUMBER: Figure 2.4	
CAD FILE NUMBER:	
SHEET: 1 OF 1	REV. A

D:\31470331_221_Site\PM_Serial\5000_Technical\Geotechnical\Phase II - Final Geotech Report\CAD\Figure 2.5.DWG User: jerry Photocopy Date: 2007 - 11:30am Plot Size: 11.30x17.00 Plot Scale: 1:12.50mm



No.	DATE	BY	REVISION

JOB No. 38476256	DESIGNED:	PRCA ENGINEER:
SCALE: As Noted	DRAWN BY SPB	APPROVED BY:
	CHECKED BY:	DATE: APRIL 2007



--	--	--

URS
 111 SW Columbia, Suite 1500
 Portland, Oregon 97201-5850
 (tel) 503-222-7200
 (fax) 503-222-4292
 www.urscorp.com

BP TERMINAL 22T
 9930 NW ST HELENS ROAD
 PORTLAND, OREGON

**Cross Section D and
 Potential Excavation Units**


DRAWING NUMBER: Figure 2.5	
CAD FILE NUMBER:	
SHEET: 1 of 1	REV. A



*Maximum Low River Stage Recorded at the Morrison Bridge from 1990-Present (Measured on 9/21/03)
 **Boring/Well Installed on a Ramp ~2 feet Above the Surrounding Area
 Revetment Toe Interpreted from Construction Drawings (Not Field Verified)

JOB No. 38476256		DESIGNED:	PRJ. ENGINEER:	<p>111 SW Columbia, Suite 1500 Portland, Oregon 97201-5850 (tel) 503-222-7200 (fax) 503-222-4292 www.urscorp.com</p>	<p>BP TERMINAL 22T</p> <p>9930 NW ST HELENS ROAD PORTLAND, OREGON</p>	DRAWING NUMBER: Figure 2.6	
SCALE: As Noted		DRAWN BY: SPB	APPROVED BY:			CAD FILE NUMBER:	
		CHECKED BY:	DATE: APRIL 2007			SHEET: 1 OF 1	
						REV. A	
No.	DATE	BY	REVISION				

D:\31470331_221_Silver_Pile_Seawall\5000_Technical\Geotechnical\Phase II - Final Geotech Report\CAD\Figure 2.7.DWG User: jerry Photocopy: 08_2007 - 11:33am User: jerry Plot: 08/24/07 - 12:39pm



No.	DATE	BY	REVISION

JOB No. 38476256	DESIGNED:	PRCA. ENGINEER.
SCALE: As Noted	DRAWN BY SPB	APPROVED BY:
	CHECKED BY:	DATE: APRIL 2007

URS

111 SW Columbia, Suite 1500
Portland, Oregon 97201-5850
(tel) 503-222-7200
(fax) 503-222-4292
www.urscorp.com


BP TERMINAL 22T

**9930 NW ST HELENS ROAD
PORTLAND, OREGON**


**Cross Section F and
Potential Excavation Units**

DRAWING NUMBER: Figure 2.7	
CAD FILE NUMBER:	
SHEET: 1 OF 1	REV. A

D:\31470331_Z21_Signal_Plan_Sound\5000_Technical\Geotechnical\Phase II - Final\Geotech_Report\CAD\Figure 2.8.dwg User: jay Date: 04/01/2007 11:34am L:\1\31470331_01_2007 - 1.10pm



- SANDY FILL WITH SILT AND WOOD DEBRIS
- FINE-GRAINED ALLUVIAL DEPOSITS
- BASE OF EXISTING SEAWALL
- STREAM DEPOSITS
- SANDY ALLUVIAL DEPOSITS
- BASE OF PROPOSED SHEET PILE WALL



				JOB No. 38476256	DESIGNED:	PROJ. ENGINEER.	URS	BP TERMINAL 22T	9930 NW ST HELENS ROAD PORTLAND, OREGON	DRAWING NUMBER: Figure 2.8
				SCALE: As Noted	DRAWN BY SPB	APPROVED BY:				111 SW Columbia, Suite 1500 Portland, Oregon 97201-5850 (tel) 503-222-7200 (fax) 503-222-4292 www.urscorp.com
No.	DATE	BY	REVISION	CHECKED BY:	DATE: APRIL 2007					SHEET: 1 of 1
										REV. A

Appendix C

Risk Assessment

CRITICAL SYSTEMS RISK ASSESSMENT

Purpose:	To identify and prioritize critical structures, equipment, tanks, and systems and the performance requirements during and following an earthquake with regards to prevention and containment of oil spills.
Scope:	This study will address all facility components covered by the Rules.
Boundaries:	<p>The team will consider possible scenarios due to earthquakes that may realistically occur and result in an uncontained spill, uncontrolled fire, explosion, or toxic release at the terminal.</p> <p>The following items will be excluded from the scope of this study:</p> <ul style="list-style-type: none"> • Failures due to non-earthquake related causes • Life-safety considerations that are not directly caused by a spill that occurs due to an earthquake (e.g. life-safety concerns from occupants of a building that collapses)
Process:	<p><i>Before the Risk Assessment Session</i></p> <ul style="list-style-type: none"> • Prepare the charter for the risk assessment. • Prepare a draft assessment based on known industry and terminal practice and knowledge of this specific terminal gained through review of terminal documentation • SGH engineers will perform a structural “walkdown” review of the facility • SGH will prepopulate the risk matrix based on the walkdown review, preliminary geotechnical review, and other factors <p><i>During the Risk Assessment Session</i></p> <ul style="list-style-type: none"> • Review the risk assessment process and techniques to be used. • Present an overview of the risk assessment matrix. • Review the pre-developed list of systems and components

	<ul style="list-style-type: none"> • Identify additional systems and components • For each physical area of the terminal, identify the following: <ul style="list-style-type: none"> • Key components or systems that require documentation according to the Rules • Which components or systems contain hydrocarbons covered by the rules where spill is a concern • Safety systems that are being relied on for mitigation or response following an earthquake as related to the scope of the Rules • For each critical system, identify key components of that system and for each component perform the following: <ul style="list-style-type: none"> • Identify the possible nature of earthquake performance as related to the Rules (e.g. collapse, damage resulting in spill, functional failure) • Identify the likelihood of possible failure / unacceptable performance, consistent with the risk matrix, based on known properties of the system and visual reviews. (Note: this is subject to revision based on more detailed evaluation or additional data) • Identify the severity of possible safety or environmental consequences, consistent with the risk matrix • Assign a risk level consistent with the risk matrix • Document team findings <p><i>After the Risk Assessment Session</i></p> <ul style="list-style-type: none"> • Update the findings of the risk assessment as appropriate based on further evaluation or additional data • Use the risk assessment results as needed in development of the facilities mitigation plan, as required by the Rules
--	---

Risk Assessment Matrix - Environmental

		LIKELIHOOD					
		1	2	3	4	5	
Environmental Consequences		Very Unlikely	Unlikely	Possible	Likely	Very Likely	
SEVERITY	A	No release.	A1	A2	A3	A4	A5
	B	Release within secondary containment and no offsite impact.	B1	B2	B3	B4	B5
	C	Release exceeds secondary containment, but no offsite impact.	C1	C2	C3	C4	C5
	D	Minor offsite release.	D1	D2	D3	D4	D5
	E	Major offsite release.	E1	E2	E3	E4	E5

- High Risk -- Mitigations to be considered using ALARP (As Low as Reasonably Practicable)
- Moderate Risk -- Further evaluation recommended to determine if mitigation is necessary
- Low Risk -- No mitigations recommended

- Very Unlikely Designed to recent standards / No significant, obvious, spill-related deficiencies
- Unlikely Not designed to recent standards / **No** specific deficiencies that could lead to spill in **large** earthquakes
- Possible Not designed to recent standards / Has **potential** deficiencies that could lead to spill in **large** earthquakes
- Likely **Major** deficiencies present that would likely lead to spill in **large** earthquakes
- Very Likely **Major** deficiencies present that could lead to spill in **low or moderate** earthquakes

Risk Assessment Matrix - Life Safety

		LIKELIHOOD					
		1	2	3	4	5	
Life-Safety Consequences		Very Unlikely	Unlikely	Possible	Likely	Very Likely	
SEVERITY	A	Minor / First Aid Injury No Impact on Public	A1	A2	A3	A4	A5
	B	Injury With Medical Treatment No Impact on Public	B1	B2	B3	B4	B5
	C	Serious Injury / Partial Disability Limited Impact on Public	C1	C2	C3	C4	C5
	D	Single Fatality / Serious Injury Impact on Public	D1	D2	D3	D4	D5
	E	Multiple Fatalities / Serious Injuries Significant Impact on Public	E1	E2	E3	E4	E5

- High Risk -- Mitigations to be considered using ALARP (As Low as Reasonably Practicable)
- Moderate Risk -- Further evaluation recommended to determine if mitigation is necessary
- Low Risk -- No mitigations recommended

- Very Unlikely Designed to recent standards / No significant, obvious, spill-related, life-safety deficiencies
- Unlikely Not designed to recent standards / **No** specific deficiencies that could lead to spill-related, life-safety concerns in **large** earthquakes
- Possible Not designed to recent standards / Has **potential** deficiencies that could lead to spill-related, life-safety concerns in **large** earthquakes
- Likely **Major** deficiencies present that would likely lead to spill-related, life-safety concerns in **large** earthquakes
- Very Likely **Major** deficiencies present that could lead to spill-related, life-safety concerns in **low or moderate** earthquakes



Risk Assessment Report

Date:

April 8, 2024

Location:

Virtual

Attendees:

Attendees:

Gayle S. Johnson, P.E., SGH, Senior Principal (Facilitator)

Julie A. Galbraith, P.E., SGH, Senior Project Manager

Luis H. Palacios, P.E., SGH, Senior Technical Manager

Justin D. Reynolds, P.E., SGH, Senior Project Manager

Jun O. Tucay, P.E., S.E., SGH, Senior Consulting Engineer

Wesley Steffy, TMS, Project Engineer

Brian Hoyman, TMS, Terminal Manager

Vivian Rupe, TMS, Administrative Assistant



Location	Item Type	Identification	Contents	Out of Service?	Risk Assessment Rankings					Item or Score Notes	
					Likelihood WITHOUT Soil Displacements	Severity		Risk Score	Likelihood WITH Soil Displacements		Risk Score
						Environmental	Safety				
North Tank Farm											
North Tank Farm	Tank	1	Flammable Fuel		3. Possible	B. Release within secondary containment	C. Serious Injury / Limited Impact on Public	C3	3. Possible	C3	flammability increases severity
	Tank	2	Groundwater Remediation		2. Unlikely	B. Release within secondary containment	B. Injury With Medical Treatment	B2	2. Unlikely	B2	
	Tank	3	Combustible Fuel		2. Unlikely	B. Release within secondary containment	B. Injury With Medical Treatment	B2	2. Unlikely	B2	
	Tank	4	Flammable Fuel		2. Unlikely	B. Release within secondary containment	C. Serious Injury / Limited Impact on Public	C2	2. Unlikely	C2	flammability increases severity
	Tank	5	Flammable Fuel		3. Possible	B. Release within secondary containment	C. Serious Injury / Limited Impact on Public	C3	3. Possible	C3	piping constrained
	Tank	6	Flammable Fuel		3. Possible	B. Release within secondary containment	C. Serious Injury / Limited Impact on Public	C3	3. Possible	C3	piping constrained
	Tank	7	Flammable Fuel		2. Unlikely	B. Release within secondary containment	C. Serious Injury / Limited Impact on Public	C2	2. Unlikely	C2	flammability increases severity
	Tank	8	Flammable Fuel		3. Possible	B. Release within secondary containment	C. Serious Injury / Limited Impact on Public	C3	3. Possible	C3	piping constrained
	Tank	11	Flammable Fuel		3. Possible	B. Release within secondary containment	C. Serious Injury / Limited Impact on Public	C3	3. Possible	C3	piping constrained
	Tank	12	Non-Combustible Petroleum		2. Unlikely	B. Release within secondary containment	B. Injury With Medical Treatment	B2	2. Unlikely	B2	
	Tank	13	Non-Combustible Petroleum		2. Unlikely	B. Release within secondary containment	B. Injury With Medical Treatment	B2	2. Unlikely	B2	
	Tank	24	Non-Combustible Petroleum		5. Very Likely	B. Release within secondary containment	B. Injury With Medical Treatment	B5	5. Very Likely	B5	
	Tank	25	Non-Combustible Petroleum		5. Very Likely	B. Release within secondary containment	B. Injury With Medical Treatment	B5	5. Very Likely	B5	
		Total									
		Piping	Flammable Fuels			3. Possible	B. Release within secondary containment	C. Serious Injury / Limited Impact on Public	C3	4. Likely	C4
	Piping	Non-flammable fuels			3. Possible	B. Release within secondary containment	B. Injury With Medical Treatment	B3	4. Likely	B4	
	Process Equipment	Truck Loading Rack Manifold			1. Very Unlikely	B. Release within secondary containment	A. Minor / First Aid Injury	B1	1. Very Unlikely	B1	
	Fire Suppression System	Tank Foam (x2)			5. Very Likely	A. No Release	E. Multiple Fatalities	E5	3. Possible	E3	Relies on municipal water
	Secondary Containment Walls				3. Possible	E. Major offsite release	C. Serious Injury / Limited Impact on Public	E3	4. Likely	E4	
South Tank Farm											
South Tank Farm	Tank	9	Combustible Fuel		2. Unlikely	B. Release within secondary containment	B. Injury With Medical Treatment	B2	2. Unlikely	B2	
	Tank	10	Combustible Fuel		2. Unlikely	B. Release within secondary containment	B. Injury With Medical Treatment	B2	2. Unlikely	B2	
	Tank	14	Combustible Fuel		3. Possible	B. Release within secondary containment	B. Injury With Medical Treatment	B3	3. Possible	B3	
	Tank	15	Combustible Fuel		2. Unlikely	B. Release within secondary containment	B. Injury With Medical Treatment	B2	2. Unlikely	B2	
	Tank	17	Combustible Fuel		3. Possible	B. Release within secondary containment	B. Injury With Medical Treatment	B3	3. Possible	B3	
	Tank	18	Combustible Fuel		2. Unlikely	B. Release within secondary containment	B. Injury With Medical Treatment	B2	2. Unlikely	B2	
	Tank	19	Flammable Fuel (Process Water)		2. Unlikely	B. Release within secondary containment	C. Serious Injury / Limited Impact on Public	C2	2. Unlikely	C2	flammability increases severity
	Tank	21	Non-Combustible Petroleum		3. Possible	B. Release within secondary containment	B. Injury With Medical Treatment	B3	3. Possible	B3	
	Tank	Red Dye Tote Tank	Non-Combustible Petroleum		2. Unlikely	B. Release within secondary containment	B. Injury With Medical Treatment	B2	2. Unlikely	B2	
		Total									
		Piping	Flammable Fuels			3. Possible	B. Release within secondary containment	C. Serious Injury / Limited Impact on Public	C3	4. Likely	C4
	Piping	Non-flammable fuels			3. Possible	B. Release within secondary containment	B. Injury With Medical Treatment	B3	4. Likely	B4	
	Secondary Containment Walls				3. Possible	E. Major offsite release	B. Injury With Medical Treatment	E3	4. Likely	E4	

Location	Item Type	Identification	Contents	Out of Service?	Risk Assessment Rankings						Item or Score Notes	
					Likelihood WITHOUT Soil Displacements	Severity		Risk Score	Likelihood WITH Soil Displacements	Risk Score		
						Environmental	Safety					
Biodiesel Tank Farm												
Biodiesel Tank Farm	Tank	46	Combustible Fuel		3. Possible	B. Release within secondary containment	B. Injury With Medical Treatment	B3	3. Possible	B3		
	Tank	40	Non-Combustible Petroleum	Yes	2. Unlikely	A. No Release	A. Minor / First Aid Injury	A2	2. Unlikely	A2	Out of Service	
	Tank	41	Non-Combustible Petroleum	Yes	2. Unlikely	A. No Release	A. Minor / First Aid Injury	A2	2. Unlikely	A2	Out of Service	
	Tank	42	Non-Combustible Petroleum	Yes	2. Unlikely	A. No Release	A. Minor / First Aid Injury	A2	2. Unlikely	A2	Out of Service	
	Tank	43	Flammable Fuel (Process Water)		2. Unlikely	B. Release within secondary containment	B. Injury With Medical Treatment	B2	2. Unlikely	B2	flammability increases severity	
	Tank	44	Flammable Fuel (Process Water)		2. Unlikely	B. Release within secondary containment	B. Injury With Medical Treatment	B2	2. Unlikely	B2	flammability increases severity	
	Tank	45	Non-Combustible Petroleum	Yes	2. Unlikely	A. No Release	A. Minor / First Aid Injury	A2	2. Unlikely	A2	Out of Service	
		Total										
	Piping	Flammable Fuels			3. Possible	B. Release within secondary containment	C. Serious Injury / Limited Impact on Public	C3	4. Likely	C4		
	Piping	Non-flammable fuels			3. Possible	B. Release within secondary containment	B. Injury With Medical Treatment	B3	4. Likely	B4		
	Secondary Containment Walls			3. Possible	E. Major offsite release	B. Injury With Medical Treatment	E3	4. Likely	E4			
Butane Area												
	Tank	101	Flammable Fuel		1. Very Unlikely	B. Release within secondary containment	B. Injury With Medical Treatment	B1	1. Very Unlikely	B1		
	Piping	Flammable Fuels			3. Possible	B. Release within secondary containment	C. Serious Injury / Limited Impact on Public	C3	4. Likely	C4		
	Piping	Non-flammable fuels			3. Possible	B. Release within secondary containment	B. Injury With Medical Treatment	B3	4. Likely	B4		
Loading Racks												
	Tank	23	Non-Combustible Petroleum		2. Unlikely	B. Release within secondary containment	B. Injury With Medical Treatment	B2	2. Unlikely	B2		
	Tank	26	Non-Combustible Petroleum		2. Unlikely	B. Release within secondary containment	B. Injury With Medical Treatment	B2	2. Unlikely	B2		
	Loading Rack Structure	Truck Loading Rack			2. Unlikely	B. Release within secondary containment	A. Minor / First Aid Injury	B2	3. Possible	B3		
	Underground Vault	Pipeline Vault			2. Unlikely	B. Release within secondary containment	A. Minor / First Aid Injury	B2	3. Possible	B3		
	Loading Rack Structure	Rail Loading Rack			2. Unlikely	B. Release within secondary containment	A. Minor / First Aid Injury	B2	3. Possible	B3		
	Piping	Flammable Fuels			3. Possible	B. Release within secondary containment	C. Serious Injury / Limited Impact on Public	C3	4. Likely	C4		
	Piping	Non-flammable fuels			3. Possible	B. Release within secondary containment	B. Injury With Medical Treatment	B3	4. Likely	B4		
Dock Area												
	Marine Structure	Dock			3. Possible	E. Major offsite release	B. Injury With Medical Treatment	E3	4. Likely	E4		
	Building	Dock House			2. Unlikely	A. No Release	B. Injury With Medical Treatment	B2	4. Likely	B4		
	Piping	Flammable Fuels			3. Possible	E. Major offsite release	C. Serious Injury / Limited Impact on Public	E3	4. Likely	E4		
	Piping	Non-flammable fuels			3. Possible	E. Major offsite release	B. Injury With Medical Treatment	E3	4. Likely	E4		
	Marine Structure	Boat House			2. Unlikely	A. No Release	A. Minor / First Aid Injury	A2	2. Unlikely	A2		
	Process Equipment	Oil Water Separator			2. Unlikely	E. Major offsite release	C. Serious Injury / Limited Impact on Public	E2	4. Likely	E4		

					Risk Assessment Rankings						
Location	Item Type	Identification	Contents	Out of Service?	Severity			Risk Score	Likelihood WITH Soil Displacements	Risk Score	Item or Score Notes
					Likelihood WITHOUT Soil Displacements	Environmental	Safety				
Other Buildings/Structures (not in yards)											
	Process Equipment	Storm Water Separator			2. Unlikely	E. Major offsite release	C. Serious Injury / Limited Impact on Public	E2	4. Likely	E4	
	Building	Guardshack			2. Unlikely	A. No Release	A. Minor / First Aid Injury	A2	3. Possible	A3	
	Building	Truck Shop			2. Unlikely	A. No Release	A. Minor / First Aid Injury	A2	3. Possible	A3	
	Building	Boiler House			2. Unlikely	A. No Release	A. Minor / First Aid Injury	A2	3. Possible	A3	
	Building	Office			2. Unlikely	A. No Release	A. Minor / First Aid Injury	A2	3. Possible	A3	
	Building	SIMOPS			2. Unlikely	A. No Release	A. Minor / First Aid Injury	A2	3. Possible	A3	
	Building	Storage			2. Unlikely	A. No Release	A. Minor / First Aid Injury	A2	3. Possible	A3	
	Building	Warehouse									
	Building	QAQC			2. Unlikely	A. No Release	A. Minor / First Aid Injury	A2	3. Possible	A3	
Overall Terminal											
	Emergency Response	Operator Staffing			1. Very Unlikely	A. No Release	A. Minor / First Aid Injury	A1	1. Very Unlikely	A1	24/7 Coverage
	Emergency Response	Power			3. Possible	A. No Release	B. Injury With Medical Treatment	B3	3. Possible	B3	Power needed for lighting and ESD. Diesel booster pump still works
	Fire System	Water Main			5. Very Likely	A. No Release	D. Single Fatality / Impact on Public	D5	5. Very Likely	D5	Water main needed for firewater and foam
	Fire System	Foam System			5. Very Likely	A. No Release	D. Single Fatality / Impact on Public	D5	5. Very Likely	D5	Relies on municipal water
	Fire System	Fire Pump			2. Unlikely	A. No Release	D. Single Fatality / Impact on Public	D2	2. Unlikely	D2	Can run only on diesel booster pump but relies on municipal water
	Fire System	Deluge System			5. Very Likely	A. No Release	D. Single Fatality / Impact on Public	D5	5. Very Likely	D5	Relies on municipal water