



Program Enforcement No. 2024-FC-8902

**Department of Environmental Quality  
Underground Storage Tank Program**

**Field Citation  
For UST Violations**

This section for  
DEQ use only

Page 1 of 3

DEQ Information		UST Facility Information	
Inspection Date:	12/05/2023	Facility ID#:	692
Inspector:	Dylan Eckert	Facility Name:	Pacific Pride
DEQ Office:	165 E. 7th Ave. STE100 Eugene, OR 97401-3049	Facility Address:	3620 N. Hwy 97 Klamath Falls, OR 97601
Phone #:	541-686-7517	County:	Klamath

Oregon DEQ inspected the facility listed above and identified the UST violations listed on page 3 of this Field Citation.

Field Citation Issued:	<input type="radio"/> In Person <input checked="" type="radio"/> By Mail <input type="radio"/> Both	Date Issued:	01/04/2024
Facility Representative Present During Inspection:	Todd Roark <input type="radio"/> Permittee <input type="radio"/> Owner <input checked="" type="radio"/> Other		
Name of Permittee or Owner:	Todd Roark   Ed Staub & Sons Petroleum, Inc.		
Mailing Address:	1301 Esplanade Ave. Klamath Falls, OR 97601-5902		

Field Citation Penalty – See Page 3 for detailed listing of each violation.	\$ 400 .00
---	------------

This Field Citation is issued in accordance with the requirements for the expedited enforcement of underground storage tank (UST) violations, OAR 340-150-0250.

**Owner or Permittee should select Option 1 or Option 2 below and return a signed copy of this form to DEQ by the following date:** 02/01/2024

DEQ Revenue Section  
700 NE Multnomah St. #600  
Portland, Oregon 97232

**Check one option**

- ☐ **Option 1** - I acknowledge that the listed violation(s) have occurred and I am remitting the listed field citation penalty.
- ☐ **Option 2** - I do not want to participate in the expedited enforcement process and understand that my file will be referred to the Department's Office of Compliance and Enforcement for formal enforcement action.

Name:	Owner / Permittee
Signature:	Date:

**Important**

**Read pages 2 and 3 for more information about your options and a detailed listing of violations and compliance requirements.**

## **Field Citation Requirements**

The permittee or owner should select Option 1 or Option 2 and return a signed copy of Page 1 of the Field Citation form within thirty (30) days of issuance of the Field Citation. If the permittee or owner fails to sign and send Page 1 of the Field Citation form back or pay the penalty within thirty days, Option 1 expires, the Field Citation will serve as a Pre-Enforcement Notice (PEN) and the permittee and owner will be subject to formal enforcement including the imposition of civil penalties in accordance with OAR Chapter 340, Division 12.

The permittee or owner must complete the actions required to correct the violations listed on the Field Citation by the date specified to prevent further enforcement action by DEQ.

### **Option 1:**

By checking Option 1 the permittee or owner acknowledges that the violations listed on Page 3 of this Field Citation have occurred and agrees to pay the established penalty.

By submitting payment of the penalty amount, the responding permittee or owner agrees to accept the field citation as a final order of the Environmental Quality Commission (commission) and waives any and all rights and objections to the form, content, manner of service and timeliness of the Field Citation; to a contested case hearing and judicial review of the Field Citation [OAR 340-150-0250(6)]; and to service of a copy of this Final Order (*i.e.*, no other copy will be provided).

Upon the Department's receipt of payment of the penalty amount set forth in the Field Citation, the Field Citation becomes a Final Order of the Commission that:

1. Imposes upon the permittee or owner a civil penalty in the amount listed on Page 1 of this Field Citation; and
2. Requires the permittee or owner to satisfactorily complete the requirements and actions necessary to correct the violations documented by the dates set forth on Page 3 of this Field Citation.

Failure by the permittee or owner to complete the actions set forth on Page 3 of the Field Citation by the specified date violates the Commission Order and subjects the permittee and owner to a formal enforcement action including the imposition of additional civil penalties.

### **Option 2:**

The permittee or owner may deny that the violations as listed on Page 3 of this Field Citation have occurred or contest the Field Citation process by checking Option 2 and submitting to the Department a signed copy of Page 1 of the Field Citation. In that event, the Field Citation will serve as a Pre-Enforcement Notice (PEN) and the permittee and owner will be subject to formal enforcement for those violations set forth in the Field Citation, including the imposition of civil penalties in accordance with OAR Chapter 340, Division 12. Civil penalties that will be imposed by the formal enforcement process will exceed the Field Citation penalties for the same violation(s).

**The Department appreciates your cooperation and efforts to  
comply with the regulations for underground storage tank  
systems.**

**UST FIELD CITATION**

DATE ISSUED: 01/04/2024

PROGRAM ENFORCEMENT No.: 2024-FC-8902

FACILITY ID: 692

Page 3 of 3

<b>Violation #1:</b> *TCR: <input checked="" type="radio"/> Y <input type="radio"/> N	Failure to test containment sumps and conduct interstitial monitoring of piping		
Corrective Action:	Complete repairs of containment sumps, integrity test sumps, submit records of testing prior to deadline		
Rule Citation: <b>OAR 340-150- 0310(8)</b>	Penalty Amount: \$ 300 .00	Correct Violation by: 07/01/2024	Date Violation Corrected:
<b>Violation #2:</b> *TCR: <input checked="" type="radio"/> Y <input type="radio"/> N	Failure to properly test release detection equipment. Failure to test lines and leak detectors within 1 year of previous test		
Corrective Action:	Test release detection equipment per national / state standard. Submit records of testing to DEQ		
Rule Citation: <b>OAR 340-150- 0400(2)</b>	Penalty Amount: \$ 100 .00	Correct Violation by: 07/01/2024	Date Violation Corrected:
<b>Violation #3:</b> *TCR: <input checked="" type="radio"/> Y <input type="radio"/> N			
Corrective Action:			
Rule Citation: <b>OAR 340-150-</b>	Penalty Amount: \$ .00	Correct Violation by:	Date Violation Corrected:
<b>Violation #4:</b> *TCR: <input type="radio"/> Y <input type="radio"/> N			
Corrective Action:			
Rule Citation: <b>OAR 340-150-</b>	Penalty Amount: \$ .00	Correct Violation by:	Date Violation Corrected:
<b>Violation #5:</b> *TCR: <input type="radio"/> Y <input type="radio"/> N			
Corrective Action:			
Rule Citation: <b>OAR 340-150-</b>	Penalty Amount: \$ .00	Correct Violation by:	Date Violation Corrected:
<b>Violation #6:</b> *TCR: <input type="radio"/> Y <input type="radio"/> N			
Corrective Action:			
Rule Citation: <b>OAR 340-150-</b>	Penalty Amount: \$ .00	Correct Violation by:	Date Violation Corrected:
	Total Penalty Amount (This Page): \$ 400 .00	Total Penalty Amount (All Pages): \$ 400 .00	

**YOU MUST CORRECT THE VIOLATIONS AS REQUIRED, ENTER THE DATES CORRECTED, SIGN THE STATEMENT BELOW AND RETURN THIS FORM TO THE DEQ INSPECTOR LISTED ON PAGE 1 ON OR BEFORE: 07/01/2024**

**Retain a copy of this form and all documentation of corrective actions for your records.**

*I hereby certify that the UST violations noted above have been corrected:* \_\_\_\_\_ / \_\_\_\_\_  
Permittee/Owner Signature
Date

\*TCR: Technical Compliance Rate

Oregon Department of Environmental Quality - Underground Storage Tank Program  
Technical Compliance Inspection - UST Inspection Report

Inspector: DK Date: 05 Dec 2017 Time: \_\_\_\_\_ Facility: 692

**I. Site Information**

Facility Name: <u>Pacific Pride</u>	Permittee: <u>Stands</u>	Contact
Site Address: <u>3620 N Hwy 97</u>	Organization: <u>Stands</u>	Phone
City: <u>K Falls</u>	Phone:	

**II. Tank Information**

DEQ Permit #	<u>BEHCB</u>	<u>BEHCC</u>	<u>BEHCD</u>		
Estimated Gallons	<u>12k</u>	<u>6k</u>	<u>12k</u>		
Substance	<u>E</u>	<u>D ?</u>	<u>D</u>		
Tank Material	<u>FRP</u>	<u>D ?</u>	<u>D</u>		<u>Single</u>
Tank Install Date	<u>93</u>				
Pipe Material	<u>Pressure</u>				
Pipe Type					
Pipe Install Date	<u>2012</u>				
Overfill Device	<u>14LA</u>				

Notes and Comments from the UST database:

☐ Check file before conducting inspection

DD D

If tanks are manifolded, which tanks:

next to A19

**III. Operating Certificate**

Compliance

☐ Yes ☐ No

☒ Current ☐ Accurate ☐ Posted for delivery drive to observe

**IV. Operator Training**

Compliance

☐ Yes ☐ No

Class A/B Operator ☒ Yes ☐ No Name: \_\_\_\_\_ Date: \_\_\_\_\_

Class C Operator ☐ Yes ☐ No ☒ Cardlock

**V. Financial Responsibility**

Compliance

☐ Yes ☐ No

Type of coverage: \_\_\_\_\_ Begin Date: \_\_\_\_\_ End Date: \_\_\_\_\_

Coverage amount correct: 3/3

Financial responsibility could also be in the form of self insurance, bonds, local government, trust fund, and or guarantee

**VI. Walkthrough Requirements**

Compliance

☐ Yes ☐ No

Spill prevention and release detection equipment checked monthly? ☐ Yes ☐ No

Stank top sumps checked annually? ☐ Yes ☐ No



VII. Release Detection		Compliance	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
<b>Annual Release Detection Operability Testing</b> (Sometimes referred to as Tank Gauge Certification)				
Date of last testing: 2027		Last three tests available?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
<b>Piping Release Detection</b> (Check all that apply)				
<input checked="" type="checkbox"/> Pressurized Piping				
<input type="checkbox"/> Mechanical Leak Detector (MLLD) <input type="checkbox"/> Electronic Leak Detector (ELLD) - check for swiftcheck requirement				
Date of last testing:		Last three tests available?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Leak detector manufacturer make and model:				
Tank gauge manufacturer make and model: TLE-350				
MLLD on turbine manifold? <input type="checkbox"/> Yes <input type="checkbox"/> No				
MLLD product appropriate? (Example, diesel Red Jacket FX series on diesel system?) <input type="checkbox"/> Yes <input type="checkbox"/> No				
If ELLD and no line testing: Annual 0.1 gph results from tank gauge? <input type="checkbox"/> Yes <input type="checkbox"/> No				
<input checked="" type="checkbox"/> Interstitial Monitoring				
[Monthly records must include, date system was checked, observations made, initials of person checking. Electronic records must include power status (on or off), alarm indication status (yes or no) and sensor malfunction notes (yes or no).]				
Date of last sump testing:		Last two tests available?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Date of last sensor testing:		Last three tests available?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
Presence of water in sumps?		<input type="checkbox"/> Yes	<input type="checkbox"/> No	
Float sensors installed correctly?		<input type="checkbox"/> Yes	<input type="checkbox"/> No	
Interstitial space opened to sump?		<input type="checkbox"/> Yes	<input type="checkbox"/> No	
<input checked="" type="checkbox"/> Safe Suction				
Check valve directly below suction pump? <input type="checkbox"/> Yes <input type="checkbox"/> No				
<b>Monthly Tank Release Detection</b> (Check all that apply)				
<input checked="" type="checkbox"/> Tank Gauge <input checked="" type="checkbox"/> CSLD <input type="checkbox"/> SCALD <input type="checkbox"/> Static				
Are correct tank sizes programmed at tank gauge? <input type="checkbox"/> Yes <input type="checkbox"/> No				
Tank diameter/length seem appropriate? <input type="checkbox"/> Yes <input type="checkbox"/> No				
Are tanks manifolded? <input type="checkbox"/> Yes <input type="checkbox"/> No				
If so, tank gauge testing setup for manifolded tanks? <input type="checkbox"/> Yes <input type="checkbox"/> No				
<input type="checkbox"/> Interstitial Monitoring [Monthly records must include, date system was checked, observations made, initials of person checking. Electronic records must include power status (on or off), alarm indication status (yes or no) and sensor malfunction notes (yes or no).]				
<input type="checkbox"/> SIR    Ensure pass or fail results within 30-day period. Inconclusive result means release detection requirement not met				
Each tank must have passing monthly tank leak detection records. Can not change leak detection methods within a month; however, each tank could be using different method				
T1: <input type="checkbox"/> Jan <input type="checkbox"/> Feb <input type="checkbox"/> Mar <input type="checkbox"/> Apr <input type="checkbox"/> May <input type="checkbox"/> Jun <input type="checkbox"/> Jul <input type="checkbox"/> Aug <input type="checkbox"/> Sep <input type="checkbox"/> Oct <input type="checkbox"/> Nov <input type="checkbox"/> Dec				
T2: <input type="checkbox"/> Jan <input type="checkbox"/> Feb <input type="checkbox"/> Mar <input type="checkbox"/> Apr <input type="checkbox"/> May <input type="checkbox"/> Jun <input type="checkbox"/> Jul <input type="checkbox"/> Aug <input type="checkbox"/> Sep <input type="checkbox"/> Oct <input type="checkbox"/> Nov <input type="checkbox"/> Dec				
T3: <input type="checkbox"/> Jan <input type="checkbox"/> Feb <input type="checkbox"/> Mar <input type="checkbox"/> Apr <input type="checkbox"/> May <input type="checkbox"/> Jun <input type="checkbox"/> Jul <input type="checkbox"/> Aug <input type="checkbox"/> Sep <input type="checkbox"/> Oct <input type="checkbox"/> Nov <input type="checkbox"/> Dec				
T4: <input type="checkbox"/> Jan <input type="checkbox"/> Feb <input type="checkbox"/> Mar <input type="checkbox"/> Apr <input type="checkbox"/> May <input type="checkbox"/> Jun <input type="checkbox"/> Jul <input type="checkbox"/> Aug <input type="checkbox"/> Sep <input type="checkbox"/> Oct <input type="checkbox"/> Nov <input type="checkbox"/> Dec				
T5: <input type="checkbox"/> Jan <input type="checkbox"/> Feb <input type="checkbox"/> Mar <input type="checkbox"/> Apr <input type="checkbox"/> May <input type="checkbox"/> Jun <input type="checkbox"/> Jul <input type="checkbox"/> Aug <input type="checkbox"/> Sep <input type="checkbox"/> Oct <input type="checkbox"/> Nov <input type="checkbox"/> Dec				
If Veeder Root tank gauge leak detection				
<input type="checkbox"/> CSLD set at 99%				
<input type="checkbox"/> Thermal coefficient set correctly?				
(Gasoline 0.00070; Diesel 0.00045)				
If Incon/Franklin tank gauge leak detection				
<input type="checkbox"/> If SCALD is Vol Qual set to 14% (or 99% confidence)				
<input type="checkbox"/> Is API gravity set correctly?				
(Regular 63.5; Plus 62.8; Super 51.3; Diesel 32.8)				
For all tank gauges doing static tests				
(Static tests require tank to be 50% full for a valid test)				
Typical static leak test times				
6,000 gal UST 3 hours test time				
8,000 gal UST 4 hours test time				
10,000 gal UST 5 hours test time				
12,000 gal UST 6 hours test time				

Inspector: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_ Facility: 164425

### VIII. Spill Prevention

#### Compliance

☐ Yes ☒ No

Date(s) of testing: \_\_\_\_\_

Number of spill buckets tested? 3/7

Did spill bucket pass most recent testing? ☐ Yes ☐ No

☐ No

If no, was spill bucket replaced/repaired? ☐ Yes ☐ No

During inspection, visual damage to spill bucket? ☐ Yes ☐ No

☐ Yes

☐ No

☐ Hydrostatic testing (test takes one hour to complete)

☐ Vacuum test (test takes 1 minute, ending vacuum must be 26 inches water column or greater)

alby 24oct 2022 3/3 ✓

### IX. Overfill Prevention

#### Compliance

☐ Yes ☐ No

Date(s) of testing: \_\_\_\_\_

Overfill device pass most recent testing? ☐ Yes ☐ No

☐ No

If no, overfill device replaced? Need

☐ Yes

☐ No

Overfill method that was tested: ☐ Alarm

☐ Alarm

☐ Flapper

☐ Ball Float

#### Overfill Alarm

Alarm sounds when tank is 90% full

☐ Yes

☐ No

Driver can see or hear alarm at point of transfer?

☐ Yes

☐ No

Sound alarm from tank guage during inspection?

☐ Yes

☐ No

#### Flapper Valve

Testing verified the valve automatically restricts flow at 95%

☐ Yes

☐ No

Visual observation of flapper on day of inspection?

☐ Yes

☐ No

#### Ball Float

Testing verified the ball float automatically restricts flow at 90%

☐ Yes

☐ No

Visual observation of ball float during inspection?

☐ Yes

☐ No

### X. Corrosion Protection

#### Compliance

☐ Yes ☒ No

☐ Cathodic

☐ Galvanic

☐ Impressed Current

Steel tank with cathodic?

☐ Yes

☐ No

Steel pipes with cathodic?

☐ Yes

☐ No

Steel flex-lines with cathodic?

☐ Yes

☐ No

Date of cathodic test: \_\_\_\_\_

Last two tests available?

☐ Yes

☐ No

Did last test pass?

☐ Yes

☐ No

If not:

Was failed test reported to DEQ?

☐ Yes

☐ No

Was system repaired?

☐ Yes

☐ No

Date of repair? \_\_\_\_\_

Cathodic retested within 6 mos of repair?

☐ Yes

☐ No

Date of retesting? \_\_\_\_\_

If impressed current system:

Rectifier Operational?

☐ Yes

☐ No

Rectifier log maintained?

☐ Yes

☐ No

Rectifier been operating continuously

☐ Yes

☐ No

☐ Tank Lining

Date of last test? \_\_\_\_\_

Pressure test conducted after tank lining inspection?

☐ Yes

☐ No



# XI. Equipment

- ☐ Tank top and transition sumps: If direct bury turbines check to make sure metal piping is not in contact with soil. If interstitial monitoring of piping check sumps for water intrusion, placement of sensors, and piping interstice is open to sump. Check to ensure MLLDs are on turbine manifold. If manifolded tanks check to ensure siphon line is not in contact with soil. Check sump for product
- ☐ Under dispenser containment (UDC): If UDC is not present make sure metal flex lines are not in contact with soil. If interstitial monitoring of piping check UDC for water intrusion and placement of sensors. Check any satellite lines to ensure proper placement of solenoid valves. Check UDC for product
- ☐ Spill buckets: Check for holes, also observe any wear and tear. Verify spill buckets are dry and free of debris
- ☐ If overfill alarm: Verify alarm can be seen or heard at the point of delivery
- ☐ If flapper: Check drop tube for obstructions
- ☐ If ball float: Verify ball float and cage are present. Ensure ball moves freely.
- ☐ If impressed current from a galvanic system: Verify that rectifier is operational

## XI. General notes from inspection

Representative onsite: Todd email: \_\_\_\_\_

21 Jun 2023 - Pd, LH 3/3 ✓ UCD 3/3 ATg ✓  
PUCS  
22 Feb 2022 - UCD 3/3 - LH ✓ ATg ✓  
23 Feb 2021 UCD, LH, ATg

CA-01 Jul 2021-

CIF

Cie

ES

H2.7

H2.9

Need ALA

Pipe Install Date 2021

2024-FC-8902

# Photo Log

692

Photo

Notes

~~1~~ b pull  
Disk  
D 4H  
Rul  
Rul 5d  
DD  
side DP  
3/4  
82  
1/2  
6  
5  
6-  
#X 5 4+

RJ  
DD

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30

RJ, Apt 208

GLU

941D, 208

D end  
through end



**FACILITY NAME: 692**  
**DATE:**

Page 1

## 1:Form







3: Diesel STP



4: Diesel STP





5: Rul



6: Rul





7: DD



8:DD





9: Site



10: Site



11: 3/4



12: 1/2 87



13: 6



14: 5





15: 5



16:6



17:



18:6





19: 5 sat



20: 5 sat



# OREGON DEPARTMENT OF ENVIRONMENTAL QUALITY INSPECTION PHOTOLOG

FACILITY NAME: 692  
DATE:

Page 10

INSPECTION PHOTOLOG

DATE: 06/21/2023

TIME: 1:15 PM

LOCATION: 3620 HWY 97

DATE OF TESTING/SERVICING: 2023-06-21

ADDRESS: 3620 HWY 97

OUTPUT RELAY SETUP

TYPE: STANDARD

NORMALLY OPEN

IN-TANK ALARMS

ALL-OVERFILL ALARM

RELAY OUTPUT TEST

DEC 5, 2023 12:15 PM

TYPE: STANDARD

NORMALLY OPEN

IN-TANK ALARMS

ALL-OVERFILL ALARM

ALARM HISTORY REPORT

----- IN-TANK ALARM -----

T 1-HIGH SULPHUR

HIGH WATER ALARM

SEP 28, 2023 8:03 AM

APR 12, 2023 11:15 AM

APR 3, 2023 7:05 PM

LOW PRODUCT ALARM

FEB 24, 2023 8:15 PM

JAN 3, 2023 4:15 PM

DEC 15, 2022 6:57 PM

INVALID FUEL LEVEL

NOV 30, 2022 6:38 AM

HIGH WATER WARNING

SEP 28, 2023 8:05 AM

APR 12, 2023 11:13 AM

APR 3, 2023 7:05 PM

DELIVERY NEEDED

FEB 22, 2023 6:20 PM

DEC 16, 2022 1:45 PM

NOV 29, 2022 4:53 PM

Dispenser ID: ALL

Dispenser Containment Sensor(s) Model: 208

Shear Valve(s)

Dispenser Containment Float(s) and Churn(s)

Dispenser ID:

Dispenser Containment Sensor(s) Model:

Shear Valve(s)

Dispenser Containment Float(s) and Churn(s)

Dispenser ID:

Dispenser Containment Sensor(s) Model:

Shear Valve(s)

Dispenser Containment Float(s) and Churn(s)

Dispenser ID:

Dispenser Containment Sensor(s) Model:

Shear Valve(s)

Dispenser Containment Float(s) and Churn(s)

Dispenser ID:

Dispenser Containment Sensor(s) Model:

Shear Valve(s)

Dispenser Containment Float(s) and Churn(s)

C. Results of Testing/Servicing

Software Version Installed: 133.95

Complete the following checklist:

☒ Yes ☐ No\* Is the audible alarm operational?

☒ Yes ☐ No\* Is the visual alarm operational?

☒ Yes ☐ No\* Were all the sensors visually inspected, functionally tested, and confirmed operational?

☒ Yes ☐ No\* Were all sensors installed at lowest point of secondary containment and positioned so that other equipment will not interfere with their proper operation?

☐ Yes ☐ No\* If alarms are relayed to a remote monitoring station, is all communications equipment (e.g. modem) operational?

☐ Yes ☐ No\* For pressurized piping systems, does the turbine automatically shut down if the piping section containment monitoring system detects a leak, fails to operate, or is electrically disconnected?

☐ Yes ☒ N/A Yes, which sensors indicate positive shutdown? ☐ Sump/Trench Sensors ☐ Dispenser Containment Sensors (Check all that apply) ☐ Did you confirm positive shutdown due to leaks and sensor failure/disconnection? ☐ Yes ☐ No

☒ Yes ☐ No\* For tank systems that utilize the monitoring system as the primary tank overflow warning device, is the tank fill point(s) and operating properly? If so, at what percent does the alarm trip?

☐ Yes ☒ No 90 %

☐ Yes ☒ No Was any monitoring equipment replaced? If yes, identify specific sensor, probe, or other equipment replaced and list the manufacturer name and model for all replacement parts in section G, below.

☐ Yes ☒ No Was liquid found inside any secondary containment systems designed as dry systems? (Check all that apply) ☐ Product ☐ Water If yes, describe cause in section G, below.

☒ Yes ☐ No\* Was monitoring system set-up reviewed to ensure proper settings? (Check all that apply)

☒ Yes ☐ No\* Is all monitoring equipment operational per manufacturer's specifications?

\* In section G below, describe how and when these deficiencies were or will be corrected.

Monitoring System Certification - Page 2 of 3



SME SOLUTIONS, LLC

10707 S. Tacoma Way  
Suite A-2  
Lakewood, WA. 98499  
(253) 572-3822

2800 N.W. 31st. Ave  
Portland, OR. 97210  
(503) 946-0000

### Mechanical Leak Detector Test Data Sheet

Site Name Pacific Pride Date 2/27/2024  
Address 3620 Hwy 97  
Klamath Falls, OR 97601

#### Test Information

	1	2	3	4	5
Product	Unleaded	Off Rd Diesel	Diesel		
Manufacturer	Red Jacket	VMI	VMI		
Model	FX1V	99LD2000	99LD2000		
Full Operating Pressure (PSI)	32	32	32		
Line Bleed Back (ml)	130	120	130		
Trip Time (sec)	3	2	3		
Metering Pressure (PSI)	12	17	17		
F/E Holding Pressure (PSI)	12	30	30		
Test Leak Rate (ml/min)(gph)	3 GPH	3 GPH	3 GPH		
<b>PASS or FAIL</b>	<b>PASS</b>	<b>PASS</b>	<b>PASS</b>		

Comments Diesel satellite is compliant

This letter certifies that the annual leak detector tests were performed at the above referenced facility according to the equipment manufacturers procedures and limitations and the results as listed are to my knowledge true and correct. The mechanical leak detector test pass/fail is determined using a low flow threshold trip rate of 3 gph at 10 PSI.

Inspected By: Contractor SME Solutions, LLC

Technician Brad Weast Lic# (U3) 8189349  
Signature Brad Weast Digitally signed by Brad Weast

# DATA CHART FOR USE WITH PETROTITE LINE TESTER

W/O #: \_\_\_\_\_

STATION NUMBER: \_\_\_\_\_

DATE: Feb 27, 2024

LOCATION: Pacific Pride - 3620 Hwy 97 - Klamath Falls, OR 97601

OWNER: Staub

OPERATOR: \_\_\_\_\_

REASON FOR  
TEST: ANNUAL LINE TEST

TEST REQUESTED BY: Todd Roark

SPECIAL INSTRUCTIONS: \_\_\_\_\_

CONTRACTOR OR COMPANY MAKING TEST  
MECHANIC(S) NAME: SME Solutions

Brad Weast (866) 205-7777

IS A TANK TEST TO BE ☐ YES MAKE AND TYPE OF

MADE WITH THIS LINE TEST? ☒ NO PUMP OR DISPENSER (SUCTION OR SUBMERSIBLE) Tokheim dsipensers, Red Jacket STP's


WEATHER 30 TEMPERATURE IN TANKS 48 °F °C COVER OVER LINE concrete BURIAL DEPTH 30"

IDENTIFY EACH LINE AS TESTED	TIME (MILITARY)	LOG OF TEST PROCEDURES, AMBIENT TEMPERATURE, WEATHER, ETC.	PRESSURE		VOLUME			REMARKS
			Psi OR kPa		READING			SIZE, LENGTH & TYPE OF LINE, # FLEX CONNECTORS CONCLUSION, REPAIRS AND COMMENTS
			BEFORE	AFTER	BEFORE	AFTER	NET CHANGE	
LINE 1	10:00	PRESTART WAIT	30MIN	75PSI				25' APT piping
Unleaded	10:30	PRESTART WAIT	30MIN	60PSI				Ball valve at STP
	11:00	START TEST		60		.0250		
	11:10	1ST READING	60	60	.0250	.0250	+0.0000	
	11:20	2ND READING	60	60	.0250	.0250	+0.0000	
	11:30	3RD READING	60	60	.0250	.0250	+0.0000	Leak Rate +0.0000 GPH
		4TH READING		60				
		BLEED BACK	60	0	.0200	.0500	+0.0300	Allowed B/B +.0800 Actual B/B +.0300 (OK)
LINE 2	10:00	PRESTART WAIT	30MIN	75PSI				25' APT piping
Off Road Diesel	10:30	PRESTART WAIT	30MIN	60PSI				Ball valve at STP
	11:00	START TEST		60		.0250		
	11:10	1ST READING	60	60	.0250	.0250	+0.0000	
	11:20	2ND READING	60	60	.0250	.0250	+0.0000	
	11:30	3RD READING	60	60	.0250	.0250	+0.0000	Leak Rate +0.0000 GPH



# DATA CHART FOR USE WITH PETROTITE LINE TESTER

WO# : \_\_\_\_\_

		4TH READING		60					
		BLEED BACK	60	0	.0500	.0800	+.0300	Allowed B/B +.0800 Actual B/B +.0300 (OK)	
LINE 3	10:00	PRESTART WAIT	30MIN	75PSI				35' APT piping	
Diesel	10:30	PRESTART WAIT	30MIN	60PSI				Ball valve at STP	
Satellite Included	11:00	START TEST		60		.0250			
	11:10	1ST READING	60	60	.0250	.0250	+.0000		
	11:20	2ND READING	60	60	.0250	.0250	+.0000		
	11:30	3RD READING	60	60	.0250	.0250	+.0000	Leak Rate +.0000 GPH	
		4TH READING		60					
		BLEED BACK	60	0	.0000	.0400	+.0400	Allowed B/B +.0920 Actual B/B +.0400 (OK)	
LINE 4		PRESTART WAIT	30MIN	75PSI					
		PRESTART WAIT	30MIN	60PSI					
		START TEST		60					
		1ST READING		60					
		2ND READING		60					
		3RD READING		60					
		4TH READING		60					
		BLEED BACK	60	0					
TEST RESULTS	Comments:							CONTRACTOR CERTIFICATION Tech: Brad Weast   Digitally signed by Brad Weast Signature CERTIFICATION# 18bff901	
	Line Identification	Pass / Fail	Net Volume Change per Hour		Date Tested				
	Line 1 Unl	Pass	+.0000 GPH		Feb 27, 2024				
	Line 2 OR Dsl	Pass	+.0000 GPH		Feb 27, 2024				
	Line 3 Diesel	Pass	+.0000 GPH		Feb 27, 2024				
	Line 4	<input type="checkbox"/>							
		<input type="checkbox"/>							



# Overfill Prevention Inspection, Spill Bucket and Containment Sump Testing Form

Inspection Date:

7-11-24

lieu of this form, DEQ prefers the manufacturer's inspection/testing forms be used and completed per manufacturer's instructions.

Overfill prevention equipment must be inspected every 3 years. Attach tank chart (if available) and depth over overfill equipment. Spill buckets and containment sumps must be tested every 3 years. Only containment sumps used for interstitial monitoring of piping require testing.

Double-walled spill buckets and containment sumps do not require testing if the integrity of both walls is monitored at least every 30 days.

Fill in the tank number, describe the sump, and check the box for items completed, leave box unchecked for non-completed items.

Facility		Person Conducting the Testing	
Name: N97 Pac Pride	ID#:	Name: Michael Skidmore	
Address:		Company Name: ED Staub & Sons	
City: Klamath Falls	Zip Code: 97601	Address: 1301 Esplanade AVE	
Contact:	Phone:	Email:	Phone: 541-331-0633

## Overfill Prevention Inspection

Identify tank (number, product type, etc.):					
Inspector:	Make and model				
Inspector: e	Shuts off flow at 95% tank capacity				
	Float moves freely, proper orientation, poppet moves into flow path, and operates per manufacturer's design	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Inspection Results (P = pass, F = fail)				



Overfill Alarm	Activates at no more than 90% capacity	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Alarm can be seen and heard by delivery driver	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Activates in test mode	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Float moves freely on the stem	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Fuel float level on the ATG agrees with gauge stick reading	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Inch level at which the alarm activates corresponds with value in ATG	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<b>Inspection Results</b> (P = pass, F = fail)					
Ball Float	Restricts flow at 90% capacity	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Tank top fittings are vapor-tight	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Ball is free of holes, cracks and moves freely in cage	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Cage is free of debris and is intact	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<b>Inspection Results</b> (P = pass, F = fail)					
	Ball floats that fail an overfill inspection cannot be replaced.					
<b>Spill Bucket Testing</b> (passes if water level drops less than 1/8 inch, minimum test time 1 hour)						
<input type="checkbox"/> Spill bucket is double-walled and monitored monthly (must be recorded on 30-day walkthrough inspection form)						
Make and model						
Identify tank (tank number, product type, etc.)	DSL	UNL	Red DYE			
Liquid and debris removed from spill bucket*	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
Water was filled 1.5 inches from top of spill bucket	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
Starting water level height (inches)	8.5	7.5	7.5			
Starting test time	10:56 AM	4:00 PM	4:00 PM			
Ending test time	12:00 PM	5:00 PM	5:00 PM			
Ending water level height (inches)	8.5	7.5	7.5			
Level change						

\* Liquid and debris must be disposed of properly.

For vacuum testing, 30-inch water column was applied and at least 26-inch water column was maintained after 1 minute or manufacturer's procedures	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Test Results</b> (P = pass, F = fail)	P	P	P		
<b>Containment Sump Testing</b>					
(passes if water level drops less than 1/8 inch, minimum test time 1 hour)					
<input type="checkbox"/> Containment sump is double-walled and monitored monthly (must be recorded on 30-day walkthrough inspection form)					
Describe sump (tank number, dispenser number, etc.):	DSL Tank	UNL Tank	RED DYE Tank		
Liquid and debris removed from sump*	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/> EPA Low-Level Test Method used ** (fill out level change info below)					
All sensors were tested confirming positive shutdown	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> PEI RP 1200 Method (fill out level change info below)					
Water was filled at least 4 inches above the highest penetration fitting or seam.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Starting water level height (inches)	6	6	6		
Starting test time	12:58pm	1:00pm	1:03		
Ending test time	1:58pm	2:00pm	2:03		
Ending water level height (inches)	6	6	6		
Level change	0	0	0		
<b>Test Results</b> (P = pass, F = fail)	P	P	P		
<b>Corrective Action</b>					
Description of actions taken if items tested or inspected were not acceptable					

\* Liquid and debris must be disposed of properly.

\*\* See <https://www.epa.gov/sites/production/files/2018-06/documents/low-level-hydrostatic-sump-testing-procedures.pdf>

  
Tester's Signature

 7-12-24  
 Date

Certifications

4/1/21

**From:** [Todd Roark](#)  
**To:** [LITKE Emily \\* DEQ](#)  
**Cc:** [ECKERT Dylan \\* DEQ](#)  
**Subject:** Re: 692 - Inspection Complete  
**Date:** Friday, July 12, 2024 11:33:47 AM  
**Attachments:** [image001.png](#)  
[Image\\_004.pdf](#)

---

Emily, Here is the testing for N97 pac pride. Very sorry I'm late with the submission.

On Tue, Jul 2, 2024 at 3:32 PM LITKE Emily \* DEQ <[Emily.Litke@deq.oregon.gov](mailto:Emily.Litke@deq.oregon.gov)> wrote:

Hey Todd,

I am following up on the corrective actions for facility 692 Pacific Pride from the inspection completed by Dylan Eckert on 12/5/23.

Corrective actions include

- Complete repairs of containment sumps, integrity test sumps, submit records of testing prior to deadline.
- Test release detection equipment per national/ state standard. Submit records of testing to DEQ

**The deadline for the corrective actions was 7/1/24.** Please email documentation on the work completed as soon as possible.

I have attached the field citation for reference.



**Emily Litke** (she/her)

Duty Officer, Underground Storage Tanks

DEQ Headquarters, Land Quality Division

700 NE Multnomah Street, Suite 600

Portland OR 97232-4100



503-806-9516

[Emily.LITKE@deq.oregon.gov](mailto:Emily.LITKE@deq.oregon.gov)

---

**From:** ECKERT Dylan \* DEQ <[Dylan.ECKERT@deq.oregon.gov](mailto:Dylan.ECKERT@deq.oregon.gov)>  
**Sent:** Thursday, January 4, 2024 12:08 PM  
**To:** Todd Roark <[todd.roark@edstaub.com](mailto:todd.roark@edstaub.com)>  
**Cc:** LITKE Emily \* DEQ <[Emily.Litke@deq.oregon.gov](mailto:Emily.Litke@deq.oregon.gov)>; FOSS Diana \* DEQ <[Diana.FOSS@deq.oregon.gov](mailto:Diana.FOSS@deq.oregon.gov)>  
**Subject:** 692 - Inspection Complete

Hello Todd –

Happy 2024.

Thanks for letting me inspect this station... We could almost walk to it from the other site.

As with a bunch of the Clough Oil sites, piping was upgraded in 2012. There are issues with the installation and the sumps have not been tested for integrity.

Additionally, testing by SME was severely deficient at this site... and testing was late.

You will need to correct the sump and piping issues and retest the tank monitor and overflow alarm. The line and leak detectors were already tested in 2023.

Please work with Emily on submitting corrective actions and payments and the like.

Payment for the field citation is due 01feb2024, if you chose to pay it.

Corrective actions to get the site back up and compliant is July 2024... Please let Emily know if you need that extended.

Thanks,

Dylan Eckert

Inspector, Underground Storage Tanks

DEQ - Eugene, Land Quality Division

165 E. 7th Ave Suite 100

Eugene, OR 97401-3049

O 541-686-7517

C 541-215-2368

Sign-up for UST Program Updates Here:

[https://service.govdelivery.com/accounts/ORDEQ/subscriber/new?topic\\_id=ORDEQ\\_546](https://service.govdelivery.com/accounts/ORDEQ/subscriber/new?topic_id=ORDEQ_546)

Oregon State Fire Marshal – Self Pumping Information – House Bill 2426

<https://www.oregon.gov/osfm/Pages/Self-Serve-Fueling.aspx>

New York A/B Operator Training Course. A helpful overview of equipment. Section 3-1 |  
Pg. 26

[https://www.dec.ny.gov/docs/remediation\\_hudson\\_pdf/tankiq.pdf](https://www.dec.ny.gov/docs/remediation_hudson_pdf/tankiq.pdf)

The UST Program. 60-Minute story: <https://www.youtube.com/watch?v=leYoLtsQ2WQ>

--

**Todd Roark**

Service and Compliance Manager

[todd.roark@edstaub.com](mailto:todd.roark@edstaub.com)

[www.edstaub.com](http://www.edstaub.com) | [www.myfastbreak.com](http://www.myfastbreak.com)



**DEPARTMENT OF ENVIRONMENTAL QUALITY  
TRANSMITTAL ADVICE  
UST EXPEDITED ENFORCEMENT PROG**

CK #	TRAN AMNT	FOR THE ACCOUNT OF	CIVIL PENALTY #
CHECK NAME		REASON FOR PAYMENT	INV # RCPT #
22159-26	450.00	MALIN CARDLOCK	2023-FC-8883
ED STAUB & SON PETROLEUM		FIELD CITATION FOR UST VIOLATION	FC-8883
22159-28	150.00	MERRILL CARD LOCK	2024-FC-8906
ED STAUB & SON PETROLEUM		FIELD CITATION FOR UST VIOLATION	FC-8906
22159-27	400.00	PACIFIC PRIDE	2024-FC-8902
ED STAUB & SON PETROLEUM		FIELD CITATION FOR UST VIOLATION	FC-8902
	1,000.00	TOTAL	



Oregon Department of Environmental Quality

DataBase Connection: **PROD**

## Program Enforcement Maintenance



Program Enforcement

Violations List (5)

Corrective Actions (2)

Link Actions

File #

692

Create PEN

Create OCE Enforcement

Name

PACIFIC PRIDE

Location

3620 N HWY 97 / KLAMATH FALLS / KLAMATH

Permit

UST General Permit.18-692-2023-OPER.Active

**Recipient  
Information:**

Show Recipient Selection

Name / Title

Roark, Todd /

Address

1301 Esplanade Ave / Klamath Falls / OR /  
97601-5902Phone / Fax /  
Email

(541) 887-8914 / /

Edit

Delete

Program

2024-FC-8902

Enforcement  
NumberRegulatory  
Program

Underground Storage Tanks

Staff Assigned

Dylan Eckert

Enforcement  
Type

Field Citation

Enforcement  
Action Issued  
Date

01/04/2024

Show Calendar

Response  
Received Date

Show Calendar

Payment Due  
Date

07/01/2024

Show Calendar

Payment  
Received Date

02/21/2024

Show Calendar

Penalty Amount

\$400.00

### Related Items

View Selected

	ID	Name/Reference	Date
Select	SV: 20861	Full Compliance Inspection (FCI)	12/05/2023
Select	PE: 8902	Field Citation	01/04/2024
Select	SV Vio: 19246	(C) Spill and Overfill Prevention - TCR	12/05/2023
Select	SV Vio: 19247	(C) Spill and Overfill Prevention - TCR	12/05/2023
Select	SV Vio: 19248	(G) General Release Detection - TCR	12/05/2023
Select	SV Vio: 19249	(H2) Release Detection Pressure Piping - TCR	12/05/2023
Select	SV Vio: 19250	(H2) Release Detection Pressure Piping - TCR	12/05/2023
Select	PE CA: 7032	PE: 8902, Violation: 19246	07/01/2024
Select	PE CA: 7033	PE: 8902, Violation: 19248	07/01/2024

Records Found = 9

### Legend

ID Type	Description
SV	Site Visit
PE	Program Enforcement
SV Vio	Site Visit Violation
PE CA	Program Enforcement Corrective Action

Compliance Events Report

PEN Referral Date	<input type="text"/>	<a href="#">Show Calendar</a>
Closed Date	<input type="text"/>	<a href="#">Show Calendar</a>
Withdrawn Date	<input type="text"/>	<a href="#">Show Calendar</a>
Link To Complaint	<input type="text"/>	
Comments	<div>PAID ON 02/21/24; PAID BY ED STAUB&amp;SONS PETROLEUM; CK # 22159; AMT 400 XIAN</div>	
<div><div>Edit</div><div>Delete</div></div>		
Create By	<div>01/04/2024 10:34:54 AM</div>	<div>Dylan Eckert</div>
Last Update By	<div>02/22/2024 11:32:40 AM</div>	<div>Christian Hector</div>
Record ID	<div>8902</div>	<div><div>Create PEN</div><div>Create OCE Enforcement</div></div>