

**GEORGIA PACIFIC CORPORATION
BROWN STOCK WASHER LINES
CLEAN CONDENSATE ALTERNATIVE
REPORT**

**TOLEDO, OREGON
PAPER MILL**

NOVEMBER 5-6, 2014

Permit #21-0005

Prepared: January 6, 2014

Prepared by:



TIM HOMER
AIR EMISSIONS LAB MANAGER

BIGHORN ENVIRONMENTAL AIR QUALITY, LLC
858 RIVER HILLS DRIVE • SPRINGFIELD, OREGON 97477 • (541) 726-2689

EXECUTIVE SUMMARY

The November 2014 results of Georgia Pacific's Brownstock Washers (BSW) testing are summarized below.

Brownstock Washers Testing Results

Source	MeOH (ppm)	Flow (dscfm)	MeOH (lb/day)	Production (ODT/day)	Emissions (lb/ODT)
Kraft Brownstock Washer #1 (EU 128-A)					
Washer Hood Vent	0.00	0	0.00	386	
Foam Breaker Vent	331.02	1,818	72.24		
Vacuum Pump Exhaust	29.52	1576	5.59		
#1 BSW Sum			77.83		
Kraft Brownstock Washer #2 (EU 128-B)					
Combined Vent	88.41	2,576	27.17	352	
#2 BSW Sum			27.17		
Kraft Brownstock Washer #3 (EU 128-C)					
Combined Vent	274.23	799	26.50	399	
#3 BSW Sum			26.50		
Totals for #1, #2, #3 Brownstock Washers			131.50	1,137	0.116

Detailed discussions and results from this emissions test project are included in the body of this report.

CONTENTS

EXECUTIVE SUMMARY	i
1.0 SOURCE INFORMATION AND TEST DATE.....	1
2.0 POLLUTANTS AND TEST METHODS.....	2
3.0 SOURCE SAMPLING EQUIPMENT	3
4.0 RESULTS.....	4
5.0 SUPPORTING DATA.....	5
6.0 QUALITY ASSURANCE	5
APPENDIX A	SUPPORTING DATA
APPENDIX B	CALCULATIONS
APPENDIX C	QUALITY RECORDS
APPENDIX D	PRODUCTION DATA
APPENDIX E	EPA/ODEQ CORRESPONDENCE

1.0 SOURCE INFORMATION AND TEST DATE

Georgia Pacific's Toledo Paper Mill hired Bighorn Environmental to conduct source testing on its Brownstock Washers (BSW) to quantify their emissions of methanol. Bighorn conducted the source tests on November 5-6, 2014 to accurately quantify emissions from these sources. This testing was conducted to determine compliance with the CCA rules as outlined in their Title V permit.

Georgia Pacific's Dan Kunde and Karl Schumacher coordinated the project. Mr. Kunde and Mr. Schumacher oversaw the testing. Bighorn's Collin Rose, Clayton Krietzman and Tim Homer conducted three-one hour runs on each source on the three Brownstock Washers. Table 1 lists sources, test dates, and times.

TABLE 1. SOURCE TEST DATES AND TIMES

SOURCE	DATE	TIME
Kraft Brownstock Washer #1 (EU 128-A)		
Washer Hood Vent	11/6/14	Not tested, see note Section 2.0
Foam Breaker Vent	11/6/14	09:10-10:10; 10:35-11:35; 11:55-12:55
Vacuum Pump Exhaust	11/6/14	09:10-10:10; 10:35-11:35; 11:55-12:55
Kraft Brownstock Washer #2 (EU 128-B)		
Combined Vent	11/5/14	14:00-15:00; 15:10-16:10; 16:19-17:19
Kraft Brownstock Washer #3 (EU 128-C)		
Combined Vent	11/5/14	09:55-10:55; 11:00-12:00; 12:5-13:05

2.0 POLLUTANTS AND TEST METHODS

Bighorn Environmental conducted Methanol source tests on Georgia Pacific's Brownstock Washers using its source sampling equipment. After the samples were gathered, they were sent to ACC for analysis. Chain of custody forms can be found in the Appendix.

Bighorn performed velocity traverses to calculate flow rates and convert analytical data to emission concentrations and rates. Table 3 outlines the test methods Bighorn used.

TABLE 3. TEST METHODS

PARAMETER	TEST METHODS
Velocity & Flow	EPA Method 1, 1A & 2
Moisture	ODEQ Method 4
Methanol	NCASI CI/SG/PULP-94.03

When trying to obtain velocity readings on the #1 BSW combined vent, the flow readings were "backward", i.e. the flow was towards the BSW hood and away from the stack vent. This was verified with both the pitot tube and also inserting a rag into the stack and observing it "flutter" toward the BSW hood. Therefore no testing was conducted on this source. These reverse flows were verified at the beginning, middle and end of each test. An explanation by the engineer who designed the system outlining the reason for this can be found in the Appendix.


Georgia Pacific petitioned EPA to use the NCASI Method in place of EPA Method 308 for Methanol. EPA approved this deviation, and the associated letters can be found in the Appendix.

Stack moisture was measured using ODEQ Method 4 and two measurements were taken and recorded during each run.

3.0 SOURCE SAMPLING EQUIPMENT

Figure 1 is a schematic of Bighorns Sampling Train used for the testing of Methanol.

FIGURE 1. NCASI METHANOL SAMPLING TRAIN



4.0 RESULTS

Table 4 summarizes the results from the Brown Stock Washer Line testing.

Table 4. Brownstock Washers Emissions Results

Source	MeOH (ppm)	Flow (dscfm)	MeOH (lb/day)	Production (ODT/day)	Emissions (lb/ODT)
Kraft Brownstock Washer #1 (EU 128-A)					
Washer Hood Vent	0.00	0	0.00	386	
Foam Breaker Vent	331.02	1,818	72.24		
Vacuum Pump Exhaust	29.52	1576	5.59		
#1 BSW Sum			77.83		
Kraft Brownstock Washer #2 (EU 128-B)					
Combined Vent	88.41	2,576	27.17	352	
#2 BSW Sum			27.17		
Kraft Brownstock Washer #3 (EU 128-C)					
Combined Vent	274.23	799	26.50	399	
#3 BSW Sum			26.50		
Totals for #1, #2, #3 Brownstock Washers				131.50	1,137
					0.116

Field data sheets, flow rate information, analytical data, calculated emissions data, and calculations are contained in Appendices A-B. Appendix D contains Georgia Pacific's production data for this project.

5.0 SUPPORTING DATA

Supporting data sheets are located in Appendix A while required support equipment quality control records are in Appendix C.

6.0 QUALITY ASSURANCE

Bighorn's QA procedures follow EPA's *Quality Assurance Handbook for Air Pollution Measurement Systems, Vol. III, Stationary Source Specific Methods* September 1994 as revised and amended (#EPA/600/R-94/038c). Bighorn used EPA method specific quality assurance procedures. The following *July 1, 2013 40 CFR 60* sections were referenced for this project:

Appendix A - Methods 1, 2, 4 and NCASI CI/SG/PULP-94.03

Bighorn Environmental is zealous in our commitment to thorough quality practices. We conduct stringent quality assurance and quality control (QA and QC) procedures on all reference CEMS and support equipment.

Bighorn employs the latest CAI and Advanced Pollution Incorporated (API) CEMS that are considered state-of-the-art by environmental professionals. We've designed an effective primary sample conditioner that works in concert with Horiba's secondary conditioners. Together, they provide dry, clean sample gas to Bighorn's CEMS.

EPA Protocol No. 1 first order QA standards allow Bighorn to challenge equipment and methods to ensure that data is valid for determining monitor accuracy and precision. Before each test, Bighorn challenges its monitors and then entire system at the probe which simulates actual sampling. QA standards introduced at the sample probe traverse through all sample lines, conditioning chambers, and monitors to determine initial system integrity or bias. Following each test, Bighorn conducts QA of the entire monitoring system to determine final system bias and test calibration drift.

Bighorn's Mobile Air Emissions Laboratory contain two APC Model 1400 uninterruptible power supplies (UPS) to complement our QA/QC commitment. These QC devices continuously regulate and condition client-supplied 120 VAC power so Bighorn's electronic analyzers receive a consistent clean 115 ± 5 VAC signal. Chronic brownout and over-voltage conditions are eliminated thereby reducing hardware failures and data errors. Also, temporary power outages do not shut down our CEMS nor jeopardize data quality because the UPS' generate consistent pure sine wave signals for up to one hour with their built in batteries.

Cross checks such as manual calculations of Bighorn's automated DAS computer generated results allow test results verification. Bighorn files manufacturers' accuracy certificates and interference tables for CEMS, flow controllers, gases, etc. Additionally dry gas meters, pitot tubes, thermocouples, gas dividers, etc. are certified as per EPA

requirements and frequencies. Where EPA frequencies are not specified, Bighorn has established those based on state regulatory criteria.

Thorough chain-of-custody procedures and documentation provide proof of our QA/QC efforts. Relevant QA/QC documentation is included in this final report's Appendices for results support and regulatory review.

**APPENDIX A
SUPPORTING DATA**

EMISSION RATE

Georgia Pacific			
#1 BSW Foam Breaker			
Emissions Rates Calculations			
6-Nov-14			
#1 BSW Foam Breaker			
	Run #1	Run #2	Run #3
MeOH (ppm)	09:10-10:10	10:35-11:35	11:55-12:55
	278.3625	470.7149	243.9800
Stack Flow:			
acfm:	2173	2250	2208
dscfm:	1789	1839	1826
Pulp Production:			
ODT/day:	386.00	386.00	386.00
MeOH Emissions at Standard Conditions:			
lb/hr.:	2.48626	4.32066	2.22345
lb/day.:	59.67023	103.69594	53.36284
lb/ODT:	0.15459	0.26864	0.13825

00001

MeOH concentration

Georgia Pacific			
#1 BSW Foam Breaker			
11/6/2014			
Total MeOH catch & DGM volume			
Run 1			
DGM Volume (l)	23.992		
Meter Y	1.006		
DGM Temp (C)	15.2		
Baro Pressure	29.81		
DGM Volume (dscl)	24.448		
MW of MeOH	32.04		
MeOH (ppmvd)	278.36253		
			Total MeOH catch (mirco g) 9070
			Correction Factor 1
Run 2			
DGM Volume (l)	24.033		
Meter Y	1.006		
DGM Temp (C)	16.4		
Baro Pressure	29.81		
DGM Volume (dscl)	24.39		
MW of MeOH	32.04		
MeOH (ppmvd)	470.71489		
			Total MeOH catch (mirco g) 15300
			Correction Factor 1
Run 3			
DGM Volume (l)	24.013		
Meter Y	1.006		
DGM Temp (C)	16.9		
Baro Pressure	29.81		
DGM Volume (dscl)	24.33		
MW of MeOH	32.04		
MeOH (ppmvd)	243.98001		
			Total MeOH catch (mirco g) 7910
			Correction Factor 1

Georgia Pacific
 #1 BSW Foam Breaker
 Stack Gas Flow Rate Data and Calculations
 6-Nov-14

Run #1

Barometric Pressure: 29.81

Stack Diameter or Dimensions (in.): 15.75

Cross Sectional Area (sq ft): 1.3529699

Pitot Tube Avg. Coeff.: 0.84

Traverse Point	Velocity Head ^P (in. H ₂ O)	Stack Temperature (deg F)	Stack Temperature (deg R)	Stack Static Pressure (in. H ₂ O)	Stack Static Pressure (in Hg.)	Sqrt ^P
1	0.2	115	575	-0.06	29.81	0.4472
2	0.21	115	575	-0.06	29.81	0.4583
3	0.21	115	575	-0.06	29.81	0.4583
4	0.19	115	575	-0.06	29.81	0.4359
5	0.22	115	575	-0.06	29.81	0.469
6	0.23	115	575	-0.06	29.81	0.4796
7	0.21	115	575	-0.06	29.81	0.4583
8	0.19	115	575	-0.06	29.81	0.4359
9	0.19	115	575	-0.06	29.81	0.4359
10	0.19	115	575	-0.06	29.81	0.4359
11	0.2	115	575	-0.06	29.81	0.4472
12	0.2	115	575	-0.06	29.81	0.4472
13	0.16	115	575	-0.06	29.81	0.4
14	0.19	115	575	-0.06	29.81	0.4359
15	0.2	115	575	-0.06	29.81	0.4472
16	0.2	115	575	-0.06	29.81	0.4472
AVG.		115.00	575.00		29.81	0.4462

wet bulb temp. (deg F): 115.00

stack vapor pressure: 2.9774087

%H₂O: 9.9894312

Molecular Density: 0.9001057

Molecular weight of dry gas: 28.708 lb/lb mole dry

Molecular weight of wet stack gas: 27.638332 lb/lb mole wet

Stack gas velocity at stack conditions: 1606.34207 afpm

Stack gas flow rate at std. conditions: 1789.45946 dscfm

Stack gas flow rate at stack conditions: 2173.33249 acfm

Georgia Pacific
 #1 BSW Foam Breaker
 Stack Gas Flow Rate Data and Calculations
 6-Nov-14

Run #2

Barometric Pressure: 29.81

Stack Diameter or Dimensions (in.): 15.75

Cross Sectional Area (sq ft): 1.3529699

Pitot Tube Avg. Coeff.: 0.84

Traverse Point	Velocity Head ^P (in. H2O)	Stack Temperature (deg F)	Stack Temperature (deg R)	Stack Static Pressure (in. H2O)	Stack Static Pressure (in Hg.)	Sqrt ^P
1	0.2	116.5	576.5	-0.06	29.81	0.4472
2	0.2	116.5	576.5	-0.06	29.81	0.4472
3	0.2	116.5	576.5	-0.06	29.81	0.4472
4	0.23	116.5	576.5	-0.06	29.81	0.4796
5	0.21	116.5	576.5	-0.06	29.81	0.4583
6	0.24	116.5	576.5	-0.06	29.81	0.4899
7	0.22	116.5	576.5	-0.06	29.81	0.469
8	0.22	116.5	576.5	-0.06	29.81	0.469
9	0.23	116.5	576.5	-0.06	29.81	0.4796
10	0.23	116.5	576.5	-0.06	29.81	0.4796
11	0.25	116.5	576.5	-0.06	29.81	0.5
12	0.23	116.5	576.5	-0.06	29.81	0.4796
13	0.22	116.5	576.5	-0.06	29.81	0.469
14	0.19	116.5	576.5	-0.06	29.81	0.4359
15	0.16	116.5	576.5	-0.06	29.81	0.4
16	0.18	116.5	576.5	-0.06	29.81	0.4243
AVG.		116.5	576.5		29.81	0.461

wet bulb temp. (deg F): 116.50

stack vapor pressure: 3.1091027

%H2O: 10.431275

Molecular Density: 0.8956873

Molecular weight of dry gas:

28.7032 lb/lb mole dry

Molecular weight of wet stack gas:

27.58672 lb/lb mole wet

Stack gas velocity at stack conditions:

1663.27274 afpm

Stack gas flow rate at std. conditions:

1838.98727 dscfm

Stack gas flow rate at stack conditions:

2250.35798 acfm

Georgia Pacific
 #1 BSW Foam Breaker
 Stack Gas Flow Rate Data and Calculations
 6-Nov-14

Run #3

Barometric Pressure: 29.81

Stack Diameter or Dimensions (in.): 15.75

Cross Sectional Area (sq ft): 1.3529699

Pitot Tube Avg. Coeff.: 0.84

Traverse Point	Velocity Head ^P (in. H2O)	Stack Temperature (deg F)	Stack Temperature (deg R)	Stack Static Pressure (in. H2O)	Stack Static Pressure (in Hg.)	Sqrt ^P
1	0.19	114.5	574.5	-0.07	29.80	0.4359
2	0.23	114.5	574.5	-0.07	29.80	0.4796
3	0.23	114.5	574.5	-0.07	29.80	0.4796
4	0.23	114.5	574.5	-0.07	29.80	0.4796
5	0.22	114.5	574.5	-0.07	29.80	0.469
6	0.2	114.5	574.5	-0.07	29.80	0.4472
7	0.2	114.5	574.5	-0.07	29.80	0.4472
8	0.2	114.5	574.5	-0.07	29.80	0.4472
9	0.18	114.5	574.5	-0.07	29.80	0.4243
10	0.19	114.5	574.5	-0.07	29.80	0.4359
11	0.2	114.5	574.5	-0.07	29.80	0.4472
12	0.19	114.5	574.5	-0.07	29.80	0.4359
13	0.19	114.5	574.5	-0.07	29.80	0.4359
14	0.21	114.5	574.5	-0.07	29.80	0.4583
15	0.22	114.5	574.5	-0.07	29.80	0.469
16	0.22	114.5	574.5	-0.07	29.80	0.469
AVG.		114.5	574.5		29.80	0.4538

wet bulb temp. (deg F): 114.00

stack vapor pressure: 2.8923602

%H2O: 9.6873009

Molecular Density: 0.903127

Molecular weight of dry gas: 28.708 lb/lb mole dry

Molecular weight of wet stack gas: 27.670684 lb/lb mole wet

Stack gas velocity at stack conditions: 1632.12459 afpm

Stack gas flow rate at std. conditions: 1825.82669 dscfm

Stack gas flow rate at stack conditions: 2208.21546 acfm

Average stack gas flow rate at standard conditions:

1818 dscfm

Average stack gas flow rate at stack conditions:

2211 acfm

Avg % Mois 10.04 **Average Velocity** 1633.91

0005

*NCASI Chilled Impinger/Silica Gel Tube Test Method At Pulp Mill Sources For
Methanol, Acetone, Acetaldehyde, Methyl Ethyl Ketone And Formaldehyde*

Field Sampling Data Sheet

Mill Name: GP-Toledo Date: 11/6/14

City, State: Toledo, OR Sampler's Name: Homer

Source Name/Description: #1 Firm Breaker

Run Number: 1

Start Time: 9:00 Stop Time: 10:00

Ambient Temp at Start: 50 Ambient Temp at Stop: 50

Barometric Pressure: 29.41

Leak Test

Time: 9:30 Initial Measurement (in Hga): 0 on Dtm, no bubbles

Time: 10:12 Final Measurement (in Hga): 0 on Dtm,

Leak Check Criteria- Must not lose more than 1 inch of Hg (vacuum) in 2 minutes.

Meets Criteria? Yes No

System Flow Rate Measurement

Average of 5 flow measurements for Pre-Sample FlowRate:

1. 58 2. 58 3. 60 4. 60 5. 61 Avg: 59.2 C

Average of 5 flow measurements for Post-Sample Flow Rate:

1. 10 2. 10 3. 10 4. 10 5. 10 Avg: 10

Overall Average Sample Flow Rate: (indicate units!) Avg:

Rotameter Readings	
Time: <u>9:20</u>	Flow: <u>3.446</u>
Time: <u>9:30</u>	Flow: <u>6.003</u>
Time: <u>9:40</u>	Flow: <u>12.013</u>
Time: <u>9:50</u>	Flow: <u>16.001</u>
Time: <u>10:00</u>	Flow: <u>16.984</u>
Time: <u>10:10</u>	Flow: <u>23.997</u>

QA/QC Measures

Train Spike Conducted? Yes No

Duplicate Conducted? Yes No

Spiked Duplicate Made? Yes No

Field Blank Made? Yes No

Field Spike Made? Yes No

Sample Bottle Weight(s):

Bottle 1: Initial Weight: _____

Bottle 2: Initial Weight: _____

Final Weight: _____

Final Weight: _____

Notes/Comments

DGM used for sample volume collection

	Dry Bulb	Wet bulb
1	115	115
2	115	115

August 1998
115

Bottle # 9

Figure 2. Field Sampling Data Sheet

Bottle #2

NCASI Chilled Impinger/Silica Gel Tube Test Method At Pulp Mill Sources For
Methanol, Acetone, Acetaldehyde, Methyl Ethyl Ketone And Formaldehyde
Field Sampling Data Sheet

Mill Name: GP-Toledo Date: 11/6/14
City, State: Toledo, OH Sampler's Name: Homer
Source Name/Description: #1 Paper Breaker

Run Number: _____
Start Time: 1035 Stop Time: 1135
Ambient Temp at Start: 50 Ambient Temp at Stop: 52
Barometric Pressure: 29.81

Leak Test

Time: 1030 Initial Measurement (in Hga): 0 on DGM, no bubbles
Time: 1136 Final Measurement (in Hga): 0 in DGM, no bubbles

Leak Check Criteria- Must not lose more than 1 inch of Hg (vacuum) in 2 minutes.

Meets Criteria? Yes No

System Flow Rate Measurement

Average of 5 flow measurements for Pre-Sample FlowRate:

1. 60 2. 61 3. 62 4. 62 5. 63 Avg: 64 C

Average of 5 flow measurements for Post-Sample Flow Rate:

1. 10 2. 10 3. 10 4. 10 5. 10 Avg: 10

Overall Average Sample Flow Rate: (indicate units!) Avg: _____

Rotameter Readings	D	QA/QC Measures
Time: 1045	Flow: 4.072	Train Spike Conducted? Yes No
Time: 1055	Flow: 4.099	Duplicate Conducted? Yes No
Time: 1105	Flow: 12.017	Spiked Duplicate Made? Yes No
Time: 1115	Flow: 16.034	Field Blank Made? Yes No
Time: 1125	Flow: 20.021	Field Spike Made? Yes No
Time: 1135	Flow: 24.033	

Sample Bottle Weight(s):

Bottle 1: Initial Weight: _____ Final Weight: _____
Bottle 2: Initial Weight: _____ Final Weight: _____

Notes/Comments

DGM used for sample volume collection

	Dry Bulb	Wet bulb
1	117	117
2	116	116

August 1998

Bottle #1

Figure 2. Field Sampling Data Sheet

Bottle #2

NCASI Chilled Impinger/Silica Gel Tube Test Method At Pulp Mill Sources For Methanol, Acetone, Acetaldehyde, Methyl Ethyl Ketone And Formaldehyde

Field Sampling Data Sheet

Mill Name: GP-Toledo Date: 11/6/94

City, State: Toledo, OH Sampler's Name: Homer

Source Name/Description: #1 From Breaker

Run Number: 3

Start Time: 1155 Stop Time: 1255

Ambient Temp at Start: 50 Ambient Temp at Stop: 50

Barometric Pressure: 29.81

Leak Test

Time: 1151 Initial Measurement (in Hga): 0 on Dtm, no bubbles

Time: 1257 Final Measurement (in Hga): 0 on Dtm

Leak Check Criteria- Must not lose more than 1 inch of Hg (vacuum) in 2 minutes.

Meets Criteria? Yes No

System Flow Rate Measurement

Average of 5 flow measurements for Pre-Sample FlowRate:

1. 62 2. 62 3. 62 4. 63 5. 63 Avg: 16.9

Average of 5 flow measurements for Post-Sample Flow Rate:

1. 10 2. 10 3. 10 4. 10 5. 10 Avg: 10

Overall Average Sample Flow Rate: (indicate units!) Avg:

Rotameter Readings		QA/QC Measures
Time: 1205	Flow: 3.902	Train Spike Conducted? Yes No
Time: 1215	Flow: 7.977	Duplicate Conducted? Yes No
Time: 1225	Flow: 11.963	Spiked Duplicate Made? Yes No
Time: 1235	Flow: 16.001	Field Blank Made? Yes No
Time: 1245	Flow: 26.022	Field Spike Made? Yes No
Time: 1255	Flow: 24.013	

Sample Bottle Weight(s):

Bottle 1: Initial Weight: _____ Final Weight: _____

Bottle 2: Initial Weight: _____

Final Weight: _____

Notes/Comments

DGM used for sample volume collection

	Dry Bulb	Wet bulb
1	114	113
2	115	115
Avg	114.5	114

August 1998

Bottle #13

Figure 2. Field Sampling Data Sheet

Bottle #2

GAS VELOCITY AND VOLUMETRIC FLOW FORM
METHOD 2

Plant	GP-Toledo	Location:	Toledo, OR	Source:	#1 Foam Breaker
Date	11/14 - 1/19/900	Operator:	Homer	Run No.:	1 & 2
Barometric Press.	29.81	Reading Location:	Lab	Ambient Temp:	
Elevation:	0	Elevation Corr.:		Corr. Bar. Press.:	0
Avg. wet bulb temp (F)		% O2		% CO2:	
Pitot tube ID #:	4' Stype	Pitot Cp:	Last Calibration:		
Traverse Point #	Velocity Head	Stack Temp (F)	Static Press.	Cyclonic Flow Check	
				Vel. At 0 reference	Angle to get 0 Flow
1	.20	See mer 1	- .06	0	0
2	.21			0	0
3	.21			0	0
4	.19			0	0
5	.22			.02	5
6	.23			.03	4
7	.21			0	0
8	.19			0	0
9	.19			.03	5
10	.19			.03	5
11	.20			0	0
12	.20			0	0
13	.16			.01	2
14	.19			0	0
15	.20			0	0
16	.20			0	0
1	.20		- .06		
2	.20				
3	.20				
4	.23				
5	.21				
6	.24				
7	.22				
8	.22				

00009

GAS VELOCITY AND VOLUMETRIC FLOW FORM
METHOD 2


Plant	GP-Toledo	Location:	Toledo, OR	Source:	#1 Foam Breaker
Date	11/6/14	Operator:	Homer	Run No.:	2&3
Barometric Press.	0	Reading Location:	Lab	Ambient Temp:	0
Elevation:	0	Elevation Corr.:		Corr. Bar. Press.:	0
Avg. wet bulb temp (F)	0	% O ₂		% CO ₂ :	
Pitot tube ID #:	4' Stype	Pitot Cp:	0	Last Calibration:	1/0/1900
Traverse Point #	Velocity Head	Stack Temp (F)	Static Press.	Cyclonic Flow Check	
				Vel. At 0 reference	Angle to get 0 Flow
9	.23				
10	.23				
11	.25				
12	.23				
13	.22				
14	.19				
15	.16				
16	.18				
1	.19			-107	
2	.23				
3	.23				
4	.23				
5	.22				
6	.20				
7	.20				
8	.20				
9	.18				
10	.19				
11	.20				
12	.19				
13	.19				
14	.21				
15	.22				
16	.22				

00010

TRAVERSE POINT LOCATION WORKSHEET

METHOD 1

DATA
STACK CROSS SECTION DIAGRAM

Plant:	GP-Toledo #1 Foam Breaker, Combined Vent	Location:	Toledo, OR	 <p>See Diagram</p>	
Source:	Combined Vent	Operator:	Homer		
Date		Port Depth(in.):	0.125		
Stack Dia. (in.)	15.75	Stack Area (ft ²):	1.35		
Distance to disturbance:					
Upstream(ft):		Downstream(ft):			
# of traverse points required:	16				
Traverse point #	% of Stack Dia.	Stack Dia.	% of Stack Dia. X Stack Dia.	Port Depth	Taverse Point Location
1	0.032	15.75	0.5	0.125	0.63
2	0.105	15.75	1.7	0.125	1.78
3	0.194	15.75	3.1	0.125	3.18
4	0.323	15.75	5.1	0.125	5.21
5	0.677	15.75	10.7	0.125	10.79
6	0.806	15.75	12.7	0.125	12.82
7	0.895	15.75	14.1	0.125	14.22
8	0.968	15.75	15.2	0.125	15.37

NOTES:

EMISSION RATE

Georgia Pacific				
#1 BSW Vacuum Pump Exhaust				
Emissions Rates Calculations				
6-Nov-14				
#1 BSW Vacuum Pump Exhaust				
	Run #1	Run #2	Run #3	Average
MeOH (ppm)	09:10-10:10	10:35-11:35	11:55-12:55	
	28.9090	28.1061	31.5413	29.5188
Stack Flow:				
acfm:	1700	1783	1904	1795.6888
dscfm:	1500	1560	1670	1576.6000
Pulp Production:				
ODT/day:	386.00	386.00	386.00	386.0000
MeOH Emissions at Standard Conditions:				
lb/hr.:	0.21643	0.21885	0.26289	0.2327
lb/day.:	5.19424	5.25245	6.30934	5.5853
lb/ODT:	0.01346	0.01361	0.01635	0.0145

00012

MeOH concentration

Georgia Pacific			
#1 BSW Vacuum Pump Exhaust			
11/6/2014			
Total MeOH catch & DGM volume			
Run 1			
DGM Volume (l)	24.029		
Meter Y	1.006		
DGM Temp (C)	13.2		
Baro Pressure	29.81		
DGM Volume (dscl)	24.657		
MW of MeOH	32.04		
MeOH (ppmvd)	28.909029		
			Total MeOH catch (mirco g) 950.00
			Correction Factor 1
Run 2			
DGM Volume (l)	24.25		
Meter Y	1.006		
DGM Temp (C)	15.40		
Baro Pressure	29.81		
DGM Volume (dscl)	24.693		
MW of MeOH	32.04		
MeOH (ppmvd)	28.106141		
			Total MeOH catch (mirco g) 925.00
			Correction Factor 1
Run 3			
DGM Volume (l)	24.01		
Meter Y	1.006		
DGM Temp (C)	17.60		
Baro Pressure	29.81		
DGM Volume (dscl)	24.264		
MW of MeOH	32.04		
MeOH (ppmvd)	31.5413		
			Total MeOH catch (mirco g) 1020.00
			Correction Factor 1

Georgia Pacific
 #1 BSW Vacuum Pump Exhaust
 Stack Gas Flow Rate Data and Calculations
 6-Nov-14

Run #1

Barometric Pressure: 29.81

Stack Diameter or Dimensions (in.): 10

Cross Sectional Area (sq ft): 0.5454149

Pitot Tube Avg. Coeff.: 0.84

Traverse Point	Velocity Head ^P (in. H ₂ O)	Stack Temperature (deg F)	Stack Temperature (deg R)	Stack Static Pressure (in. H ₂ O)	Stack Static Pressure (in Hg.)	Sqrt ^P
1	0.53	101.3	561.3	0	29.81	0.728
2	0.91	101.3	561.3	0	29.81	0.9539
3	0.94	101.3	561.3	0	29.81	0.9695
4	0.82	101.3	561.3	0	29.81	0.9055
5	0.44	101.3	561.3	0	29.81	0.6633
6	0.88	101.3	561.3	0	29.81	0.9381
7	0.9	101.3	561.3	0	29.81	0.9487
8	0.92	101.3	561.3	0	29.81	0.9592
AVG.		101.30	561.30		29.81	0.8833

wet bulb temp. (deg F): 97.70

stack vapor pressure: 1.7836937 O₂ CO₂ N₂

%H₂O: 5.8569194 17.7 0 82.3

Molecular Density: 0.9414308

Molecular weight of dry gas: 28.708 lb/lb mole dry

Molecular weight of wet stack gas: 28.080841 lb/lb mole wet

Stack gas velocity at stack conditions: 3116.8014 afpm

Stack gas flow rate at std. conditions: 1499.90525 dscfm

Stack gas flow rate at stack conditions: 1699.95002 acfm

Georgia Pacific
 #1 BSW Vacuum Pump Exhaust
 Stack Gas Flow Rate Data and Calculations
 6-Nov-14

Run #2

Barometric Pressure: 29.81

Stack Diameter or Dimensions (in.): 10

Cross Sectional Area (sq ft): 0.5454149

Pitot Tube Avg. Coeff.: 0.84

Traverse Point	Velocity Head ^P (in. H ₂ O)	Stack Temperature (deg F)	Stack Temperature (deg R)	Stack Static Pressure (in. H ₂ O)	Stack Static Pressure (in Hg.)	Sqrt ^P
1	0.62	102.5	562.5	0	29.81	0.7874
2	0.9	102.5	562.5	0	29.81	0.9487
3	0.92	102.5	562.5	0	29.81	0.9592
4	0.88	102.5	562.5	0	29.81	0.9381
5	0.9	102.5	562.5	0	29.81	0.9487
6	0.89	102.5	562.5	0	29.81	0.9434
7	0.91	102.5	562.5	0	29.81	0.9539
8	0.84	102.5	562.5	0	29.81	0.9165
AVG.		102.5	562.5		29.81	0.9245

wet bulb temp. (deg F): 100.60

stack vapor pressure: 1.9460891 O₂ CO₂ N₂

%H₂O: 6.4617748 17.58 0 82.42

Molecular Density: 0.9353823

Molecular weight of dry gas: 28.7032 lb/lb mole dry

Molecular weight of wet stack gas: 28.011583 lb/lb mole wet

Stack gas velocity at stack conditions: 3269.69571 afpm

Stack gas flow rate at std. conditions: 1560.03833 dscfm

Stack gas flow rate at stack conditions: 1783.34086 acfm

Georgia Pacific
 #1 BSW Vacuum Pump Exhaust
 Stack Gas Flow Rate Data and Calculations
 6-Nov-14

Run #3

Barometric Pressure: 29.81

Stack Diameter or Dimensions (in.): 10

Cross Sectional Area (sq ft): 0.5454149

Pitot Tube Avg. Coeff.: 0.84

Traverse Point	Velocity Head ^P (in. H ₂ O)	Stack Temperature (deg F)	Stack Temperature (deg R)	Stack Static Pressure (in. H ₂ O)	Stack Static Pressure (in Hg.)	Sqrt ^P
1	0.84	102.5	562.5	0	29.81	0.9165
2	0.96	102.5	562.5	0	29.81	0.9798
3	1	102.5	562.5	0	29.81	1
4	1.1	102.5	562.5	0	29.81	1.0488
5	1	102.5	562.5	0	29.81	1
6	0.96	102.5	562.5	0	29.81	0.9798
7	0.98	102.5	562.5	0	29.81	0.9899
8	0.97	102.5	562.5	0	29.81	0.9849
AVG.		102.5	562.5		29.81	0.9875

wet bulb temp. (deg F): 99.50

stack vapor pressure: 1.8828898

%H₂O: 6.2110657

Molecular Density: 0.9378893

Molecular weight of dry gas: 28.708 lb/lb mole dry

Molecular weight of wet stack gas: 28.042919 lb/lb mole wet

Stack gas velocity at stack conditions: 3490.50879 afpm

Stack gas flow rate at std. conditions: 1669.85646 dscfm

Stack gas flow rate at stack conditions: 1903.77561 acfm

Average stack gas flow rate at standard conditions:

1577 dscfm

Average stack gas flow rate at stack conditions:

1796 acfm

Avg % Mois	6.18	Average Velocity	3292.34
-------------------	-------------	-------------------------	----------------

NCASI Chilled Impinger/Silica Gel Tube Test Method At Pulp Mill Sources For
Methanol, Acetone, Acetaldehyde, Methyl Ethyl Ketone And Formaldehyde
Field Sampling Data Sheet

Mill Name: CP-Toledo Date: 11/6/94
City, State: Toledo, OH Sampler's Name: Homer
Source Name/Description: #4 BSW - Vacuum pump

Run Number: 1
Start Time: 910 Stop Time: 1010
Ambient Temp at Start: 50 Ambient Temp at Stop: 50
Barometric Pressure: 29.91

Leak Test

Time: 09305 Initial Measurement (in Hga): 0 on DGM, no bubbles
Time: 1012 Final Measurement (in Hga): 0 on DGM, no bubbles.

Leak Check Criteria- Must not lose more than 1 inch of Hg (vacuum) in 2 minutes.

Meets Criteria? Yes No

System Flow Rate Measurement

Average of 5 flow measurements for Pre-Sample FlowRate:

1. 12 2. 12 3. 14 4. 14 5. 14 Avg: 13.2

OC

Average of 5 flow measurements for Post-Sample Flow Rate:

1. 10 2. 10 3. 10 4. 10 5. 10 Avg: 10

Overall Average Sample Flow Rate: (indicate units!)

Avg:

Rotameter Readings		OC
Time: 0910	Flow: 15.4.2	
Time: 0930	Flow: 8.09	
Time: 0940	Flow: 12.64	
Time: 0950	Flow: 16.34	
Time: 1000	Flow: 20.14	
Time: 1010	Flow: 24.029	

QA/QC Measures

Train Spike Conducted?	Yes	No
Duplicate Conducted?	Yes	No
Spiked Duplicate Made?	Yes	No
Field Blank Made?	Yes	No
Field Spike Made?	Yes	No

Sample Bottle Weight(s):

Bottle 1: Initial Weight: _____
Final Weight: _____

Bottle 2: Initial Weight: _____
Final Weight: _____

Notes/Comments

DGM used for sample volume collection

Bottle #8

Figure 2. Field Sampling Data Sheet

Dry Bulb	Wet bulb
1 102.2	98.6
2 100.4	96.8
Avg 101.3	97.7

August 1998

Bottle #2 V21006

17

39
27

00017

NCASI Chilled Impinger/Silica Gel Tube Test Method At Pulp Mill Sources For
Methanol, Acetone, Acetaldehyde, Methyl Ethyl Ketone And Formaldehyde

Field Sampling Data Sheet

Mill Name: GP-Tel do Date: 11/6/94
 City, State: Tel do, OR Sampler's Name: Homer
 Source Name/Description: BSU #1 - Vacuum Pump

Run Number: 2
 Start Time: 1035 Stop Time: 1135
 Ambient Temp at Start: 50 Ambient Temp at Stop:

Barometric Pressure:

Leak Test

Time: 1025 Initial Measurement (in Hg): 0 on 0 bar, no bubbles
 Time: 1137 Final Measurement (in Hg): 0 on 0 bar no bubble

Leak Check Criteria: Must not lose more than 1 inch of Hg (vacuum) in 2 minutes.

Meets Criteria? Yes No

System Flow Rate Measurement

Average of 5 flow measurements for Pre-Sample FlowRate:

1. 10 2. 10 3. 10 4. 10 5. 10 Avg: 15.4 Used count Rem 1 i3

Average of 5 flow measurements for Post-Sample Flow Rate:

1. 10 2. 10 3. 10 4. 10 5. 10 Avg: 15.4 Used count Rem 1 i3

Overall Average Sample Flow Rate: (indicate units!)

Avg:

Rotameter Readings	
Time: 1045	Flow: 4.08
Time: 1055	Flow: 8.09
Time: 1105	Flow: 12.08
Time: 1115	Flow: 16.2
Time: 1125	Flow: 20.2
Time: 1135	Flow: 24.25

QA/QC Measures

Train Spike Conducted?	Yes	No
Duplicate Conducted?	Yes	No
Spiked Duplicate Made?	Yes	No
Field Blank Made?	Yes	No
Field Spike Made?	Yes	No

Sample Bottle Weight(s):

Bottle 1: Initial Weight: _____ Final Weight: _____
 Bottle 2: Initial Weight: _____ Final Weight: _____

Notes/Comments

DGM use: for sample volume collection

Dry Bulb	Wet bulb
1 101	99
2 104	102.2

Aug 102.5 August 1998
 10016

Bottle #10

Figure 2. Field Sampling Data Sheet

Bottle #2

NCASI Chilled Impinger/Silica Gel Tube Test Method At Pulp Mill Sources For
Methanol, Acetone, Acetaldehyde, Methyl Ethyl Ketone And Formaldehyde

Field Sampling Data Sheet

Mill Name: GP-Toledo Date: 11/6/94
 City, State: Toledo, OR Sampler's Name: Homer
 Source Name/Description: #1 BSW Vacuum Pump

Run Number: 3 Start Time: 1155 Stop Time: 1255
 Ambient Temp at Start: 50 Ambient Temp at Stop: 56
 Barometric Pressure:

Leak Test

Time: 1150 Initial Measurement (in Hga): 0 on 0bm, no bubbles
 Time: 1257 Final Measurement (in Hga): 0 on 0bm, no bubbles
 Leak Check Criteria- Must not lose more than 1 inch of Hg (vacuum) in 2 minutes.

Meets Criteria? Yes No

System Flow Rate Measurement

Average of 5 flow measurements for Pre-Sample Flow Rate:

1. 17 2. 17 3. 18 4. 18 5. 18 Avg: 17.6

Average of 5 flow measurements for Post-Sample Flow Rate:

1. 10 2. 10 3. 10 4. 10 5. 10 Avg: 10

Overall Average Sample Flow Rate: (indicate units!) Avg:

DGM
Jewel
DGM
Pressure

Rotameter Readings	
Time: 1205	Flow: 4.02
Time: 1215	Flow: 8.08
Time: 1225	Flow: 12.15
Time: 1235	Flow: 16.70
Time: 1245	Flow: 20.15
Time: 1255	Flow: 24.01

QA/QC Measures

Train Spike Conducted?	Yes	No
Duplicate Conducted?	Yes	No
Spiked Duplicate Made?	Yes	No
Field Blank Made?	Yes	No
Field Spike Made?	Yes	No

Sample Bottle Weight(s):

Bottle 1: Initial Weight: _____ Final Weight: _____
 Bottle 2: Initial Weight: _____ Final Weight: _____

Notes/Comments

DGM used for sample volume collection

	Dry Bulb	Wet bulb
1	102	99
2	103	101

August 1998

Pavg 102.5 99.5

Bottle #12

Figure 2. Field Sampling Data Sheet

Bottle #2

GAS VELOCITY AND VOLUMETRIC FLOW FORM
METHOD 2

Plant	GP-Toledo	Location:	Toledo, OR	Source:	#1 Vacuum Pump
Date		Operator:	Homer	Run No.:	1 & 2&3
Barometric Press.		Reading Location:	Lab	Ambient Temp:	
Elevation:	0	Elevation Corr.:		Corr. Bar. Press.:	0
Avg. wet bulb temp (F)		% O2		% CO2:	
Pitot tube ID #:	4' Stype	Pitot Cp:		Last Calibration:	
Traverse Point #	Velocity Head	Stack Temp (F)	Static Press.	Cyclonic Flow Check	
				Vel. At 0 reference	Angle to get 0 Flow
1	.53	102.2	0	.07	5
2	.91			.06	2
3	.94			.17	5
4	.82			.11	3
5	.94			0	0
6	.88			.14	3
7	.90			.17	3
8	.92			.06	3
1	.62			.06	5
2	.90			.07	3
3	.92			.10	5
4	.89			.11	5
5	.90			.02	3
6	.89			.07	5
7	.91			.06	5
8	.89	100.4		.01	3
1	.84				
2	.96				
3	1.0				
4	1.1				
5	1.0				
6	.96				
7	.90				
8	.97				

Horizontal traverse only Bottom port pointed block layer everywhere

TRAVERSE POINT LOCATION WORKSHEET

METHOD 1

DATA

STACK CROSS SECTION DIAGRAM

NOTES:

00021

EMISSION RATE

Georgia Pacific				
Kraft BSW #2 Combined Vent				
Emissions Rates Calculations				
5-Nov-14				
Kraft BSW #2 Combined Vent				
	Run #1	Run #2	Run #3	Average
	14:00-15:00	15:10-16:09	16:19-17:19	
MeOH (ppm)	118.4989	92.7630	53.9736	88.4118
Stack Flow:				
acf m:	3301	3308	3401	3337
dscfm:	2540	2561	2628	2576
Pulp Production:				
ODT/day:	352.00	352.00	352.00	352.00
MeOH Emissions at Standard Conditions:				
lb/hr.:	1.50240	1.18554	0.70792	1.13195
lb/day.:	36.05751	28.45294	16.99003	27.16683
lb/ODT:	0.10244	0.08083	0.04827	0.07718

MeOH concentration

Georgia Pacific
 Kraft BSW #2 Combined Vent
 Stack Gas Flow Rate Data and Calculations
 5-Nov-14

Run #1

Barometric Pressure: 29.76

Stack Diameter or Dimensions (in.): 16

Cross Sectional Area (sq ft): 1.3962622

Pitot Tube Avg. Coeff.: 0.84

Traverse Point	Velocity Head ^P (in. H2O)	Stack Temperature (deg F)	Stack Temperature (deg R)	Stack Static Pressure (in. H2O)	Stack Static Pressure (in Hg.)	Sqrt ^P
1	0.5	130.1	590.1	-0.74	29.71	0.7071
2	0.52	130.1	590.1	-0.74	29.71	0.7211
3	0.53	130.1	590.1	-0.74	29.71	0.728
4	0.29	130.1	590.1	-0.74	29.71	0.5385
5	0.31	130.1	590.1	-0.74	29.71	0.5568
6	0.38	130.1	590.1	-0.74	29.71	0.6164
7	0.4	130.1	590.1	-0.74	29.71	0.6325
8	0.34	130.1	590.1	-0.74	29.71	0.5831
9	0.38	130.1	590.1	-0.74	29.71	0.6164
10	0.41	130.1	590.1	-0.74	29.71	0.6403
11	0.35	130.1	590.1	-0.74	29.71	0.5916
12	0.27	130.1	590.1	-0.74	29.71	0.5196
13	0.51	130.1	590.1	-0.74	29.71	0.7141
14	0.55	130.1	590.1	-0.74	29.71	0.7416
15	0.44	130.1	590.1	-0.74	29.71	0.6633
16	0.53	130.1	590.1	-0.74	29.71	0.728
AVG.		130.10	590.10		29.71	0.6437

wet bulb temp. (deg F): 125.60

stack vapor pressure: 4.0208647

%H2O: 13.388152

Molecular Density: 0.8661185

Molecular weight of dry gas: 28.7796 lb/lb mole dry

Molecular weight of wet stack gas: 27.336411 lb/lb mole wet

Stack gas velocity at stack conditions: 2364.43494 afpm

Stack gas flow rate at std. conditions: 2540.13345 dscfm

Stack gas flow rate at stack conditions: 3301.37118 acfm

Georgia Pacific
 Kraft BSW #2 Combined Vent
 Stack Gas Flow Rate Data and Calculations
 5-Nov-14

Run #2

Barometric Pressure: 29.76

Stack Diameter or Dimensions (in.): 16

Cross Sectional Area (sq ft): 1.3962622

Pitot Tube Avg. Coeff.: 0.84

Traverse Point	Velocity Head ^P (in. H ₂ O)	Stack Temperature (deg F)	Stack Temperature (deg R)	Stack Static Pressure (in. H ₂ O)	Stack Static Pressure (in Hg.)	Sqrt ^P
1	0.51	128.6	588.6	-0.77	29.70	0.7141
2	0.54	128.6	588.6	-0.77	29.70	0.7348
3	0.55	128.6	588.6	-0.77	29.70	0.7416
4	0.31	128.6	588.6	-0.77	29.70	0.5568
5	0.31	128.6	588.6	-0.77	29.70	0.5568
6	0.33	128.6	588.6	-0.77	29.70	0.5745
7	0.41	128.6	588.6	-0.77	29.70	0.6403
8	0.36	128.6	588.6	-0.77	29.70	0.6
9	0.51	128.6	588.6	-0.77	29.70	0.7141
10	0.5	128.6	588.6	-0.77	29.70	0.7071
11	0.5	128.6	588.6	-0.77	29.70	0.7071
12	0.36	128.6	588.6	-0.77	29.70	0.6
13	0.25	128.6	588.6	-0.77	29.70	0.5
14	0.39	128.6	588.6	-0.77	29.70	0.6245
15	0.46	128.6	588.6	-0.77	29.70	0.6782
16	0.47	128.6	588.6	-0.77	29.70	0.6856
AVG.		128.6	588.6		29.70	0.646

wet bulb temp. (deg F): 124.70

stack vapor pressure: 3.9216231

%H₂O: 13.074289

Molecular Density: 0.8692571

Molecular weight of dry gas: 28.7688 lb/lb mole dry

Molecular weight of wet stack gas: 27.360856 lb/lb mole wet

Stack gas velocity at stack conditions: 2368.94023 afpm

Stack gas flow rate at std. conditions: 2560.51501 dscfm

Stack gas flow rate at stack conditions: 3307.66174 acfm

00025

Georgia Pacific
 Kraft BSW #2 Combined Vent
 Stack Gas Flow Rate Data and Calculations
 5-Nov-14

Run #3

Barometric Pressure: 29.76

Stack Diameter or Dimensions (in.): 16

Cross Sectional Area (sq ft): 1.3962622

Pitot Tube Avg. Coeff.: 0.84

Traverse Point	Velocity Head ^P (in. H2O)	Stack Temperature (deg F)	Stack Temperature (deg R)	Stack Static Pressure (in. H2O)	Stack Static Pressure (in Hg.)	Sqrt ^P
1	0.47	130.1	590.1	-0.79	29.70	0.6856
2	0.37	130.1	590.1	-0.79	29.70	0.6083
3	0.4	130.1	590.1	-0.79	29.70	0.6325
4	0.41	130.1	590.1	-0.79	29.70	0.6403
5	0.42	130.1	590.1	-0.79	29.70	0.6481
6	0.36	130.1	590.1	-0.79	29.70	0.6
7	0.51	130.1	590.1	-0.79	29.70	0.7141
8	0.62	130.1	590.1	-0.79	29.70	0.7874
9	0.49	130.1	590.1	-0.79	29.70	0.7
10	0.5	130.1	590.1	-0.79	29.70	0.7071
11	0.41	130.1	590.1	-0.79	29.70	0.6403
12	0.36	130.1	590.1	-0.79	29.70	0.6
13	0.4	130.1	590.1	-0.79	29.70	0.6325
14	0.32	130.1	590.1	-0.79	29.70	0.5657
15	0.48	130.1	590.1	-0.79	29.70	0.6928
16	0.58	130.1	590.1	-0.79	29.70	0.7616
AVG.		130.1	590.1		29.70	0.6635

wet bulb temp. (deg F): 124.70

stack vapor pressure: 3.9216231

%H2O: 13.025587

Molecular Density: 0.8697441

Molecular weight of dry gas: 28.7704 lb/lb mole dry

Molecular weight of wet stack gas: 27.367492 lb/lb mole wet

Stack gas velocity at stack conditions: 2436.11765 afpm

Stack gas flow rate at std. conditions: 2627.77316 dscfm

Stack gas flow rate at stack conditions: 3401.45904 acfm

Average stack gas flow rate at standard conditions:

2576 dscfm

Average stack gas flow rate at stack conditions:

3337 acfm

Avg % Mois	13.16	Average Velocity	2389.83
------------	-------	------------------	---------

*NCASI Chilled Impinger/Silica Gel Tube Test Method At Pulp Mill Sources For
Methanol, Acetone, Acetaldehyde, Methyl Ethyl Ketone And Formaldehyde*

Field Sampling Data Sheet

Mill Name: GP-Toledo Date: 11/15/14
 City, State: Toledo, OH Sampler's Name: Homer
 Source Name/Description: B5W VENT TZ

Run Number: 1
 Start Time: 1400 Stop Time: 1500
 Ambient Temp at Start: 60 Ambient Temp at Stop: 60
 Barometric Pressure: 29.76

Leak Test

Time: 1356 Initial Measurement (in Hga): V on 0fm, no bubbles
 Time: 1501 Final Measurement (in Hga): 0 on 0fm, no bubbles
Leak Check Criteria- Must not lose more than 1 inch of Hg (vacuum) in 2 minutes.

Meets Criteria? Yes No

System Flow Rate Measurement

Average of 5 flow measurements for Pre-Sample FlowRate:

1. 74 2. 76 3. 78 4. 80 5. 81 Avg: 75.4 C

Average of 5 flow measurements for Post-Sample Flow Rate:

1. 10 2. 10 3. 10 4. 10 5. 10 Avg: 10

Overall Average Sample Flow Rate: (indicate units!)

Avg: _____

<i>Rotameter Readings</i>	
Time: <u>1410</u>	Flow: <u>3.941</u>
Time: <u>1420</u>	Flow: <u>7.991</u>
Time: <u>1430</u>	Flow: <u>12.444</u>
Time: <u>1440</u>	Flow: <u>6.973</u>
Time: <u>1450</u>	Flow: <u>19.875</u>
Time: <u>1500</u>	Flow: <u>29.007</u>

QA/QC Measures

Train Spike Conducted?	Yes	No
Duplicate Conducted?	Yes	No
Spiked Duplicate Made?	Yes	No
Field Blank Made?	Yes	No
Field Spike Made?	Yes	No

Sample Bottle Weight(s):

Bottle 1: Initial Weight: _____

Bottle 2: Initial Weight: _____

Final Weight: _____

Final Weight: _____

Notes/Comments

DGM used for sample volume collection

Bottle # 4

Figure 2. Field Sampling Data Sheet

Dry Bulb	Wet bulb
<u>1131</u>	<u>1274</u>
<u>2129.2</u>	<u>123.8</u>

August 1998

BUX #2 Y2101

*NCASI Chilled Impinger/Silica Gel Tube Test Method At Pulp Mill Sources For
Methanol, Acetone, Acetaldehyde, Methyl Ethyl Ketone And Formaldehyde*

Field Sampling Data Sheet

Mill Name: GP-Toledo Date: 11/5/14
 City, State: Toledo, OH Sampler's Name: Homer
 Source Name/Description: B5W VENT #2

Run Number: 2
 Start Time: 15:00 Stop Time: 16:10
 Ambient Temp at Start: 60 Ambient Temp at Stop: 56
 Barometric Pressure: 29.76

Leak Test

Time: 15:05 Initial Measurement (in Hga): 0 on 06m, no bubbles
 Time: 16:12 Final Measurement (in Hga): 0 on 06m, no bubbles

Leak Check Criteria- Must not lose more than 1 inch of Hg (vacuum) in 2 minutes.

Meets Criteria? Yes No

System Flow Rate Measurement

Average of 5 flow measurements for Pre-Sample FlowRate:

1. 78 2. 76 3. 76 4. 76 5. 76 Avg: 74.7 c

Average of 5 flow measurements for Post-Sample Flow Rate:

1. 10 2. 10 3. 10 4. 10 5. 10 Avg: 10

Overall Average Sample Flow Rate: (indicate units!)

Avg: _____

Rotameter Readings	QA/QC Measures
Time: <u>15:20</u> Flow: <u>4.131</u>	Train Spike Conducted? Yes <u> </u> No <u> </u>
Time: <u>15:30</u> Flow: <u>8.002</u>	Duplicate Conducted? Yes <u> </u> No <u> </u>
Time: <u>15:40</u> Flow: <u>11.905</u>	Spiked Duplicate Made? Yes <u> </u> No <u> </u>
Time: <u>15:50</u> Flow: <u>16.151</u>	Field Blank Made? Yes <u> </u> No <u> </u>
Time: <u>16:00</u> Flow: <u>20.009</u>	Field Spike Made? Yes <u> </u> No <u> </u>
Time: <u>16:10</u> Flow: <u>24.051</u>	

Sample Bottle Weight(s):

Bottle 1: Initial Weight: _____ Final Weight: _____
 Bottle 2: Initial Weight: _____ Final Weight: _____

Notes/Comments

DGM used for sample volume collection

Bottle #25

Figure 2. Field Sampling Data Sheet

Dry Bulb	Wet bulb
<u>1127.9</u>	<u>123.8</u>
<u>2129.2</u>	<u>125.6</u>

August 1998

Bon #2

Avg 128.6 124.7

*NCASI Chilled Impinger/Silica Gel Tube Test Method At Pulp Mill Sources For
Methanol, Acetone, Acetaldehyde, Methyl Ethyl Ketone And Formaldehyde*

Field Sampling Data Sheet

Mill Name: GP-Toledo Date: 11/5/94
 City, State: Toledo, OH Sampler's Name: Homer
 Source Name/Description: BSW VENT #2

Run Number: 3
 Start Time: 1620 Stop Time: 1720
 Ambient Temp at Start: 54 Ambient Temp at Stop: 55
 Barometric Pressure: 29.76

Leak Test

Time: 1615 Initial Measurement (in Hga): 0 on 06m, no bubbles
 Time: 1725 Final Measurement (in Hga): 0 on 06m, no bubbles

Leak Check Criteria- Must not lose more than 1 inch of Hg (vacuum) in 2 minutes.

Meets Criteria? Yes No

System Flow Rate Measurement

Average of 5 flow measurements for Pre-Sample FlowRate:

1. 71 2. 74 3. 76 4. 75 5. 76 Avg: 74.0

Average of 5 flow measurements for Post-Sample Flow Rate:

1. 10 2. 10 3. 10 4. 10 5. 10 Avg: 10

Overall Average Sample Flow Rate: (indicate units!)

Avg: _____

Rotameter Readings

Time: 1630 Flow: 3.859
 Time: 1640 Flow: 7.920
 Time: 1650 Flow: 1.918
 Time: 1700 Flow: 16.1009
 Time: 1710 Flow: 20.0500
 Time: 1720 Flow: 29.1260

QA/QC Measures

Train Spike Conducted?	Yes	No
Duplicate Conducted?	Yes	No
Spiked Duplicate Made?	Yes	No
Field Blank Made?	Yes	No
Field Spike Made?	Yes	No

Sample Bottle Weight(s):

Bottle 1: Initial Weight: _____

Bottle 2: Initial Weight: _____

Final Weight: _____

Final Weight: _____

Notes/Comments

DGM used for sample volume collection

Bottle #5

Figure 2. Field Sampling Data Sheet

	Dry Bulb	Wet bulb
1	142.2 124.2	123.8
2	131	125.6

17

Aug 1998

Bottle #1

AVG 131.1

124.7

00029

GAS VELOCITY AND VOLUMETRIC FLOW FORM
METHOD 2

Plant	GP-Toledo	Location:	Toledo, OR	Source:	112#3 BSW Combined Vent
Date	11-5-14	Operator:	Homer	Run No.:	1 & 2
Barometric Press.	29.76	Reading Location:	Lab	Ambient Temp.:	55
Elevation:	0	Elevation Corr.:	0	Corr. Bar. Press.:	0
Avg. wet bulb temp (F)	127.4	% O2		% CO2:	
Pitot tube ID #:	4' Stype	Pitot Cp:	0.84	Last Calibration:	
Traverse Point #	Velocity Head	Stack Temp (F)	Static Press.	Cyclonic Flow Check	
				Vel. At 0 reference	Angle to get 0 Flow
1	.50	131	-.74	0	0
2	.52			0	0
3	.53			0	0
4	.29			0	0
5	.31			.15	5
6	.38			0	0
7	.40			0	0
8	.34			0	0
9	.38			0	0
10	.41			.09	3
11	.35			.06	4
12	.27			0	0
13	.51			0	0
14	.55			0	0
15	.44			0	0
16	.53			0	0
RUN #1					
1	.51	127.4	-.77		
2	.54				
3	.55				
4	.31				
5	.31				
6	.33				
7	.41				
8	.36				
RUN #2					
1	.51	127.4	-.77		
2	.54				
3	.55				
4	.31				
5	.31				
6	.33				
7	.41				
8	.36				
RUN #3					
Dry 129.2		131			
Wet 123.8		125.6			
Run 1					
Dry 131		129.2			
Wet 127.4		123.8			

Run 2
Dry 127.4 | +12.2 129.2
Wet 123.8 | 125.6

Run 3
Dry 129.2 | 131
Wet 123.8 | 125.6

Run 1
Dry 131 | 129.2
Wet 127.4 | 123.8

00030

GAS VELOCITY AND VOLUMETRIC FLOW FORM
METHOD 2

Plant	GP-Toledo	Location:	Toledo, OR	Source:	#7248 BSW Combined Vent
Date	11-5-14	1/07/1900	Operator:	Homer	Run No.: 2&3
Barometric Press.	29.76	0	Reading Location:	Lab	Ambient Temp: 55 0
Elevation:	0	0	Elevation Corr.:		Corr. Bar. Press.: 0
Avg. wet bulb temp (F)	0	% O2		% CO2:	
Pitot tube ID #:	4' Stype	Pitot Cp:	0.84	Last Calibration:	
Traverse Point #	Velocity Head	Stack Temp (F)	Static Press.	Cyclonic Flow Check	
				Vel. At 0 reference	Angle to get 0 Flow
9	.51				
10	.50				
11	.50				
12	.36				
13	.25				
14	.39				
15	.46				
16	.47				
1	.47	130	- .79		
2	.37				
3	.40				
4	.41				
5	.42				
6	.36				
7	.51				
8	.62				
9	.49				
10	.50				
11	.41				
12	.36				
13	.40				
14	.32				
15	.48				
16	.58				

TRAVERSE POINT LOCATION WORKSHEET
METHOD 1

DATA

STACK CROSS SECTION DIAGRAM

Plant: #2 BSW Combined	GP-Toledo Vent	Location: Toledo, OR	See Diagram		
Source:	Vent	Operator: Horner			
Date		Port Depth(in.): 1.5			
Stack Dia. (in.)	16	Stack Area (ft ²): 1.40			
Distance to disturbance:					
Upstream(ft):		Downstream(ft):			
# of traverse points required:		16			
Traverse point #	% of Stack Dia.	Stack Dia.			
1	0.032	16	0.5	1.5	2.01
2	0.105	16	1.7	1.5	3.18
3	0.194	16	3.1	1.5	4.60
4	0.323	16	5.2	1.5	6.67
5	0.677	16	10.8	1.5	12.33
6	0.806	16	12.9	1.5	14.40
7	0.895	16	14.3	1.5	15.82
8	0.968	16	15.5	1.5	16.99

NOTES: _____

EMISSION RATE

Georgia Pacific				
Karft BSW #3 Combined Vent				
Emissions Rates Calculations				
5-Nov-14				
Karft BSW #3 Combined Vent				
	Run #1	Run #2	Run #3	Average
MeOH (ppm)	09:55-10:55	11:00-12:00	12:05-13:05	
	251.0819	298.5045	273.1132	274.2332
Stack Flow:				
acfM:	865	1226	1252	1114
dscfm:	627	888	884	799
Pulp Production:				
ODT/day:	399.00	399.00	399.00	399.00
MeOH Emissions at Standard Conditions:				
lb/hr.:	0.78552	1.32261	1.20464	1.10426
lb/day.:	18.85249	31.74256	28.91137	26.50214
lb/ODT:	0.04725	0.07956	0.07246	0.06642

17 08633

MeOH concentration

Georgia Pacific			
Karft BSW #3 Combined Vent			
11/5/2014			
Total MeOH catch & DGM volume			
Run 1			
DGM Volume (l)	23.995		
Meter Y	1.01		
DGM Temp (C)	21.7		
Baro Pressure	29.76		
DGM Volume (dscl)	23.97		
MW of MeOH	32.04	Total MeOH catch (mirco g)	8020
MeOH (ppmvd)	251.08188	Correction Factor	1
Run 2			
DGM Volume (l)	24.036		
Meter Y	1.01		
DGM Temp (C)	25.8		
Baro Pressure	29.76		
DGM Volume (dscl)	23.68	Total MeOH catch (mirco g)	9420
MW of MeOH	32.04	Correction Factor	1
MeOH (ppmvd)	298.50453		
Run 3			
DGM Volume (l)	23.988		
Meter Y	1.01		
DGM Temp (C)	27.6		
Baro Pressure	29.76		
DGM Volume (dscl)	23.49	Total MeOH catch (mirco g)	8550
MW of MeOH	32.04	Correction Factor	1
MeOH (ppmvd)	273.11319		

Georgia Pacific
 Karft BSW #3 Combined Vent
 Stack Gas Flow Rate Data and Calculations
 5-Nov-14

Run #1

Barometric Pressure: 29.76

Stack Diameter or Dimensions (in.): 16

Cross Sectional Area (sq ft): 1.3962622

Pitot Tube Avg. Coeff.: 0.84

Traverse Point	Velocity Head ^P (in. H2O)	Stack Temperature (deg F)	Stack Temperature (deg R)	Stack Static Pressure (in. H2O)	Stack Static Pressure (in Hg.)	Sqrt ^P
1	0.06	141.6	601.6	-0.01	29.76	0.2449
2	0.06	141.6	601.6	-0.01	29.76	0.2449
3	0.04	141.6	601.6	-0.01	29.76	0.2
4	0.03	141.6	601.6	-0.01	29.76	0.1732
5	0.04	141.6	601.6	-0.01	29.76	0.2
6	0.02	141.6	601.6	-0.01	29.76	0.1414
7	0.02	141.6	601.6	-0.01	29.76	0.1414
8	0.01	141.6	601.6	-0.01	29.76	0.1
9	0.01	141.6	601.6	-0.01	29.76	0.1
10	0.01	141.6	601.6	-0.01	29.76	0.1
11	0.01	141.6	601.6	-0.01	29.76	0.1
12	0.02	141.6	601.6	-0.01	29.76	0.1414
13	0.03	141.6	601.6	-0.01	29.76	0.1732
14	0.03	141.6	601.6	-0.01	29.76	0.1732
15	0.03	141.6	601.6	-0.01	29.76	0.1732
16	0.06	141.6	601.6	-0.01	29.76	0.2449
AVG.		141.60	601.60		29.76	0.1657

wet bulb temp. (deg F): 134.60

stack vapor pressure: 5.1325697

%H2O: 17.026291

Molecular Density: 0.8297371

Molecular weight of dry gas:

28.6624 lb/lb mole dry

Molecular weight of wet stack gas:

26.846989 lb/lb mole wet

Stack gas velocity at stack conditions:

619.774873 afpm

Stack gas flow rate at std. conditions:

626.798805 dscfm

Stack gas flow rate at stack conditions:

865.368242 acfm

Georgia Pacific
 Kartt BSW #3 Combined Vent
 Stack Gas Flow Rate Data and Calculations
 5-Nov-14

Run #2

Barometric Pressure: 29.76

Stack Diameter or Dimensions (in.): 16

Cross Sectional Area (sq ft): 1.3962622

Pitot Tube Avg. Coeff.: 0.84

Traverse Point	Velocity Head ^P (in. H ₂ O)	Stack Temperature (deg F)	Stack Temperature (deg R)	Stack Static Pressure (in. H ₂ O)	Stack Static Pressure (in Hg.)	Sqrt ^P
1	0.1	141.6	601.6	-0.01	29.76	0.3162
2	0.07	141.6	601.6	-0.01	29.76	0.2646
3	0.04	141.6	601.6	-0.01	29.76	0.2
4	0.05	141.6	601.6	-0.01	29.76	0.2236
5	0.06	141.6	601.6	-0.01	29.76	0.2449
6	0.08	141.6	601.6	-0.01	29.76	0.2828
7	0.01	141.6	601.6	-0.01	29.76	0.1
8	0.01	141.6	601.6	-0.01	29.76	0.1
9	0.06	141.6	601.6	-0.01	29.76	0.2449
10	0.07	141.6	601.6	-0.01	29.76	0.2646
11	0.08	141.6	601.6	-0.01	29.76	0.2828
12	0.05	141.6	601.6	-0.01	29.76	0.2236
13	0.06	141.6	601.6	-0.01	29.76	0.2449
14	0.07	141.6	601.6	-0.01	29.76	0.2646
15	0.04	141.6	601.6	-0.01	29.76	0.2
16	0.08	141.6	601.6	-0.01	29.76	0.2828
AVG.		141.6	601.6		29.76	0.2338

wet bulb temp. (deg F): 134.60

stack vapor pressure: 5.1325697

%H₂O: 17.026291

Molecular Density: 0.8297371

Molecular weight of dry gas: 28.4004 lb/lb mole dry

Molecular weight of wet stack gas: 26.629598 lb/lb mole wet

Stack gas velocity at stack conditions: 877.751734 afpm

Stack gas flow rate at std. conditions: 887.699326 dscfm

Stack gas flow rate at stack conditions: 1225.57159 acfm

Georgia Pacific
 Kartt BSW #3 Combined Vent
 Stack Gas Flow Rate Data and Calculations
 5-Nov-14

Run #3

Barometric Pressure: 29.76

Stack Diameter or Dimensions (in.): 16

Cross Sectional Area (sq ft): 1.3962622

Pitot Tube Avg. Coeff.: 0.84

Traverse Point	Velocity Head ^P (in. H ₂ O)	Stack Temperature (deg F)	Stack Temperature (deg R)	Stack Static Pressure (in. H ₂ O)	Stack Static Pressure (in. Hg.)	Sqrt ^P
1	0.08	140.6	600.6	-0.01	29.76	0.2828
2	0.06	140.6	600.6	-0.01	29.76	0.2449
3	0.05	140.6	600.6	-0.01	29.76	0.2236
4	0.06	140.6	600.6	-0.01	29.76	0.2449
5	0.05	140.6	600.6	-0.01	29.76	0.2236
6	0.04	140.6	600.6	-0.01	29.76	0.2
7	0.04	140.6	600.6	-0.01	29.76	0.2
8	0.04	140.6	600.6	-0.01	29.76	0.2
9	0.06	140.6	600.6	-0.01	29.76	0.2449
10	0.04	140.6	600.6	-0.01	29.76	0.2
11	0.05	140.6	600.6	-0.01	29.76	0.2236
12	0.08	140.6	600.6	-0.01	29.76	0.2828
13	0.08	140.6	600.6	-0.01	29.76	0.2828
14	0.06	140.6	600.6	-0.01	29.76	0.2449
15	0.07	140.6	600.6	-0.01	29.76	0.2646
16	0.06	140.6	600.6	-0.01	29.76	0.2449
AVG.		140.6	600.6		29.76	0.238

wet bulb temp. (deg F): 139.00

stack vapor pressure: 5.7601395

%H₂O: 19.306524

Molecular Density: 0.8069348

Molecular weight of dry gas: 28.4012 lb/lb mole dry

Molecular weight of wet stack gas: 26.39309 lb/lb mole wet

Stack gas velocity at stack conditions: 896.987301 afpm

Stack gas flow rate at std. conditions: 883.691965 dscfm

Stack gas flow rate at stack conditions: 1252.42948 acfm

Average stack gas flow rate at standard conditions:

799 dscfm

Average stack gas flow rate at stack conditions:

1114 acfm

Avg % Mois	17.79	Average Velocity	798.17
------------	-------	------------------	--------

NCASI Chilled Impinger/Silica Gel Tube Test Method At Pulp Mill Sources For Methanol, Acetone, Acetaldehyde, Methyl Ethyl Ketone And Formaldehyde

Field Sampling Data Sheet

Mill Name: GP-Toledo Date: 11/5/14
 City, State: Toledo, OH Sampler's Name: Homer
 Source Name/Description: B5W Vent #3

Run Number: 1
 Start Time: 0955 Stop Time: 1055
 Ambient Temp at Start: 53 Ambient Temp at Stop: 58
 Barometric Pressure: 29.70

Leak Test

Time: 0945 Initial Measurement (in Hga): 0 on DGM, no bubbles
 Time: 1055 Final Measurement (in Hga): 0 on DGM, no bubbles
 Leak Check Criteria- Must not lose more than 1 inch of Hg (vacuum) in 2 minutes.

Meets Criteria? Yes No

System Flow Rate Measurement

Average of 5 flow measurements for Pre-Sample FlowRate:

1. 65 2. 68 3. 71 4. 75 5. 76 Avg: 71 ± 2.176

Average of 5 flow measurements for Post-Sample Flow Rate:

1. 10 2. 10 3. 10 4. 10 5. 10 Avg: 10

Overall Average Sample Flow Rate: (indicate units!)

Avg: _____

Rotameter Readings

Time: 0945 Flow: 4.154
 Time: 1015 Flow: 8.046
 Time: 1025 Flow: 11.802
 Time: 1035 Flow: 16.083
 Time: 1045 Flow: 20.017
 Time: 1055 Flow: 23.775

QA/QC Measures

Train Spike Conducted?	Yes	No
Duplicate Conducted?	Yes	No
Spiked Duplicate Made?	Yes	No
Field Blank Made?	Yes	No
Field Spike Made?	Yes	No

Sample Bottle Weight(s):

Bottle 1: Initial Weight: _____ Final Weight: _____
 Bottle 2: Initial Weight: _____ Final Weight: _____

Notes/Comments

DGM used for sample volume collection

Bottle #1

Figure 2. Field Sampling Data Sheet

	Dry Bulb	Wet bulb
1	141.8	131
2	141.4	138.2

August 1008

Box #1 41.61 17 00038 Aug 1416 134.6

NCASI Chilled Impinger/Silica Gel Tube Test Method At Pulp Mill Sources For
Methanol, Acetone, Acetaldehyde, Methyl Ethyl Ketone And Formaldehyde

Field Sampling Data Sheet

Mill Name: GP-Toledo Date: 11/5/14
City,State: Toledo, OH Sampler's Name: Homer
Source Name/Description: BSW Vent #3

Run Number: 2
Start Time: 11:00 Stop Time: 12:00
Ambient Temp at Start: 58 Ambient Temp at Stop: 60
Barometric Pressure: 29.26

Leak Test

Time: 11:58 Initial Measurement (in Hga): 0 on DGM, no bubbles
Time: 12:01 Final Measurement (in Hga): 0 on DGM, no bubbles

Leak Check Criteria- Must not lose more than 1 inch of Hg (vacuum) in 2 minutes.

Meets Criteria? Yes No

System Flow Rate Measurement

Average of 5 flow measurements for Pre-Sample FlowRate:

1. 78 2. 78 3. 78 4. 78 5. 80 Avg: 75.8

Average of 5 flow measurements for Post-Sample Flow Rate:

1. 10 2. 10 3. 10 4. 10 5. 10 Avg: 10

Overall Average Sample Flow Rate: (indicate units!)

Avg: _____

Rotameter Readings 0

Time: 11:00	Flow: > 919
Time: 11:20	Flow: 8.037
Time: 11:30	Flow: 11.817
Time: 11:40	Flow: 16.135
Time: 11:50	Flow: 19.815
Time: 12:00	Flow: 29.036

QA/QC Measures

Train Spike Conducted?	Yes	No
Duplicate Conducted?	Yes	No
Spiked Duplicate Made?	Yes	No
Field Blank Made?	Yes	No
Field Spike Made?	Yes	No

Sample Bottle Weight(s):

Bottle 1: Initial Weight: _____
Final Weight: _____

Bottle 2: Initial Weight: _____

Final Weight: _____

Notes/Comments

DGM used for sample volume collection



Bottle #2

17

00039

Avg Dry 147.2
140.9 wet

*NCASI Chilled Impinger/Silica Gel Tube Test Method At Pulp Mill Sources For
Methanol, Acetone, Acetaldehyde, Methyl Ethyl Ketone And Formaldehyde*

Field Sampling Data Sheet

Mill Name: GP-Toledo Date: 11/5/14
 City, State: Toledo, OH Sampler's Name: Homer
 Source Name/Description: RSW Vent #3

Run Number: 2
 Start Time: 1205 Stop Time: 1305
 Ambient Temp at Start: 60 Ambient Temp at Stop: 60
 Barometric Pressure: 29.76

Leak Test

Time: 1203 Initial Measurement (in Hga): 0 on 06m, no bubbles
 Time: 1307 Final Measurement (in Hga): 0 on 06m, 1d b/w bubbles

Leak Check Criteria- Must not lose more than 1 inch of Hg (vacuum) in 2 minutes.

Meets Criteria? Yes No

System Flow Rate Measurement

Average of 5 flow measurements for Pre-Sample FlowRate:

1. 71 2. 81 3. 82 4. 83 5. 83 Avg: 77.60

Average of 5 flow measurements for Post-Sample Flow Rate:

1. 10 2. 10 3. 10 4. 10 5. 10 Avg: 10

Overall Average Sample Flow Rate: (indicate units!)

Avg:

Rotameter Readings	
Time: 1215	Flow: 9.065
Time: 1225	Flow: 8.095
Time: 1235	Flow: 12.07
Time: 1245	Flow: 16.414
Time: 1255	Flow: 9.913
Time: 1305	Flow: 2.3988

QA/QC Measures

Train Spike Conducted?	Yes	No
Duplicate Conducted?	Yes	No
Spiked Duplicate Made?	Yes	No
Field Blank Made?	Yes	No
Field Spike Made?	Yes	No

Sample Bottle Weight(s):

Bottle 1: Initial Weight: _____

Bottle 2: Initial Weight: _____

Final Weight: _____

Final Weight: _____

Notes/Comments

DGM used for sample volume collection

Bottle #3

Figure 2. Field Sampling Data Sheet

Dry Bulb	Wet bulb
140.00	136.4
2141.8	141.6

August 1998
140.6 139

Bottle #2

GAS VELOCITY AND VOLUMETRIC FLOW FORM
METHOD 2

Plant	GP-Toledo	Location:	Toledo, OR	Source:	#3 BSW Combined Vent
Date	11-5-14	Operator:	Homer	Run No.:	✓ 1 & 2
Barometric Press.	29.76	Reading Location:	Lab	Ambient Temp.:	55°
Elevation:	0	Elevation Corr.:		Corr. Bar. Press.:	0
Avg. wet bulb temp (F)	13	% O2		% CO2:	
Pitot tube ID #:	4' Stype	Pitot Cp:	.84	Last Calibration:	
Traverse Point #	Velocity Head ft	Stack Temp (F)	Static Press.	Cyclonic Flow Check	
				Vel. At 0 reference RG	Angle to get 0 Flow
1	.06	141.8	-.01	.02	30 15
2	.06			0	0
3	.04			0	0
4	.03			0	0
5	.04			0	0
6	.02			0	0
7	.02			0	0
8	.01			0	0
9	.01			0	0
10	.01			0	0
11	.01			0	0
12	.02			0	0
13	.03			0	0
14	.03			0	0
15	.03			0	0
16	.06	145.4		0	0
1	.10	147.2	-.01		
2	.07				
3	.04				
4	.05				
5	.06				
6	.08				
7	.01				
8	.01				

RUN #1

RUN #2

00041

GAS VELOCITY AND VOLUMETRIC FLOW FORM
METHOD 2

Page 2

Plant	GP-Toledo	Location:	Toledo, OR	Source:	#3 BSW Combined Vent
Date	11-5-14	11/05/1900	Operator:	Homer	Run No.: 2&3
Barometric Press.	29.76	0	Reading Location:	Lab	Ambient Temp: 55 0
Elevation:	0	Elevation Corr.:	0	Corr. Bar. Press.:	0
Avg. wet bulb temp (F)	0	% O2		% CO2:	
Pitot tube ID #:	4' Stype	Pitot Cp:	0	Last Calibration:	
Traverse Point #	Velocity Head	Stack Temp (F)	Static Press.	Cyclonic Flow Check	
				Vel. At 0 reference	Angle to get 0 Flow
9	.06		-.01		
10	.07				
11	.08				
12	.05				
13	.06				
14	.07				
15	.04				
16	.08	147.2			
1	.08	140	-.01		
2	.06				
3	.05				
4	.06				
5	.05				
6	.04				
7	.04				
8	.04				
9	.06	141.80	-.01		
10	.04				
11	.05				
12	.08				
13	.08				
14	.06				
15	.07				
16	.06				

RUN #2

RUN #3

00042

TRAVERSE POINT LOCATION WORKSHEET

METHOD 1

DATA

STACK CROSS SECTION DIAGRAM

NOTES:

00043

GAS VELOCITY AND VOLUMETRIC FLOW FORM
METHOD 2

Plant	GP-Toledo	Location:	Toledo, OR	Source:	#1 BSW Combined Vent
Date	11/6/2014	Operator:	Homer	Run No.:	1 & 2
Barometric Press.	Reading Location: Lab			Ambient Temp:	
Elevation:	0	Elevation Corr.:	0	Corr. Bar. Press.:	0
Avg. wet bulb temp (F)	% O2			% CO2:	
Pitot tube ID #:	4' Stype	Pitot Cp:		Last Calibration:	
Traverse Point #	Velocity Head	Stack Temp (F)	Static Press.	Cyclonic Flow Check	
				Vel. At 0 reference	Angle to get 0 Flow
1					
2					
3					
4					
5	Flow on #1 BSW is "backward"				
6	Wester head. This was verified by inserting contour tape and				
7	Seeing it flutter toward the head. Therefore source was not				
8	tested and emissions assumed to be 0.				
9					
10					
11	The reverse flow was checked during each run				
12					
13					
14					
15					
16					
1					
2					
3	Reverse flow				
4					
5					
6					
7					
8					



00044

GAS VELOCITY AND VOLUMETRIC FLOW FORM
METHOD 2



Plant	GP-Toledo	Location:	Toledo, OR	Source:	#1 BSW Combined Vent
Date	11/6/2014	Operator:	Homer	Run No.:	2&3
Barometric Press.	0	Reading Location:	Lab	Ambient Temp:	0
Elevation:	0	Elevation Corr.:		Corr. Bar. Press.:	0
Avg. wet bulb temp (F)	0	% O2		% CO2:	
Pitot tube ID #:	4' Stype	Pitot Cp:		Last Calibration:	1/0/1900
Traverse Point #	Velocity Head	Stack Temp (F)	Static Press.	Cyclonic Flow Check	
				Vel. At 0 reference	Angle to get 0 Flow
9					
10					
11					
12					
13		↑ ↑			
14					
15					
16					
1					
2					
3					
4					
5					
6					
7	<i>Reverse Flow</i>				
8					
9					
10					
11					
12					
13					
14					
15					
16					

00045

Kraft Washer #1 – Foam Breaker Vent




Kraft Washer #1 – Vacuum Pump Exhaust




00046


16 c Kraft Washer #1 Hood Exhaust
00047



Kraft Washer #2 Hood Exhaust



Kraft Washer #3 Hood Exhaust



BIGHORN ENVIRONMENTAL - FIELD DATA CALIBRATION SHEET

	Plant Name	Source	Stack Diameter	QA Checks			
				Gas Divider	NO2 Conv	Leak Check	Response Time
	(5P-7) check	B&W Burner	16	✓	✓	✓	✓

Cylinder ID	O ₂ (%)	CO ₂ (%)	NO _x (ppm)	CO (ppm)	SO ₂ (ppm)	VOC (as Propane)	H ₂ S (ppm)
	Mid	11.91					
	High						

Analyzer Calibration	O ₂ (%)	CO ₂ (%)	NO _x (ppm)	CO (ppm)	SO ₂ (ppm)	VOC (as Propane)	H ₂ S (ppm)
	C _v	C _{dir}	C _v	C _{dir}	C _v	C _{dir}	C _v
Zero (UPN)	0	-1.0	0	-1.15			
Low	9.09	9.76	9.2	9.35			
Mid	20.93	21.01	21.33	21.33			
Span							

Run Data	Run #1	Run #2	Run #3	Run #4	Run #5	Run #6	Run #7	Run #8	Run #9	Run #10	Run #11	Run #12	Run #13	Run #14	Run #15	Run #16	Run #17
Start Time	9/10	10:35	11:55														
End Time	10/10	11:35	12:55														
O ₂ Run Average																	
CO ₂ Run Average																	
NO _x Run average																	
CO Run Average																	
SO ₂ Run Average																	
TRS Run Average																	
VOC Run Average																	

Glas Checks	O ₂ (%)	CO ₂ (%)	NO _x (ppm)	CO (ppm)	SO ₂ (ppm)	VOC (as Propane)	H ₂ S (ppm)	
	Zero	Upscale	Zero	Upscale	Zero	Upscale	Zero	Upscale
Pre Run #1	-1.15	21.17	-1.10	21.25				
Post #1/Pre #2	-0.12	20.96	-0.09	21.27				
Post #2/Pre #3								
Post #3/Pre #4								
Post #4/Pre #5								
Post #5/Pre #6								
Post #6/Pre #7								
Post #7/Pre #8								
Post #8/Pre #9								
Post #9/Pre #10								
Post #10/Pre #11								
Post #11/Pre #12								
Post #12/Pre #13								
Post #13/Pre #14								
Post #14/Pre #15								
Post #15/Pre #16								
Post #16								

All zero values from Grade
5.0 UPN

BIGHORN ENVIRONMENTAL - FIELD DATA CALIBRATION SHEET

Plant Name	202 - 1000cc	Date	11/15/15
Source	Wastes	Project #	P-14
Stack Diameter	16	Probe Length	24"

Cylinder ID	Mid	O ₂ (%)	CO ₂ (%)	NO _x (ppm)	CO (ppm)	SO ₂ (ppm)	VOC (as Propane)	H ₂ S (ppm)
	High	20.93	71.65	X	X	X	X	X

Analyzer Calibration	O ₂ (%)	CO ₂ (%)	NO _x (ppm)	CO (ppm)	SO ₂ (ppm)	VOC (as Propane)	H ₂ S (ppm)
Zero (UPN)	C _v	C _{dir}	C _v	C _{dir}	C _v	C _{dir}	C _v
Low	0	-11	6	-15	X	X	X
Mid	10.47	10.71	11.16	10.02	X	X	X
Span	18.44	19.04	19.32	19.43	X	X	X
	18.3 BSW		#12 13.5 J.W.				

Run Data	Run #1	Run #2	Run #3	Run #4	Run #5	Run #6	Run #7	Run #8	Run #9	Run #10	Run #11	Run #12	Run #13	Run #14	Run #15	Run #16	Run #17
Start Time	04:55	11:00	12:05	14:00	15:10	16:19											
End Time	10:51	11:51	13:04	13:00	16:09	17:10											
O ₂ Run Average																	
CO ₂ Run Average																	
NO _x Run average																	
CO Run Average																	
SO ₂ Run Average																	
TRS Run Average																	
VOC Run Average																	

Bias Checks	O ₂ (%)	CO ₂ (%)	NO _x (ppm)	CO (ppm)	SO ₂ (ppm)	VOC (as Propane)	H ₂ S (ppm)
C.I.	Zero	Upscale	Zero	Upscale	Zero	Upscale	Zero
Pre-Run #1	-11	18.93	-13	2.02			
Post #1/Pre #2	-12	18.99	-01	2.06			
Post #2/Pre #3							
Post #3/Pre #4	-12	18.99	-10	2.02			
Post #4/Pre #5	-11	18.89	-12	2.06			
Post #5/Pre #6							
Post #6/Pre #7							
Post #7/Pre #8							
Post #8/Pre #9							
Post #9/Pre #10							
Post #10/Pre #11							
Post #11/Pre #12							
Post #12/Pre #13							
Post #13/Pre #14							
Post #14/Pre #15							
Post #15/Pre #16							
Post #16							

All zero values from Grade
5.0 UPN

All zero values from Grade
5.0 UPN

#2 BSW

#2 BSW

#1 #2 and #3 BSW 1 min avgs.xls

Date	Time	O2	CO2
11/5/2014	6:30	20.9	-0.06
11/5/2014	6:31	20.9	-0.06
11/5/2014	6:32	20.9	-0.06
11/5/2014	6:33	20.91	-0.06
11/5/2014	6:34	20.9	-0.06
11/5/2014	6:35	20.9	-0.06
11/5/2014	6:36	20.9	-0.07
11/5/2014	6:37	20.9	-0.06
11/5/2014	6:38	20.9	-0.06
11/5/2014	6:39	16.17	-0.06
11/5/2014	6:40	0.05	-0.11
11/5/2014	6:41	-0.11	-0.13
11/5/2014	6:42	-0.12	-0.13
11/5/2014	6:43	0.75	-0.03
11/5/2014	6:44	1.84	1.57
11/5/2014	6:45	1.84	2.03
11/5/2014	6:46	1.84	2.03
11/5/2014	6:47	1.84	2.04
11/5/2014	6:48	16.92	14.42
11/5/2014	6:49	18.99	19.39
11/5/2014	6:50	18.98	19.38
11/5/2014	6:51	18.98	19.38
11/5/2014	6:52	18.98	19.39
11/5/2014	6:53	20.64	7.25
11/5/2014	6:54	20.98	0.39
11/5/2014	6:55	20.96	0.2
11/5/2014	6:56	20.94	0.12
11/5/2014	6:57	20.93	0.06
11/5/2014	6:58	20.93	0.01
11/5/2014	6:59	20.92	0
11/5/2014	7:00	20.92	-0.02
11/5/2014	7:01	20.91	-0.04
11/5/2014	7:02	20.9	-0.05
11/5/2014	7:03	20.9	-0.05
11/5/2014	7:04	20.9	-0.05
11/5/2014	7:05	20.89	-0.05
11/5/2014	7:06	20.89	-0.05
11/5/2014	7:07	20.89	-0.05
11/5/2014	7:08	20.89	-0.05
11/5/2014	7:09	20.9	0
11/5/2014	7:10	20.87	-0.02
11/5/2014	7:11	20.86	-0.05
11/5/2014	7:12	20.85	-0.06
11/5/2014	7:13	20.85	-0.06
11/5/2014	7:14	20.85	-0.06
11/5/2014	7:15	20.85	-0.06
11/5/2014	7:16	20.86	-0.06
11/5/2014	7:17	20.85	-0.06
11/5/2014	7:18	20.85	-0.06
11/5/2014	7:19	20.86	-0.06
11/5/2014	7:20	20.85	-0.05
11/5/2014	7:21	20.86	-0.05
11/5/2014	7:22	20.87	-0.06
11/5/2014	7:23	20.87	-0.06
11/5/2014	7:24	20.87	-0.06
11/5/2014	7:25	20.81	-0.03
11/5/2014	7:26	20.69	0.46
11/5/2014	7:27	20.85	0
11/5/2014	7:28	20.84	-0.06
11/5/2014	7:29	20.85	-0.06
11/5/2014	7:30	20.86	-0.07
11/5/2014	7:31	20.86	-0.06
11/5/2014	7:32	20.86	-0.06
11/5/2014	7:33	20.86	-0.06
11/5/2014	7:34	20.87	-0.06
11/5/2014	7:35	20.87	-0.06
11/5/2014	7:36	20.87	-0.06

00053

#1 #2 and #3 BSW 1 min avgs.xls

Date	Time	O2	CO2
11/5/2014	7:37	20.87	-0.07
11/5/2014	7:38	20.88	-0.07
11/5/2014	7:39	20.87	-0.06
11/5/2014	7:40	20.88	-0.07
11/5/2014	7:41	20.87	-0.07
11/5/2014	7:42	20.87	-0.07
11/5/2014	7:43	20.87	-0.06
11/5/2014	7:44	20.87	-0.07
11/5/2014	7:45	20.88	-0.07
11/5/2014	7:46	20.88	-0.07
11/5/2014	7:47	20.89	-0.07
11/5/2014	7:48	20.89	-0.07
11/5/2014	7:49	20.89	-0.07
11/5/2014	7:50	20.9	-0.07
11/5/2014	7:51	20.9	-0.07
11/5/2014	7:52	20.91	-0.07
11/5/2014	7:53	20.92	-0.07
11/5/2014	7:54	20.92	-0.06
11/5/2014	7:55	20.92	-0.07
11/5/2014	7:56	20.92	-0.06
11/5/2014	7:57	20.92	-0.06
11/5/2014	7:58	20.92	-0.06
11/5/2014	7:59	20.92	-0.06
11/5/2014	8:00	20.92	-0.06
11/5/2014	8:01	20.93	-0.06
11/5/2014	8:02	20.93	-0.06
11/5/2014	8:03	20.92	-0.07
11/5/2014	8:04	20.92	-0.06
11/5/2014	8:05	20.93	-0.06
11/5/2014	8:06	20.93	-0.07
11/5/2014	8:07	20.93	-0.06
11/5/2014	8:08	20.92	-0.06
11/5/2014	8:09	20.91	-0.05
11/5/2014	8:10	20.9	-0.06
11/5/2014	8:11	20.9	-0.06
11/5/2014	8:12	20.9	-0.06
11/5/2014	8:13	20.91	-0.06
11/5/2014	8:14	20.91	-0.06
11/5/2014	8:15	20.92	-0.07
11/5/2014	8:16	20.92	-0.06
11/5/2014	8:17	20.92	-0.07
11/5/2014	8:18	20.92	-0.05
11/5/2014	8:19	20.93	-0.06
11/5/2014	8:20	20.92	-0.06
11/5/2014	8:21	20.93	-0.07
11/5/2014	8:22	20.93	-0.06
11/5/2014	8:23	20.94	-0.06
11/5/2014	8:24	20.94	-0.07
11/5/2014	8:25	20.94	-0.06
11/5/2014	8:26	20.94	-0.07
11/5/2014	8:27	20.94	-0.07
11/5/2014	8:28	20.94	-0.07
11/5/2014	8:29	20.95	-0.07
11/5/2014	8:30	20.94	-0.07
11/5/2014	8:31	20.94	-0.07
11/5/2014	8:32	20.94	-0.07
11/5/2014	8:33	20.93	-0.07
11/5/2014	8:34	20.39	-0.03
11/5/2014	8:35	17.59	3.65
11/5/2014	8:36	20.74	0.27
11/5/2014	8:37	20.86	0.04
11/5/2014	8:38	20.89	-0.02
11/5/2014	8:39	20.91	-0.05
11/5/2014	8:40	20.91	-0.07
11/5/2014	8:41	20.9	-0.07
11/5/2014	8:42	20.91	-0.07
11/5/2014	8:43	20.9	-0.07

00054

#1 #2 and #3 BSW 1 min avgs.xls

Date	Time	O2	CO2
11/5/2014	8:44	20.9	-0.06
11/5/2014	8:45	20.9	-0.07
11/5/2014	8:46	20.91	-0.06
11/5/2014	8:47	20.91	-0.07
11/5/2014	8:48	20.91	-0.06
11/5/2014	8:49	20.91	-0.07
11/5/2014	8:50	20.91	-0.07
11/5/2014	8:51	20.91	-0.07
11/5/2014	8:52	20.9	-0.07
11/5/2014	8:53	20.9	-0.06
11/5/2014	8:54	20.9	-0.07
11/5/2014	8:55	20.91	-0.06
11/5/2014	8:56	20.9	-0.06
11/5/2014	8:57	20.89	-0.06
11/5/2014	8:58	20.9	-0.06
11/5/2014	8:59	20.9	-0.06
11/5/2014	9:00	20.9	-0.06
11/5/2014	9:01	20.9	-0.06
11/5/2014	9:02	20.9	-0.06
11/5/2014	9:03	20.9	-0.06
11/5/2014	9:04	20.9	-0.06
11/5/2014	9:05	20.89	-0.07
11/5/2014	9:06	20.9	-0.06
11/5/2014	9:07	20.89	-0.06
11/5/2014	9:08	20.88	-0.06
11/5/2014	9:09	20.88	-0.06
11/5/2014	9:10	20.89	-0.06
11/5/2014	9:11	20.89	-0.06
11/5/2014	9:12	20.89	-0.06
11/5/2014	9:13	20.78	-0.06
11/5/2014	9:14	20.87	-0.06
11/5/2014	9:15	20.88	-0.06
11/5/2014	9:16	20.88	-0.06
11/5/2014	9:17	20.88	-0.07
11/5/2014	9:18	20.88	-0.06
11/5/2014	9:19	20.87	-0.06
11/5/2014	9:20	20.87	-0.06
11/5/2014	9:21	20.88	-0.06
11/5/2014	9:22	20.87	-0.06
11/5/2014	9:23	20.87	-0.06
11/5/2014	9:24	20.87	-0.06
11/5/2014	9:25	20.87	-0.07
11/5/2014	9:26	20.88	-0.06
11/5/2014	9:27	20.87	-0.06
11/5/2014	9:28	20.84	-0.06
11/5/2014	9:29	20.87	-0.06
11/5/2014	9:30	20.86	-0.06
11/5/2014	9:31	20.87	-0.06
11/5/2014	9:32	20.82	-0.06
11/5/2014	9:33	20.87	-0.06
11/5/2014	9:34	20.87	-0.06
11/5/2014	9:35	20.87	-0.06
11/5/2014	9:36	20.88	-0.06
11/5/2014	9:37	20.87	-0.06
11/5/2014	9:38	20.87	-0.06
11/5/2014	9:39	20.87	-0.06
11/5/2014	9:40	20.87	-0.06
11/5/2014	9:41	20.87	-0.06
11/5/2014	9:42	20.88	-0.06
11/5/2014	9:43	20.88	-0.06
11/5/2014	9:44	20.88	-0.06
11/5/2014	9:45	15.79	-0.07
11/5/2014	9:46	11.43	-0.1
11/5/2014	9:47	12.47	-0.1
11/5/2014	9:48	11.35	-0.11
11/5/2014	9:49	11.16	-0.1
11/5/2014	9:50	11.09	-0.11

00055

#1 #2 and #3 BSW 1 min avgs.xls

Date	Time	O2	CO2
11/5/2014	9:51	11.03	-0.11
11/5/2014	9:52	10.96	-0.11
11/5/2014	9:53	10.93	-0.11
11/5/2014	9:54	10.99	-0.1
11/5/2014	9:55	11.05	-0.11
11/5/2014	9:56	10.89	-0.1
11/5/2014	9:57	10.79	-0.1
11/5/2014	9:58	10.76	-0.11
11/5/2014	9:59	10.68	-0.11
11/5/2014	10:00	10.51	-0.11
11/5/2014	10:01	10.35	-0.1
11/5/2014	10:02	10.26	-0.11
11/5/2014	10:03	10.26	-0.12
11/5/2014	10:04	10.27	-0.11
11/5/2014	10:05	10.22	-0.11
11/5/2014	10:06	10.17	-0.12
11/5/2014	10:07	10.16	-0.1
11/5/2014	10:08	10.16	-0.1
11/5/2014	10:09	10.16	-0.12
11/5/2014	10:10	10.14	-0.12
11/5/2014	10:11	10.12	-0.12
11/5/2014	10:12	10.07	-0.12
11/5/2014	10:13	10.02	-0.11
11/5/2014	10:14	9.97	-0.11
11/5/2014	10:15	9.98	-0.12
11/5/2014	10:16	9.94	-0.11
11/5/2014	10:17	9.9	-0.12
11/5/2014	10:18	9.9	-0.11
11/5/2014	10:19	9.88	-0.11
11/5/2014	10:20	9.84	-0.1
11/5/2014	10:21	9.77	-0.11
11/5/2014	10:22	9.76	-0.1
11/5/2014	10:23	9.77	-0.11
11/5/2014	10:24	9.74	-0.11
11/5/2014	10:25	9.67	-0.11
11/5/2014	10:26	9.66	-0.11
11/5/2014	10:27	9.68	-0.12
11/5/2014	10:28	9.68	-0.11
11/5/2014	10:29	9.74	-0.11
11/5/2014	10:30	9.79	-0.12
11/5/2014	10:31	9.86	-0.12
11/5/2014	10:32	9.95	-0.11
11/5/2014	10:33	10.04	-0.11
11/5/2014	10:34	10.1	-0.11
11/5/2014	10:35	10.1	-0.12
11/5/2014	10:36	10.02	-0.12
11/5/2014	10:37	9.91	-0.11
11/5/2014	10:38	9.75	-0.11
11/5/2014	10:39	9.67	-0.11
11/5/2014	10:40	9.67	-0.12
11/5/2014	10:41	9.68	-0.12
11/5/2014	10:42	9.65	-0.12
11/5/2014	10:43	9.66	-0.12
11/5/2014	10:44	9.67	-0.12
11/5/2014	10:45	9.69	-0.12
11/5/2014	10:46	9.73	-0.12
11/5/2014	10:47	9.77	-0.12
11/5/2014	10:48	9.78	-0.12
11/5/2014	10:49	9.79	-0.12
11/5/2014	10:50	9.78	-0.12
11/5/2014	10:51	9.74	-0.12
11/5/2014	10:52	9.66	-0.12
11/5/2014	10:53	9.62	-0.11
11/5/2014	10:54	9.61	-0.11
11/5/2014	10:55	9.61	-0.12
11/5/2014	10:56	9.56	-0.12
11/5/2014	10:57	9.53	-0.12

#1 #2 and #3 BSW 1 min avgs.xls

Date	Time	O2	CO2
11/5/2014	10:58	9.49	-0.12
11/5/2014	10:59	9.51	-0.11
11/5/2014	11:00	9.5	-0.11
11/5/2014	11:01	9.47	-0.12
11/5/2014	11:02	9.47	-0.12
11/5/2014	11:03	9.46	-0.12
11/5/2014	11:04	9.43	-0.12
11/5/2014	11:05	9.42	-0.12
11/5/2014	11:06	9.48	-0.11
11/5/2014	11:07	9.57	-0.12
11/5/2014	11:08	9.67	-0.12
11/5/2014	11:09	9.77	-0.11
11/5/2014	11:10	9.9	-0.11
11/5/2014	11:11	10.04	-0.11
11/5/2014	11:12	10.11	-0.11
11/5/2014	11:13	10.19	-0.11
11/5/2014	11:14	10.21	-0.11
11/5/2014	11:15	10.11	-0.11
11/5/2014	11:16	10.05	-0.1
11/5/2014	11:17	10.02	-0.11
11/5/2014	11:18	10	-0.11
11/5/2014	11:19	9.97	-0.11
11/5/2014	11:20	9.98	-0.11
11/5/2014	11:21	10.02	-0.11
11/5/2014	11:22	10.05	-0.12
11/5/2014	11:23	10.03	-0.1
11/5/2014	11:24	10.04	-0.1
11/5/2014	11:25	10.03	-0.1
11/5/2014	11:26	10.01	-0.1
11/5/2014	11:27	9.99	-0.1
11/5/2014	11:28	10.02	-0.1
11/5/2014	11:29	10.05	-0.1
11/5/2014	11:30	10.06	-0.1
11/5/2014	11:31	10.1	-0.1
11/5/2014	11:32	10.18	-0.1
11/5/2014	11:33	10.23	-0.1
11/5/2014	11:34	10.28	-0.1
11/5/2014	11:35	10.28	-0.1
11/5/2014	11:36	10.26	-0.1
11/5/2014	11:37	10.21	-0.1
11/5/2014	11:38	10.21	-0.1
11/5/2014	11:39	10.22	-0.1
11/5/2014	11:40	10.21	-0.1
11/5/2014	11:41	10.22	-0.1
11/5/2014	11:42	10.19	-0.1
11/5/2014	11:43	10.15	-0.1
11/5/2014	11:44	10.12	-0.1
11/5/2014	11:45	10.1	-0.1
11/5/2014	11:46	10.11	-0.1
11/5/2014	11:47	10.08	-0.1
11/5/2014	11:48	10.09	-0.1
11/5/2014	11:49	10.13	-0.1
11/5/2014	11:50	10.14	-0.1
11/5/2014	11:51	10.14	-0.11
11/5/2014	11:52	10.13	-0.1
11/5/2014	11:53	10.11	-0.11
11/5/2014	11:54	10.08	-0.1
11/5/2014	11:55	10.08	-0.1
11/5/2014	11:56	10.08	-0.1
11/5/2014	11:57	10.07	-0.11
11/5/2014	11:58	10.05	-0.11
11/5/2014	11:59	10.03	-0.1
11/5/2014	12:00	10.03	-0.1
11/5/2014	12:01	10.04	-0.11
11/5/2014	12:02	10.05	-0.1
11/5/2014	12:03	10.05	-0.11
11/5/2014	12:04	10.06	-0.11

#1 #2 and #3 BSW 1 min avgs.xls

Date	Time	O2	CO2
11/5/2014	12:05	10.08	-0.1
11/5/2014	12:06	10.06	-0.1
11/5/2014	12:07	10.04	-0.1
11/5/2014	12:08	10.02	-0.1
11/5/2014	12:09	10.04	-0.1
11/5/2014	12:10	10.03	-0.1
11/5/2014	12:11	10.02	-0.1
11/5/2014	12:12	10.04	-0.1
11/5/2014	12:13	10.05	-0.1
11/5/2014	12:14	10.05	-0.11
11/5/2014	12:15	10.06	-0.11
11/5/2014	12:16	10.09	-0.1
11/5/2014	12:17	10.13	-0.1
11/5/2014	12:18	10.16	-0.1
11/5/2014	12:19	10.2	-0.11
11/5/2014	12:20	10.23	-0.11
11/5/2014	12:21	10.24	-0.1
11/5/2014	12:22	10.25	-0.11
11/5/2014	12:23	10.24	-0.1
11/5/2014	12:24	10.22	-0.11
11/5/2014	12:25	10.22	-0.11
11/5/2014	12:26	10.23	-0.1
11/5/2014	12:27	10.26	-0.1
11/5/2014	12:28	10.27	-0.11
11/5/2014	12:29	10.22	-0.1
11/5/2014	12:30	10.19	-0.1
11/5/2014	12:31	10.2	-0.1
11/5/2014	12:32	10.2	-0.11
11/5/2014	12:33	10.19	-0.11
11/5/2014	12:34	10.16	-0.1
11/5/2014	12:35	10.1	-0.11
11/5/2014	12:36	10.08	-0.11
11/5/2014	12:37	10.06	-0.1
11/5/2014	12:38	10.04	-0.11
11/5/2014	12:39	10.03	-0.1
11/5/2014	12:40	10.03	-0.1
11/5/2014	12:41	10.05	-0.1
11/5/2014	12:42	10	-0.11
11/5/2014	12:43	9.95	-0.11
11/5/2014	12:44	9.94	-0.1
11/5/2014	12:45	9.93	-0.11
11/5/2014	12:46	9.9	-0.1
11/5/2014	12:47	9.85	-0.11
11/5/2014	12:48	9.84	-0.1
11/5/2014	12:49	9.81	-0.1
11/5/2014	12:50	9.78	-0.1
11/5/2014	12:51	9.8	-0.1
11/5/2014	12:52	9.82	-0.11
11/5/2014	12:53	9.85	-0.11
11/5/2014	12:54	9.85	-0.11
11/5/2014	12:55	9.82	-0.11
11/5/2014	12:56	9.81	-0.11
11/5/2014	12:57	9.83	-0.11
11/5/2014	12:58	10.05	-0.11
11/5/2014	12:59	10.02	-0.11
11/5/2014	13:00	9.94	-0.11
11/5/2014	13:01	9.85	-0.11
11/5/2014	13:02	9.82	-0.11
11/5/2014	13:03	9.82	-0.11
11/5/2014	13:04	9.81	-0.11
11/5/2014	13:05	9.76	-0.1
11/5/2014	13:06	9.67	-0.1
11/5/2014	13:07	9.58	-0.11
11/5/2014	13:08	9.56	-0.11
11/5/2014	13:09	9.56	-0.11
11/5/2014	13:10	9.57	-0.11
11/5/2014	13:11	9.59	-0.11

#1 #2 and #3 BSW 1 min avgs.xls

Date	Time	O2	CO2
11/5/2014	13:12	9.6	-0.11
11/5/2014	13:13	9.59	-0.11
11/5/2014	13:14	9.61	-0.11
11/5/2014	13:15	9.62	-0.1
11/5/2014	13:16	9.61	-0.1
11/5/2014	13:17	9.61	-0.1
11/5/2014	13:18	9.62	-0.1
11/5/2014	13:19	9.64	-0.1
11/5/2014	13:20	7.84	-0.09
11/5/2014	13:21	3.78	3.87
11/5/2014	13:22	3.9	4.46
11/5/2014	13:23	4.09	4.48
11/5/2014	13:24	3.11	2.42
11/5/2014	13:25	1.85	2.06
11/5/2014	13:26	1.84	2.06
11/5/2014	13:27	7.38	1.98
11/5/2014	13:28	15.18	4.5
11/5/2014	13:29	18.99	0.03
11/5/2014	13:30	18.98	-0.1
11/5/2014	13:31	9.73	-0.1
11/5/2014	13:32	0.03	-0.1
11/5/2014	13:33	-0.12	-0.09
11/5/2014	13:34	-0.13	-0.1
11/5/2014	13:35	11.02	0.03
11/5/2014	13:36	4.44	2.51
11/5/2014	13:37	9.03	0.17
11/5/2014	13:38	9.24	-0.05
11/5/2014	13:39	9.22	-0.09
11/5/2014	13:40	9.21	-0.09
11/5/2014	13:41	9.23	-0.09
11/5/2014	13:42	9.25	-0.1
11/5/2014	13:43	9.26	-0.1
11/5/2014	13:44	9.31	-0.1
11/5/2014	13:45	9.38	-0.1
11/5/2014	13:46	9.46	-0.1
11/5/2014	13:47	9.51	-0.1
11/5/2014	13:48	9.58	-0.1
11/5/2014	13:49	9.57	-0.1
11/5/2014	13:50	9.56	-0.1
11/5/2014	13:51	9.53	-0.1
11/5/2014	13:52	10.1	-0.1
11/5/2014	13:53	19.44	-0.08
11/5/2014	13:54	19.98	-0.06
11/5/2014	13:55	19.51	-0.07
11/5/2014	13:56	19.53	-0.08
11/5/2014	13:57	19.54	-0.08
11/5/2014	13:58	19.59	-0.08
11/5/2014	13:59	19.63	-0.08
11/5/2014	14:00	19.64	-0.07
11/5/2014	14:01	19.63	-0.07
11/5/2014	14:02	19.61	-0.08
11/5/2014	14:03	19.62	-0.07
11/5/2014	14:04	19.6	-0.08
11/5/2014	14:05	19.6	-0.07
11/5/2014	14:06	19.6	-0.08
11/5/2014	14:07	19.6	-0.08
11/5/2014	14:08	19.6	-0.08
11/5/2014	14:09	19.6	-0.08
11/5/2014	14:10	19.6	-0.07
11/5/2014	14:11	19.61	-0.08
11/5/2014	14:12	19.6	-0.08
11/5/2014	14:13	19.6	-0.07
11/5/2014	14:14	19.59	-0.08
11/5/2014	14:15	19.6	-0.07
11/5/2014	14:16	19.6	-0.08
11/5/2014	14:17	19.58	-0.08
11/5/2014	14:18	19.57	-0.07

00059

#1 #2 and #3 BSW 1 min avgs.xls

Date	Time	O2	CO2
11/5/2014	14:19	19.57	-0.07
11/5/2014	14:20	19.56	-0.08
11/5/2014	14:21	19.56	-0.08
11/5/2014	14:22	19.53	-0.07
11/5/2014	14:23	19.51	-0.07
11/5/2014	14:24	19.5	-0.07
11/5/2014	14:25	19.48	-0.07
11/5/2014	14:26	19.47	-0.07
11/5/2014	14:27	19.47	-0.07
11/5/2014	14:28	19.46	-0.07
11/5/2014	14:29	19.44	-0.07
11/5/2014	14:30	19.42	-0.07
11/5/2014	14:31	19.4	-0.07
11/5/2014	14:32	19.41	-0.07
11/5/2014	14:33	19.41	-0.08
11/5/2014	14:34	19.42	-0.07
11/5/2014	14:35	19.4	-0.07
11/5/2014	14:36	19.46	-0.08
11/5/2014	14:37	19.46	-0.08
11/5/2014	14:38	19.47	-0.08
11/5/2014	14:39	19.47	-0.08
11/5/2014	14:40	19.48	-0.07
11/5/2014	14:41	19.47	-0.07
11/5/2014	14:42	19.48	-0.08
11/5/2014	14:43	19.49	-0.07
11/5/2014	14:44	19.5	-0.07
11/5/2014	14:45	19.49	-0.08
11/5/2014	14:46	19.47	-0.07
11/5/2014	14:47	19.45	-0.07
11/5/2014	14:48	19.43	-0.07
11/5/2014	14:49	19.41	-0.08
11/5/2014	14:50	19.39	-0.07
11/5/2014	14:51	19.41	-0.07
11/5/2014	14:52	19.39	-0.07
11/5/2014	14:53	19.37	-0.07
11/5/2014	14:54	19.33	-0.07
11/5/2014	14:55	19.32	-0.07
11/5/2014	14:56	19.33	-0.07
11/5/2014	14:57	19.34	-0.07
11/5/2014	14:58	19.33	-0.08
11/5/2014	14:59	19.31	-0.07
11/5/2014	15:00	19.29	-0.07
11/5/2014	15:01	19.27	-0.07
11/5/2014	15:02	19.25	-0.07
11/5/2014	15:03	19.24	-0.07
11/5/2014	15:04	19.22	-0.07
11/5/2014	15:05	19.19	-0.07
11/5/2014	15:06	19.16	-0.07
11/5/2014	15:07	19.14	-0.07
11/5/2014	15:08	19.12	-0.07
11/5/2014	15:09	19.11	-0.07
11/5/2014	15:10	19.11	-0.07
11/5/2014	15:11	19.13	-0.07
11/5/2014	15:12	19.41	-0.06
11/5/2014	15:13	19.39	-0.05
11/5/2014	15:14	19.35	-0.05
11/5/2014	15:15	19.34	-0.06
11/5/2014	15:16	19.35	-0.06
11/5/2014	15:17	19.36	-0.06
11/5/2014	15:18	19.35	-0.06
11/5/2014	15:19	19.33	-0.06
11/5/2014	15:20	19.31	-0.06
11/5/2014	15:21	19.29	-0.06
11/5/2014	15:22	19.27	-0.06
11/5/2014	15:23	19.26	-0.06
11/5/2014	15:24	19.24	-0.06
11/5/2014	15:25	19.21	-0.06

#1 #2 and #3 BSW 1 min avgs.xls

Date	Time	O2	CO2
11/5/2014	15:26	19.19	-0.07
11/5/2014	15:27	19.14	-0.07
11/5/2014	15:28	19.11	-0.06
11/5/2014	15:29	19.01	-0.07
11/5/2014	15:30	18.97	-0.07
11/5/2014	15:31	19.01	-0.07
11/5/2014	15:32	19.13	-0.07
11/5/2014	15:33	19.17	-0.07
11/5/2014	15:34	19.11	-0.06
11/5/2014	15:35	19.09	-0.07
11/5/2014	15:36	19.12	-0.07
11/5/2014	15:37	19.2	-0.06
11/5/2014	15:38	19.63	-0.06
11/5/2014	15:39	19.41	-0.06
11/5/2014	15:40	19.32	-0.06
11/5/2014	15:41	19.63	-0.06
11/5/2014	15:42	19.26	-0.05
11/5/2014	15:43	19.24	-0.04
11/5/2014	15:44	19.23	-0.05
11/5/2014	15:45	19.21	-0.04
11/5/2014	15:46	19.18	-0.05
11/5/2014	15:47	19.16	-0.05
11/5/2014	15:48	19.11	-0.05
11/5/2014	15:49	19.08	-0.05
11/5/2014	15:50	18.98	-0.04
11/5/2014	15:51	18.94	-0.05
11/5/2014	15:52	18.98	-0.05
11/5/2014	15:53	19.1	-0.05
11/5/2014	15:54	19.14	-0.05
11/5/2014	15:55	19.08	-0.05
11/5/2014	15:56	19.06	-0.06
11/5/2014	15:57	19.09	-0.06
11/5/2014	15:58	19.17	-0.05
11/5/2014	15:59	19.6	-0.05
11/5/2014	16:00	19.38	-0.05
11/5/2014	16:01	19.18	-0.05
11/5/2014	16:02	19.16	-0.04
11/5/2014	16:03	19.14	-0.04
11/5/2014	16:04	19.13	-0.05
11/5/2014	16:05	19.13	-0.05
11/5/2014	16:06	19.15	-0.04
11/5/2014	16:07	19.43	-0.04
11/5/2014	16:08	19.41	-0.04
11/5/2014	16:09	19.37	-0.04
11/5/2014	16:10	19.36	-0.04
11/5/2014	16:11	19.37	-0.04
11/5/2014	16:12	19.38	-0.05
11/5/2014	16:13	19.37	-0.05
11/5/2014	16:14	19.35	-0.04
11/5/2014	16:15	19.33	-0.05
11/5/2014	16:16	19.31	-0.05
11/5/2014	16:17	19.28	-0.05
11/5/2014	16:18	19.28	-0.05
11/5/2014	16:19	19.26	-0.05
11/5/2014	16:20	19.23	-0.05
11/5/2014	16:21	19.21	-0.05
11/5/2014	16:22	19.16	-0.05
11/5/2014	16:23	19.18	-0.05
11/5/2014	16:24	19.12	-0.05
11/5/2014	16:25	19.1	-0.05
11/5/2014	16:26	19.13	-0.05
11/5/2014	16:27	19.21	-0.05
11/5/2014	16:28	19.64	-0.05
11/5/2014	16:29	19.42	-0.05
11/5/2014	16:30	19.22	-0.05
11/5/2014	16:31	19.2	-0.05
11/5/2014	16:32	19.18	-0.04

00061

#1 #2 and #3 BSW 1 min avgs.xls

Date	Time	O2	CO2
11/5/2014	16:33	19.17	-0.05
11/5/2014	16:34	19.17	-0.05
11/5/2014	16:35	19.19	-0.05
11/5/2014	16:36	19.47	-0.05
11/5/2014	16:37	19.45	-0.05
11/5/2014	16:38	19.41	-0.05
11/5/2014	16:39	19.4	-0.05
11/5/2014	16:40	19.11	-0.05
11/5/2014	16:41	19.05	-0.05
11/5/2014	16:42	19.03	-0.05
11/5/2014	16:43	19.06	-0.05
11/5/2014	16:44	19.14	-0.05
11/5/2014	16:45	19.57	-0.05
11/5/2014	16:46	19.35	-0.05
11/5/2014	16:47	19.15	-0.05
11/5/2014	16:48	19.13	-0.05
11/5/2014	16:49	19.11	-0.05
11/5/2014	16:50	19.1	-0.04
11/5/2014	16:51	19.1	-0.05
11/5/2014	16:52	19.12	-0.05
11/5/2014	16:53	19.4	-0.05
11/5/2014	16:54	19.38	-0.05
11/5/2014	16:55	19.34	-0.05
11/5/2014	16:56	19.33	-0.05
11/5/2014	16:57	19.34	-0.04
11/5/2014	16:58	19.23	-0.03
11/5/2014	16:59	19.51	-0.04
11/5/2014	17:00	19.49	-0.04
11/5/2014	17:01	19.45	-0.03
11/5/2014	17:02	19.44	-0.03
11/5/2014	17:03	19.15	-0.05
11/5/2014	17:04	19.09	-0.04
11/5/2014	17:05	19.07	-0.03
11/5/2014	17:06	19.1	-0.05
11/5/2014	17:07	19.18	-0.05
11/5/2014	17:08	19.81	-0.05
11/5/2014	17:09	19.39	-0.05
11/5/2014	17:10	19.19	-0.05
11/5/2014	17:11	19.17	-0.05
11/5/2014	17:12	19.15	-0.05
11/5/2014	17:13	19.14	-0.05
11/5/2014	17:14	19.14	-0.05
11/5/2014	17:15	19.16	-0.04
11/5/2014	17:16	19.44	-0.04
11/5/2014	17:17	19.51	-0.05
11/5/2014	17:18	19.49	-0.05
11/5/2014	17:19	19.45	-0.05
11/5/2014	17:20	20.79	-0.05
11/5/2014	17:21	20.81	-0.05
11/5/2014	17:22	20.83	-0.05
11/5/2014	17:23	20.83	-0.05
11/5/2014	17:24	5.87	-0.06
11/5/2014	17:25	-0.09	-0.1
11/5/2014	17:26	-0.11	-0.1
11/5/2014	17:27	-0.12	-0.1
11/5/2014	17:28	2.5	0.22
11/5/2014	17:29	1.85	1.89
11/5/2014	17:30	1.85	2.06
11/5/2014	17:31	1.85	2.06
11/5/2014	17:32	10.64	7.01
11/5/2014	17:33	18.89	19.04
11/5/2014	17:34	20.9	1.72
11/5/2014	17:35	20.87	0.07
11/5/2014	17:36	20.48	0.39
11/5/2014	17:37	7.98	8.12
11/5/2014	17:38	20.07	0.42
11/5/2014	17:39	21.19	-0.06

00062

#1 #2 and #3 BSW 1 min avgs.xls

Date	Time	O2	CO2
11/5/2014	17:40	20.59	-0.06
11/5/2014	17:41	20.58	-0.09
11/5/2014	17:42	20.58	-0.09
11/5/2014	17:43	20.58	-0.09
11/5/2014	17:44	20.58	-0.1
11/5/2014	17:45	20.58	-0.1
11/5/2014	17:46	20.91	-0.1
11/5/2014	17:47	21.02	-0.1
11/5/2014	17:48	21.02	-0.1
11/5/2014	17:49	21.01	-0.1
11/5/2014	17:50	16	0.13
11/5/2014	17:51	18.49	0.35
11/5/2014	17:52	20.79	-0.02
11/5/2014	17:53	20.83	-0.04
11/5/2014	17:54	20.83	-0.04
11/5/2014	17:55	20.82	-0.04
11/5/2014	17:56	20.83	-0.04
11/5/2014	17:57	20.82	-0.04
11/5/2014	17:58	20.83	-0.04
11/5/2014	17:59	20.83	-0.04
11/5/2014	18:00	20.83	-0.04
11/6/2014	6:00	20.93	-0.06
11/6/2014	6:01	20.93	-0.05
11/6/2014	6:02	20.93	-0.05
11/6/2014	6:03	20.93	-0.05
11/6/2014	6:04	20.93	-0.05
11/6/2014	6:05	20.92	-0.04
11/6/2014	6:06	20.92	-0.05
11/6/2014	6:07	20.92	-0.05
11/6/2014	6:08	20.92	-0.05
11/6/2014	6:09	20.92	-0.06
11/6/2014	6:10	20.92	-0.05
11/6/2014	6:11	20.93	-0.05
11/6/2014	6:12	20.92	-0.05
11/6/2014	6:13	20.93	-0.05
11/6/2014	6:14	20.93	-0.05
11/6/2014	6:15	20.93	-0.06
11/6/2014	6:16	20.93	-0.05
11/6/2014	6:17	20.93	-0.05
11/6/2014	6:18	20.93	-0.06
11/6/2014	6:19	20.93	-0.06
11/6/2014	6:20	20.93	-0.04
11/6/2014	6:21	20.93	-0.05
11/6/2014	6:22	20.93	-0.05
11/6/2014	6:23	20.93	-0.05
11/6/2014	6:24	20.93	-0.05
11/6/2014	6:25	20.93	-0.05
11/6/2014	6:26	20.93	-0.06
11/6/2014	6:27	20.93	-0.06
11/6/2014	6:28	20.93	-0.06
11/6/2014	6:29	20.93	-0.05
11/6/2014	6:30	20.93	-0.04
11/6/2014	6:31	20.93	-0.05
11/6/2014	6:32	20.93	-0.06
11/6/2014	6:33	20.93	-0.05
11/6/2014	6:34	20.93	-0.05
11/6/2014	6:35	20.93	-0.05
11/6/2014	6:36	20.92	-0.05
11/6/2014	6:37	20.92	-0.05
11/6/2014	6:38	20.92	-0.05
11/6/2014	6:39	20.92	-0.05
11/6/2014	6:40	20.92	-0.05
11/6/2014	6:41	20.92	-0.05
11/6/2014	6:42	20.92	-0.05
11/6/2014	6:43	20.92	-0.06
11/6/2014	6:44	20.92	-0.06
11/6/2014	6:45	20.92	-0.06

#1 #2 and #3 BSW 1 min avgs.xls

Date	Time	O2	CO2
11/6/2014	6:46	20.92	-0.05
11/6/2014	6:47	20.92	-0.05
11/6/2014	6:48	20.92	-0.05
11/6/2014	6:49	20.91	-0.05
11/6/2014	6:50	20.91	-0.05
11/6/2014	6:51	20.91	-0.05
11/6/2014	6:52	20.91	-0.05
11/6/2014	6:53	20.91	-0.05
11/6/2014	6:54	20.91	-0.05
11/6/2014	6:55	10.23	-0.06
11/6/2014	6:56	-0.06	-0.1
11/6/2014	6:57	-0.1	-0.1
11/6/2014	6:58	0.73	-0.1
11/6/2014	6:59	9.09	0.07
11/6/2014	7:00	1.69	1.82
11/6/2014	7:01	1.68	2.23
11/6/2014	7:02	1.69	2.25
11/6/2014	7:03	5.68	2.21
11/6/2014	7:04	14.33	5.13
11/6/2014	7:05	9.22	11.13
11/6/2014	7:06	9.26	11.16
11/6/2014	7:07	9.28	11.16
11/6/2014	7:08	12.99	9.21
11/6/2014	7:09	21	0.2
11/6/2014	7:10	20.9	0.03
11/6/2014	7:11	20.84	0.02
11/6/2014	7:12	20.82	0.02
11/6/2014	7:13	20.82	0.01
11/6/2014	7:14	20.82	0
11/6/2014	7:15	20.82	0
11/6/2014	7:16	20.83	-0.01
11/6/2014	7:17	20.83	-0.01
11/6/2014	7:18	20.84	-0.01
11/6/2014	7:19	20.84	-0.02
11/6/2014	7:20	20.85	-0.02
11/6/2014	7:21	20.85	-0.02
11/6/2014	7:22	20.85	-0.02
11/6/2014	7:23	20.85	-0.04
11/6/2014	7:24	20.86	-0.04
11/6/2014	7:25	20.86	-0.04
11/6/2014	7:26	20.86	-0.04
11/6/2014	7:27	20.86	-0.04
11/6/2014	7:28	20.86	-0.04
11/6/2014	7:29	20.86	-0.04
11/6/2014	7:30	20.86	-0.04
11/6/2014	7:31	20.86	-0.04
11/6/2014	7:32	20.87	-0.04
11/6/2014	7:33	20.87	-0.04
11/6/2014	7:34	20.87	-0.04
11/6/2014	7:35	20.87	-0.05
11/6/2014	7:36	20.87	-0.04
11/6/2014	7:37	20.87	-0.04
11/6/2014	7:38	20.88	-0.04
11/6/2014	7:39	20.88	-0.04
11/6/2014	7:40	20.83	-0.02
11/6/2014	7:41	20.8	0.03
11/6/2014	7:42	20.81	0.01
11/6/2014	7:43	20.8	-0.01
11/6/2014	7:44	20.77	-0.02
11/6/2014	7:45	20.75	-0.03
11/6/2014	7:46	20.74	-0.02
11/6/2014	7:47	20.73	-0.02
11/6/2014	7:48	20.75	-0.02
11/6/2014	7:49	20.78	-0.02
11/6/2014	7:50	20.79	-0.02
11/6/2014	7:51	20.8	-0.02
11/6/2014	7:52	20.8	-0.02

00064

#1 #2 and #3 BSW 1 min avg.xls

Date	Time	O2	CO2
11/6/2014	7:53	20.81	-0.02
11/6/2014	7:54	20.81	-0.02
11/6/2014	7:55	20.81	-0.02
11/6/2014	7:56	20.81	-0.02
11/6/2014	7:57	20.81	-0.02
11/6/2014	7:58	20.81	-0.02
11/6/2014	7:59	20.81	-0.02
11/6/2014	8:00	20.81	-0.02
11/6/2014	8:01	20.81	-0.02
11/6/2014	8:02	20.81	-0.02
11/6/2014	8:03	20.81	-0.01
11/6/2014	8:04	20.81	-0.01
11/6/2014	8:05	20.81	-0.01
11/6/2014	8:06	20.81	-0.01
11/6/2014	8:07	20.83	-0.04
11/6/2014	8:08	20.19	-0.06
11/6/2014	8:09	20.81	-0.05
11/6/2014	8:10	20.84	-0.05
11/6/2014	8:11	20.84	-0.04
11/6/2014	8:12	20.83	-0.05
11/6/2014	8:13	20.82	-0.06
11/6/2014	8:14	20.8	-0.06
11/6/2014	8:15	20.8	-0.06
11/6/2014	8:16	20.82	-0.06
11/6/2014	8:17	20.84	-0.06
11/6/2014	8:18	20.84	-0.05
11/6/2014	8:19	20.85	-0.05
11/6/2014	8:20	20.85	-0.06
11/6/2014	8:21	20.83	-0.05
11/6/2014	8:22	20.75	-0.01
11/6/2014	8:23	20.68	0.02
11/6/2014	8:24	20.71	0.09
11/6/2014	8:25	20.77	-0.04
11/6/2014	8:26	20.77	-0.05
11/6/2014	8:27	20.78	-0.05
11/6/2014	8:28	20.78	-0.05
11/6/2014	8:29	20.78	-0.05
11/6/2014	8:30	20.77	-0.05
11/6/2014	8:31	20.77	-0.05
11/6/2014	8:32	20.78	-0.05
11/6/2014	8:33	20.77	-0.05
11/6/2014	8:34	20.78	-0.05
11/6/2014	8:35	20.78	-0.06
11/6/2014	8:36	20.78	-0.06
11/6/2014	8:37	20.77	-0.05
11/6/2014	8:38	20.78	-0.05
11/6/2014	8:39	20.77	-0.05
11/6/2014	8:40	20.77	-0.05
11/6/2014	8:41	20.77	-0.05
11/6/2014	8:42	20.77	-0.05
11/6/2014	8:43	20.77	-0.05
11/6/2014	8:44	20.77	-0.05
11/6/2014	8:45	20.77	-0.05
11/6/2014	8:46	20.77	-0.05
11/6/2014	8:47	20.78	-0.05
11/6/2014	8:48	20.77	-0.05
11/6/2014	8:49	20.77	-0.05
11/6/2014	8:50	20.77	-0.05
11/6/2014	8:51	20.78	-0.05
11/6/2014	8:52	20.77	-0.05
11/6/2014	8:53	18.53	-0.07
11/6/2014	8:54	17.62	-0.09
11/6/2014	8:55	17.58	-0.1
11/6/2014	8:56	17.51	-0.1
11/6/2014	8:57	17.51	-0.1
11/6/2014	8:58	17.52	-0.1
11/6/2014	8:59	17.49	-0.1

#1 #2 and #3 BSW 1 min avg.xls

Date	Time	O2	CO2
11/6/2014	9:00	17.48	-0.1
11/6/2014	9:01	17.48	-0.1
11/6/2014	9:02	17.5	-0.1
11/6/2014	9:03	17.49	-0.1
11/6/2014	9:04	17.59	-0.1
11/6/2014	9:05	17.62	-0.1
11/6/2014	9:06	17.59	-0.1
11/6/2014	9:07	17.57	-0.1
11/6/2014	9:08	17.49	-0.1
11/6/2014	9:09	17.49	-0.1
11/6/2014	9:10	17.5	-0.1
11/6/2014	9:11	17.5	-0.1
11/6/2014	9:12	17.43	-0.1
11/6/2014	9:13	17.42	-0.1
11/6/2014	9:14	17.39	-0.1
11/6/2014	9:15	17.36	-0.1
11/6/2014	9:16	17.38	-0.1
11/6/2014	9:17	17.54	-0.1
11/6/2014	9:18	17.7	-0.1
11/6/2014	9:19	17.6	-0.1
11/6/2014	9:20	17.67	-0.1
11/6/2014	9:21	17.72	-0.1
11/6/2014	9:22	17.74	-0.1
11/6/2014	9:23	17.63	-0.1
11/6/2014	9:24	17.47	-0.1
11/6/2014	9:25	17.4	-0.1
11/6/2014	9:26	17.37	-0.1
11/6/2014	9:27	17.47	-0.1
11/6/2014	9:28	17.56	-0.1
11/6/2014	9:29	17.73	-0.1
11/6/2014	9:30	17.85	-0.1
11/6/2014	9:31	17.87	-0.1
11/6/2014	9:32	17.91	-0.1
11/6/2014	9:33	17.86	-0.1
11/6/2014	9:34	17.82	-0.1
11/6/2014	9:35	17.79	-0.1
11/6/2014	9:36	17.76	-0.1
11/6/2014	9:37	17.76	-0.1
11/6/2014	9:38	17.71	-0.1
11/6/2014	9:39	17.69	-0.1
11/6/2014	9:40	17.73	-0.1
11/6/2014	9:41	17.76	-0.1
11/6/2014	9:42	17.71	-0.1
11/6/2014	9:43	17.81	-0.1
11/6/2014	9:44	17.85	-0.1
11/6/2014	9:45	17.78	-0.1
11/6/2014	9:46	17.66	-0.1
11/6/2014	9:47	17.62	-0.1
11/6/2014	9:48	17.55	-0.1
11/6/2014	9:49	17.54	-0.1
11/6/2014	9:50	17.51	-0.1
11/6/2014	9:51	17.54	-0.1
11/6/2014	9:52	17.67	-0.1
11/6/2014	9:53	17.68	-0.1
11/6/2014	9:54	17.78	-0.1
11/6/2014	9:55	17.91	-0.1
11/6/2014	9:56	17.93	-0.1
11/6/2014	9:57	18.02	-0.1
11/6/2014	9:58	17.96	-0.1
11/6/2014	9:59	18	-0.1
11/6/2014	10:00	17.94	-0.1
11/6/2014	10:01	17.94	-0.1
11/6/2014	10:02	17.84	-0.1
11/6/2014	10:03	17.89	-0.1
11/6/2014	10:04	17.82	-0.1
11/6/2014	10:05	17.81	-0.1
11/6/2014	10:06	17.73	-0.1

00066

#1 #2 and #3 BSW 1 min avgs.xls

Date	Time	O2	CO2
11/6/2014	10:07	17.75	-0.1
11/6/2014	10:08	17.73	-0.1
11/6/2014	10:09	17.72	-0.1
11/6/2014	10:10	17.68	-0.1
11/6/2014	10:11	17.75	-0.1
11/6/2014	10:12	17.7	-0.1
11/6/2014	10:13	17.67	-0.1
11/6/2014	10:14	17.63	-0.1
11/6/2014	10:15	17.54	-0.1
11/6/2014	10:16	17.52	-0.09
11/6/2014	10:17	17.5	-0.1
11/6/2014	10:18	17.59	-0.09
11/6/2014	10:19	17.52	-0.09
11/6/2014	10:20	17.54	-0.09
11/6/2014	10:21	17.51	-0.09
11/6/2014	10:22	17.45	-0.09
11/6/2014	10:23	17.51	-0.09
11/6/2014	10:24	17.45	-0.09
11/6/2014	10:25	17.48	-0.1
11/6/2014	10:26	17.54	-0.09
11/6/2014	10:27	17.55	-0.09
11/6/2014	10:28	17.59	-0.1
11/6/2014	10:29	17.49	-0.09
11/6/2014	10:30	17.43	-0.09
11/6/2014	10:31	17.5	-0.09
11/6/2014	10:32	17.49	-0.09
11/6/2014	10:33	17.57	-0.09
11/6/2014	10:34	17.55	-0.09
11/6/2014	10:35	17.56	-0.09
11/6/2014	10:36	17.58	-0.1
11/6/2014	10:37	17.4	-0.09
11/6/2014	10:38	17.49	-0.1
11/6/2014	10:39	17.66	-0.09
11/6/2014	10:40	17.59	-0.09
11/6/2014	10:41	17.63	-0.1
11/6/2014	10:42	17.6	-0.09
11/6/2014	10:43	17.66	-0.09
11/6/2014	10:44	17.56	-0.09
11/6/2014	10:45	17.61	-0.1
11/6/2014	10:46	17.49	-0.1
11/6/2014	10:47	17.51	-0.1
11/6/2014	10:48	17.58	-0.1
11/6/2014	10:49	17.68	-0.09
11/6/2014	10:50	17.64	-0.1
11/6/2014	10:51	17.66	-0.1
11/6/2014	10:52	17.69	-0.1
11/6/2014	10:53	17.6	-0.1
11/6/2014	10:54	17.61	-0.1
11/6/2014	10:55	17.55	-0.1
11/6/2014	10:56	17.5	-0.1
11/6/2014	10:57	17.57	-0.1
11/6/2014	10:58	17.61	-0.09
11/6/2014	10:59	17.62	-0.09
11/6/2014	11:00	17.7	-0.1
11/6/2014	11:01	17.65	-0.1
11/6/2014	11:02	17.67	-0.09
11/6/2014	11:03	17.65	-0.1
11/6/2014	11:04	17.61	-0.1
11/6/2014	11:05	17.61	-0.09
11/6/2014	11:06	17.52	-0.1
11/6/2014	11:07	17.54	-0.09
11/6/2014	11:08	17.5	-0.09
11/6/2014	11:09	17.54	-0.09
11/6/2014	11:10	17.5	-0.09
11/6/2014	11:11	17.61	-0.1
11/6/2014	11:12	17.59	-0.09
11/6/2014	11:13	17.59	-0.1

00067

#1 #2 and #3 BSW 1 min avgs.xls

Date	Time	O2	CO2
11/6/2014	11:14	17.53	-0.1
11/6/2014	11:15	17.55	-0.09
11/6/2014	11:16	17.53	-0.09
11/6/2014	11:17	17.62	-0.09
11/6/2014	11:18	17.6	-0.1
11/6/2014	11:19	17.58	-0.09
11/6/2014	11:20	17.56	-0.09
11/6/2014	11:21	17.6	-0.09
11/6/2014	11:22	17.51	-0.09
11/6/2014	11:23	17.52	-0.09
11/6/2014	11:24	17.52	-0.1
11/6/2014	11:25	17.48	-0.1
11/6/2014	11:26	17.47	-0.09
11/6/2014	11:27	17.49	-0.09
11/6/2014	11:28	17.53	-0.09
11/6/2014	11:29	17.63	-0.1
11/6/2014	11:30	17.64	-0.09
11/6/2014	11:31	17.67	-0.09
11/6/2014	11:32	17.63	-0.09
11/6/2014	11:33	17.69	-0.1
11/6/2014	11:34	17.63	-0.09
11/6/2014	11:35	17.5	-0.09
11/6/2014	11:36	17.38	-0.1
11/6/2014	11:37	17.39	-0.09
11/6/2014	11:38	17.47	-0.09
11/6/2014	11:39	17.35	-0.09
11/6/2014	11:40	17.77	-0.09
11/6/2014	11:41	17.77	-0.09
11/6/2014	11:42	17.86	-0.09
11/6/2014	11:43	17.42	-0.09
11/6/2014	11:44	17.45	-0.09
11/6/2014	11:45	17.8	-0.09
11/6/2014	11:46	17.75	-0.08
11/6/2014	11:47	17.59	-0.09
11/6/2014	11:48	17.52	-0.09
11/6/2014	11:49	17.51	-0.09
11/6/2014	11:50	17.59	-0.09
11/6/2014	11:51	17.64	-0.09
11/6/2014	11:52	17.74	-0.1
11/6/2014	11:53	17.77	-0.09
11/6/2014	11:54	17.72	-0.08
11/6/2014	11:55	17.81	-0.09
11/6/2014	11:56	18.06	-0.09
11/6/2014	11:57	17.62	-0.09
11/6/2014	11:58	17.59	-0.09
11/6/2014	11:59	17.75	-0.09
11/6/2014	12:00	17.58	-0.09
11/6/2014	12:01	17.45	-0.09
11/6/2014	12:02	17.61	-0.09
11/6/2014	12:03	17.6	-0.09
11/6/2014	12:04	17.5	-0.09
11/6/2014	12:05	17.43	-0.09
11/6/2014	12:06	17.51	-0.09
11/6/2014	12:07	17.42	-0.09
11/6/2014	12:08	17.41	-0.09
11/6/2014	12:09	17.45	-0.09
11/6/2014	12:10	17.59	-0.09
11/6/2014	12:11	17.93	-0.09
11/6/2014	12:12	17.91	-0.09
11/6/2014	12:13	18.01	-0.09
11/6/2014	12:14	17.74	-0.09
11/6/2014	12:15	17.9	-0.09
11/6/2014	12:16	17.83	-0.09
11/6/2014	12:17	17.75	-0.09
11/6/2014	12:18	17.84	-0.09
11/6/2014	12:19	17.68	-0.09
11/6/2014	12:20	17.72	-0.09

#1 #2 and #3 BSW 1 min avgs.xls

Date	Time	O2	CO2
11/6/2014	12:21	17.75	-0.09
11/6/2014	12:22	17.71	-0.09
11/6/2014	12:23	17.51	-0.09
11/6/2014	12:24	17.61	-0.09
11/6/2014	12:25	17.59	-0.09
11/6/2014	12:26	17.5	-0.09
11/6/2014	12:27	17.51	-0.1
11/6/2014	12:28	17.57	-0.09
11/6/2014	12:29	17.5	-0.09
11/6/2014	12:30	17.58	-0.09
11/6/2014	12:31	17.61	-0.09
11/6/2014	12:32	17.65	-0.09
11/6/2014	12:33	17.75	-0.09
11/6/2014	12:34	17.64	-0.1
11/6/2014	12:35	17.59	-0.1
11/6/2014	12:36	17.56	-0.1
11/6/2014	12:37	17.96	-0.1
11/6/2014	12:38	17.72	-0.1
11/6/2014	12:39	17.66	-0.1
11/6/2014	12:40	17.69	-0.1
11/6/2014	12:41	17.76	-0.1
11/6/2014	12:42	17.98	-0.09
11/6/2014	12:43	17.74	-0.09
11/6/2014	12:44	17.82	-0.09
11/6/2014	12:45	17.78	-0.09
11/6/2014	12:46	17.98	-0.1
11/6/2014	12:47	17.8	-0.1
11/6/2014	12:48	17.69	-0.09
11/6/2014	12:49	17.83	-0.1
11/6/2014	12:50	17.74	-0.09
11/6/2014	12:51	17.77	-0.09
11/6/2014	12:52	17.83	-0.1
11/6/2014	12:53	18.14	-0.08
11/6/2014	12:54	17.67	-0.09
11/6/2014	12:55	17.54	-0.1
11/6/2014	12:56	17.88	-0.09
11/6/2014	12:57	1.38	-0.06
11/6/2014	12:58	-0.1	-0.09
11/6/2014	12:59	-0.12	-0.09
11/6/2014	13:00	-0.12	-0.09
11/6/2014	13:01	1.95	-0.04
11/6/2014	13:02	1.67	1.61
11/6/2014	13:03	6.35	2.26
11/6/2014	13:04	21.02	2.27
11/6/2014	13:05	20.96	2.22
11/6/2014	13:06	20.92	0.68
11/6/2014	13:07	20.91	-0.01

00069

GP BSW #1, #2 and #3 MeOH Testing
QA/QC Spikes

→ Bottle Z0 - Blank

Lab result: 1502 L

→ Bottle Z1 - ~~Low~~ Low Spike


50 μL \times 15,000 μg/mL = 750 μg

Lab result = 835 μg

→ Bottle Z2 - High Spike

300 μL \times 15,000 μg/mL = 4500 μg

Lab result = 4940 μg



Atmospheric Analysis & Consulting, Inc.

Client : Bighorn Environmental
Client Project Name : GP-Toledo 2014 BSW testing
Client Project Number : NA
AAC Project Number : 141814
Reporting Date : 11/21/2014

On November 19, 2014, Atmospheric Analysis & Consulting, Inc. received fifteen (15) liquid samples for Methanol Analysis by NCASI Method 94.02. Upon receipt the samples were assigned unique Laboratory ID numbers as follows:

Client Sample ID	AAC Sample ID	Client Sample ID	AAC Sample ID
BSW #2 Combined Vent Run 1	141814-75802	#1 Vacumn Pump Run 3	141814-75810
BSW #2 Combined Vent Run 2	141814-75803	#1 Foam Breaker Run 1	141814-75811
BSW #2 Combined Vent Run 3	141814-75804	#1 Foam Breaker Run 2	141814-75812
BSW #3 Combined Vent Run 1	141814-75805	#1 Foam Breaker Run 3	141814-75813
BSW #3 Combined Vent Run 2	141814-75806	Blank	141814-75814
BSW #3 Combined Vent Run 3	141814-75807	High Spike	141814-75815
#1 Vacumn Pump Run 1	141814-75808	Low Spike	141814-75816
#1 Vacumn Pump Run 2	141814-75809		

NCASI Method 94.02 – A portion of each of the liquid samples was transferred to a GC vial and spiked with internal standard, and was then analyzed on a GC/FID. Holding times for preparation and analysis were complied with.

No problems were encountered during receiving, preparation, and/or analysis of these samples. The test results included in this report meet all requirements of the NELAC Standards and/or AAC SOP# N.94.02.02.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. Release of the data contained in this hardcopy data package has been authorized by the Laboratory Director or his designee, as verified by the following signature. If you have any questions or require further explanation of data results, please contact the undersigned.


Marcus Hueppe
Laboratory Director

This report consists of 7 pages.



Page 1





Atmospheric Analysis & Consulting, Inc.

Laboratory Analysis Report

Client

Client Project Name : Bighorn Environmental
AAC Project No. : GP-Toledo 2014 BSW testing
Analyst : 141814
: EG

Sampling Date : 11/05/06/2014
Receiving Date : 11/19/2014
Analysis Date : 11/20/2014
Reporting Date : 11/21/2014

Methanol Analysis by NCASI Method 94.02


Client Sample ID	AAC Sample ID	Sample Volume (mL)	Methanol (ug/mL)	Methanol (ug/sample)	SRL (ug/sample)	Internal Standard (Cyclohexanol) % Recovery
BSW #2 Combined Vent Run 1	141814-75802	26.0	144	3740	13.0	97.9
BSW #2 Combined Vent Run 2	141814-75803	30.2	97.3	2940	15.1	101
BSW #2 Combined Vent Run 3	141814-75804	19.0	90.4	1720	9.50	99.6
BSW #3 Combined Vent Run 1	141814-75805	20.2	397	8020	10.1	98.7
BSW #3 Combined Vent Run 2	141814-75806	29.8	316	9420	14.9	100
BSW #3 Combined Vent Run 3	141814-75807	31.0	276	8550	15.5	100
#1 Vacuum Pump Run 1	141814-75808	23.3	40.8	950	11.7	101
#1 Vacuum Pump Run 2	141814-75809	22.7	40.8	925	11.4	101
#1 Vacuum Pump Run 3	141814-75810	25.0	40.9	1020	12.5	98.6
#1 Foam Breaker Run 1	141814-75811	23.5	386	9070	11.8	106
#1 Foam Breaker Run 2	141814-75812	41.2	372	15300	20.6	104
#1 Foam Breaker Run 3	141814-75813	29.2	271	7910	14.6	105
Blank	141814-75814	40.5	<SRL	<SRL	20.3	108
High Spike	141814-75815	41.0	121	4940	20.5	98.9
Low Spike	141814-75816	40.5	20.6	835	20.3	99.4

MRL - Method Reporting Limit = 0.500 ug/mL

SRL - Sampling Reporting Limit (ug/sample) = MRL (0.500 ug/mL) x Sample Volume (mL) x Analysis Dilution Factor

<SRL - Analyte was analyzed for but not detected at or above the SRL

00072



Atmospheric Analysis & Consulting, Inc.

Laboratory Analysis Report

Methanol Analysis by NCASI Method 04 02

Client : Bighorn Environmental
Client Project Name : GP-Toledo 2014 BSW testing
AAC Project No. : 141814
Analyst : EG

Sampling Date : 11/05/2014
Receiving Date : 11/19/2014
Analysis Date : 11/20/2014
Reporting Date : 11/21/2014

Spiking Solution Evaluation

Client Sample ID	Sample Volume (mL)	Analyte	Measured Concentration (ug/sample)	Target Concentration (ug/sample)	Internal Standard % Recovery	% Recovery
High Spike	41.0	Methanol	4940	4740	108	104
Low Spike	40.5	Methanol	835	790	98.9	106
Client Sample ID	Sample Volume (mL)	Analyte	Measured Concentration (ug/ml)	Target Concentration (ug/ml)	Internal Standard % Recovery	% Recovery
Lab Spiking Solution (retained at Lab and analyzed with samples)	23.0	Methanol	15700	NA	10413	NA
Field Spiking Solution (went to field and back with samples)	23.0	Methanol	15800	15700	10739	101

<SRL - Analyte was analyzed for but not detected at or above the SRL


Internal Standard recovery should be between 80-120%

The target concentration for the Spikes is based on the measured Field Spiking Solution concentration x the spiked amount



Marcus Heuppe
Laboratory Director





Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report

NCASI Method 94.02

FID Calibration Verification of the 9/18/2014 Calibration

Analysis Date : 11/20/2014
Analyst : EG

Instrument ID : GC 6890 #1

Sample ID	Analyte	Target Concentration (ug/mL)	Measured Concentration (ug/mL)	Percent Recovery (%)*
Opening CV	Methanol	500	475	95.0
	Cyclohexanol (IS)	20.0	19.4	96.9
Continuing CV	Methanol	500	502	100
	Cyclohexanol (IS)	20.0	19.9	99.4
Continuing CV	Methanol	500	527	105
	Cyclohexanol (IS)	20.0	20.2	101
Closing CV	Methanol	500	504	101
	Cyclohexanol (IS)	20.0	20.7	104
Second Source	Methanol	500	503	101
	Cyclohexanol (IS)	20.0	20.7	103


* Must be 85 - 115 %

IS - Internal Standard



Marcus Hueppe
Laboratory Director





Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report NCASI Method 94.02

Analysis Date : 11/20/2014

Analyst : EG
Instrument ID : GC 6890 #1

Laboratory Control Spike Analysis

Analyte	Sample Concentration (ug/mL)	Spike Concentration (ug/mL)	Measured Spike Concentration (ug/mL)	Measured Spike Dup Concentration (ug/mL)	Spike Recovery (%)*	Spike Dup Recovery (%)*	%RPD**
Methanol	0.000	250	254	256	102	102	0.7
Cyclohexanol (IS)	0.000	20.0	19.5	19.8	97.3	99	1.9

* Must be 85-115%

** Must be $\leq 25\%$

Matrix Spike Analysis (141802-75804)


Analyte	Sample Concentration (ug/mL)	Spike Concentration (ug/mL)	Measured Spike Concentration (ug/mL)	Measured Spike Dup Concentration (ug/mL)	Spike Recovery (%)*	Spike Dup Recovery (%)*	%RPD**
Methanol	44.9	250	304	301	104	102	1.0
Cyclohexanol (IS)	0.000	20.0	19.9	19.3	99.4	96.3	3.2

* Must be 75-125%

** Must be $\leq 25\%$

Marcus Hueppe
Laboratory Director

00075



Atmospheric Analysis & Consulting, Inc.

Quality Control/Quality Assurance Report NCASI Method 94.02

Analysis Date : 11/20/2014
Analyst : EG

Instrument ID : GC 6890 #1

Duplicate Analysis

Sample ID	Analyte	Sample Concentration (ug/mL)	Duplicate Concentration (ug/mL)	%RPD*
141802-75804	Methanol	90.4	89.3	1.2
	Cyclohexanol (IS)	19.9	20.6	3.4
141802-75803	Methanol	97.3	98.3	1.0
	Cyclohexanol (IS)	20.1	19.4	3.6
141802-75812	Methanol	372	374	0.5
	Cyclohexanol (IS)	20.7	20.4	1.9

* Must be $\leq 15\%$

Method Blank Analysis

Sample ID	Analyte	Concentration (ug/mL)	RL / SRL (ug/mL)
Method Blank	Methanol	<RL	0.500
Internal Standard (IS)	Target Concentration (ug/mL)	Measured Conc. (ug/mL)	% Recovery
Cyclohexanol (IS)	20.0	19.9	99.5

RL - Reporting Limit

SRL - Sample Reporting Limit


Marcus Hueppe
Laboratory Director



ATMOSPHERIC ANALYSIS & CONSULTING, INC.
 1534 Eastman Avenue, Suite A
 Ventura, California 93003
 Phone (805) 650-1642 Fax (805) 650-1644
 E-mail: Info@aaclab.com

AAC Project No. 141814 Page 1 of 1



CHAIN OF CUSTODY / ANALYSIS REQUEST FORM

Client Name GP-Toledo		Project Name 2014 BSW testing		Analysis Requested				Send report: Tim Homer	
Project Mgr (Print Name) Tim Homer		Project Number							
Sampler's Name (Print Name) Tim Homer		Sampler's Signature							
AAC Sample No.	Date Sampled	Time Sampled	Sample Type	Client Sample ID/Description	Type/No. of Containers	NCASI CR-94.02 (Med)		Attn:	Phone#: Fax#
BSW #2 Combined Vent	Run 2	"	Liq	75802		X			
BSW #2 Combined Vent	Run 3	"		75803		X			
BSW #3 Combined Vent	Run 1	"		75804		X			
BSW #3 Combined Vent	Run 2	"		75805		X			
#1 Vacuum Pump	Run 3	"		75806		X			
#1 Vacuum Pump	Run 1	"		75807		X			
#1 Vacuum Pump	Run 2	"		75808		X			
#1 Vacuum Pump	Run 3	"		75809		X			
#1 Foam Breaker	Run 1	"		75810		X			
#1 Foam Breaker	Run 2	"		75811		X			
#1 Foam Breaker	Run 3	"		75812		X			
#1 Foam Breaker				75813		X			
Relinquished by (Signature): <i>Tim Homer</i>		Print Name: Tim Homer		Date/Time 11/15 13:00	Received by (signature):		Print Name		
Relinquished by (Signature): <i>Tony Dickey</i>		Print Name: Tony Dickey		Date/Time 11/14 14:20	Received by (signature):		Print Name		

00077

FedEx 7.6°C

APPENDIX B CALCULATIONS

CALCULATIONS

FLOW RATES:

$$A = \text{Vent pipe cross-sectional area (ft}^2) = \pi r^2$$

P_{bar} = Barometric pressure at measurement site (in Hg)

P_g = Stack static pressure (in Hg) = in. H₂O ÷ 13.6 in H₂O/in. Hg

P_s = Absolute stack gas pressure (in. Hg) = $P_{\text{bar}} + P_g$

t_d = Temperature dry bulb (°F)

t_w = Temperature wet bulb (°F)

e'' = Stack vapor pressure (in. Hg)

$$= (0.00000608746 \times t_w^3) - (0.00100431 \times t_w^2) + (0.0756026 \times t_w) - 1.69343$$

$$\%H_2O = [e'' - (P_s - e'') \times (t_d - t_w)] \div (2800 - (1.3 \times t_w)) \div P_s \times 100$$

$$MD = \text{Molecular Density} = (100 - \%H_2O) \div 100$$

M_d = Molecular weight of dry stack gas (lb/lb-mole)

$$= (%CO_2 \times 0.44) + (%O_2 \times 0.32) + [(%CO + %N_2) \times 0.28]$$

M_s = Molecular weight of wet stack gas (lb/lb-mole)

$$= M_d \times (MD) + 18 \text{lb/lb-mole} \times (1-MD)$$

C_p = Pitot tube coefficient

$(\sqrt{\Delta p})_{\text{avg}}$ = Average square root velocity head of stack gas (in. H₂O)

$$T_s = \text{Absolute stack temperature (°R)} = 460 + t_d$$

V_s = Average stack gas velocity (ft³/min.)

$$= 85.49 \text{ ft/sec} \times 60 \text{ sec/min} \times C_p \times (\sqrt{\Delta p})_{\text{avg}} \times \sqrt{T_s \times (P_s \times M_s)}$$

Q_{sd} = Stack gas dry molecular flow rate corrected to standard conditions

$$(\text{dscfm}) = MD \times V_s \times A \times (528^\circ R \div T_s) \times (P_s \div 29.92" \text{ Hg})$$

Q_{ac} = Stack gas flow rate at actual conditions (acf m) = $V_s \times A$

EMISSION RATES:

ODT = Oven Dry Tons of pulp production

$$\frac{\text{lb MeOH}}{\text{hour}} = \left(C_{\text{gas}} \div 1,000,000 \right) \times \left(1 \text{lb-mole} \div 385 \text{ft}^3 \right) \times 32.04 \text{ lb MeOH/lb-mole} \times Q_{\text{sd}} \times 60 \text{min/hr}$$

$$\frac{\text{lb MeOH}}{\text{ODT}} = \frac{\text{lb MeOH}}{\text{hour}} \div \frac{\text{ODT}}{\text{hour}}$$

COMPLIANCE TEST - MANUAL CALCULATIONS SHEET

CLIENT: GP-Toledo
 PROJECT: #1 BSW Foam Breaker
 RUN TIME CHECKED: 9:00-10:10
 DATE: 11/6/14
 CHECKED BY: WV

FLOW RATES: 40CFR 60 APP. A, Method 2

$$r = \text{Stack radius (ft)} = (\text{diameter (in.)} \div 12) \div 2 = \underline{15.75} \quad - .6563$$

$$A = \text{Stack cross-sectional area (ft}^2\text{)} = \pi r^2 = 3.14159 \times (\underline{.6563})^2 = \underline{1.353}$$

$$P_{\text{bar}} = \text{Barometric pressure at measurement site (in Hg)} = \underline{29.81}$$

$$P_g = \text{Stack static pressure (in Hg)} = \text{in. H}_2\text{O} \div 13.6 \text{ in H}_2\text{O/in. Hg} = \frac{\underline{7.06}}{13.6} = \underline{.526}$$

$$P_s = \text{Absolute stack gas pressure (in. Hg)} = P_{\text{bar}} + P_g = \underline{29.81} + \underline{.526} = \underline{29.806}$$

$$t_d = \text{Temperature dry bulb (}^{\circ}\text{F)} = \underline{115}$$

$$t_w = \text{Temperature wet bulb (}^{\circ}\text{F)} = \underline{115}$$

e'' = Stack vapor pressure (in. Hg)

$$\begin{aligned} &= (0.00000608746 \times t_w^3) - (0.00100431 \times t_w^2) + (0.0756026 \times t_w) - 1.69343 \\ &= (0.00000608746 \times \underline{115}^3) - (0.00100431 \times \underline{115}^2) + (0.0756026 \times \underline{115}) - 1.69343 = \underline{2.977} \\ &\qquad\qquad\qquad \underline{9.259} \qquad\qquad\qquad \underline{13.242} \qquad\qquad\qquad \underline{0.694} \end{aligned}$$

$$\%H_2O = e'' - [(P_s - e'') \times (t_d - t_w)] \div (2800 - (1.3 \times t_w)) \div P_s \times 100 \\ = \frac{\underline{2.977} - [(\underline{29.806} - \underline{2.977}) \times (\underline{115} - \underline{115})]}{(2800 - (1.3 \times \underline{115}))} \div \underline{29.806} \times 100 = \underline{9.99}$$

$$MD = \text{Molecular Density} = (100 - \%H_2O) \div 100 = \frac{\underline{100} - \underline{9.99}}{100} = \underline{9.001}$$

$$(\%CO + \%N_2) = 100 - \%CO_2 - \%O_2 = 100 - (\underline{17.7}) - (\underline{0}) = \underline{82.3}$$

$$M_d = \text{Molecular weight of dry stack gas (lb/lb-mole)} = (%CO_2 \times 0.44) + (%O_2 \times 0.32) + [(%CO + \%N_2) \times 0.28] \\ = (\underline{0} \times 0.44) + (\underline{17.7} \times 0.32) + ((\underline{82.3}) \times 0.28) = \underline{24.705}$$

$$M_s = \text{Molecular weight of wet stack gas (lb/lb-mole)} = M_d \times (MD) + (18 \text{ lb/lb-mole} \times (1-MD))$$

$$= \underline{23,701} \times (\underline{.901}) + (18 \text{ lb/lb-mole} \times (1 - \underline{.901})) = \underline{27,638}$$

C_p = Pitot tube coefficient = .84

$(\sqrt{\Delta p})_{avg}$ = Average square root velocity head of stack gas (in. H₂O) = .4462

T_s = Absolute stack temperature (°R) = 460 + t_d = 460 + 115 = 575

V_s = Average stack gas velocity (ft²/min.)

$$= 85.49 \text{ ft/sec} \times 60 \text{ sec/min} \times C_p \times (\sqrt{\Delta p})_{avg} \times \sqrt{T_s \div (P_s \times M_s)} \\ = (85.49) \times (60) \times (\underline{.84}) \times (\underline{.4462}) \times \sqrt{\frac{575}{(27,638 \times 29.806)}} = \underline{1606.2}$$

$$Q_{sd} = \text{Dry stack gas flow rate at standard conditions} = MD \times V_s \times A \times (528^{\circ}\text{R} \div T_s) \times (P_s \div 29.92 \text{ in. Hg}) \\ = \underline{1,901} \times \underline{1606.2} \times \underline{1.353} \times \underline{(528^{\circ}\text{R})} \times \underline{(29.806)} = \underline{1789.4} \\ (575) \times (29.92)$$

$$Q = \text{Stack gas flow rate at actual conditions (acf m)} = V_s \times A = (\underline{1606.2}) \times (\underline{1.353}) = \underline{2173.2}$$

Combined Stack Flow = _____ + _____ + _____ + _____ = _____

EMISSIONS:

Molecular Weight (MW) = lb
 lb mole

MeOH = 32.04

$$\frac{\text{lb Pollutant}}{\text{hour}} = (C_{gas} \div 1,000,000) \times (1 \text{ lb-mole} \div 385 \text{ ft}^3) \times \text{MW} \times Q_{sd} \times 60 \text{ min/hr} \\ = \frac{(\underline{278.36}) \times (\underline{32.04})}{1,000,000} \times (1) \times (\underline{1789.4}) \times (60) = \underline{2.486}$$

$$\frac{\text{lb Pollutant}}{\text{ODTP}} = \frac{\text{lb Pollutant}}{\text{hour}} \div \frac{\text{ODTP}}{\text{hour}} \\ = \frac{(\underline{2.486})}{(\underline{1606.2})} = \underline{1.5416}$$

$$\text{Meter Vol (dscl)} = \text{Meter vol} * ((273+20)/(273+\text{Meter temp}) * \text{Meter Y} * (\text{Meter Pressure}/29.92)) = \\ 23.492 \times 1.006 \times \frac{293}{283.2} \times \frac{29.81}{29.62} = 24.4448$$

$$\text{MeOH ppm} = \frac{\text{ug/sample}}{\text{MeOH MW}} \times \frac{24.04}{\text{Meter Vol (dscl)}} = \frac{9070}{37.04} \times \frac{24.04}{24.4448} = 278.36$$

COMPLIANCE TEST - MANUAL CALCULATIONS SHEET

CLIENT: (SD-T) Toledo
 PROJECT: #1 BSW Vacuum Pump
 RUN TIME CHECKED: 910-1010
 DATE: 11/6/14
 CHECKED BY: TP

FLOW RATES: 40CFR 60 APP. A, Method 2

$$r = \text{Stack radius (ft)} = (\text{diameter (in.)} \div 12) \div 2 = \underline{10} = \underline{4.167}$$

$$A = \text{Stack cross-sectional area (ft}^2\text{)} = \pi r^2 = 3.14159 \times (\underline{4.167})^2 = \underline{54.54}$$

$$P_{\text{bar}} = \text{Barometric pressure at measurement site (in Hg)} = \underline{29.81}$$

$$P_g = \text{Stack static pressure (in Hg)} = \text{in. H}_2\text{O} \div 13.6 \text{ in H}_2\text{O/in. Hg} = (\underline{0}) \div \frac{13.6}{13.6} = \underline{0}$$

$$P_s = \text{Absolute stack gas pressure (in. Hg)} = P_{\text{bar}} + P_g = \underline{29.81} + \underline{0} = \underline{29.81}$$

$$t_d = \text{Temperature dry bulb (}^{\circ}\text{F)} = \underline{101.3}$$

$$t_w = \text{Temperature wet bulb (}^{\circ}\text{F)} = \underline{97.7}$$

$$e'' = \text{Stack vapor pressure (in. Hg)}$$

$$\begin{aligned} &= (0.00000608746 \times t_w^3) - (0.00100431 \times t_w^2) + (0.0756026 \times t_w) - 1.69343 \\ &= (0.00000608746 \times \underline{97.7}^3) - (0.00100431 \times \underline{97.7}^2) + (0.0756026 \times \underline{97.7}) - 1.69343 = \underline{1.784} \\ &\quad \underline{5.677} \qquad \underline{9.586} \qquad \underline{7.386} \end{aligned}$$

$$\begin{aligned} \%H_2O &= e'' - [(P_s - e'') \times (t_d - t_w)] \div (2800 - (1.3 \times t_w)) \div P_s \times 100 \\ &= \frac{\underline{1.784} - [(\underline{29.81} - \underline{1.784}) \times (\underline{101.3} - \underline{97.7})]}{(2800 - (1.3 \times \underline{97.7}))} \times 100 = \underline{5.961} \end{aligned}$$

$$MD = \text{Molecular Density} = (100 - \%H_2O) \div 100 = \frac{(100 - \underline{5.961})}{100} = \underline{94.139}$$

$$(\%CO + \%N_2) = 100 - \%CO_2 - \%O_2 = 100 - (\underline{17.0}) - (\underline{0}) = \underline{82.3}$$

$$\begin{aligned} M_d &= \text{Molecular weight of dry stack gas (lb/lb-mole)} = (%CO_2 \times 0.44) + (%O_2 \times 0.32) + [(%CO + \%N_2) \times 0.28] \\ &= (\underline{0} \times 0.44) + (\underline{17.0} \times 0.32) + ((\underline{82.3}) \times 0.28) = \underline{29.704} \end{aligned}$$

$$M_s = \text{Molecular weight of wet stack gas (lb/lb-mole)} = M_d \times (MD) + (18 \text{ lb/lb-mole} \times (1-MD))$$

$$= \underline{.94139} \times (\underline{28.702}) + (18 \text{ lb/lb-mole} \times (1 - \underline{.94139})) = \underline{28.082}$$

C_p = Pitot tube coefficient = , 84

$(\sqrt{\Delta p})_{avg}$ = Average square root velocity head of stack gas (in. H₂O) = , 4833

T_s = Absolute stack temperature (°R) = $460 + t_d = 460 + \underline{1913} = \underline{5613}$

V_s = Average stack gas velocity (ft²/min.)

$$\begin{aligned} &= 85.49 \text{ ft/sec} \times 60 \text{ sec/min} \times C_p \times (\sqrt{\Delta p})_{avg} \times \sqrt{T_s \div (P_s \times M_s)} \\ &= (85.49) \times (60) \times (\underline{.84}) \times (\underline{.4833}) \times \sqrt{\frac{5613}{(28.082 \times 29.92)}} = \underline{3116.4} \end{aligned}$$

$$\begin{aligned} Q_{sd} &= \text{Dry stack gas flow rate at standard conditions} = MD \times V_s \times A \times (528^\circ R \div T_s) \times (P_s \div 29.92 \text{ in. Hg}) \\ &= \underline{.64139} \times \underline{.5454} \times \underline{3116.4} \times \frac{(528^\circ R)}{(29.92)} \times \frac{(\underline{29.92})}{(561.3) \times (29.92)} = \underline{1499.6} \end{aligned}$$

$$Q = \text{Stack gas flow rate at actual conditions (acf m)} = V_s \times A = \underline{3116.4} \times \underline{.5454} = \underline{1699.7}$$

Combined Stack Flow = _____ + _____ + _____ + _____ = _____

EMISSIONS:

Molecular Weight (MW) = lb
 lb mole

MeOH = 32.04

$$\begin{aligned} \text{lb Pollutant} &= (C_{gas} \div 1,000,000) \times (1 \text{ lb-mole} \div 385 \text{ ft}^3) \times \text{MW} \times Q_{sd} \times 60 \text{ min/hr} \\ &= \frac{(\underline{.28.41}) \times (\underline{32.04}) \times (\underline{1})}{1,000,000} \times \frac{(\underline{1499.6}) \times (60)}{385} = \underline{.2164} \end{aligned}$$

$$\begin{aligned} \frac{\text{lb Pollutant}}{\text{ODTP}} &= \frac{\text{lb Pollutant}}{\text{hour}} \div \frac{\text{ODTP}}{\text{hour}} \\ &= \frac{(\underline{.2164})}{(\underline{1600})} = \underline{.135} \end{aligned}$$

Meter Vol (dscl) = Meter vol * ((273+20)/(273+Meter temp)* Meter Y* (Meter Pressure/29.92)) = _____

$$24.029 \times 1.006 \times \frac{29.92}{28.62} \times \frac{29.91}{29.92} = 24.657$$

$$\frac{950}{32.04} \times \frac{24.04}{24.657} = 28.91$$

COMPLIANCE TEST - MANUAL CALCULATIONS SHEET

CLIENT: GP-Toledo
 PROJECT: #2 BSW
 RUN TIME CHECKED: 1400-1500
 DATE: 11/5/14
 CHECKED BY: gj

FLOW RATES: 40CFR 60 APP. A, Method 2

$$r = \text{Stack radius (ft)} = (\text{diameter (in.)} \div 12) \div 2 = \underline{16}$$

$$A = \text{Stack cross-sectional area (ft}^2) = \pi r^2 = 3.14159 \times (\underline{16})^2 = \underline{1.396}$$

$$P_{\text{bar}} = \text{Barometric pressure at measurement site (in Hg)} = \underline{29.76}$$

$$P_g = \text{Stack static pressure (in Hg)} = \text{in. H}_2\text{O} \div 13.6 \text{ in H}_2\text{O/in. Hg} = (\underline{1.74}) = \frac{.0544}{13.6}$$

$$P_s = \text{Absolute stack gas pressure (in. Hg)} = P_{\text{bar}} + P_g = \underline{29.76} + \underline{.0544} = \underline{29.7056}$$

$$t_d = \text{Temperature dry bulb (}^{\circ}\text{F)} = \underline{130.1}$$

$$t_w = \text{Temperature wet bulb (}^{\circ}\text{F)} = \underline{125.6}$$

$$e'' = \text{Stack vapor pressure (in. Hg)}$$

$$= (0.00000608746 \times t_w^3) - (0.00100431 \times t_w^2) + (0.0756026 \times t_w) - 1.69343$$

$$= (0.00000608746 \times \underline{125.6}^3) - (0.00100431 \times \underline{125.6}^2) + (0.0756026 \times \underline{125.6}) - 1.69343 = \underline{4.022}$$

$$\underline{12.062} \quad \underline{15.843} \quad \underline{9.496}$$

$$\%H_2O = e'' - [(P_s - e'') \times (t_d - t_w)] \div (2800 - (1.3 \times t_w)) \div P_s \times 100$$

$$= \frac{\underline{4.022} - [(\underline{29.7056} - \underline{4.022}) \times (\underline{130.1} - \underline{125.6})]}{(2800 - (1.3 \times \underline{125.6}))} \div \underline{29.7056} \times 100 = \underline{13.389}$$

$$MD = \text{Molecular Density} = (100 - \%H_2O) \div 100 = \frac{(100 - \underline{13.389})}{100} = \underline{86.611}$$

$$(\%CO + \%N_2) = 100 - \%CO_2 - \%O_2 = 100 - (\underline{14.49}) - (\underline{12}) \approx \underline{80.51}$$

$$M_d = \text{Molecular weight of dry stack gas (lb/lb-mole)} = (%CO_2 \times 0.44) + (%O_2 \times 0.32) + [(%CO + \%N_2) \times 0.28]$$

$$= (\underline{12} \times 0.44) + (\underline{14.49} \times 0.32) + ((\underline{80.51}) \times 0.28) = \underline{24.777}$$

$$M_s = \text{Molecular weight of wet stack gas (lb/lb-mole)} = M_d \times (MD) + (18 \text{ lb/lb-mole} \times (1-MD))$$

$$= \underline{23,777} \times (\underline{.06611}) + (18 \text{ lb/lb-mole} \times (1 - \underline{.06611})) = \underline{27,336}$$

C_p = Pitot tube coefficient = .84

$(\sqrt{\Delta p})_{avg}$ = Average square root velocity head of stack gas (in. H₂O) = .6437

T_s = Absolute stack temperature (°R) = $460 + t_d = 460 + \underline{130.1} = \underline{590.1}$

V_s = Average stack gas velocity (ft²/min.)

$$= 85.49 \text{ ft/sec} \times 60 \text{ sec/min} \times C_p \times (\sqrt{\Delta p})_{avg} \times \sqrt{T_s \div (P_s \times M_s)}$$

$$= (85.49) \times (60) \times (\underline{.84}) \times (\underline{.6437}) \times \sqrt{\frac{\underline{590.1}}{(27,336 \times 29.7056)}} = \underline{2364.3}$$

$$Q_{sd} = \text{Dry stack gas flow rate at standard conditions} = MD \times V_s \times A \times (528^{\circ}\text{R} \div T_s) \times (P_s \div 29.92^{\prime\prime} \text{ Hg})$$

$$= \underline{.06611} \times \underline{1,396} \times \underline{2364.3} \times \frac{(528^{\circ}\text{R})}{(\underline{590.1})} \times \frac{(29,7056)}{(29.92)} = \underline{2539.5}$$

$$Q = \text{Stack gas flow rate at actual conditions (acf m)} = V_s \times A = \underline{2364.3} \times \underline{1,396} = \underline{3300.6}$$

Combined Stack Flow = _____ + _____ + _____ + _____ = _____

EMISSIONS:

Molecular Weight (MW) = $\frac{\text{lb}}{\text{lb mole}}$

MeOH = 32.04

lb Pollutant = $(C_{gas} \div 1,000,000) \times (1 \text{ lb-mole} \div 385 \text{ ft}^3) \times \text{MW} \times Q_{sd} \times 60 \text{ min/hr}$

$$\text{hour} \\ = \frac{(\underline{118,150})}{1,000,000} \times \frac{(\underline{32.04})}{385} \times (\underline{1}) \times (\underline{2539.5}) \times (60) = \underline{1,502}$$

lb Pollutant = lb Pollutant \div ODTP

$$\text{ODTP} \quad \frac{\text{hour}}{\text{hour}} \quad \frac{\text{hour}}{\text{hour}} \\ = \frac{(\underline{1,502})}{(\underline{14,67})} = \underline{.1024}$$

Meter Vol (dscl) = Meter vol * ((273+20)/(273+Meter temp)* Meter Y* (Meter Pressure/29.92) = _____

$$= 24.007 \times 1.01 \times \frac{293}{298.4} \times \frac{29.76}{29.92} = 23.68$$

$$\text{Mol/L ppm} \quad \frac{3740}{32.04}, \quad \frac{24.007}{23.68} = 109.50$$

COMPLIANCE TEST - MANUAL CALCULATIONS SHEET

CLIENT: (GP-T) edo
 PROJECT: #2 BSW MeOH
 RUN TIME CHECKED: 9:55-10:55
 DATE: 11/5/14
 CHECKED BY: WP

FLOW RATES: 40CFR 60 APP. A, Method 2

$$r = \text{Stack radius (ft)} = (\text{diameter (in.)} \div 12) \div 2 = \underline{16} \quad . \quad 67$$

$$A = \text{Stack cross-sectional area (ft}^2\text{)} = \pi r^2 = 3.14159 \times (\underline{16})^2 = \underline{1,396}$$

$$P_{\text{bar}} = \text{Barometric pressure at measurement site (in Hg)} = \underline{29.76}$$

$$P_g = \text{Stack static pressure (in Hg)} = \text{in. H}_2\text{O} \div 13.6 \text{ in H}_2\text{O/in. Hg} = (\underline{1.01}) \div \frac{13.6}{13.6} = \underline{0.0731}$$

$$P_s = \text{Absolute stack gas pressure (in. Hg)} = P_{\text{bar}} + P_g = \underline{29.76} + \underline{0.0731} = \underline{29.835}$$

$$t_d = \text{Temperature dry bulb (}^{\circ}\text{F)} = \underline{141.6}$$

$$t_w = \text{Temperature wet bulb (}^{\circ}\text{F)} = \underline{134.6}$$

$$e'' = \text{Stack vapor pressure (in. Hg)}$$

$$= (0.00000608746 \times t_w^3) - (0.00100431 \times t_w^2) + (0.0756026 \times t_w) - 1.69343$$

$$= (0.00000608746 \times \underline{134.6}^3) - (0.00100431 \times \underline{134.6}^2) + (0.0756026 \times \underline{134.6}) - 1.69343 = \underline{5133}$$

$$\%H_2O = e'' - [(P_s - e'') \times (t_d - t_w)] \div (2800 - (1.3 \times t_w)) \div P_s \times 100 \\ = \frac{\underline{5133} - [(\underline{29.835} - \underline{5133}) \times (\underline{141.6} - \underline{134.6})]}{2800 - (1.3 \times \underline{134.6})} \times 100 = \underline{17.028}$$

$$MD = \text{Molecular Density} = (100 - \%H_2O) \div 100 = \frac{(100 - \underline{17.028})}{100} = \underline{82.972}$$

$$(\%CO + \%N_2) = 100 - \%CO_2 - \%O_2 = 100 - (\underline{9.18}) - (\underline{0}) = \underline{90.82}$$

$$M_d = \text{Molecular weight of dry stack gas (lb/lb-mole)} = (%CO_2 \times 0.44) + (%O_2 \times 0.32) + [(%CO + \%N_2) \times 0.28] \\ = (\underline{1}) \times 0.44 + (\underline{9.18} \times 0.32) + (\underline{90.82} \times 0.28) = \underline{28.663}$$

$$M_s = \text{Molecular weight of wet stack gas (lb/lb-mole)} = M_d \times (MD) + (18 \text{ lb/lb-mole} \times (1-MD))$$

$$= \frac{28663}{1} \times (1.02972) + (18 \text{ lb/lb-mole} \times (1 - 1.02972)) = 26.844$$

C_p = Pitot tube coefficient = ,84

$(\sqrt{\Delta p})_{avg}$ = Average square root velocity head of stack gas (in. H₂O) = .1657

T_s = Absolute stack temperature (°R) = $460 + t_d = 460 + 141.6 = 601.6$

V_s = Average stack gas velocity (ft²/min.)

$$= 85.49 \text{ ft/sec} \times 60 \text{ sec/min} \times C_p \times (\sqrt{\Delta p})_{avg} \times \sqrt{T_s \div (P_s \times M_s)} \\ = (85.49) \times (60) \times (,84) \times (.1657) \times \sqrt{\frac{601.6}{(26.844 \times 29.751)}} = 619.57$$

$$Q_{sd} = \text{Dry stack gas flow rate at standard conditions} = MD \times V_s \times A \times (528^{\circ}\text{R} \div T_s) \times (P_s \div 29.92 \text{ in. Hg}) \\ = \frac{.47472}{1} \times \frac{1.396}{1} \times \frac{619.57}{1} \times \frac{(528^{\circ}\text{R})}{(601.6)} \times \frac{(29.751)}{(29.92)} = \frac{626.5}{.016}$$

$$Q = \text{Stack gas flow rate at actual conditions (acfm)} = V_s \times A = (.619.57) \times (1.396) = 864.9$$

Combined Stack Flow = _____ + _____ + _____ + _____ = _____

EMISSIONS:

Molecular Weight (MW) = lb
 lb mole

MeOH = 32.04

$$\frac{\text{lb Pollutant}}{\text{hour}} = \frac{C_{gas}}{1,000,000} \times \frac{1 \text{ lb-mole}}{385 \text{ ft}^3} \times \text{MW} \times Q_{sd} \times 60 \text{ min/hr} \\ = \frac{(251.085)}{1,000,000} \times \frac{(32.04)}{385} \times (1) \times (626.5) \times (60) = .785$$

$$\frac{\text{lb Pollutant}}{\text{ODTP}} = \frac{\text{lb Pollutant}}{\text{hour}} \div \frac{\text{ODTP}}{\text{hour}} \\ = \frac{.785}{(161.63)} = .047$$

Meter Vol (dscl) = Meter vol * ((273+20)/(273+Meter temp)* Meter Y* (Meter Pressure/29.92) = _____

$$23.995 \times 1.01 \times \frac{29.2}{29.47} \times \frac{29.75}{29.92} \approx 23.966$$

$$\frac{23.966}{32.04} \times \frac{24.04}{23.966} = 251.085$$

00008

**APPENDIX C
QUALITY RECORDS**

2014 Probe / S-Type Pitot Cals

Date:	8/18/2014	Calibrated by:	CK	Pitot to probe components								Meets criteria for Cp = 0.84		
				Dimensions				Alignment				Pitot to Sheath	Pitot to T/CW	Pitot to T/CZ
BH Probe	(Dt)	(PA)	(PB)	A ₁ < 10°	A ₂ < 10°	B ₁ < 5°	B ₂ < 5°	Z	W	P-0.500"				
BH#1-3'ss	0.377	0.414	0.416	0	1	2	1°	0	0	1.280	3.816	5.722	.815.5	Yes
BH#2-3'ss	0.375	0.422	0.422	1°	1	2	1	0	0	1.602	3.724	4.427	0.873	Yes
BH#1-4'	0.374	0.425	0.429	0	1	1	0	0	0	1.023	3.395	6.501	1.275	YES
BH#1-4'HT	0.375	0.429	0.428	1	2	3	1°	0	0	1.315	3.234	2.372	1.023	Yes
BH#1-5'ss	0.375	0.430	0.432	1	2	2	1	0	0	1.826	3.577	5.833	1.356	Yes
BH#1-6'ss	0.376	0.416	0.415	0	2	1	0	0	0	1.751	4.093	5.735	0.758	Yes
BH#2-6'ss	0.375	0.465	0.466	1	2	2	1	0	0	1.152	3.137	5.522	0.790	Yes
BH#4-6'ss	0.377	0.451	0.457	2	2	1	1	0	0	1.380	3.406	5.764	0.913	Yes
BH#1-7'ss	0.373	0.456	0.457	0	1	1	1	0	0	1.426	3.387	5.891	1.052	Yes
BH#2-7'ss	0.375	0.443	0.440	2	1	1	2	0	0	1.202	3.421	5.418	1.199	Yes
BH#1-8'ss	0.376	0.431	0.425	0	1	1	1	0	0	1.250	1.242	3.366	0.949	Yes
BH#1-9'	0.374	0.434	0.435	0	2	2	1	0	0	1.241	3.340	5.891	1.228	YES
BH#1-10'ss	0.372	0.441	0.444	1	1	1	2	0	0	1.157	3.477	5.808	1.992	Yes
BH#2-10'ss	0.377	0.426	0.424	1	0	2	2	0	0	1.820	3.040	5.207	1.083	Yes
BH#1-16'ss	0.377	0.251	0.250	2°	0	1°	2	0	0	1.085	0.421	0.417	0.216	Yes
BH#2-16'ss	0.379	0.250	0.252	1°	1°	2°	1	0	0	1.041	0.421	0.419	0.216	Yes
										>3/4	>3	>3	>3/4	
				Dimensions								Alignment		
BH S-Type	(Dt)	(PA)	(PB)	A ₁ < 10°	A ₂ < 10°	B ₁ < 5°	B ₂ < 5°	Z	W	CP - 0.84				
BH#1-4'ss	0.373	0.451	0.451	1	1	2	1	0	0	Yes				
BH#1-7'ss	0.376	0.450	0.450	0	0	2	2	0	0	Yes				
BH#1-10'ss	0.375	0.445	0.444	2	2	1	1	0	0	Yes				

00001

Thermo cal 10-14-07

8/18/2014									
Calibration date:	8/18/2014								
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device NIST	32	N/A	7.38	210	N/A	10.05	450	N/A	13.65
BH 3' #1 Probe	32	0		208	-2		448	-2	
Calibration date:	8/18/2014								
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device NIST	32	N/A	7.38	210	N/A	10.05	450	N/A	13.65
BH 3' #2 Probe	34	2		208	-2		449	-1	
Calibration date:	8/18/2014								
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device NIST	32	N/A	7.38	210	N/A	10.05	450	N/A	13.65
BH 4' Hi-Temp Probe	34	2		208	-2		452	2	
Calibration date:	8/18/2014								
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device NIST	32	N/A	7.38	210	N/A	10.05	450	N/A	13.65
BH 4' #1	34	2		206	-4		446	-4	
Calibration date:	8/18/2014								
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device NIST	32	N/A	7.38	210	N/A	10.05	450	N/A	13.65
BH 5' Probe	34	2		208	-2		448	-2	
NIST Thermometer I.D.:	E93-486								
Calibration date:	8/18/2014								
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device NIST	32	N/A	7.38	210	N/A	10.05	450	N/A	13.65
BH 6' #1 Probe	36	4		206	-4		446	-4	
NIST Thermometer I.D.:	E93-486								
Calibration date:	8/18/2014								
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device NIST	32	N/A	7.38	210	N/A	10.05	450	N/A	13.65
BH 6' #2 Probe	34	2		206	-4		447	-3	
NIST Thermometer I.D.:	E93-486								
Calibration date:	2/26/2013								
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device NIST		N/A	6.9		N/A	6.9		N/A	6.9
		0			0			0	
NIST Thermometer I.D.:	E93-486								
Calibration date:	8/18/2014								
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device NIST	32	N/A	7.38	210	N/A	10.05	450	N/A	13.65
BH 6' #4 Probe	33	1		206	-4		453	3	
NIST Thermometer I.D.:	E93-486								

Thermo cal 10-14-07

Calibration date:		2/19/2014							
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device		N/A	6.9		N/A	6.9		N/A	6.9
NIST									
		0			0			0	
Calibration date:		8/18/2014							
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device		N/A	7.38	210	N/A	10.05	450	N/A	13.65
NIST	32								
MFB 7' #1 Probe	31	-1		207	-3		453	3	
Calibration date:		8/18/2014							
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device		N/A	7.38	210	N/A	10.05	450	N/A	13.65
NIST	32								
BH 7' #2 Probe	31	-1		207	-3		450	0	
Calibration date:		8/18/2014							
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device		N/A	7.38	210	N/A	10.05	450	N/A	13.65
NIST	32								
BH 8' #1	32	0		207	-3		451	1	
Calibration date:		8/18/2014							
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device		N/A	7.38	210	N/A	10.05	450	N/A	13.65
NIST	32								
BH 9' #1 Probe	33	1		208	-2		447	-3	
Calibration date:		8/18/2014							
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device		N/A	7.38	210	N/A	10.05	450	N/A	13.65
NIST	32								
BH 10' #1 Probe	31	-1		207	-3		448	-2	
Calibration date:		8/18/2014							
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device		N/A	7.38	210	N/A	10.05	450	N/A	13.65
NIST	32								
BH 10' #2 Probe	34	2		207	-3		445	-5	
Calibration date:		8/18/2014							
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device		N/A	7.38	210	N/A	10.05	450	N/A	13.65
NIST	32								
BH 10' #2 Probe	34	2		207	-3		445	-5	
Calibration date:		8/18/2014							
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device		N/A	7.38	212	N/A	10.08	450	N/A	13.65
NIST	32								
BH 16' #1 Probe	30	-2		209	-3		449	-1	
Calibration date:		8/18/2014							
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)
Device		N/A	7.38	212	N/A	10.08	450	N/A	13.65
NIST	32								
BH 16' #2 Probe	29	-3		210	-2		453	3	

Calibration date:	8/18/2014					
Temp.	Test	Difference	Acceptance	Test	Difference	Acceptance
Device	Value	(°K)	Criteria (+/-)	Value	(°K)	Criteria (+/-)
NIST	32	N/A	7.38	210	N/A	10.05
BH Impinger Exit #1	31	-1		208	-2	
Calibration date:	8/18/2014					
Temp.	Test	Difference	Acceptance	Test	Difference	Acceptance
Device	Value	(°K)	Criteria (+/-)	Value	(°K)	Criteria (+/-)
NIST	32	N/A	7.38	210	N/A	10.05
BH Impinger Exit #2	32	0		205	-5	
Calibration date:	8/18/2014					
Temp.	Test	Difference	Acceptance	Test	Difference	Acceptance
Device	Value	(°K)	Criteria (+/-)	Value	(°K)	Criteria (+/-)
NIST	32	N/A	7.38	210	N/A	10.05
BH Impinger Exit #3	33	1		208	-2	
Calibration date:	8/18/2014					
Temp.	Test	Difference	Acceptance	Test	Difference	Acceptance
Device	Value	(°K)	Criteria (+/-)	Value	(°K)	Criteria (+/-)
NIST	32	N/A	7.38	210	N/A	10.05
BH Impinger Exit #4	33	1		206	-4	
Calibration date:	8/18/14					
Temp.	Test	Difference	Acceptance	Test	Difference	Acceptance
Device	Value	(°K)	Criteria (+/-)	Value	(°K)	Criteria (+/-)
NIST	32	N/A	7.38	210	N/A	10.05
BH Filter Oven #1	29	-3		208	-2	
Calibration date:	8/18/2014					
Temp.	Test	Difference	Acceptance	Test	Difference	Acceptance
Device	Value	(°K)	Criteria (+/-)	Value	(°K)	Criteria (+/-)
NIST	32	N/A	7.38	210	N/A	10.05
BH Filter Oven #2	33	1		207	-3	
Calibration date:	8/18/2014					
Temp.	Test	Difference	Acceptance	Test	Difference	Acceptance
Device	Value	(°K)	Criteria (+/-)	Value	(°K)	Criteria (+/-)
NIST	32	N/A	7.38	210	N/A	10.05
BH Filter Oven #3	29	-3		207	-3	
Calibration date:	8/18/2014					
Temp.	Test	Difference	Acceptance	Test	Difference	Acceptance
Device	Value	(°K)	Criteria (+/-)	Value	(°K)	Criteria (+/-)
NIST	32	N/A	7.38	210	N/A	10.05

Thermo cal 10-14-07

BH Filter Oven #4	31	-1		205	-5		
Calibration date:		8/18/2014					
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	
Device NIST	32	N/A	7.38	210	N/A	10.05	
	32	0		207	-3		
Meter Box #906017							
Calibration date:		8/18/2014					
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	
Device NIST	32	N/A	7.38	210	N/A	10.05	
Meter Box #0610022	32	0		207	-3		
Calibration date:		8/18/2014					
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	
Device NIST	32	N/A	7.38	210	N/A	10.05	
	34	2		206	-4		
Meter Box #0307031							
Calibration date:		8/18/2014					
Temp.	Test Value	Difference (°K)	Acceptance Criteria (+/-)	Test Value	Difference (°K)	Acceptance Criteria (+/-)	
Device NIST	32	N/A	7.38	210	N/A	10.05	
	30			208			
Meter Box #1208030		-2			-2		

PR E

19-Sep-14

DRY GAS METER

Model:	623			
Serial #:	805005 Box 2			
Location:	GEG			
Date	9/19/2014	9/19/2014	9/19/2014	9/19/2014
Console leak check (cfm)	0	0	0	0
Orifice setting ('h)	1.575	2.362	3.15	3.937
Barometric pressure (in. Hg)	27.77	27.77	27.77	27.77
Volume				
beginning reading	0	0	0	0
ending reading	0.3474257	0.4048121	0.48314	0.5309914
Total Volume (Vd) ft3	0.3474257	0.4048121	0.48314	0.5309914
Temperature (deg F)				
beginning inlet	66.2	75.2	77	78.8
ending inlet	75.2	77	78.8	80.6
beginning outlet	66.2	80.6	77	78.8
ending outlet	75.2	77	78.8	80.6
average outlet temp (Tmo)	70.7	78.8	77.9	79.7
average temp (Tm)	70.7	77.45	77.9	79.7

CALIBRATION METER

	Yc	1.006	1.006	1.006	1.006	AVERAGE
Volume						
beginning reading	467.160	467.510	467.920	468.4		
ending reading	467.510	467.920	468.400	468.92		
Total Volume (Vc) ft3	0.35	0.41	0.48	0.52		
Temperature						
beginning	69.8	71.6	71.6	71.6		
ending	71.6	71.6	71.6	71.6		
average temp (Tc)	70.7	71.6	71.6	71.6		
Time (min)		11	11	11	10	
Y:	1.009	1.023	1.002	0.989		1.006
Difference from Average:	0.003	0.017	-0.003	-0.017		

Y Acceptance criteria: +/- 0.02 From Average

00006

DRY GAS METER

P12.12

19-Aug-14

Model:	623	805005 BOX 1	High Flow	
Serial #:	GEG			
Location:				0.0353147
Date	8/19/2014	8/19/2014	8/19/2014	8/19/2014
Console leak check (cfm)	0	0	0	0
Orifice setting (^h)	1.575	2.362	3.15	3.937
Barometric pressure (in. Hg)	27.77	27.77	27.77	27.77
Volume				
beginning reading	0	0	0	0
ending reading	1.1689509	1.5748224	2.1676498	2.35550647
Total Volume (Vd) ft ³	1.1689509	1.5748224	2.1676498	2.35550647

Temperature (deg F)				
beginning inlet	66	69	73	76
ending inlet	69	73	76	77
beginning outlet	66	69	73	76
ending outlet	69	73	76	77
average outlet temp (Tmo)	67.5	71	74.5	76.5
average temp (Tm)	67.5	71	74.5	76.5

CALIBRATION METER

Volume	Yc	1.006	1.006	1.006
beginning reading	459.560	460.730	462.310	464.48
ending reading	460.730	462.310	464.480	466.84
Total Volume (Vc) ft ³	1.17	1.58	2.17	2.36
Temperature				
beginning	66	67	67	67
ending	67	67	67	67
average temp (Tc)	66.5	67	67	67
Time (min)				
	10	10	12	12
Difference from Average:	Y:	1.004	1.010	1.015
		-0.006	0.000	0.005
				AVERAGE 1.010

Y Acceptance criteria: +/- 0.02 From Average

20-Nov-14

DRY GAS METER

Model: 623
Serial #: 805005 BOX 1
Location: GEG
Date 11/20/2014 11/20/2014 11/20/2014
Console leak check (cfm) 0 0 0
Orifice setting ('h) 1.575 2.362 3.15 3.937
Barometric pressure (in. Hg) 27.75 27.75 27.75 27.75

Volume
beginning reading 0 0 0 0
ending reading 1.1969907 1.5976004 1.8181758 1.9046967
Total Volume (Va) ft³ 1.1969907 1.5976004 1.8181758 1.9046967
Temperature (deg F)
beginning inlet 63 58 61 63
ending inlet 58 61 63 64
beginning outlet 63 58 61 63
ending outlet 58 61 63 64
average outlet temp (Tmo) 60.5 59.5 62 63.5
Average temp (Tm) 60.5 59.5 62 63.5

CALIBRATION METER

Yc 1.006 1.006 1.006 1.006
Volume
beginning reading 76.525 77.730 79.345 81.170
ending reading 77.730 79.345 81.170 83.085
Total Volume (Vc) ft³ 1.205 1.615 1.825 1.915
Temperature
beginning 51 56 55 55
ending 56 55 55 56
average temp (Tc) 53.5 55.5 55 55.5
Time (min) 10 10 10 10
AVERAGE
Y: 1.022 1.018 1.015 1.016
Difference from Average: 0.004 0.000 -0.003 -0.002

Y Acceptance criteria: +/- 0.02 From Average

20-Nov-14

DRY GAS METER

Model:	623	805005 Box 2	High Flow
Serial #:			0.0353147
Location:	GEG		
Date	11/20/2014	11/20/2014	11/20/2014
Console leak check (cfm)	0	0	0
Orifice setting (^h)	1.575	2.362	3.15
Barometric pressure (in. Hg)	27.75	27.75	27.75
Volume			
beginning reading	0	0	0
ending reading	0.6269413	0.7423497	0.9241849
Total Volume (Vd) ft3	0.6269413	0.7423497	0.9241849
Temperature (deg F)			
beginning inlet	50	62.6	64.4
ending inlet	62.6	64.4	66.2
beginning outlet	50	62.6	64.4
ending outlet	62.6	64.4	66.2
average outlet temp (Tmo)	56.3	63.5	65.3
average temp (Tm)	56.3	63.5	65.3
CALIBRATION METER	Yc	1.006	1.006
Volume			
beginning reading	83.435	84.060	85.620
ending reading	84.060	84.790	86.540
Total Volume (Vc) ft3	0.625	0.73	0.92
Temperature			
beginning	57.2	57.2	59
ending	57.2	59	59
average temp (Tc)	57.2	58.1	59
Time (min)			
	10	10	11
			10
			AVERAGE
Difference from Average:	Y: -0.001	0.993	1.005
		-0.004	0.007
			0.995
			-0.002
			0.997

Y Acceptance criteria: +/- 0.02 From Average

GAS DILUTION SYSTEM VERIFICATION METHOD						
Project: GP-Toledo		Date: 11/3/2014				
Dilution Gas	20.93 % O ₂	1ST DILUTION=		90 %		
Undiluted Gas	18.01 % O ₂	2ND DILUTION=		50 %		
		Run 1	Run 2	Run 3	Average	
	Actual Concen. (ppm)	Instrument Response (ppm)	% Diff. from Average (ppm)	Instrument Response (ppm)	% Diff. from Average (ppm)	Instrument Response (ppm)
1ST DILUTION	18.837	19.1	0.1%	19.12	0.2%	19.03
2ND DILUTION	10.465	10.31	-0.1%	10.35	0.3%	10.3
Mid-Level Gas	18.01	18.41	0.3%	18.32	-0.1%	18.31
Note: All percent differences must be within +/- 2.0%.						



DocNumber: 000052499

Praxair
5700 South Alameda Street
Los Angeles, CA 90058
Tel: (323) 585-2154 Fax: (714) 542-6689
PGVPID: F22013

Customer & Order Information:

PRAXAIR WHSE VANCOUVER W
603 SE VICTORY AVE
VANCOUVER WA 986610

Praxair Order Number: 23050520
Customer P. O. Number: 04307063
Customer Reference Number:

Fill Date: 3/9/2013
Part Number: NI CD2205E-AS
Lot Number: 109308801
Cylinder Style & Outlet: AS CGA 590
Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	4/13/2021	NIST Traceable
Cylinder Number:	CC49794	Analytical Uncertainty:
21.85	% CARBON DIOXIDE	± 2 %
20.93	% OXYGEN	± 1 %
Balance	NITROGEN	

Certification Information: Certification Date: 4/13/2013 Term: 96 Months Expiration Date: 4/13/2021

This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-800/R-97/121, using Procedure G2. The certification expiration date was assigned using the May 2012 revision of the EPA Traceability Protocol document. Do Not Use this Standard if Pressure is less than 150 PSIG.

G2 ANALYSIS FOR CO2 WAS DONE USING STEC INC SGD-710C @ 70% (C.F.=0.6943)**Analytical Data:**

(R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON DIOXIDE

Requested Concentration: 22 %
Certified Concentration: 21.85 %
Instrument Used: Horiba VIA-510 S/N 2807014
Analytical Method: NDIR
Last Multipoint Calibration: 3/20/2013

First Analysis Data:			Date:
Z:	0	R:	17.97
R:	17.87	Z:	0
Z:	0	C:	15.04
UOM: %			Mean Test Assay: 15.03 %

Reference Standard Type:

GMIS
Ref. Std. Cylinder #: CC265304
Ref. Std. Conc: 17.97%
Ref. Std. Traceable to SRM #: 2745
SRM Sample #: 9-B-09
SRM Cylinder #: CAL-010765

Second Analysis Data:

Second Analysis Data:				Date:
Z:	0	R:	0	C: 0
R:	0	Z:	0	C: 0
Z:	0	C:	0	R: 0
UOM: %				Mean Test Assay: 0 %

Reference Standard Type:

GMIS
Ref. Std. Cylinder #: CC92589
Ref. Std. Conc: 19.99%
Ref. Std. Traceable to SRM #: 2659a
SRM Sample #: 71-37-B
SRM Cylinder #: CLM-005734

Second Analysis Data:

Second Analysis Data:				Date:
Z:	0	R:	0	C: 0
R:	0	Z:	0	C: 0
Z:	0	C:	0	R: 0
UOM: %				Mean Test Assay: 0 %

2. Component: OXYGEN

Requested Concentration: 21 %
Certified Concentration: 20.93 %
Instrument Used: OXYMAT 5E
Analytical Method: PARAMAGNETIC
Last Multipoint Calibration: 3/20/2013

First Analysis Data:			Date:
Z:	0	R:	20
R:	20	Z:	0
Z:	0	C:	20.94
UOM: %			Mean Test Assay: 20.93 %

Reference Standard Type:

GMIS
Ref. Std. Cylinder #: CC92589
Ref. Std. Conc: 19.99%
Ref. Std. Traceable to SRM #: 2659a
SRM Sample #: 71-37-B
SRM Cylinder #: CLM-005734

Second Analysis Data:

Second Analysis Data:				Date:
Z:	0	R:	0	C: 0
R:	0	Z:	0	C: 0
Z:	0	C:	0	R: 0
UOM: %				Mean Test Assay: 0 %

Analyzed by:

Sharneela Jiffrey

Certified by:

Information contained herein has been prepared at your request by qualified experts within Praxair Distribution, Inc. While we believe that the information is accurate within the limits of the analytical methods employed and is complete to the extent of the specific analyses performed, we make no warranty or representation as to the suitability of the use of the information for any purpose. The information is offered with the understanding that any use of the information is at the sole discretion and risk of the user. In no event shall the liability of Praxair Distribution, Inc., arising out of the use of the information contained herein exceed the fee established for providing such information.

00011



DocNumber: 000051337

Praxair
 5700 South Alameda Street
 Los Angeles, CA 90058
 Tel: (323) 585-2154 Fax: (714) 542-6689
 PGVP ID: F22013

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

PRAXAIR WHSE VANCOUVER W
 603 SE VICTORY AVE
 VANCOUVER WA 986610

Praxair Order Number: 23050701
 Customer P. O. Number: 04307067
 Customer Reference Number:

Fill Date: 3/9/2013
 Part Number: NI CD1105E-AS
 Lot Number: 109306804
 Cylinder Style & Outlet: AS CGA 580
 Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	3/27/2021	NIST Traceable
Cylinder Number:	CC120997	Analytical Uncertainty:
11.02 %	CARBON DIOXIDE	± 1 %
10.49 %	OXYGEN	± 1 %
Balance	NITROGEN	

Certification Information: Certification Date: 3/27/2013 Term: 96 Months Expiration Date: 3/27/2021

This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-600/R-97/121, using Procedure G1. The certification expiration date was assigned using the May 2012 revision of the EPA Traceability Protocol document. Do Not Use this Standard if Pressure is less than 150 PSIG.

Analytical Data: (R=Reference Standard, Z=Zero Gas, C=Gas Candidate)

1. Component: CARBON DIOXIDE

Requested Concentration: 11 %
 Certified Concentration: 11.02 %
 Instrument Used: Horiba VIA-510 S/N 2807014
 Analytical Method: NDIR
 Last Multipoint Calibration: 3/4/2013

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: CC7663
 Ref. Std. Conc: 10.07%
 Ref. Std. Traceable to SRM #: 1675b
 SRM Sample #: 6-F-51
 SRM Cylinder #: CAL014538

First Analysis Data:				Date:
Z: 0	R: 10.07	C: 11.01	Conc: 11.01	
R: 10.07	Z: 0	C: 11.02	Conc: 11.02	
Z: 0	R: 10.07	C: 11.03	Conc: 11.03	
UOM: %		Mean Test Assay:	11.02 %	

Second Analysis Data:				Date:
Z: 0	R: 0	C: 0	Conc: 0	0
R: 0	Z: 0	C: 0	Conc: 0	0
Z: 0	C: 0	R: 0	Conc: 0	0
UOM: %		Mean Test Assay:	0 %	

2. Component: OXYGEN

Requested Concentration: 10.5 %
 Certified Concentration: 10.49 %
 Instrument Used: OXYMAT 5E
 Analytical Method: PARAMAGNETIC
 Last Multipoint Calibration: 3/4/2013

Reference Standard Type: GMIS
 Ref. Std. Cylinder #: SA15925
 Ref. Std. Conc: 10.01%
 Ref. Std. Traceable to SRM #: 2658a
 SRM Sample #: 72-28-B
 SRM Cylinder #: CLM-006896

First Analysis Data:				Date:
Z: 0	R: 10	C: 10.48	Conc: 10.49	
R: 10	Z: 0	C: 10.48	Conc: 10.49	
Z: 0	C: 10.48	R: 10	Conc: 10.49	
UOM: %		Mean Test Assay:	10.49 %	

Second Analysis Data:				Date:
Z: 0	R: 0	C: 0	Conc: 0	0
R: 0	Z: 0	C: 0	Conc: 0	0
Z: 0	C: 0	R: 0	Conc: 0	0
UOM: %		Mean Test Assay:	0 %	

Analyzed by:

Certified by:

Shameela Jiffrey

AIRDATA MULTIMETER CERTIFICATE OF CALIBRATION

Customer ID: 020243S/N: M1217Customer: Bighorn EnvironmentalCity: Liberty LakeState: WAModel #: 860C

PO #:

Calibration Due Date:

Order #: 120531Test By: FJWDate 03-19-12Rh 25% Ambient Temperature 72 °F Barometric Pressure 28.36ABSOLUTE PRESSURE TEST (in Hg)
TEST METER TOLERANCE = ± 2.0 % ± .1 in Hg

Pressure Standard: Heise #02-R S/N: 41741/42451

✓

Pressure Standard: Heise #12-R S/N: 43168/44731

Pressure Standard: Heise #04-R S/N: 41743/42453

✓

Pressure Standard: Heise #14-R S/N: 43412/45043

Pressure Standard: Heise #06-R S/N: 41742/42452

✓

Pressure Standard: Heise #16-R S/N: 44581/46845

Pressure Standard: Heise #08-R S/N: 42186/43328

✓

Pressure Standard: Heise #20-R S/N: 44582/46847

Pressure Standard: Heise #10-R S/N: 42203/43352

✓

Approx Set Point	Standard	Test Meter	% Diff
14.0	13.84	13.8	-.29
28.4	28.36	28.3	-.21
40.0	40.39	40.3	-.22

DIFFERENTIAL PRESSURE TEST (in wc)
TEST METER TOLERANCE = ± 2.0 % ± 0.001 in wc

Pressure Standard: Heise #01-L S/N: 41739/42449

✓

Pressure Standard: Heise #11-L S/N: 43165/44551

Pressure Standard: Heise #01-R S/N: 41739/42448

✓

Pressure Standard: Heise #11-R S/N: 43165/44730

Pressure Standard: Heise #02-L S/N: 41741/42454

✓

Pressure Standard: Heise #12-L S/N: 43168/44732

Pressure Standard: Heise #03-L S/N: 41738/42448

✓

Pressure Standard: Heise #13-L S/N: 43415/45041

Pressure Standard: Heise #03-R S/N: 41738/42445

✓

Pressure Standard: Heise #13-R S/N: 43415/45039

Pressure Standard: Heise #04-L S/N: 41743/42456

✓

Pressure Standard: Heise #14-L S/N: 43412/45045

Pressure Standard: Heise #05-L S/N: 41740/42450

✓

Pressure Standard: Heise #17-L S/N: 44579/46842

Pressure Standard: Heise #05-R S/N: 41740/42447

✓

Pressure Standard: Heise #17-R S/N: 44579/46841

Pressure Standard: Heise #06-L S/N: 41742/42455

✓

Pressure Standard: Heise #18-L S/N: 44581/46848

Pressure Standard: Heise #07-L S/N: 42185/42186

✓

Pressure Standard: Heise #19-L S/N: 44580/46844

Pressure Standard: Heise #07-R S/N: 42186/43326

✓

Pressure Standard: Heise #19-R S/N: 44580/46843

Pressure Standard: Heise #08-L S/N: 42186/43328

✓

Pressure Standard: Heise #20-L S/N: 44582/46848

Pressure Standard: Heise #08-R S/N: 42202/43351

✓

Pressure Standard: Heise #09-L S/N: 42202/43350

✓

Pressure Standard: Heise #10-L S/N: 42203/43353

✓

Approx Set Point	Standard	Test Meter	% Diff
.0500	.0515	.0513	-.39
.1250	.1277	.1274	-.23
.2250	.2254	.2250	-.18
.2700	.2705	.2701	-.15
2.000	2.059	2.053	-.29
3.600	3.661	3.648	-.36
4.400	4.415	4.414	-.02
27.00	27.31	27.37	.22
50.00	50.56	50.58	.04
Over Pressure	NA	/	NA

Shortridge Instruments, Inc.
 7855 East Redfield Road Scottsdale, Arizona 85260
 (480) 991-6744 • Fax (480) 443-1267 • www.shortridge.com

Shortridge Instruments, Inc. AirData Multimeter Calibration Equipment

Order Number: 20539

Serial Number: M12172

Test Type: Initial As-Received Final

			ABSOLUTE PRESSURE STANDARDS			
ADM #02-R	S/N: 41741/42451	Heise Model: PPM-2	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 04/08/11	Due Date: 04/2012	
ADM #04-R	S/N: 41743/42453	Heise Model: PPM-2	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 10/10/11	Due Date: 10/2012	
ADM #06-R	S/N: 41742/42452	Heise Model: PPM-2	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 09/19/11	Due Date: 09/2012	
ADM #08-R	S/N: 42188/43328	Heise Model: PPM-2	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 03/16/11	Due Date: 03/2012	
ADM #10-R	S/N: 42203/43362	Heise Model: PPM-2	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 01/16/12	Due Date: 01/2013	
ADM #12-R	S/N: 43185/44731	Heise Model: PPM-2	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 12/13/11	Due Date: 12/2012	
ADM #14-R	S/N: 43412/45043	Heise Model: PPM-2	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 07/21/11	Due Date: 07/2012	
ADM #16-R	S/N: 44581/46845	Heise Model: PPM-2	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 04/29/11	Due Date: 04/2012	
ADM #20-R	S/N: 44582/46847	Heise Model: PPM-2	Mfd & Calibrated by Ashcroft, Inc.	Calibration Date: 05/28/11	Due Date: 05/2012	
#02-R, 04-R, 06-R, 08-R, 10-R, 12-R, 14-R	Rated Accuracy: 0.05% fa (0.0305 in Hg)		Range: 0-60 in Hg	Resolution: 0.01	Uncertainty: < 0.0358	
#16-R, 20-R	Rated Accuracy: 0.05% fa (0.0305 in Hg)		Range: 0-60 in Hg	Resolution: 0.001	Uncertainty: < 0.0358	

			DIFFERENTIAL PRESSURE STANDARDS			
ADM #01-L	S/N: 41739/42449	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 04/29/11	Due Date: 04/2012	
ADM #01-R	S/N: 41739/42446	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 05/04/11	Due Date: 04/2012	
ADM #02-L	S/N: 41741/42454	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 04/09/11	Due Date: 04/2012	
ADM #03-L	S/N: 41739/42448	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 11/09/11	Due Date: 10/2012	
ADM #03-R	S/N: 41738/42445	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 10/19/11	Due Date: 10/2012	
ADM #04-L	S/N: 41743/42456	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 10/18/11	Due Date: 10/2012	
ADM #05-L	S/N: 41746/42450	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 10/14/11	Due Date: 09/2012	
ADM #05-R	S/N: 41740/42447	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 08/30/11	Due Date: 08/2012	
ADM #06-L	S/N: 41742/42455	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 08/27/11	Due Date: 08/2012	
ADM #07-L	S/N: 42185/42195	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 05/15/11	Due Date: 05/2012	
ADM #07-R	S/N: 42185/43329	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 03/10/11	Due Date: 03/2012	
ADM #08-L	S/N: 42185/43329	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 03/10/11	Due Date: 03/2012	
ADM #08-R	S/N: 42202/43351	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 01/25/12	Due Date: 01/2013	
ADM #09-L	S/N: 42202/43350	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 01/23/12	Due Date: 01/2013	
ADM #10-L	S/N: 42203/43358	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 01/23/12	Due Date: 01/2013	
ADM #11-L	S/N: 43165/44551	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 12/22/11	Due Date: 12/2012	
ADM #11-R	S/N: 43185/44730	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 12/20/11	Due Date: 12/2012	
ADM #12-L	S/N: 43185/44732	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 12/14/11	Due Date: 12/2012	
ADM #13-L	S/N: 43415/45041	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 07/21/11	Due Date: 07/2012	
ADM #13-R	S/N: 43415/45038	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 07/14/11	Due Date: 07/2012	
ADM #14-L	S/N: 43412/45045	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 07/14/11	Due Date: 07/2012	
ADM #17-L	S/N: 44578/46842	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 04/15/11	Due Date: 04/2012	
ADM #17-R	S/N: 44578/46841	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 04/08/11	Due Date: 04/2012	
ADM #18-L	S/N: 44581/46846	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 04/28/11	Due Date: 04/2012	
ADM #19-L	S/N: 44580/46844	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 08/27/11	Due Date: 08/2012	
ADM #19-R	S/N: 44580/46843	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 08/21/11	Due Date: 08/2012	
ADM #20-L	S/N: 44582/46848	Heise Model: PPM-1	Mfd & Calibrated by Dresser Industries (Ashcroft)	Calibration Date: 08/14/11	Due Date: 08/2012	
#01-L, 03-L, 05-L, 07-L, 09-L, 11-L, 13-L, 17-L, 19-L	Rated Accuracy: > 0.07% fa (0.000175 in wc)		Range: 0.0-0.25 in wc	Res.: 0.00001	Uncertainty: < 0.00035	
201-R, 03-R, 05-R, 07-R, 09-R, 11-R, 13-R, 17-R, 19-R	Rated Accuracy: > 0.06% fa (0.003 in wc)		Range: 0.0-5.0 in wc	Res.: 0.0001	Uncertainty: < 0.00348	
202-L, 04-L, 06-L, 08-L, 10-L, 12-L, 14-L, 18-L, 20-L	Rated Accuracy: > 0.06% fa (0.03 in wc)		Range: 0.0-50.0 in wc	Res.: 0.001	Uncertainty: < 0.0348	

			LOW VELOCITY EQUIVALENT CONFIRMATION STANDARDS			
Vel Eqv Transfer Standard S/N: M02009	Model ADM-870C	Mfd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 12/13/11	Due Date: 12/2012		
Vel Eqv Transfer Standard S/N: M02003	Model ADM-870C	Mfd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 01/24/12	Due Date: 01/2013		
Vel Eqv Transfer Standard S/N: M02003	Model ADM-870C	Mfd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 12/13/11	Due Date: 12/2012		
Vel Eqv Transfer Standard S/N: M10838	Model ADM-870C	Mfd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 12/13/11	Due Date: 12/2012		
Vel Eqv Transfer Standard S/N: M10840	Model ADM-870C	Mfd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 12/13/11	Due Date: 12/2012		
Vel Eqv Transfer Standard S/N: M10897	Model ADM-870C	Mfd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 01/24/12	Due Date: 01/2013		
Vel Eqv Transfer Standard S/N: M10801	Model ADM-870C	Mfd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 12/13/11	Due Date: 12/2012		
Rated Accuracy: Velocity ± 1.5 % ± 3.5 fpm		Range: 100-500 fpm	Resolution: 0.1	Uncertainty: < 5.00 fpm at 100 fpm; < 7.50 fpm at 500 fpm		

			TEMPERATURE STANDARDS			
RTD Simulator S/N: 248	Model RTD-1000/500	Mfd by General Resistance	Calibrated by Hart Scientific (Fluke)	Calibration Date: 01/24/08	Due Date: 01/2012	
RTD Simulator S/N: 250	Model RTD-1000/500	Mfd by General Resistance	Calibrated by Hart Scientific (Fluke)	Calibration Date: 01/24/08	Due Date: 01/2012	
RTD Simulator S/N: 253	Model RTD-1000/500	Mfd by General Resistance	Calibrated by Hart Scientific (Fluke)	Calibration Date: 01/24/08	Due Date: 01/2012	
RTD Simulator S/N: 254	Model RTD-1000/500	Mfd by General Resistance	Calibrated by Hart Scientific (Fluke)	Calibration Date: 03/07/08	Due Date: 03/2012	
RTD Simulator S/N: 256	Model RTD-1000/500	Mfd by General Resistance	Calibrated by Hart Scientific (Fluke)	Calibration Date: 03/07/08	Due Date: 03/2012	
RTD Simulator S/N: 257	Model RTD-1000/500	Mfd by General Resistance	Calibrated by Hart Scientific (Fluke)	Calibration Date: 03/07/08	Due Date: 03/2012	
RTD Simulator S/N: 282	Model RTD-1000/500	Mfd by General Resistance	Calibrated by IET Labs	Calibration Date: 12/18/11	Due Date: 12/2015	
RTD Simulator S/N: 293	Model RTD-1000/500	Mfd by General Resistance	Calibrated by IET Labs	Calibration Date: 12/18/11	Due Date: 12/2015	
RTD Simulator S/N: 294	Model RTD-1000/500	Mfd by General Resistance	Calibrated by IET Labs	Calibration Date: 12/18/11	Due Date: 12/2015	
Rated Accuracy: 0.025% of setting		Range: 100 Ω to 1111.10 Ω	Resolution: 0.01 Ω	Uncertainty: < 0.0003° F		

Thermometer #1 S/N: BA089/Thermistor S/N A410880	Model 1504/5810	Mfd & Calibrated by Hart Scientific (Fluke)	Calibration Date: 01/14/11	Due Date: 01/2013
Thermometer #2 S/N: BB104/Thermistor S/N 571507	Model 1504/5810	Mfd & Calibrated by Hart Scientific (Fluke)	Calibration Date: 11/08/10	Due Date: 11/2012
Thermometer #5 S/N: B11760/Thermistor S/N B10505	Model 1504/5810	Mfd & Calibrated by Hart Scientific (Fluke)	Calibration Date: 01/24/11	Due Date: 01/2013
Thermometer #6 S/N: B11762/Thermistor S/N B10503	Model 1504/5810	Mfd & Calibrated by Hart Scientific (Fluke)	Calibration Date: 01/24/11	Due Date: 01/2013
Rated Accuracy(combined): 0.028° F/0.018° F		Range: 32° F-178° F	Resolution: 0.001° F	Combined Uncertainty with Bath: < 0.040° F

Temp Transfer Standard S/N M00136	Model ADM-870	Mfd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 10/25/11	Due Date: 10/2012
Temp Transfer Standard S/N M00100	Model ADA4-870	Mfd & Calibrated by Shortridge Instruments, Inc.	Calibration Date: 03/08/11	Due Date: 03/2012
Rated Accuracy: 0.03° F		Range: 33° F-158° F	Resolution: 0.01° F	Uncertainty: < 0.023° F

Total combined Uncertainty for MultiTemp and TempProbe testing: < 0.046° F

This form must remain with the Certificate of Calibration corresponding to the Order Number listed above.


Shortridge Instruments, Inc.

7855 East Redfield Road Scottsdale, Arizona 85260 • (480) 991-5744 • Fax (480) 443-1267 • www.shortridge.com

00014

Span + Interferent: 40CFR60 App. 4-A Method 7E

40CFR60 App. A-4 Method 7E - Zero + Interferent Effect as a Percentage of Span



AN INSTRUMENTS REFERENCE METER VERIFICATION
TURBIDITY METER CALIBRATION

DRAFT EDITION

REPORT ENGLISH UNIT

१०	१०	१०	१०
१०	१०	१०	१०
१०	१०	१०	१०
१०	१०	१०	१०
१०	१०	१०	१०

Calibration Certificate		B-09	
Date	Time	16-Jan-14	
Refractive Index		29.60	in air
Calibration Test		EW	
BIG Serial Number		S-113-367165	

	528	28.92	17,947	1,311
Old Year				
New Year				
Total				

early that the author of *This Matter* was deeply imbued with the spirit of A.S.T.R.

四

00016

APPENDIX D
GP PRODUCTION DATA

Source Tested BSW#2	Date 11/5/2014 14:00:00	Date 11/5/2014 15:00:00	time (days) 0.042	BSW#2 cooks/day 22	BSW#2 ADT/day 391	BSW#2 ODT/day 352	BSW#2 GPM 1824	31FIC365 stock flow GPM 1824
								33FIC004A Target P.M. Average Stock Flow GPM During Tests 1733-2179 1861
								Average Stock Flow Day 1539.9

Date 11/5/2014 15:10:00	Date 11/5/2014 16:10:00	time (days) 0.042	BSW#2 cooks/day 22	BSW#2 ADT/day 391	BSW#2 ODT/day 352	BSW#2 GPM 1748	33FIC004A stock flow GPM 2011
11/5/14 4:19 PM	11/5/2014 17:19	0.042	22	391	352		

October Average
Washer Flow GPM
Tons Production
1649.53972 from PI
1175 From pjp2014

Source Tested	Date	Date	time	BSW#3	BSW#3	BSW#3	33FIC028
BSW#3	11/5/14 9:55 AM	11/5/14 10:55 AM	(days) 0.042	cooks/day 26	ADT/day 443	ODT/day 399	stock flow GPM 1220
							Average Stock Flow GPM During Tests
							1224
							Target Range
							1170-130
Date	Date	time	BSW#3	BSW#3	BSW#3	33FIC028	
11/5/14 11:00 AM	11/5/14 12:00 PM	(days) 0.042	cooks/day 26	ADT/day 443	ODT/day 399	stock flow GPM 1228	
							Average Stock Flow Day
							1035.8
Date	Date	time	BSW#3	BSW#3	BSW#3	33FIC028	
11/5/14 12:05 PM	11/5/14 1:05 PM	(days) 0.042	cooks/day 26	ADT/day 443	ODT/day 399	stock flow GPM 1225	
							October Average
							Washer Flow GPM
							Tons Production
							1046.46243 from PI
							1175 From plp2014

APPENDIX E
EPA/ODEQ CORRESPONDENCE

September 25, 2014

Mr. Mike Eisele
Oregon Department of Environmental Quality
750 Front Street, Suite 120
Salem, OR 97301

RE: Georgia-Pacific West Toledo, Oregon Mill's Brown Stock Washer Methanol Testing

Dear Mr. Eisele:

Please allow this letter to serve as notification that Bighorn Environmental is scheduled to perform methanol testing on Georgia Pacific's Brown Stock Washer Lines to comply with the CCA rules at their Toledo, Oregon Pulp and Paper Mill.

Purpose of Tests: To determine compliance with the CCA rules as outlined in GP's permit.

Sources, Parameters, and Test Dates: The following table outlines sources, parameters, and proposed test dates.

SOURCES	PARAMETERS	TEST DATES
#1 Wash Row Combined Vent	Methanol, Velocity & Moisture	November 3-7
#1 Wash Row Foam Breaker	Methanol, Velocity & Moisture	
#1 Wash Row Vacuum Pump	Methanol, Velocity & Moisture	
#2 Wash Row Combined Vent	Methanol, Velocity & Moisture	
#3 Wash Row Combined Vent	Methanol, Velocity & Moisture	

If testing dates change, Bighorn or Georgia Pacific personnel will call you soon after scheduling the new dates so you can make preparations to observe.

Test Methods: Testing will be conducted in accordance with EPA Methods in *Title 40 CFR 60, Appendix A , July 2013*, and ODEQ methods in its *Source Sampling Manual, Volume 1, January 1992*.

Flow Rates: EPA Methods 1 & 2 (Shortridge digital manometer for low velocity sources, expected to be used on #1 WR combined vent)
O₂ & CO₂: EPA Method 3A
Moisture: Oregon DEQ Method 4
Methanol: NCASI CI/SG/PULP 94.03

Discussion of Methods: EPA Methods 1 & 2 will be used to determine flow rates. O₂ and CO₂ will be measured at each stack either directly or with a bag sample. The absence of cyclonic flow will be verified for each source. Georgia Pacific's Sam Adams received approval to use NCASI Method 94.03 (see attached letter). This method includes a spike solution and method blank as part of its QA/QC.

Data Collection: Bighorn uses standard forms, which contain all required regulatory data and any additional information necessary for flow rate determinations.

Process data: GP personnel will record the pulp production from each wash row during each test period.

Sampling Replicates and Duration: Bighorn will conduct tests consisting of a minimum of three-one hour runs for methanol including a pitot traverse and moisture determination during each run to determine flow rates. These

will be conducted concurrently with each test run. Testing on the three #1 Wash Row Vents will be conducted simultaneously.

QC/QA: Cross checks such as manual calculations of Bighorn's computer generated spreadsheet summaries allow test results verification. Bighorn files manufacturers' accuracy certificates and interference tables for CEMS, flow controllers, gases, etc. Additionally dry gas meters, pitot tubes, thermocouples, gas dividers, etc. are certified as per ODEQ and EPA requirements and frequencies. Where EPA or ODEQ frequencies are not specified, Bighorn has established those based on neighboring state's regulatory criteria.

Thorough sample methodology adherence, chain-of-custody procedures, and documentation provide proof of our QA/QC efforts. Relevant QA/QC documentation is included in the final report's Appendices for results support and regulatory review.

- ODEQ Source Sampling Manual Volume One Language**
- a. It is assumed today, but will be confirmed on or before the test day, that the duct air flow measuring meets criteria in EPA Methods 1 and 2.
 - b. In no case, will sampling replicates be accepted if separated by a time duration of 24 or more hours, unless prior authorization is granted by ODEQ.
 - c. The source to be tested must operate at a normal production rate during testing. Rates not in agreement with those stipulated in the Title V Operating Permit can result in test rejection for application to determine compliance. Imposed process limitations could also result from atypical rates.
 - d. The department must be notified of any changes in source test plans prior to testing. Significant changes not acknowledged by ODEQ which could affect the accuracy and reliability of results could result in test report rejection.
 - e. Method specific quality assurance/quality control procedures must be performed to ensure the data is valid for determining source compliance. Documentation of the procedures and results shall be presented in the source test report for review. Omission of this critical information may result in rejection of the data, requiring a re-test.
 - f. Source test reports must be submitted to the department within 60 days of the test dates, unless another deadline has been stipulated, either by permit condition, or by ODEQ letter approval.
 - g. Two copies of the completed source test report must be sent to the ODEQ Regional Operations staff person responsible for the source and the second copy to the Source Testing Coordinator, ODEQ headquarters in Portland, Oregon.

Please call me if you have any questions.

Sincerely,

Tim Homer
Air Emissions Lab Manager

cc: Dan Kunde - Georgia Pacific



Oregon

John A. Kitzhaber, MD, Governor

Department of Environmental Quality

Western Region - Salem Office

750 Front St NE Ste 120

Salem, OR 97301-1011

Ph: (503) 378-8240

Fax: (503) 373-7944

OTRS 1-800-735-2900

www.oregon.gov/DEQ

September 29, 2014

Mr. Daniel Kunde
Georgia Pacific Corporation
1400 SE Butler Bridge Rd.
Toledo, OR 97391

Mr. Tim Homer
Bighorn Environmental Air Quality
1324 N Liberty Lake Rd.
Liberty Lake, WA 99019

Re: Georgia Pacific Corporation
Title V Permit 21-0005-TV-01
Brown Stock Washer Methanol Source Test Plan

Dear Mr. Kunde and Mr. Homer:

The source test plan received on September 26, 2014 for testing at the Georgia Pacific facility located in Toledo, OR has been reviewed. The plan proposes to check the methanol emission rates from the brown stock washers. The methanol testing is approved with the following conditions:

GENERAL PROCESS CONDITIONS

- 1.) Only regular operating staff may adjust the production process and emission control parameters during the source performance tests and within two (2) hours prior to the tests. Any operating adjustments made during the source performance tests, which are a result of consultation during the tests with source testing personnel, equipment vendors or consultants, may render the source performance test invalid.
- 2.) Unless otherwise specified in the Permit, source testing shall be performed as follows:
 - At least 90% of the design capacity for new or modified equipment.
 - At least 90% of the maximum operating rate for existing equipment; or
 - At 90 to 110% of the normal maximum operating rate for existing equipment. The normal maximum operating rate is defined as the 90th percentile of the average hourly operating rates during a 12 month period.
- 3.) Documentation supporting the design capacity or operating rate determinations used must be included within the source test report.
- 4.) During compliance source testing, the following process parameters shall be determined, recorded and documented in the source test report. The process parameters below are to be reported for each individual test run and averaged for all test runs if appropriate.
 - Washer production rate (oven dried ton/hr)

EPA/ODEQ METHODS 1-4 CONDITIONS

- 4.) The flow rate for the exhaust stacks must meet the EPA Methods 1 & 2 criteria. For ducts with diameters less than 12" use EPA Method 1A instead of EPA Method 1. Clear diagrams and documentation of this must be included in the source test report.
- 5.) The exhaust ducts must be checked for cyclonic flow. Documentation of this must be provided in the test report.



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
RESEARCH TRIANGLE PARK, NC 27711

AUG 23 2006

OFFICE OF
AIR QUALITY PLANNING
AND STANDARDS

Mr. W. Samuel Adams, Jr.
Environmental Superintendent
Georgia-Pacific West, Inc.
Toledo Pulp and Paper Operations
1400 SE Butler Bridge Road
Toledo, Oregon 97391

Dear Mr. Adams:

This is in response to your letter dated August 3, 2006, which requests the approval of an alternative test method for measuring the methanol concentration of gas emission streams from your Kraft pulp mill in Toledo, Oregon. The method that you are proposing would be an alternative to Method 308 required by 40 CFR Part 63, Subpart S, National Emission Standards for Hazardous Air Pollutants from the Pulp and Paper Industry, Section 63.457. You are proposing to use NCASI Method CUSQ/PULP-94-03, entitled, "Chilled Impinger Test Method for Use on Pulp Mill Sources to Quantify Methanol Emissions," developed by the National Council for Air and Stream Improvement (NCASI) to measure methanol emissions. I notified the NCASI by letter dated October 6, 2004, that this test method met Method 301 criteria for measuring methanol from pulp and paper mill sources provided that the tester uses the appropriate correction factor. A copy of this letter is enclosed. Based on the data submitted by the NCASI and the similarity of the gas streams for which you propose to use the method to the gas streams from which the NCASI collected their supporting data, we are approving your request for use of this alternative test method at your facility in Toledo, Oregon.

Because we are currently able to approve alternative methods only on a site-specific basis, this approval to use NCASI Method CUSQ/PULP-94-03 is limited to its use at your facility in Toledo, Oregon. If you need further assistance, please contact Gary McAllister at (919) 541-1062.

Sincerely,

Connie B. Oldham, Ph.D., Group Leader
Measurement Technology Group

Enclosure

cc: Mr. Gary Andes, DEQ Western Regional Office
Mr. Doug Hendley, Region 10
Mr. Rai Peterson, DEQ Western Regional Office
Mr. Stephen Shedd, EPA/OAQPS/SPPD



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
RESEARCH TRIANGLE PARK, NC 27711

OCT 6 2004

Dr. Vipin Varma
NCASI
Southern Regional Center
P.O. Box 141020
Gainesville, Florida 32614-1020

OFFICE OF
AIR QUALITY PLANNING
AND STANDARDS

Dear Dr. Varma:

I am writing in response to your request dated June 5, 2003, asking that we review the date that you submitted supporting your request to modify NCASI Method CI/SG/PULP-94.02 by eliminating the backup silica gel tubes from the sampling train when it is used to measure only methanol. The modified method would be renamed as NCASI Method CI/SG/PULP-94.03. We agree with your conclusion that the modified method met Method 301 criteria for measuring methanol in air emissions samples from various sources at pulp and paper mills regulated under 40 CFR Part 63, Subpart S, Paragraph 446. I have summarized in the enclosed Table the correction factors for the different sources. During any future testing, the tester must document and use the appropriate correction factor to correct the data from the test method.

As we discussed, each specific source must make its own alternative test method request. However, we can and will consider the validation data that you submitted in evaluating an alternative method request from any source similar to the ones at which you collected your validation data.

If you have any questions about our comments or you would like to meet to discuss them, please contact Gary McAllister of my staff at (919) 541-1062.

Sincerely,

Conniesue B. Oldham
Conniesue B. Oldham, Ph.D., Group Leader
Source Measurement Technology Group

Enclosure

cc: K. C. Hustedt (C439-03)
Stephen A. Shedd (C439-03)
Jeffrey A. Telander (C504-05)