



Oregon

Tina Kotek, Governor

Department of Environmental Quality

Western Region Salem Office

4026 Fairview Industrial Dr SE

Salem, OR 97302

(503) 378-8240

FAX (503) 373-7944

TTY 711

January 3, 2025

Jennifer Hayward, Director of Facilities Management and Planning
Lane Community College
4000 East 30th Avenue
Eugene, OR 97406

Re: *Corrected* Pre-Enforcement Notice
Lane Community College
2024-PEN-9746
NPDES Permit #102116, EPA ID OR0026875
File 48854
WQ-Lane County

Dear Ms. Hayward,

DEQ has completed a records review for Lane Community College to determine compliance with the conditions of National Pollutant Discharge Elimination System permit number 102116 issued by DEQ on January 29, 2001. The findings are summarized below.

The original *Pre-Enforcement Notice 2024-PEN-9746* dated December 11, 2024, listed several missing annual reports. These reports were found by Lane Community College and were submitted as required by the permit and, therefore, are being removed from the list of violations. This also will remove any requested corrective actions listed in the original letter. In the future, please attach these reports in NetDMR or any other electronic data base as directed by DEQ.

Records Review

I reviewed records from January 2020 through November 2024. Lane Community College has submitted all monthly discharge monitoring reports (DMR) on time in NetDMR.

Schedule A Violations

Lane Community College is required to meet BOD₅ loading limits as listed in Schedule A of the permit. Lane Community College violated the following permit limits. The class of these violations is determined by OAR 340-012-0055(1)(k) and 340-012-0055(2)(a) as listed in Table 1 below.

Table 1: Schedule A Effluent Limit Violations

Monitoring Period	Parameter	Reported Value	Percentage Over Limit	Violation Class
February 2024	Monthly average, lb/day	50	43%	II
February 16, 2024	Daily maximum, lb/day	84.1	20%	II

Monitoring Period	Parameter	Reported Value	Percentage Over Limit	Violation Class
Week of Feb 11, 2024	Weekly average, lb/day	84.1	59%	I

Schedule B Violations

Lane Community College violated the following monitoring and reporting requirements in Schedule B of the permit. The class of these violations is determined by OAR 340-012-0055(1)(o) and OAR 340-012-0055(2)(b) as listed in Table 2 below.

Table 2: Schedule B Monitoring and Reporting Violations

Monitoring Period	Parameter	Monitoring Event Missed	Violation Class
March 30, 2024	Chlorine Residual, mg/L	Daily maximum	I
March 31, 2024	Chlorine Residual, mg/L	Daily maximum	I


Class I violations are the most serious violations; Class III violations are the least serious. Compliance with your permit is required by Oregon Revised Statute 468B.025(2).

These are serious violations, and they are being referred to DEQ's Office of Compliance and Enforcement for formal enforcement action. Formal enforcement action may result in assessment of a civil penalty and/or DEQ order. Civil penalties can be assessed for each day of violation.

If you believe any of the facts in this pre-enforcement letter are in error, you may provide information to me at the office at the address shown at the top of this letter. DEQ will consider the new information you submit and take appropriate action.

If you have any questions, please contact me in writing at brenda.kuiken@deq.oregon.gov or by phone at (503) 893-0924.

Sincerely,



Brenda Kuiken
WQ Compliance Specialist

cc: DEQ Salem Office file

ec: Ranei Nomura, Manager, Western Region DEQ
Oregon Records Management Solution