



Oregon

Tina Kotek, Governor

Department of Environmental Quality

Northwest Region

700 NE Multnomah Street, Suite 600

Portland, OR 97232

(503) 229-5696

FAX (503) 229-6124

TTY 711

July 30, 2024

Cain Petroleum Inc.
Attn: Ronald G Cain
4512 S Kelly Ave
Portland, OR 97239-4218

RE: UST Compliance Inspection
DEQ UST #11912 – 990 N Adair St, Cornelius

Dear Cain Petroleum Inc.:

The Oregon Department of Environmental Quality (DEQ) is conducting underground storage tank (UST) inspections throughout Oregon. The purpose of this letter is to inform you that your facilities, among others, has been selected for inspection. A thorough inspection of your facilities will be conducted to determine compliance with state and federal UST requirements. **The date you receive this letter is the date that the inspection starts.** If you have work done after that date, you will need to have the previous set of records available for evaluation in addition to the most recent records.

If I do not hear from you, the inspection for these facilities is scheduled for August 28th, 2024 starting at approximately 8:30 am at the DEQ UST #s listed below.

August 28th 8:30 am:

- **DEQ UST # 11912 – 990 N Adair St, Cornelius**

Please note that the inspection will require uninterrupted participation and attendance by you or a knowledgeable assistant. For the inspection you need to provide access to tank sumps, under dispenser areas, cathodic protection rectifiers, and leak monitoring equipment. DEQ will not touch the equipment or enter the facility, if you are unable to assist with equipment access, please have your UST Service Provider there. This inspection may also include review of Stage I Vapor Recovery.

DEQ staff will not assist with operating tank gauges.

The DEQ requests the following documentation be submitted electronically via email prior to the inspection:

- Line and leak detector testing results for the past three years,
- Monthly tank leak detection records, one year
- Class A, B, and C training documentation,
- Financial responsibility mechanism,
- Annual tank gauge certification for the past three years
- Spill prevention testing records, was due by October 2020
- Monthly walkthroughs, one year
- Overfill Prevention Equipment testing, was due by October 2020
- Cathodic protection testing (if applicable). All tests since 2019.

Please submit these records to ingrid.gaffney@deq.oregon.gov for review. If these records cannot be submitted prior to the inspection, please have them available for review at the facility.

Owners must also be able to operate the tank gauge and print out applicable reports such as the tank setup and in-tank alarm reports. Owners also must be able to sound high fill over alarm from the tank gauge, if applicable.


DEQ will not touch any equipment, if you are unable to assist with equipment access, please have your UST Service Provider there. DEQ will need to observe what equipment is in the tank top sumps and under the dispensers. If ball floats are the primary overfill protection device, these will need to be verified during the inspection, please be able to locate and remove the ball floats.

If violations are found at the time of the inspection without prior notification, DEQ is required to initiate enforcement action. For UST violations, enforcement usually begins with a field citation option, which is much like paying a traffic ticket and making corrections.

Some enforcement situations including repeat violations will go through a longer and more formal process including civil penalties.

Thank you for your cooperation. I can be reached at 503-229-5048 ingrid.gaffney@deq.oregon.gov to answer any questions you may have and assist you in the preparation for your inspection.

Sincerely,



Ingrid Gaffney
UST Compliance Specialist

Oregon Department of Environmental Quality - Underground Storage Tank Program
Technical Compliance Inspection - UST Inspection Report

Inspector: Ingrid Gaffney Date: 8/28/2024 Time: 8:30 Facility: 11912

| | | |
|---|---------------------------------------|-------------------------------|
| I. Site Information | | |
| Facility Name: <u>Cornelius chevron</u> | Permittee: <u>CAIN Petroleum INC.</u> | Contact: <u>Michael Bacon</u> |
| Site Address: <u>990 N Adair St</u> | Organization: <u>SAME</u> | Phone: _____ |
| City: <u>Cornelius, OR 97113</u> | Phone: _____ | |

| | | | | | |
|-----------------------------|-------------------------------------|---------------|----------|----------------|--|
| II. Tank Information | | | | | |
| DEQ Permit # | BEJAJ | BEJBK | BEJBA | BEJBB | |
| Estimated Gallons | 20,000 | 20,000 | 10,000 | 10,000 | |
| Substance | GASOLINE | GASOLINE | GASOLINE | DIESEL | |
| Tank Material | Fiberglass Xerxes | Xerxes | —————→ | —————→ | |
| Tank Install Date | 3/17/1999 | 3/17/1999 | —————→ | —————→ | |
| Pipe Material | APT Total containment | total contain | —————→ | APT | |
| Pipe Type | Pressure | Pressure | —————→ | —————→ | |
| Pipe Install Date | 3/17/1999 2009 | —————→ | —————→ | Newish line | |
| Overfill Device | Alarm | ALARM | ALARM | ALARM | |

Notes and Comments from the UST database: ☒ Check file before conducting inspection

*Two 20000 gal. tanks are siphon manifolded.

*7 liquid sensors.

If tanks are manifolded, which tanks: 20,000 x 2 (1/2)

| | | | |
|---|--|--|---|
| III. Operating Certificate | | Compliance | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| <input checked="" type="checkbox"/> Current | <input checked="" type="checkbox"/> Accurate | <input checked="" type="checkbox"/> Posted for delivery drive to observe | |

| | | | |
|------------------------------|---|----------------------------|---|
| IV. Operator Training | | Compliance | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| Class A/B Operator | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | Name: <u>Michael Bacon</u> | Date: <u>1/30/2015</u> |
| Class C Operator | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Cardlock | <u>Benjamin Huffman</u> | <u>1/30/2015</u> |

| | | | |
|--|-----------------------------------|----------------------------|---|
| V. Financial Responsibility | | Compliance | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| Type of coverage: <u>Insurance</u> | Begin Date: <u>7/31/2024</u> | End Date: <u>7/31/2025</u> | |
| Coverage amount correct: <u>\$1,000,000</u> | Number of tanks covered: <u>4</u> | | |
| Financial responsibility could also be in the form of self insurance, bonds, local government, trust fund, and or guaranteed | | | |

| | | | |
|---|--|---|---|
| VI. Walkthrough Requirements | | Compliance | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| Spill prevention and release detection equipment checked monthly? | | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No |
| Tank top sumps checked annually? | | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No |

11912

| | | | | | | | | | | | | |
|--|------------------------------|------------------------------|------------------------------|---|------------------------------|---|------------------------------|------------------------------|--|------------------------------|------------------------------|------------------------------|
| VII. Release Detection | | | | | | Compliance | | <input type="checkbox"/> Yes | <input checked="" type="checkbox"/> No | | | |
| a) Annual Release Detection Operability Testing (Sometimes referred to as Tank Gauge Certification) | | | | | | | | | | | | |
| Date of last testing: 1/3/2023 9/8/2022 | | | | Last three tests available? | | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No | | | | | |
| b) Piping Release Detection (Check all that apply) | | | | | | | | | | | | |
| acquired site in 2022 | | | | | | | | | | | | |
| <input checked="" type="checkbox"/> Pressurized Piping | | | | | | | | | | | | |
| <input checked="" type="checkbox"/> Mechanical Leak Detector (MLLD) <input type="checkbox"/> Electronic Leak Detector (ELLD) - check for swiftcheck requirement | | | | | | | | | | | | |
| Date of last testing: 9/21/2023 9/8/2022 | | | | Last three tests available? | | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No | | | | | |
| Number of lines tested: 4 | | | | Number of LD tested: 4 | | | | | | | | |
| Leak detector manufacturer make and model: 99LD Vaporless | | | | | | | | | | | | |
| Tank gauge manufacturer make and model: TLS 350 Veeder Root | | | | | | | | | | | | |
| MLLD on turbine manifold? | | | | | | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No | | | | | |
| MLLD product appropriate? (Example, diesel Red Jacket FX series on diesel system?) | | | | | | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No | | | | | |
| If ELLD and no line testing: Annual 0.1 gph results from tank gauge? | | | | | | <input type="checkbox"/> Yes | <input type="checkbox"/> No | | | | | |
| <input checked="" type="checkbox"/> Interstitial Monitoring | | | | | | | | | | | | |
| [Monthly records must include, date system was checked, observations made, initials of person checking. Electronic records must include power status (on or off), alarm indication status (yes or no) and sensor malfunction notes (yes or no).] | | | | | | | | | | | | |
| Date of last sump testing: N/A | | | | Last two tests available? | | <input type="checkbox"/> Yes | <input type="checkbox"/> No | | | | | |
| Date of last sensor testing: N/A | | | | Last three tests available? | | <input type="checkbox"/> Yes | <input type="checkbox"/> No | | | | | |
| Float sensors installed correctly? | | | | <input type="checkbox"/> Yes | <input type="checkbox"/> No | | | | | | | |
| Interstitial space opened to sump? | | | | <input type="checkbox"/> Yes | <input type="checkbox"/> No | | | | | | | |
| Presence of water in sumps? | | | | <input type="checkbox"/> Yes | <input type="checkbox"/> No | | | | | | | |
| <input type="checkbox"/> Safe Suction | | | | | | | | | | | | |
| Check valve directly below suction pump? | | | | <input type="checkbox"/> Yes | <input type="checkbox"/> No | | | | | | | |
| c) Monthly Tank Release Detection (Check all that apply) | | | | | | | | | | | | |
| <input checked="" type="checkbox"/> Tank Gauge <input checked="" type="checkbox"/> CSLD <input type="checkbox"/> SCALD <input type="checkbox"/> Static | | | | | | | | | | | | |
| Are correct tank sizes programmed at tank gauge? | | | | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No | | | | | | | |
| Tank diameter/length seem appropriate? | | | | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No | | | | | | | |
| Are tanks manifolded? | | | | <input checked="" type="checkbox"/> Yes | <input type="checkbox"/> No | | | | | | | |
| If so, tank gauge testing setup for manifolded tanks? | | | | <input type="checkbox"/> Yes | <input type="checkbox"/> No | | | | | | | |
| <div style="border: 1px solid black; padding: 5px; margin-top: 10px;">If Veeder Root tank gauge leak detection <input checked="" type="checkbox"/> CSLD set at 99% <input checked="" type="checkbox"/> Thermal coefficient set correctly? (Gasoline 0.00070; Diesel 0.00045) If Incon/Franklin tank gauge leak detection <input type="checkbox"/> If SCALD is Vol Qual set to 14% (or 99% confidence) <input type="checkbox"/> Is API gravity set correctly? (Regular 63.5; Plus 62.8; Super 51.3; Diesel 32.8) For all tank gauges doing static tests (Static tests require tank to be 50% full for a valid test)</div> | | | | | | | | | | | | |
| <input checked="" type="checkbox"/> Interstitial Monitoring [Monthly records must include, date system was checked, observations made, initials of person checking. Electronic records must include power status (on or off), alarm indication status (yes or no) and sensor malfunction notes (yes or no).] | | | | | | | | | | | | |
| <input type="checkbox"/> SIR Ensure pass or fail results within 30 day period. Inconclusive result means release detection requirement not met | | | | | | | | | | | | |
| siphon manifold. | | | | | | | | | | | | |
| Tank release detection records available during inspection | | | | | | | | | | | | |
| 2023 2023 | | | | | | | | | | | | |
| T1: | <input type="checkbox"/> Jan | <input type="checkbox"/> Feb | <input type="checkbox"/> Mar | <input type="checkbox"/> Apr | <input type="checkbox"/> May | <input type="checkbox"/> Jun | <input type="checkbox"/> Jul | <input type="checkbox"/> Aug | <input type="checkbox"/> Sep | <input type="checkbox"/> Oct | <input type="checkbox"/> Nov | <input type="checkbox"/> Dec |
| T2: | <input type="checkbox"/> Jan | <input type="checkbox"/> Feb | <input type="checkbox"/> Mar | <input type="checkbox"/> Apr | <input type="checkbox"/> May | <input type="checkbox"/> Jun | <input type="checkbox"/> Jul | <input type="checkbox"/> Aug | <input type="checkbox"/> Sep | <input type="checkbox"/> Oct | <input type="checkbox"/> Nov | <input type="checkbox"/> Dec |
| T3: | <input type="checkbox"/> Jan | <input type="checkbox"/> Feb | <input type="checkbox"/> Mar | <input type="checkbox"/> Apr | <input type="checkbox"/> May | <input type="checkbox"/> Jun | <input type="checkbox"/> Jul | <input type="checkbox"/> Aug | <input type="checkbox"/> Sep | <input type="checkbox"/> Oct | <input type="checkbox"/> Nov | <input type="checkbox"/> Dec |
| T4: | <input type="checkbox"/> Jan | <input type="checkbox"/> Feb | <input type="checkbox"/> Mar | <input type="checkbox"/> Apr | <input type="checkbox"/> May | <input type="checkbox"/> Jun | <input type="checkbox"/> Jul | <input type="checkbox"/> Aug | <input type="checkbox"/> Sep | <input type="checkbox"/> Oct | <input type="checkbox"/> Nov | <input type="checkbox"/> Dec |
| T5: | <input type="checkbox"/> Jan | <input type="checkbox"/> Feb | <input type="checkbox"/> Mar | <input type="checkbox"/> Apr | <input type="checkbox"/> May | <input type="checkbox"/> Jun | <input type="checkbox"/> Jul | <input type="checkbox"/> Aug | <input type="checkbox"/> Sep | <input type="checkbox"/> Oct | <input type="checkbox"/> Nov | <input type="checkbox"/> Dec |

Inspector: Ingrid Gaffney

Date: _____

Time: _____

Facility: 11912

VIII. Spill Prevention**Compliance**☒ Yes☐ No

Date(s) of testing:

11/2/2023

site acquired 2022

Number of spill buckets tested?

4

Did spill bucket pass most recent testing?

☒ Yes☐ No

If no, was spill bucket replaced/repaired?

☐ Yes☐ No

During inspection, visual damage to spill bucket?

☐ Yes☒ No☒ Hydrostatic testing (test takes one hour to complete)☐ Vacuum test (test takes 1 minute, ending vacuum must be 26 inches water column or greater)**IX. Overfill Prevention****Compliance**☒ Yes☐ No

Date(s) of testing:

9/21/2023

site acquired 2022

Overfill device pass most recent testing?

☐ Yes☐ No

If no, overfill device replaced?

☐ Yes☐ No

Overfill method that was tested:

☒ Alarm☐ Flapper☐ Ball FloatOverfill Alarm

Alarm sounds when tank is 90% full

☒ Yes☐ No

Driver can see or hear alarm at point of transfer?

☒ Yes☐ No

Sound alarm from tank gauge during inspection?

☒ Yes☐ NoFlapper Valve

Testing verified the valve automatically restricts flow at 95%

☐ Yes☐ No

Visual observation of flapper on day of inspection?

☐ Yes☐ NoBall Float

Testing verified the ball float automatically restricts flow at 90%

☐ Yes☐ No

Visual observation of ball float during inspection?

☐ Yes☐ No**X. Corrosion Protection****Compliance**☐ Yes☐ No☐ Cathodic☐ Galvanic☐ Impressed Current

Steel tank with cathodic?

☐ Yes☐ No

Steel pipes with cathodic?

☐ Yes☐ No

Steel flex-lines with cathodic?

☐ Yes☐ No

Date of cathodic test: _____

Last two tests available?

☐ Yes☐ No

Did last test pass?

☐ Yes☐ No

If not:

Was failed test reported to DEQ?

☐ Yes☐ No

Was system repaired?

☐ Yes☐ No

Date of repair? _____

Cathodic retested within 6 mos. of repair?

☐ Yes☐ No

Date of retesting? _____

If impressed current system:

Rectifier Operational?

☐ Yes☐ No

Rectifier log maintained?

☐ Yes☐ No

Rectifier been operating continuously

☐ Yes☐ No☐ Tank Lining

Date of last test? _____

Pressure test conducted after tank lining inspection?

☐ Yes☐ No

XI. General notes from inspection

Representative onsite: Michael Bacon email: mbacon@campetroleum.com

+ Acquired in 2022

* Monday Sept. 16th Testing

• CSW & Siphon manifold w/ 20,000 tanks x2

violation

* Dispenser #1 Supreme pipe is leaking. *

Compliance Determination: ☐ No Violations Observed ☒ Observed violations resulting in enforcement

Inspector Signature: Ingrid Gaffney Date: 8/28/2024



**OREGON DEPARTMENT OF ENVIRONMENTAL QUALITY
INSPECTION PHOTOLOG**

**FACILITY NAME: Cornelius Chevron #11912
INSPECTION DATE: August 28, 2024**

Page 1



1:990 N Adair St, Cornelius, OR 97113



2: Tank nest looking north



**OREGON DEPARTMENT OF ENVIRONMENTAL QUALITY
INSPECTION PHOTOLOG**

**FACILITY NAME: Cornelius Chevron #11912
INSPECTION DATE: August 28, 2024**

Page 1



3:Dispenser #10



4: UDC #10



OREGON DEPARTMENT OF ENVIRONMENTAL QUALITY
INSPECTION PHOTOLOG

FACILITY NAME: Cornelius Chevron #11912
INSPECTION DATE: August 28, 2024

Page 1



5:Dispenser #9



6: UDC #9



OREGON DEPARTMENT OF ENVIRONMENTAL QUALITY
INSPECTION PHOTOLOG

FACILITY NAME: Cornelius Chevron #11912
INSPECTION DATE: August 28, 2024

Page 1



7: UDC #8



8: Dispenser #8



**OREGON DEPARTMENT OF ENVIRONMENTAL QUALITY
INSPECTION PHOTOLOG**

**FACILITY NAME: Cornelius Chevron #11912
INSPECTION DATE: August 28, 2024**

Page 1



9: UDC #4



10: Dispenser #4



**OREGON DEPARTMENT OF ENVIRONMENTAL QUALITY
INSPECTION PHOTOLOG**

**FACILITY NAME: Cornelius Chevron #11912
INSPECTION DATE: August 28, 2024**

Page 1



11: UDC #1



12: UDC #1 leaking supreme pipe



**OREGON DEPARTMENT OF ENVIRONMENTAL QUALITY
INSPECTION PHOTOLOG**

**FACILITY NAME: Cornelius Chevron #11912
INSPECTION DATE: August 28, 2024**

Page 1



13: Pipe leak in UDC #1




14: Unleaded sump



**OREGON DEPARTMENT OF ENVIRONMENTAL QUALITY
INSPECTION PHOTOLOG**

**FACILITY NAME: Cornelius Chevron #11912
INSPECTION DATE: August 28, 2024**

Page 1



15: Unleaded fill



16: Diesel sump



**OREGON DEPARTMENT OF ENVIRONMENTAL QUALITY
INSPECTION PHOTOLOG**

**FACILITY NAME: Cornelius Chevron #11912
INSPECTION DATE: August 28, 2024**

Page 1



17: Diesel fill



18: Unleaded sump with manifold of 20,000 gallon tanks



**OREGON DEPARTMENT OF ENVIRONMENTAL QUALITY
INSPECTION PHOTOLOG**

**FACILITY NAME: Cornelius Chevron #11912
INSPECTION DATE: August 28, 2024**

Page 1



19: Premium fill



20: Premium sump



State of Oregon
Department of
Environmental
Quality

Program Enforcement No. 2024-FC-9507

Department of Environmental Quality Underground Storage Tank Program

Field Citation For UST Violations

This section for
DEQ use only

Page 1 of 3

| DEQ Information | | UST Facility Information | |
|------------------|---|--------------------------|---------------------------------------|
| Inspection Date: | 08/28/2024 | Facility ID#: | 11912 |
| Inspector: | Ingrid Gaffney | Facility Name: | Cornelius Chevron |
| DEQ Office: | 700 NE Multnomah St, Ste 600 Portland, OR 97232-9535 | Facility Address: | 990 N Adair St Cornelius, OR 97113 |
| Phone #: | 503-875-1246 | County: | Multnomah |

Oregon DEQ inspected the facility listed above and identified the UST violations listed on page 3 of this Field Citation.

| | | | |
|--|---|--|------------|
| Field Citation Issued: | <input type="radio"/> In Person <input checked="" type="radio"/> By Mail <input type="radio"/> Both | Date Issued: | 08/28/2024 |
| Facility Representative Present During Inspection: | Benjamin Huffman | <input type="radio"/> Permittee <input type="radio"/> Owner <input checked="" type="radio"/> Other | |
| Name of Permittee or Owner: | Cain Petroleum, Inc. Attn: Michael Bacon | | |
| Mailing Address: | 4512 S Kelly Ave, Portland, OR 97239-4218 | | |
| | | | |
| | | | |

| | | |
|---|--------|-----|
| Field Citation Penalty – See Page 3 for detailed listing of each violation. | \$ 300 | .00 |
|---|--------|-----|

This Field Citation is issued in accordance with the requirements for the expedited enforcement of underground storage tank (UST) violations, OAR 340-150-0250.

Owner or Permittee should select Option 1 or Option 2 below and return a signed copy of this form to DEQ by the following date: 09/28/2024

DEQ Revenue Section
700 NE Multnomah St. #600
Portland, Oregon 97232

Check one option

- ☐ **Option 1** - I acknowledge that the listed violation(s) have occurred and I am remitting the listed field citation penalty.
- ☐ **Option 2** - I do not want to participate in the expedited enforcement process and understand that my file will be referred to the Department's Office of Compliance and Enforcement for formal enforcement action.

| | |
|------------|-------------------|
| Name: | Owner / Permittee |
| Signature: | Date: |

Important

Read pages 2 and 3 for more information about your options and a detailed listing of violations and compliance requirements.

Field Citation Requirements

The permittee or owner should select Option 1 or Option 2 and return a signed copy of Page 1 of the Field Citation form within thirty (30) days of issuance of the Field Citation. If the permittee or owner fails to sign and send Page 1 of the Field Citation form back or pay the penalty within thirty days, Option 1 expires, the Field Citation will serve as a Pre-Enforcement Notice (PEN) and the permittee and owner will be subject to formal enforcement including the imposition of civil penalties in accordance with OAR Chapter 340, Division 12.

The permittee or owner must complete the actions required to correct the violations listed on the Field Citation by the date specified to prevent further enforcement action by DEQ.

Option 1:

By checking Option 1 the permittee or owner acknowledges that the violations listed on Page 3 of this Field Citation have occurred and agrees to pay the established penalty.

By submitting payment of the penalty amount, the responding permittee or owner agrees to accept the field citation as a final order of the Environmental Quality Commission (commission) and waives any and all rights and objections to the form, content, manner of service and timeliness of the Field Citation; to a contested case hearing and judicial review of the Field Citation [OAR 340-150-0250(6)]; and to service of a copy of this Final Order (*i.e.*, no other copy will be provided).

Upon the Department's receipt of payment of the penalty amount set forth in the Field Citation, the Field Citation becomes a Final Order of the Commission that:

1. Imposes upon the permittee or owner a civil penalty in the amount listed on Page 1 of this Field Citation; and
2. Requires the permittee or owner to satisfactorily complete the requirements and actions necessary to correct the violations documented by the dates set forth on Page 3 of this Field Citation.

Failure by the permittee or owner to complete the actions set forth on Page 3 of the Field Citation by the specified date violates the Commission Order and subjects the permittee and owner to a formal enforcement action including the imposition of additional civil penalties.

Option 2:

The permittee or owner may deny that the violations as listed on Page 3 of this Field Citation have occurred or contest the Field Citation process by checking Option 2 and submitting to the Department a signed copy of Page 1 of the Field Citation. In that event, the Field Citation will serve as a Pre-Enforcement Notice (PEN) and the permittee and owner will be subject to formal enforcement for those violations set forth in the Field Citation, including the imposition of civil penalties in accordance with OAR Chapter 340, Division 12. Civil penalties that will be imposed by the formal enforcement process will exceed the Field Citation penalties for the same violation(s).

The Department appreciates your cooperation and efforts to comply with the regulations for underground storage tank systems.

UST FIELD CITATION

DATE ISSUED: 08/28/2024

PROGRAM ENFORCEMENT No.: 2024-FC-9507

FACILITY ID: 11912

Page 3 of 3

| | | | |
|---|---|--|-----------------|
| Violation #1: *TCR: <input checked="" type="radio"/> Y <input type="radio"/> N | Failing investigate or confirm a suspected release in dispenser #1 from the supreme pipe. | | |
| Corrective Action: | Initiate investigation to confirm suspected release from UDC #1 supreme piping within 5 days. Repair or replace pipe and check regular sump. Provide repair and testing report to DEQ within 30 days. | | |
| Rule Citation: OAR 340-150- 0163(1) | Penalty Amount: \$ 300 .00 | Correct Violation by: 9/28/2024 | Date Corrected: |
| Violation #2: *TCR: <input type="radio"/> Y <input type="radio"/> N | | | |
| Corrective Action: | | | |
| Rule Citation: OAR 340-150- | Penalty Amount: \$.00 | Correct Violation by: | Date Corrected: |
| Violation #3: *TCR: <input type="radio"/> Y <input type="radio"/> N | | | |
| Corrective Action: | | | |
| Rule Citation: OAR 340-150- | Penalty Amount: \$.00 | Correct Violation by: | Date Corrected: |
| Violation #4: *TCR: <input type="radio"/> Y <input type="radio"/> N | | | |
| Corrective Action: | | | |
| Rule Citation: OAR 340-150- | Penalty Amount: \$.00 | Correct Violation by: | Date Corrected: |
| Violation #5: *TCR: <input type="radio"/> Y <input type="radio"/> N | | | |
| Corrective Action: | | | |
| Rule Citation: OAR 340-150- | Penalty Amount: \$.00 | Correct Violation by: | Date Corrected: |
| Violation #6: *TCR: <input type="radio"/> Y <input type="radio"/> N | | | |
| Corrective Action: | | | |
| Rule Citation: OAR 340-150- | Penalty Amount: \$.00 | Correct Violation by: | Date Corrected: |
| | Total Penalty Amount (This Page): \$ 300 .00 | Total Penalty Amount (All Pages): \$ 300 .00 | |

YOU MUST CORRECT THE VIOLATIONS AS REQUIRED, ENTER THE DATES CORRECTED, SIGN THE STATEMENT BELOW AND RETURN THIS FORM TO THE DEQ INSPECTOR LISTED ON PAGE 1 ON OR BEFORE: _____

Retain a copy of this form and all documentation of corrective actions for your records.

I hereby certify that the UST violations noted above have been corrected: _____ / _____
Permittee/Owner Signature Date

*TCR: Technical Compliance Rate

354514 CORNELIUS
990 N. ADAIR
CORNELIUS, OR. 97113
90759506005001

SEP 25, 2024 10:11 AM

SYSTEM STATUS REPORT
ALL FUNCTIONS NORMAL

INVENTORY REPORT

T 1:UNLEADED 1
VOLUME = 8326 GALS
ULLAGE = 11377 GALS
90% ULLAGE = 9406 GALS
TC VOLUME = 8284 GALS
HEIGHT = 51.38 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.4 DEG F

T 2:UNLEADED 2
VOLUME = 8295 GALS
ULLAGE = 11408 GALS
90% ULLAGE = 9437 GALS
TC VOLUME = 8252 GALS
HEIGHT = 51.24 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.5 DEG F

T 3:SUPER UNLEADED
VOLUME = 5355 GALS
ULLAGE = 4825 GALS
90% ULLAGE = 3807 GALS
TC VOLUME = 5328 GALS
HEIGHT = 61.30 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.3 DEG F

T 4:B20BIODIESEL
VOLUME = 4899 GALS
ULLAGE = 5470 GALS
90% ULLAGE = 4433 GALS
TC VOLUME = 4884 GALS
HEIGHT = 55.96 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 66.7 DEG F

* * * * * END * * * * *

354514 CORNELIUS
990 N. ADAIR
CORNELIUS, OR. 97113
90759506005001

SEP 25, 2024 10:11 AM

SYSTEM STATUS REPORT
ALL FUNCTIONS NORMAL

INVENTORY REPORT

T 1:UNLEADED 1
VOLUME = 8325 GALS
ULLAGE = 11378 GALS
90% ULLAGE = 9407 GALS
TC VOLUME = 8283 GALS
HEIGHT = 51.38 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.4 DEG F

T 2:UNLEADED 2
VOLUME = 8296 GALS
ULLAGE = 11407 GALS
90% ULLAGE = 9436 GALS
TC VOLUME = 8253 GALS
HEIGHT = 51.24 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.5 DEG F

T 3:SUPER UNLEADED
VOLUME = 5355 GALS
ULLAGE = 4825 GALS
90% ULLAGE = 3807 GALS
TC VOLUME = 5328 GALS
HEIGHT = 61.30 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.3 DEG F

T 4:B20BIODIESEL
VOLUME = 4899 GALS
ULLAGE = 5470 GALS
90% ULLAGE = 4433 GALS
TC VOLUME = 4884 GALS
HEIGHT = 55.96 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 66.7 DEG F

MANIFOLDED TANKS INVENTORY TOTALS

T 1:UNLEADED 1
T 2:UNLEADED 2
VOLUME = 16621 GALS
TC VOLUME = 16535 GALS

* * * * * END * * * * *



Since 1960

Remit To:
MASCOTT EQUIPMENT CO.
435 NE Hancock
Portland, OR 97212
(503) 282-2587
FAX (503) 288-9664

www.mascottec.com

INVOICE

| | |
|--------|------------|
| Number | 610622 |
| Date | 09/05/2024 |
| Page | 1 |

Bill-to Account #: 3880
CAIN PETROLEUM
4512 SW KELLY AVENUE
PORTLAND, OR 97239

Ship-to #: 31
CAIN PETROLEUM
990 N ADAIR AVE
CORNELIUS, OR 97113

| Reference # | Shipped | Salesperson | Terms | Tax Code | Doc # | Wh | Freight | Ship Via |
|------------------|------------|-------------|-------------|----------|--------|----|---------|----------|
| BEN 971-409-8860 | 09/05/2024 | HOWELLS | NET 10 DAYS | OR NOTAX | 492819 | 01 | BILL | SERVICE |

| Item | Description | Ordered | Shipped | Backordr | UM | Price | UM | Extension |
|---------------------|---|---------|---------|----------|----|--------|----|-----------|
| | DEQ INSPECTION REVEALED SEEPAGE ON PIPE NEAR SHEAR VALVE. PUMP # 1/2 PREMIUM. CLEAN AND TIGHTEN AS NEEDED | | | | | | | |
| LABOR-PD | LABOR, (On-Site/Shop Service) | .75 | .75 | .00 | EA | 105.00 | EA | 78.75 |
| LAPTOP CHARGE-PD | Network Access/Software Update | 1 | 1 | 0 | EA | 33.00 | EA | 33.00 |
| TRIP CHARGE-PD20 | LABOR, TRAVEL 0-20 MILEAGE | 1 | 1 | 0 | EA | 121.00 | EA | 121.00 |
| FUEL SURCHARGE-PD20 | FUEL SURCHARGE | 1 | 1 | 0 | EA | 6.70 | EA | 6.70 |
| SHOP-PD | Miscellaneous Materials Used | 1 | 1 | 0 | EA | 19.73 | EA | 19.73 |
| | 09/04 TECH TG: #1/2 TRACED LEAKAGE TO BASE PLATE CONNECTION TO TESTER'S PORT DISMANTLED, CLEANED, RE-PIPE DOPED, REASSEMBLED, VERIFIED 09/04 SAP | | | | | | | |

| 1. 15% RESTOCK FEE ON ANY RETURNED MERCHANDISE 2. NO RETURNS ACCEPTED WITHOUT PRIOR APPROVAL 3. THE CONDITIONS AS SET FORTH ON THE REVERSE SIDE HEREON SHALL APPLY TO THIS SALE 4. 15 DAYS ALLOWED FOR CORE RETURN REFUNDS | Merchandise | Misc | Discount | CAT Tax | Freight | Total Due |
|--|-------------|------|----------|---------|---------|-----------|
| | 259.18 | .00 | | 1.17 | .00 | 260.35 |

PLEASE PAY ON INVOICE - REMIT TO 435 NE HANCOCK - PORTLAND, OR 97212 - NO STATEMENT ISSUED UNLESS REQUESTED
PAST DUE ACCOUNTS SUBJECT TO 1.0% INTEREST CHARGE PER MONTH, 12% ANNUAL RATE
CREDIT CARD PAYMENTS ARE SUBJECT TO 3% SERVICE FEE.

Do not write below this line

Customer Copy

Continued on next page ...

SOINV



01-610622





Portland 435 NE Hancock Portland, OR 97212
Tri-Cities 200 S. 20th Ave. Pasco, WA 99301
Seattle 6530 5th Place South Seattle, WA 98108
Alaska 5610 Silverado Way Anchorage, AK 98518

Site Name: _____ Cornelius Chevron _____ Test Date: _____ 09/16/2024
Address: _____ 990 N Adair St _____
City, State, Zip: _____ Cornelius, OR 97113 _____

Test Data:

| | 1 | 2 | 3 | 4 | 5 |
|--------------------------------|-----------|-----------|-----------|-----------|---|
| Product | Regular 1 | Regular 2 | Super | Diesel | |
| Manufacturer | Vaporless | Vaporless | Vaporless | Vaporless | |
| Model | 99LD2000 | 99LD2000 | 99LD2000 | 99LD2000 | |
| Full Operating Pressure (psi) | 31 | 30 | 30 | 28 | |
| Trip Time (sec) | 3 | 4 | 3 | 4 | |
| Test Leak Rate (ml / min)(gph) | 3.0 gph | 3.0 gph | 3.0 gph | 3.0 gph | |
| Pass / Fail | Pass | Pass | Pass | Pass | |

Notes: _____

Per PEI RP 1200 9.1.6

This document certifies that the leak detectors tests were performed at the facility referenced above in accordance to the equipment manufacturers specifications. The results as listed are to my knowledge true and accurate. This document's test pass/fail is determined using a low flow threshold trip rate of 3 gph at 10 PSI.

Inspected By: _____

Technician Name: G. Druery

Technician Signature: Greg Druery

Digitally signed by Greg Druery
DN: cn=Greg Druery, o=pe, email=gdruery@mascottec.com, c=US
Date: 2024.09.17 12:12:28 -0700

DATA CHART FOR USE WITH PETROTITE LINE TESTER

WO#: 493573

STATION NUMBER: _____

DATE: 09/16/2024

1 LOCATION: Cornelius Chevron - 990 N Adair St - Cornelius, OR 97113

2 OWNER: Cain Petroleum

3 OPERATOR: Cain Petroleum

4 REASON FOR ANNUAL COMPLIANCE TESTING TEST: _____

5 TEST REQUESTED BY: Cain Petroleum

6 SPECIAL INSTRUCTIONS: _____

7 CONTRACTOR OR COMPANY MAKING TEST MASCOTT EQUIPMENT CO. G. Drury
MECHANIC(S) NAME: _____

8 IS A TANK TEST TO BE ☐ YES 9 MAKE AND TYPE OF FE Petro and Red Jacket submersible
MADE WITH THIS LINE TEST? ☒ NO PUMP OR DISPENSER (SUCTION OR SUBMERSIBLE)

10 WEATHER Warming TEMPERATURE IN TANKS 68 °F °C COVER Concrete OVER LINE BURIAL DEPTH 30"

| 11 IDENTIFY EACH LINE AS TESTED | 12 TIME (MILITARY) | 13 LOG OF TEST PROCEDURES, AMBIENT TEMPARATURE, WEATHER, ETC | 14 PRESSURE | | 15 VOLUME | | | 16 REMARKS |
|---------------------------------------|-----------------------|--|----------------|-------|----------------|-------|----------------|--|
| | | | Psi OR kPa | | READING | | NET CHANGE | SIZE, LENGTH & TYPE OF LINE, # FLEX CONNECTORS CONCLUSION, REPAIRS AND COMMENTS |
| | | | BEFORE | AFTER | BEFORE | AFTER | | |
| Regular | 1345 | Set up for line test. Pressurize line and observe. | 75 | | | | | APPROX. 220' Double wall flexible |
| | 1415 | Begin testing | ----- ----- | 60 | ----- ----- | .0630 | ----- ----- | Method of isolation: BALL VALVE |
| | 1430 | First reading | 60 | 60 | .0630 | .0630 | +0.0000 | |
| | 1445 | Second reading | 60 | 60 | .0630 | .0630 | +0.0000 | TESTED ALL LINES SIMULTANEOUSLY USING |
| | 1500 | Third reading | 60 | 60 | .0630 | .0630 | +0.0000 | MANIFOLD. |
| | 1515 | End of test | 60 | 60 | .0630 | .0630 | +0.0000 | |
| | | | | | | | | Passed sensitivity test |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

DATA CHART FOR USE WITH PETROTITE LINE TESTER

WO#: 493573

| | | | | | | | | |
|--------------|---------------------|---|----------------------------|----|-------------------------|-------|---------|--|
| Super | 1345 | Set up for line test. Pressurize line and observe. | 75 | | | | | APPROX. 190' Double wall flexible |
| | 1415 | Begin testing | ----- 60 ----- | 60 | ----- .0630 ----- | | | Method of isolation: BALL VALVE |
| | 1430 | First reading | 60 | 60 | .0630 | .0630 | + .0000 | |
| | 1445 | Second reading | 60 | 60 | .0630 | .0630 | + .0000 | TESTED ALL LINES SIMULTANEOUSLY USING |
| | 1500 | Third reading | 60 | 60 | .0630 | .0630 | + .0000 | MANIFOLD. |
| | 1515 | End of test | 60 | 60 | .0630 | .0630 | + .0000 | |
| | | | | | | | | Passed sensitivity test |
| | | | | | | | | |
| Diesel | 1345 | Set up for line test. Pressurize line and observe. | 75 | | | | | APPROX. 25' Double wall flexible |
| | 1415 | Begin testing | ----- 60 ----- | 60 | ----- .0630 ----- | | | Method of isolation: BALL VALVE |
| | 1430 | First reading | 60 | 60 | .0630 | .0630 | + .0000 | |
| | 1445 | Second reading | 60 | 60 | .0630 | .0630 | + .0000 | TESTED ALL LINES SIMULTANEOUSLY USING |
| | 1500 | Third reading | 60 | 60 | .0630 | .0630 | + .0000 | MANIFOLD. |
| | 1515 | End of test | 60 | 60 | .0630 | .0630 | + .0000 | |
| | | | | | | | | Passed sensitivity test |
| TEST RESULTS | | | | | | | | 17 CONTRACTOR CERTIFICATION |
| | | | | | | | | Tech: G. Druery |
| | Line Identification | Pass / Fail | Net Volume Change per Hour | | Date Tested | | | X Greg Druery |
| | Regular | Pass | + .0000 | | 09/16/2024 | | | Signature |
| | Super | Pass | + .0000 | | 09/16/2024 | | | CERTIFICATION# |
| | Diesel | Pass | + .0000 | | 09/16/2024 | | | 8d0c96fb |



Mascott Equipment Co.
435 NE Hancock Portland, OR 97212
(800) 452-5019

| Company Name: <u>Cornelius Chevron</u> | | | | Monitor Make: <u>Veeder-Root</u> | | | | |
|--|-----------------------|------|------------------------------------|---|------------------|------|-----|----------|
| Site Address: <u>990 N Adair St</u> | | | | Monitor Model: <u>TLS-350</u> | | | | |
| City, State, Zip: <u>Cornelius, OR 97113</u> | | | | Serial Number: <u>90759506005001</u> | | | | |
| Date: <u>09/16/2024</u> | | | | Software Version: <u>133.01</u> | | | | |
| Console | Tank # / Size | Pass | Fail | Actions Performed / Console | Pass | Fail | N/A | Comments |
| Print or view status of all tanks. Leave copy on site if any programming changes are made. | Unleaded 1 19,703 gal | X | | Verify date and time | X | | | |
| | Unleaded 2 19,703 gal | X | | Verify setup values | X | | | |
| | Super 10,180 gal | X | | Check battery | X | | | |
| | Diesel 10,369 gal | X | | Test external alarm if applicable | X | | | |
| | | | | Run system diagnostics | X | | | |
| | | | | Verify tests for compliance | X | | | |
| | | | | | | | | |
| Sensors | Sensor # / Location | Pass | Fail | Actions Performed / Probes | Pass | Fail | N/A | Comments |
| Print out sensor status and leave on site. Put all sensors into alarm and verify proper operation. | Unleaded 1 STP sump | X | | Run probe diagnostics | X | | | |
| | Unleaded 2 STP sump | X | | Inspect cables and connections | X | | | |
| | Super STP sump | X | | Removed, Cleaned and inspected probe | X | | | |
| | Diesel STP sump | X | | Verified overfill function at 90% | | | X | |
| | Unleaded 1 annular | X | | | | | | |
| | Unleaded 2 annular | X | | Actions Performed / Sensors | Pass | Fail | N/A | Comments |
| | Super-Diesel annular | X | | Run sensor diagnostics | X | | | |
| | | | | Inspect cables and connections | X | | | |
| | | | | Test sensor for operation | X | | | |
| | | | | Inspect and clean sensors | X | | | |
| | | | | | | | | |
| | | | | Additional Service Checks | Yes | No | N/A | Comments |
| | | | | Lights, LED's, annunciator functioning? | X | | | |
| | | | | Is customer saving required reports? | X | | | |
| | | | | Is Cathodic Protection Required? | | X | | |
| | | | | *Note CP issues and test date* | | | | |
| | | | | Type of Overfill Protection | Electronic alarm | | | |
| | | | Type of Leak Detection | Mechanical | | | | |
| | | | Primary Tank Leak Detection Method | CSLD | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

Technician Name: G. Druery Technician Signature: Greg Druery

Digitally signed by Greg Druery
DN: cn=Greg Druery, o, ou,
email=gdrury@mascottec.com, c=US
Date: 2024.09.17 12:11:38 -07'00'



Annual Release Detection Operability Testing Form

- In-tank setup and alarm history reports must be attached to testing form.
- Maintain three years of testing records.
- [Instructions on how to use this form.](#)

| I. FACILITY INFORMATION – Type or print (in ink) all items. | | | | TEST DATE |
|--|--|---|--|--|
| Facility ID #: | 11912 | Facility Name: | Cornelius Chevron | 09/16/2024 |
| II. AUTOMATIC TANK GAUGE | | | | <input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail |
| ATG Manufacturer: | Veeder Root | | ATG Model: | TLS-350 |
| Release Detection Method: | | Tank Gauge 0.2 gph leak tests: (<input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Static) <input type="checkbox"/> SIR <input checked="" type="checkbox"/> Interstitial Monitoring | | |
| Battery Backup Functional? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | ATG software properly programmed? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | |
| ATG alarms functional and audible? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | ATG In-Tank Setup Reports attached to form? <input checked="" type="checkbox"/> Yes | | |
| III. TEST PROCEDURE | | | | |
| <input type="checkbox"/> PEI/RP 1200 | <input checked="" type="checkbox"/> Oregon Testing Procedures (Page 2) | | <input type="checkbox"/> Manufacturer Testing Procedures | <input type="checkbox"/> Other Method (Describe) |
| | | | | |

IV. PROBE AND TESTING INFORMATION

| | | | | | |
|---|--|--|--|--|---|
| Tank Number | 1 | 2 | 3 | 4 | |
| Product Stored | Regular | Regular | Super | Diesel | |
| Model | MAG | MAG | MAG Plus | MAG | |
| Is the ATG console clear of alarms? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Disconnect cable from tank probe. Is appropriate alarm triggered? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Tank gauge probes removed and inspected for damage? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Residual buildup on floats has been removed? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Float(s) move freely? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Measured product and water levels match ATG values? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Alarm history report attached? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| V. TEST RESULT | <input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail | <input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail | <input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail | <input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail | <input type="checkbox"/> Pass <input type="checkbox"/> Fail |

Any "No" answer indicates the test failed. Failed tests must be remedied and retested immediately.

VIII. COMMENTS

The comments section should be used to note additional information discovered or actions taken during testing that affect compliance

IX. TESTER

Person conducting testing: G. Druery

DEQ tank gauge and probe functionality testing procedures

1. Inspect console and verify that there are no active or recurring warnings or alarms.
2. Confirm that both the visual and audible alarms on the tank gauge console function correctly.
3. Verify that the correct set-up parameters for the probes and appropriate tank leak detection is programmed correctly.
4. Test battery backup (if present).
5. Remove tank probe from tank.
6. Disconnect probe, wait for "Probe Out" alarm, reconnect probe and reset tank gauge.
7. Remove build up from probes.
8. Measure the fuel and water contents of the tank and compare with the tank gauge inventory report ensuring that they are the same.
9. Ensure that the probe's fuel and water floats are the correct type for the product stored in the tank.
10. Reposition the floats, measure distance from bottom of the probe, and utilize tank charts to confirm accuracy of the tank gauge.
11. Reinstall probes ensuring that the tank riser cap seals properly and the communication cable seal is tight.
12. If tank gauge is equipped with printer, attach the printed tank gauge in-tank setup and alarm history report demonstrating that probes were tested.

DEQ sensor functionality testing procedures

1. Inspect sensor for damage.
2. Place sensor in at least three inches of testing liquid.
3. Verify sensor alarms at tank gauge or sensor has appropriate alarm response (dispenser or turbine shut down).
4. Clear alarm.
5. Reinstall sensor upon verification of proper operation.
6. If tank gauge is equipped with printer, attach the printed tank gauge in-tank setup and alarm history report demonstrating that sensors were tested.

SYSTEM SETUP

SEP 16, 2024 12:40 PM

SYSTEM UNITS

U.S.

SYSTEM LANGUAGE

ENGLISH

SYSTEM DATE/TIME FORMAT

MON DD YYYY HH:MM:SS xM

354514 CORNELIUS

990 N. ADAIR

CORNELIUS, OR. 97113

90759506005001

SHIFT TIME 1 : 6:00 AM

SHIFT TIME 2 : DISABLED

SHIFT TIME 3 : DISABLED

SHIFT TIME 4 : DISABLED

TANK PER TST NEEDED WRN

DISABLED

TANK ANN TST NEEDED WRN

DISABLED

LINE RE-ENABLE METHOD

PASS LINE TEST

LINE PER TST NEEDED WRN

DISABLED

LINE ANN TST NEEDED WRN

DISABLED

PRINT TC VOLUMES

ENABLED

TEMP COMPENSATION

VALUE (DEG F): 60.0

STICK HEIGHT OFFSET

DISABLED

ULLAGE: 90%

H-PROTOCOL DATA FORMAT

HEIGHT

DAYLIGHT SAVING TIME

ENABLED

START DATE

MAR WEEK 2 SUN

START TIME

2:00 AM

END DATE

NOV WEEK 1 SUN

END TIME

2:00 AM

RE-DIRECT LOCAL PRINTOUT

DISABLED

EURO PROTOCOL PREFIX

S

SYSTEM SECURITY

CODE : 000000

TANK CHART SECURITY

DISABLED

CUSTOM ALARMS

DISABLED

SERVICE NOTICE

DISABLED

T 4:B20BIODIESEL
PRODUCT CODE : 4
THERMAL COEFF : .000450
TANK DIAMETER : 120.00
TANK PROFILE : 20 PTS
FULL VOL : 10369
114.0 INCH VOL : 10297
108.0 INCH VOL : 10042
102.0 INCH VOL : 9670
96.0 INCH VOL : 9209
90.0 INCH VOL : 8676
84.0 INCH VOL : 8085
78.0 INCH VOL : 7448
72.0 INCH VOL : 6778
66.0 INCH VOL : 6084
60.0 INCH VOL : 5377
54.0 INCH VOL : 4667
48.0 INCH VOL : 3965
42.0 INCH VOL : 3280
36.0 INCH VOL : 2624
30.0 INCH VOL : 2007
24.0 INCH VOL : 1441
18.0 INCH VOL : 939
12.0 INCH VOL : 516
6.0 INCH VOL : 193

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 2.5
WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10369
OVERFILL LIMIT : 90%
: 9332
HIGH PRODUCT : 95%
: 9850
DELIVERY LIMIT : 10%
: 1036

LOW PRODUCT : 500
LEAK ALARM LIMIT: 10
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 15%
: 1555

LEAK MIN ANNUAL : 0%
: 0

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN

ALARM HISTORY REPORT

----- IN-TANK ALARM -----

T 1:UNLEADED 1

OVERFILL ALARM

SEP 21, 2023 12:14 PM
JAN 3, 2023 2:15 PM

HIGH PRODUCT ALARM

JAN 3, 2023 2:15 PM

INVALID FUEL LEVEL

SEP 21, 2023 12:12 PM
DEC 23, 2022 2:45 PM

PROBE OUT

SEP 16, 2024 2:35 PM
SEP 21, 2023 12:15 PM
SEP 21, 2023 12:14 PM

DELIVERY NEEDED

JAN 19, 2024 8:03 AM
SEP 21, 2023 12:12 PM
AUG 3, 2023 8:06 PM

PER TST NEEDED WRN

JAN 7, 2023 12:00 AM

PER TST NEEDED ALM

FEB 1, 2023 12:00 AM
JAN 31, 2023 12:00 AM
JAN 29, 2023 12:00 AM

CSLD INCR RATE WARN

JUN 21, 2023 3:26 AM
JUN 6, 2023 8:00 AM
MAY 31, 2023 5:43 AM

LOW TEMP WARNING

SEP 16, 2024 2:37 PM
SEP 21, 2023 12:15 PM

* * * * * END * * * * *

ALARM HISTORY REPORT

----- IN-TANK ALARM -----

T 2:UNLEADED 2

OVERFILL ALARM

SEP 21, 2023 12:06 PM
JAN 3, 2023 2:21 PM

HIGH PRODUCT ALARM

JAN 3, 2023 2:21 PM

From: [LITKE Emily * DEQ](#)
To: [GAFFNEY Ingrid * DEQ](#); [Michael Bacon](#)
Cc: [UST Duty Officer * DEQ](#); bhuffman@cainpetroleum.com
Subject: RE: DEQ UST Inspection Determination: Cornelius Chevron #11912
Date: Tuesday, October 1, 2024 3:21:00 PM

I am following up on the inspection completed by Ingrid Gaffney on 8/28/24 for facility 11912 Cornelius Chevron

The deadline for the payment of the \$300 fine and corrective was 9/28/24.

Please send the invoice from the work completed by Mascott on 9/16/24 and the invoice/work order for work completed by Patriot Environmental on 9/25/24.

Emily Litke (she/her)
Duty Officer, Underground Storage Tanks
DEQ Headquarters, Land Quality Division
700 NE Multnomah Street, Suite 600
Portland OR 97232-4100
503-806-9516
Emily.LITKE@deq.oregon.gov

-----Original Message-----

From: GAFFNEY Ingrid * DEQ <Ingrid.GAFFNEY@deq.oregon.gov>
Sent: Monday, September 23, 2024 5:21 PM
To: Michael Bacon <MBacon@cainpetroleum.com>
Cc: UST Duty Officer * DEQ <UST.DutyOfficer@DEQ.oregon.gov>; bhuffman@cainpetroleum.com; LITKE Emily * DEQ <Emily.Litke@deq.oregon.gov>
Subject: RE: DEQ UST Inspection Determination: Cornelius Chevron #11912

Great. Thanks so much! Make sure to send the payment too.

Regards,

Ingrid Gaffney
UST Compliance Inspector
DEQ UST Program
700 NE Multnomah St, Ste 600
Portland, OR 97232
<https://www.oregon.gov/deq/Pages/index.aspx>
she/ her

-----Original Message-----

From: Michael Bacon <MBacon@cainpetroleum.com>
Sent: Monday, September 23, 2024 4:32 PM
To: GAFFNEY Ingrid * DEQ <Ingrid.GAFFNEY@deq.oregon.gov>
Cc: UST Duty Officer * DEQ <UST.DutyOfficer@deq.oregon.gov>; bhuffman@cainpetroleum.com; LITKE Emily * DEQ <Emily.Litke@deq.oregon.gov>
Subject: Re: DEQ UST Inspection Determination: Cornelius Chevron #11912

Yes we had Mascott out the next day to address the seepage and found that it was a simple fix. I will forward you the invoice. Testing was performed on the 16th and everything passed. I will forward you the test results from Mascott. Alex from Patriot Environmental will be onsite 09/25 to address veeder root issues

On Mon, Sep 23, 2024 at 9:40 AM GAFFNEY Ingrid * DEQ <Ingrid.GAFFNEY@deq.oregon.gov> wrote:

>

> Hello Cain Petroleum

>

> Has anything been sent or done to demonstrate to DEQ the below violations are addressed?

>

>

>

> Please provide an update. Thank you!

>

>

>

> Regards,

>

>

>

> Ingrid Gaffney

>

> UST Compliance Inspector

>

> DEQ UST Program

>

> 700 NE Multnomah St, Ste 600

>

> Portland, OR 97232

>

> <https://www.oregon.gov/deq/Pages/index.aspx>

>

> she/ her

>

>

>

> From: UST Duty Officer * DEQ

> Sent: Wednesday, August 28, 2024 3:35 PM

> To: Michael Bacon <MBacon@cainpetroleum.com>

> Cc: bhuffman@cainpetroleum.com

> Subject: DEQ UST Inspection Determination: Cornelius Chevron #11912

>

>

>

> Hello Michael and Ben,

>

> Thank you for meeting with DEQ onsite August 28, 2024, to inspect the underground storage tanks at 990 N Adair St, Cornelius, OR 97113.

>

>

>

> Since DEQ observed a release of product in UDC #1 (product
> dripping/weeping from the supreme pipe) at 990 N Adair St, Cornelius.

> DEQ must issue a field citation, per enforcement guidance. Please see

> the attached citation and note about your set up for the siphoned

> tanks

>

>

>

> This field citation will help DEQ keep track of the necessary repairs and testing required due to the observed

release. The field citation states Troutdale Foodmart has 30 days to perform or schedule the repairs and necessary repair testing.

>

> If you require more time, please let the DEQ UST Duty Officer know (see contact below).

>

> Please contact the UST Duty Officer at 503-229-5034 or ust.dutyofficer@deq.oregon.gov for the investigation and testing and be sure to email the UST duty officer when sending over the final documentation.

>

>

>

> CORRECTIVE ACTIONS:

>

>

>

> Initiate investigation to confirm suspected release into UDC #1 supreme pipe within 5 days. Provide repair and testing report to DEQ within 30 days.

> Have the service provider correct the siphon manifold setting for the site so that the two 20,000 tanks are set up correctly in the veeder root.

>

>

>

>

>

>

>

> Regards,

>

>

>

> Ingrid Gaffney

>

> UST Compliance Inspector

>

> DEQ UST Program

>

> 700 NE Multnomah St, Ste 600

>

> Portland, OR 97232

>

> <https://www.oregon.gov/deq/Pages/index.aspx>

>

> she/ her

>

>

--

Michael Bacon
Retail Operations Coordinator
Cain Petroleum
971-717-4383

**DEPARTMENT OF ENVIRONMENTAL QUALITY
TRANSMITTAL ADVICE
UST EXPEDITED ENFORCEMENT PROG**

| CK # | TRAN AMNT | FOR THE ACCOUNT OF | CIVIL PENALTY # |
|----------------|-----------|----------------------------------|-----------------|
| CHECK NAME | | REASON FOR PAYMENT | INV # RCPT # |
| 43242 | 300.00 | CORNELIUS CHEVRON | 2024-FC-9507 |
| CAIN PETROLEUM | | FIELD CITATION FOR UST VIOLATION | FC-9507 |
| | 300.00 | TOTAL | |

| | | | | | | | | | |
|--------------|-------|----------|-------------------|----------------|---------|--------------|----------|----------------------------------|-----------|
| ED20241002AD | 43242 | \$300.00 | CORNELIUS CHEVRON | CAIN PETROLEUM | FC-9507 | 2024-FC-9507 | USTXPENF | FIELD CITATION FOR UST VIOLATION | 10/2/2024 |
|--------------|-------|----------|-------------------|----------------|---------|--------------|----------|----------------------------------|-----------|

Program Enforcement Maintenance

Program Enforcement

Violations List (1)

Corrective Actions (0)

Link Actions

File #

11912

Create PEN

Create OCE Enforcement

Name CORNELIUS CHEVRON

Location 990 N ADAIR ST / CORNELIUS / WASHINGTON

Permit UST General Permit.34-11912-2024-OPER.Active

Recipient Information:

Show Recipient Selection

Name / Title Bacon, Michael /

Address 4512 S Kelly Ave / Portland / OR / 97239-4218

Phone / Fax / Email 503-546-3535 / 503-546-3530 / Mbacon@cainpetroleum.com

Edit

Delete

Program Enforcement Number 2024-FC-9507

Regulatory Program Underground Storage Tanks

Staff Assigned Ingrid Gaffney

Enforcement Type Field Citation

Enforcement Action Issued Date 08/28/2024

Show Calendar

Response Received Date

Show Calendar

Payment Due Date 09/28/2024

Show Calendar

Payment Received Date

Show Calendar

Penalty Amount \$300.00

PEN Referral Date

Show Calendar

Closed Date

Show Calendar

Withdrawn Date

Show Calendar

Link To Complaint

Comments

Dispenser #1 has a suspected release from a weeping supreme pipe.
Check #43242 for \$300 on the account of Cain Petroleum was received and processed on 10/2/24. DA

Edit

Delete

Create By 08/28/2024 03:24:11 PM

Ingrid Gaffney



State of Oregon
Department of
Environmental
Quality

Program Enforcement No. 2024-FC-9507

Department of Environmental Quality Underground Storage Tank Program

This section for
DEQ use only

Field Citation

OCT 02 2024

For UST Violations

Page 1 of 3

| DEQ Information | | UST Facility Information | |
|------------------|---|--------------------------|---------------------------------------|
| Inspection Date: | 08/28/2024 | Facility ID#: | 11912 |
| Inspector: | Ingrid Gaffney | Facility Name: | Cornelius Chevron |
| DEQ Office: | 700 NE Multnomah St, Ste 600 Portland, OR 97232-9535 | Facility Address: | 990 N Adair St Cornelius, OR 97113 |
| Phone #: | 503-875-1246 | County: | Multnomah |

Oregon DEQ inspected the facility listed above and identified the UST violations listed on page 3 of this Field Citation.

| | | | |
|--|---|--|------------|
| Field Citation Issued: | <input type="radio"/> In Person <input checked="" type="radio"/> By Mail <input type="radio"/> Both | Date Issued: | 08/28/2024 |
| Facility Representative Present During Inspection: | Benjamin Huffman | <input type="radio"/> Permittee <input type="radio"/> Owner <input checked="" type="radio"/> Other | |
| Name of Permittee or Owner: | Cain Petroleum, Inc. Attn: Michael Bacon | | |
| Mailing Address: | 4512 S Kelly Ave, Portland, OR 97239-4218 | | |

| | |
|---|------------|
| Field Citation Penalty – See Page 3 for detailed listing of each violation. | \$ 300 .00 |
|---|------------|

This Field Citation is issued in accordance with the requirements for the expedited enforcement of underground storage tank (UST) violations, OAR 340-150-0250.

Owner or Permittee should select Option 1 or Option 2 below and return a signed copy of this form to DEQ by the following date: 09/28/2024

DEQ Revenue Section
700 NE Multnomah St. #600
Portland, Oregon 97232

Check one option

- ☒ **Option 1** - I acknowledge that the listed violation(s) have occurred and I am remitting the listed field citation penalty.
- ☐ **Option 2** - I do not want to participate in the expedited enforcement process and understand that my file will be referred to the Department's Office of Compliance and Enforcement for formal enforcement action.

| | |
|-------------------------------|-----------------------|
| Name: <u>MICHAEL BACON</u> | Owner / Permittee |
| Signature: <u>[Signature]</u> | Date: <u>09/25/24</u> |

Important

Read pages 2 and 3 for more information about your options and a detailed listing of violations and compliance requirements.

Field Citation Requirements

The permittee or owner should select Option 1 or Option 2 and return a signed copy of Page 1 of the Field Citation form within thirty (30) days of issuance of the Field Citation. If the permittee or owner fails to sign and send Page 1 of the Field Citation form back or pay the penalty within thirty days, Option 1 expires, the Field Citation will serve as a Pre-Enforcement Notice (PEN) and the permittee and owner will be subject to formal enforcement including the imposition of civil penalties in accordance with OAR Chapter 340, Division 12.

The permittee or owner must complete the actions required to correct the violations listed on the Field Citation by the date specified to prevent further enforcement action by DEQ.

Option 1:

By checking Option 1 the permittee or owner acknowledges that the violations listed on Page 3 of this Field Citation have occurred and agrees to pay the established penalty.

By submitting payment of the penalty amount, the responding permittee or owner agrees to accept the field citation as a final order of the Environmental Quality Commission (commission) and waives any and all rights and objections to the form, content, manner of service and timeliness of the Field Citation; to a contested case hearing and judicial review of the Field Citation [OAR 340-150-0250(6)]; and to service of a copy of this Final Order (*i.e.*, no other copy will be provided).

Upon the Department's receipt of payment of the penalty amount set forth in the Field Citation, the Field Citation becomes a Final Order of the Commission that:

1. Imposes upon the permittee or owner a civil penalty in the amount listed on Page 1 of this Field Citation; and
2. Requires the permittee or owner to satisfactorily complete the requirements and actions necessary to correct the violations documented by the dates set forth on Page 3 of this Field Citation.

Failure by the permittee or owner to complete the actions set forth on Page 3 of the Field Citation by the specified date violates the Commission Order and subjects the permittee and owner to a formal enforcement action including the imposition of additional civil penalties.

Option 2:

The permittee or owner may deny that the violations as listed on Page 3 of this Field Citation have occurred or contest the Field Citation process by checking Option 2 and submitting to the Department a signed copy of Page 1 of the Field Citation. In that event, the Field Citation will serve as a Pre-Enforcement Notice (PEN) and the permittee and owner will be subject to formal enforcement for those violations set forth in the Field Citation, including the imposition of civil penalties in accordance with OAR Chapter 340, Division 12. Civil penalties that will be imposed by the formal enforcement process will exceed the Field Citation penalties for the same violation(s).

**The Department appreciates your cooperation and efforts to
comply with the regulations for underground storage tank
systems.**

UST FIELD CITATION

DATE ISSUED: 08/28/2024

PROGRAM ENFORCEMENT No.: 2024-FC-9507

FACILITY ID: 11912

Page 3 of 3

Violation #1:
***TCR:** ☒ Y ☐ N

Failing investigate or confirm a suspected release in dispenser #1 from the supreme pipe.

Corrective Action:

Initiate investigation to confirm suspected release from UDC #1 supreme piping within 5 days. Repair or replace pipe and check regular sump. Provide repair and testing report to DEQ within 30 days.

Rule Citation: **OAR 340-150- 0163(1)**

Penalty Amount: \$ 300 .00

Correct Violation by: 9/28/2024

Date Corrected: 9/5/24

Violation #2:
***TCR:** ☐ Y ☐ N

Corrective Action:

Rule Citation: **OAR 340-150-**

Penalty Amount: \$.00

Correct Violation by:

Date Corrected:

Violation #3:
***TCR:** ☐ Y ☐ N

Corrective Action:

Rule Citation: **OAR 340-150-**

Penalty Amount: \$.00

Correct Violation by:

Date Corrected:

Violation #4:
***TCR:** ☐ Y ☐ N

Corrective Action:

Rule Citation: **OAR 340-150-**

Penalty Amount: \$.00

Correct Violation by:

Date Corrected:

Violation #5:
***TCR:** ☐ Y ☐ N

Corrective Action:

Rule Citation: **OAR 340-150-**

Penalty Amount: \$.00

Correct Violation by:

Date Corrected:

Violation #6:
***TCR:** ☐ Y ☐ N

Corrective Action:

Rule Citation: **OAR 340-150-**

Penalty Amount: \$.00

Correct Violation by:

Date Corrected:

Total Penalty Amount (This Page): \$ 300 .00

Total Penalty Amount (All Pages): \$ 300 .00

YOU MUST CORRECT THE VIOLATIONS AS REQUIRED, ENTER THE DATES CORRECTED, SIGN THE STATEMENT BELOW AND RETURN THIS FORM TO THE DEQ INSPECTOR LISTED ON PAGE 1 ON OR BEFORE: _____

Retain a copy of this form and all documentation of corrective actions for your records.

I hereby certify that the UST violations noted above have been corrected:

Permittee/Owner Signature

1 09/25/24
Date

354514 CORNELIUS
990 N. ADAIR
CORNELIUS, OR. 97113
90759506005001

SEP 25, 2024 10:11 AM

SYSTEM STATUS REPORT
ALL FUNCTIONS NORMAL

INVENTORY REPORT

T 1:UNLEADED 1
VOLUME = 8326 GALS
ULLAGE = 11377 GALS
90% ULLAGE = 9406 GALS
TC VOLUME = 8284 GALS
HEIGHT = 51.38 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.4 DEG F

T 2:UNLEADED 2
VOLUME = 8295 GALS
ULLAGE = 11408 GALS
90% ULLAGE = 9437 GALS
TC VOLUME = 8252 GALS
HEIGHT = 51.24 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.5 DEG F

T 3:SUPER UNLEADED
VOLUME = 5355 GALS
ULLAGE = 4825 GALS
90% ULLAGE = 3807 GALS
TC VOLUME = 5328 GALS
HEIGHT = 61.30 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.3 DEG F

T 4:B20BIODIESEL
VOLUME = 4899 GALS
ULLAGE = 5470 GALS
90% ULLAGE = 4433 GALS
TC VOLUME = 4884 GALS
HEIGHT = 55.96 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 66.7 DEG F

* * * * * END * * * * *

354514 CORNELIUS
990 N. ADAIR
CORNELIUS, OR. 97113
90759506005001

SEP 25, 2024 10:11 AM

SYSTEM STATUS REPORT
ALL FUNCTIONS NORMAL

INVENTORY REPORT

T 1:UNLEADED 1
VOLUME = 8325 GALS
ULLAGE = 11378 GALS
90% ULLAGE = 9407 GALS
TC VOLUME = 8283 GALS
HEIGHT = 51.38 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.4 DEG F

T 2:UNLEADED 2
VOLUME = 8296 GALS
ULLAGE = 11407 GALS
90% ULLAGE = 9436 GALS
TC VOLUME = 8253 GALS
HEIGHT = 51.24 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.5 DEG F

T 3:SUPER UNLEADED
VOLUME = 5355 GALS
ULLAGE = 4825 GALS
90% ULLAGE = 3807 GALS
TC VOLUME = 5328 GALS
HEIGHT = 61.30 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.3 DEG F

T 4:B20BIODIESEL
VOLUME = 4899 GALS
ULLAGE = 5470 GALS
90% ULLAGE = 4433 GALS
TC VOLUME = 4884 GALS
HEIGHT = 55.96 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 66.7 DEG F

MANIFOLDED TANKS INVENTORY TOTALS

T 1:UNLEADED 1
T 2:UNLEADED 2
VOLUME = 16621 GALS
TC VOLUME = 16535 GALS

* * * * * END * * * * *



Since 1960

Remit To:
MASCOTT EQUIPMENT CO.
435 NE Hancock
Portland, OR 97212
(503) 282-2587
FAX (503) 288-9664

www.mascottec.com

INVOICE

| | |
|--------|------------|
| Number | 610622 |
| Date | 09/05/2024 |
| Page | 1 |

Bill-to Account #: 3880
CAIN PETROLEUM
4512 SW KELLY AVENUE
PORTLAND, OR 97239

Ship-to #: 31
CAIN PETROLEUM
990 N ADAIR AVE
CORNELIUS, OR 97113

| Reference # | Shipped | Salesperson | Terms | Tax Code | Doc # | Wh | Freight | Ship Via |
|------------------|------------|-------------|-------------|----------|--------|----|---------|----------|
| BEN 971-409-8860 | 09/05/2024 | HOWELLS | NET 10 DAYS | OR NOTAX | 492819 | 01 | BILL | SERVICE |

| Item | Description | Ordered | Shipped | Backordr | UM | Price | UM | Extension |
|---------------------|---|---------|---------|----------|----|--------|----|-----------|
| | DEQ INSPECTION REVEALED SEEPAGE ON PIPE NEAR SHEAR VALVE. PUMP # 1/2 PREMIUM. CLEAN AND TIGHTEN AS NEEDED | | | | | | | |
| LABOR-PD | LABOR, (On-Site/Shop Service) | .75 | .75 | .00 | EA | 105.00 | EA | 78.75 |
| LAPTOP CHARGE-PD | Network Access/Software Update | 1 | 1 | 0 | EA | 33.00 | EA | 33.00 |
| TRIP CHARGE-PD20 | LABOR, TRAVEL 0-20 MILEAGE | 1 | 1 | 0 | EA | 121.00 | EA | 121.00 |
| FUEL SURCHARGE-PD20 | FUEL SURCHARGE | 1 | 1 | 0 | EA | 6.70 | EA | 6.70 |
| SHOP-PD | Miscellaneous Materials Used | 1 | 1 | 0 | EA | 19.73 | EA | 19.73 |
| | 09/04 TECH TG: #1/2 TRACED LEAKAGE TO BASE PLATE CONNECTION TO TESTER'S PORT DISMANTLED, CLEANED, RE-PIPE DOPED, REASSEMBLED, VERIFIED 09/04 SAP | | | | | | | |

| 1. 15% RESTOCK FEE ON ANY RETURNED MERCHANDISE 2. NO RETURNS ACCEPTED WITHOUT PRIOR APPROVAL 3. THE CONDITIONS AS SET FORTH ON THE REVERSE SIDE HEREON SHALL APPLY TO THIS SALE 4. 15 DAYS ALLOWED FOR CORE RETURN REFUNDS | Merchandise | Misc | Discount | CAT Tax | Freight | Total Due |
|--|-------------|------|----------|---------|---------|-----------|
| | 259.18 | .00 | | 1.17 | .00 | 260.35 |

PLEASE PAY ON INVOICE - REMIT TO 435 NE HANCOCK - PORTLAND, OR 97212 - NO STATEMENT ISSUED UNLESS REQUESTED
PAST DUE ACCOUNTS SUBJECT TO 1.0% INTEREST CHARGE PER MONTH, 12% ANNUAL RATE
CREDIT CARD PAYMENTS ARE SUBJECT TO 3% SERVICE FEE.

Do not write below this line

Customer Copy

Continued on next page ...

SOINV



01-610622





Portland 435 NE Hancock Portland, OR 97212
Tri-Cities 200 S. 20th Ave. Pasco, WA 99301
Seattle 6530 5th Place South Seattle, WA 98108
Alaska 5610 Silverado Way Anchorage, AK 98518

Site Name: _____ Cornelius Chevron _____ Test Date: _____ 09/16/2024
Address: _____ 990 N Adair St _____
City, State, Zip: _____ Cornelius, OR 97113 _____

Test Data:

| | 1 | 2 | 3 | 4 | 5 |
|--------------------------------|-----------|-----------|-----------|-----------|---|
| Product | Regular 1 | Regular 2 | Super | Diesel | |
| Manufacturer | Vaporless | Vaporless | Vaporless | Vaporless | |
| Model | 99LD2000 | 99LD2000 | 99LD2000 | 99LD2000 | |
| Full Operating Pressure (psi) | 31 | 30 | 30 | 28 | |
| Trip Time (sec) | 3 | 4 | 3 | 4 | |
| Test Leak Rate (ml / min)(gph) | 3.0 gph | 3.0 gph | 3.0 gph | 3.0 gph | |
| Pass / Fail | Pass | Pass | Pass | Pass | |

Notes: _____

Per PEI RP 1200 9.1.6

This document certifies that the leak detectors tests were performed at the facility referenced above in accordance to the equipment manufacturers specifications. The results as listed are to my knowledge true and accurate. This document's test pass/fail is determined using a low flow threshold trip rate of 3 gph at 10 PSI.

Inspected By: _____

Technician Name: G. Druery

Technician Signature: Greg Druery

Digitally signed by Greg Druery
DN: cn=Greg Druery, o=pe, email=gdruery@mascottec.com, c=US
Date: 2024.09.17 12:12:28 -07'00'

DATA CHART FOR USE WITH PETROTITE LINE TESTER

WO#: 493573

STATION NUMBER: _____

DATE: 09/16/2024

1 LOCATION: Cornelius Chevron - 990 N Adair St - Cornelius, OR 97113

2 OWNER: Cain Petroleum

3 OPERATOR: Cain Petroleum

4 REASON FOR TEST: ANNUAL COMPLIANCE TESTING

5 TEST REQUESTED BY: Cain Petroleum

6 SPECIAL INSTRUCTIONS: _____

7 CONTRACTOR OR COMPANY MAKING TEST MECHANIC(S) NAME: MASCOTT EQUIPMENT CO. G. Drury

8 IS A TANK TEST TO BE MADE WITH THIS LINE TEST? ☐ YES ☒ NO 9 MAKE AND TYPE OF PUMP OR DISPENSER (SUCTION OR SUBMERSIBLE) FE Petro and Red Jacket submersible

10 WEATHER Warming TEMPERATURE IN TANKS 68 °F °C COVER OVER LINE Concrete BURIAL DEPTH 30"

| 11 IDENTIFY EACH LINE AS TESTED | 12 TIME (MILITARY) | 13 LOG OF TEST PROCEDURES, AMBIENT TEMPARATURE, WEATHER, ETC | 14 PRESSURE | | 15 VOLUME | | | 16 REMARKS SIZE, LENGTH & TYPE OF LINE, # FLEX CONNECTORS CONCLUSION, REPAIRS AND COMMENTS |
|---------------------------------------|-----------------------|--|----------------|-------|----------------|-------|----------------|--|
| | | | Psi OR kPa | | READING | | NET CHANGE | |
| | | | BEFORE | AFTER | BEFORE | AFTER | | |
| Regular | 1345 | Set up for line test. Pressurize line and observe. | 75 | | | | | APPROX. 220' Double wall flexible |
| | 1415 | Begin testing | ----- ----- | 60 | ----- ----- | .0630 | ----- ----- | Method of isolation: BALL VALVE |
| | 1430 | First reading | 60 | 60 | .0630 | .0630 | +0.0000 | |
| | 1445 | Second reading | 60 | 60 | .0630 | .0630 | +0.0000 | TESTED ALL LINES SIMULTANEOUSLY USING |
| | 1500 | Third reading | 60 | 60 | .0630 | .0630 | +0.0000 | MANIFOLD. |
| | 1515 | End of test | 60 | 60 | .0630 | .0630 | +0.0000 | |
| | | | | | | | | Passed sensitivity test |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

DATA CHART FOR USE WITH PETROTITE LINE TESTER

WO#: 493573

| | | | | | | | | |
|--------------|---------------------|---|----------------------------|----|-------------------------|-------|---------|--|
| Super | 1345 | Set up for line test. Pressurize line and observe. | 75 | | | | | APPROX. 190' Double wall flexible |
| | 1415 | Begin testing | ----- 60 ----- | 60 | ----- .0630 ----- | | | Method of isolation: BALL VALVE |
| | 1430 | First reading | 60 | 60 | .0630 | .0630 | +0.0000 | |
| | 1445 | Second reading | 60 | 60 | .0630 | .0630 | +0.0000 | TESTED ALL LINES SIMULTANEOUSLY USING |
| | 1500 | Third reading | 60 | 60 | .0630 | .0630 | +0.0000 | MANIFOLD. |
| | 1515 | End of test | 60 | 60 | .0630 | .0630 | +0.0000 | |
| | | | | | | | | Passed sensitivity test |
| | | | | | | | | |
| Diesel | 1345 | Set up for line test. Pressurize line and observe. | 75 | | | | | APPROX. 25' Double wall flexible |
| | 1415 | Begin testing | ----- 60 ----- | 60 | ----- .0630 ----- | | | Method of isolation: BALL VALVE |
| | 1430 | First reading | 60 | 60 | .0630 | .0630 | +0.0000 | |
| | 1445 | Second reading | 60 | 60 | .0630 | .0630 | +0.0000 | TESTED ALL LINES SIMULTANEOUSLY USING |
| | 1500 | Third reading | 60 | 60 | .0630 | .0630 | +0.0000 | MANIFOLD. |
| | 1515 | End of test | 60 | 60 | .0630 | .0630 | +0.0000 | |
| | | | | | | | | Passed sensitivity test |
| TEST RESULTS | | | | | | | | 17 CONTRACTOR CERTIFICATION |
| | | | | | | | | Tech: G. Druery |
| | Line Identification | Pass / Fail | Net Volume Change per Hour | | Date Tested | | X | Digitally signed by Greg Druery DN: cn=Greg Druery, o=pet, email=gdruery@petrotite.com, c=US Date: 2024.09.17 12:12:56 -0700 |
| | Regular | Pass | +0.0000 | | 09/16/2024 | | | Signature |
| | Super | Pass | +0.0000 | | 09/16/2024 | | | CERTIFICATION# |
| | Diesel | Pass | +0.0000 | | 09/16/2024 | | | 8d0c96fb |



Mascott Equipment Co.
435 NE Hancock Portland, OR 97212
(800) 452-5019

| Company Name: <u>Cornelius Chevron</u> | | | | Monitor Make: <u>Veeder-Root</u> | | | | |
|--|-----------------------|------|------------------------------------|---|------------------|------|-----|----------|
| Site Address: <u>990 N Adair St</u> | | | | Monitor Model: <u>TLS-350</u> | | | | |
| City, State, Zip: <u>Cornelius, OR 97113</u> | | | | Serial Number: <u>90759506005001</u> | | | | |
| Date: <u>09/16/2024</u> | | | | Software Version: <u>133.01</u> | | | | |
| Console | Tank # / Size | Pass | Fail | Actions Performed / Console | Pass | Fail | N/A | Comments |
| Print or view status of all tanks. Leave copy on site if any programming changes are made. | Unleaded 1 19,703 gal | X | | Verify date and time | X | | | |
| | Unleaded 2 19,703 gal | X | | Verify setup values | X | | | |
| | Super 10,180 gal | X | | Check battery | X | | | |
| | Diesel 10,369 gal | X | | Test external alarm if applicable | X | | | |
| | | | | Run system diagnostics | X | | | |
| | | | | Verify tests for compliance | X | | | |
| | | | | | | | | |
| Sensors | Sensor # / Location | Pass | Fail | Actions Performed / Probes | Pass | Fail | N/A | Comments |
| Print out sensor status and leave on site. Put all sensors into alarm and verify proper operation. | Unleaded 1 STP sump | X | | Run probe diagnostics | X | | | |
| | Unleaded 2 STP sump | X | | Inspect cables and connections | X | | | |
| | Super STP sump | X | | Removed, Cleaned and inspected probe | X | | | |
| | Diesel STP sump | X | | Verified overfill function at 90% | | | X | |
| | Unleaded 1 annular | X | | | | | | |
| | Unleaded 2 annular | X | | Actions Performed / Sensors | Pass | Fail | N/A | Comments |
| | Super-Diesel annular | X | | Run sensor diagnostics | X | | | |
| | | | | Inspect cables and connections | X | | | |
| | | | | Test sensor for operation | X | | | |
| | | | | Inspect and clean sensors | X | | | |
| | | | | | | | | |
| | | | | Additional Service Checks | Yes | No | N/A | Comments |
| | | | | Lights, LED's, annunciator functioning? | X | | | |
| | | | | Is customer saving required reports? | X | | | |
| | | | | Is Cathodic Protection Required? | | X | | |
| | | | | *Note CP issues and test date* | | | | |
| | | | | Type of Overfill Protection | Electronic alarm | | | |
| | | | | Type of Leak Detection | Mechanical | | | |
| | | | Primary Tank Leak Detection Method | CSLD | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

Technician Name: G. Druery Technician Signature: Greg Druery

Digitally signed by Greg Druery
DN: cn=Greg Druery, o, ou,
email=gdrury@mascottec.com, c=US
Date: 2024.09.17 12:11:38 -07'00'



Annual Release Detection Operability Testing Form

- In-tank setup and alarm history reports must be attached to testing form.
- Maintain three years of testing records.
- [Instructions on how to use this form.](#)

| I. FACILITY INFORMATION – Type or print (in ink) all items. | | | | TEST DATE |
|--|--|---|--|--|
| Facility ID #: | 11912 | Facility Name: | Cornelius Chevron | 09/16/2024 |
| II. AUTOMATIC TANK GAUGE | | | | <input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail |
| ATG Manufacturer: | Veeder Root | | ATG Model: | TLS-350 |
| Release Detection Method: | | Tank Gauge 0.2 gph leak tests: (<input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Static) <input type="checkbox"/> SIR <input checked="" type="checkbox"/> Interstitial Monitoring | | |
| Battery Backup Functional? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | ATG software properly programmed? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | |
| ATG alarms functional and audible? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | | ATG In-Tank Setup Reports attached to form? <input checked="" type="checkbox"/> Yes | | |
| III. TEST PROCEDURE | | | | |
| <input type="checkbox"/> PEI/RP 1200 | <input checked="" type="checkbox"/> Oregon Testing Procedures (Page 2) | | <input type="checkbox"/> Manufacturer Testing Procedures | <input type="checkbox"/> Other Method (Describe) |
| | | | | |

IV. PROBE AND TESTING INFORMATION

| | | | | | |
|---|--|--|--|--|---|
| Tank Number | 1 | 2 | 3 | 4 | |
| Product Stored | Regular | Regular | Super | Diesel | |
| Model | MAG | MAG | MAG Plus | MAG | |
| Is the ATG console clear of alarms? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Disconnect cable from tank probe. Is appropriate alarm triggered? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Tank gauge probes removed and inspected for damage? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Residual buildup on floats has been removed? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Float(s) move freely? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Measured product and water levels match ATG values? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Alarm history report attached? | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| V. TEST RESULT | <input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail | <input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail | <input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail | <input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail | <input type="checkbox"/> Pass <input type="checkbox"/> Fail |

Any "No" answer indicates the test failed. Failed tests must be remedied and retested immediately.

VIII. COMMENTS

The comments section should be used to note additional information discovered or actions taken during testing that affect compliance

IX. TESTER

Person conducting testing: G. Druery

DEQ tank gauge and probe functionality testing procedures

1. Inspect console and verify that there are no active or recurring warnings or alarms.
2. Confirm that both the visual and audible alarms on the tank gauge console function correctly.
3. Verify that the correct set-up parameters for the probes and appropriate tank leak detection is programmed correctly.
4. Test battery backup (if present).
5. Remove tank probe from tank.
6. Disconnect probe, wait for "Probe Out" alarm, reconnect probe and reset tank gauge.
7. Remove build up from probes.
8. Measure the fuel and water contents of the tank and compare with the tank gauge inventory report ensuring that they are the same.
9. Ensure that the probe's fuel and water floats are the correct type for the product stored in the tank.
10. Reposition the floats, measure distance from bottom of the probe, and utilize tank charts to confirm accuracy of the tank gauge.
11. Reinstall probes ensuring that the tank riser cap seals properly and the communication cable seal is tight.
12. If tank gauge is equipped with printer, attach the printed tank gauge in-tank setup and alarm history report demonstrating that probes were tested.

DEQ sensor functionality testing procedures

1. Inspect sensor for damage.
2. Place sensor in at least three inches of testing liquid.
3. Verify sensor alarms at tank gauge or sensor has appropriate alarm response (dispenser or turbine shut down).
4. Clear alarm.
5. Reinstall sensor upon verification of proper operation.
6. If tank gauge is equipped with printer, attach the printed tank gauge in-tank setup and alarm history report demonstrating that sensors were tested.

SYSTEM SETUP

SEP 16, 2024 12:40 PM

SYSTEM UNITS

U.S.

SYSTEM LANGUAGE

ENGLISH

SYSTEM DATE/TIME FORMAT

MON DD YYYY HH:MM:SS xM

354514 CORNELIUS

990 N. ADAIR

CORNELIUS, OR. 97113

90759506005001

SHIFT TIME 1 : 6:00 AM

SHIFT TIME 2 : DISABLED

SHIFT TIME 3 : DISABLED

SHIFT TIME 4 : DISABLED

TANK PER TST NEEDED WRN

DISABLED

TANK ANN TST NEEDED WRN

DISABLED

LINE RE-ENABLE METHOD

PASS LINE TEST

LINE PER TST NEEDED WRN

DISABLED

LINE ANN TST NEEDED WRN

DISABLED

PRINT TC VOLUMES

ENABLED

TEMP COMPENSATION

VALUE (DEG F): 60.0

STICK HEIGHT OFFSET

DISABLED

ULLAGE: 90%

H-PROTOCOL DATA FORMAT

HEIGHT

DAYLIGHT SAVING TIME

ENABLED

START DATE

MAR WEEK 2 SUN

START TIME

2:00 AM

END DATE

NOV WEEK 1 SUN

END TIME

2:00 AM

RE-DIRECT LOCAL PRINTOUT

DISABLED

EURO PROTOCOL PREFIX

S

SYSTEM SECURITY

CODE : 000000

TANK CHART SECURITY

DISABLED

CUSTOM ALARMS

DISABLED

SERVICE NOTICE

DISABLED

T 4:B20BIODIESEL
PRODUCT CODE : 4
THERMAL COEFF : .000450
TANK DIAMETER : 120.00
TANK PROFILE : 20 PTS
FULL VOL : 10369
114.0 INCH VOL : 10297
108.0 INCH VOL : 10042
102.0 INCH VOL : 9670
96.0 INCH VOL : 9209
90.0 INCH VOL : 8676
84.0 INCH VOL : 8085
78.0 INCH VOL : 7448
72.0 INCH VOL : 6778
66.0 INCH VOL : 6084
60.0 INCH VOL : 5377
54.0 INCH VOL : 4667
48.0 INCH VOL : 3965
42.0 INCH VOL : 3280
36.0 INCH VOL : 2624
30.0 INCH VOL : 2007
24.0 INCH VOL : 1441
18.0 INCH VOL : 939
12.0 INCH VOL : 516
6.0 INCH VOL : 193

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 2.5
WATER ALARM FILTER: LOW

MAX OR LABEL VOL: 10369
OVERFILL LIMIT : 90%
: 9332
HIGH PRODUCT : 95%
: 9850
DELIVERY LIMIT : 10%
: 1036

LOW PRODUCT : 500
LEAK ALARM LIMIT: 10
SUDDEN LOSS LIMIT: 99
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 15%
: 1555

LEAK MIN ANNUAL : 0%
: 0

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 1 MIN

ALARM HISTORY REPORT

----- IN-TANK ALARM -----

T 1:UNLEADED 1

OVERFILL ALARM

SEP 21, 2023 12:14 PM
JAN 3, 2023 2:15 PM

HIGH PRODUCT ALARM

JAN 3, 2023 2:15 PM

INVALID FUEL LEVEL

SEP 21, 2023 12:12 PM
DEC 23, 2022 2:45 PM

PROBE OUT

SEP 16, 2024 2:35 PM
SEP 21, 2023 12:15 PM
SEP 21, 2023 12:14 PM

DELIVERY NEEDED

JAN 19, 2024 8:03 AM
SEP 21, 2023 12:12 PM
AUG 3, 2023 8:06 PM

PER TST NEEDED WRN

JAN 7, 2023 12:00 AM

PER TST NEEDED ALM

FEB 1, 2023 12:00 AM
JAN 31, 2023 12:00 AM
JAN 29, 2023 12:00 AM

CSLD INCR RATE WARN

JUN 21, 2023 3:26 AM
JUN 6, 2023 8:00 AM
MAY 31, 2023 5:43 AM

LOW TEMP WARNING

SEP 16, 2024 2:37 PM
SEP 21, 2023 12:15 PM

* * * * * END * * * * *

ALARM HISTORY REPORT

----- IN-TANK ALARM -----

T 2:UNLEADED 2

OVERFILL ALARM

SEP 21, 2023 12:06 PM
JAN 3, 2023 2:21 PM

HIGH PRODUCT ALARM

JAN 3, 2023 2:21 PM