



# PUBLIC NOTICE

Date posted: X/X/25

## Public Hearing and Comments Requested About Proposed U.S. Army Corps of Engineers McNary Lock and Dam's Proposed Water Quality Permit Issuance

### HOW TO PROVIDE PUBLIC COMMENT

**Facility name:** U.S. Army Corps of Engineers McNary Lock and Dam

**Permit type:** National Pollutant Discharge Elimination System permit

**Hearing details:** Date, time, location or Zoom link, conference number & passcode

**Send written comments to:** Patty Isaak, DEQ Water Quality Permit Coordinator

**By mail:** 800 SE Emigrant Ave., Ste. 330 Pendleton, OR 97801

**By email:** [water.permitter@deq.oregon.gov](mailto:water.permitter@deq.oregon.gov)

**Comments due by:** [Date] at 5 p.m.

The Oregon Department of Environmental Quality invites the public to provide written comments and attend a public hearing to provide verbal comments on the conditions of U.S. Army Corps of Engineers McNary Lock and Dam's proposed water quality permit, known officially as a National Pollutant Discharge Elimination System permit. This hearing will be combined for three different proposed U.S. Army Corps of Engineers NPDES permits. The public will have the opportunity to comment on all three or just one of the three proposed NPDES permits.

### Summary

Subject to public review and comment, DEQ intends to issue the proposed water quality permit, which allows McNary Lock and Dam to discharge industrial cooling water and industrial wastewater from its operations at the McNary Lock and Dam into the Columbia River in Umatilla.

### About the facility

The U.S. Army Corps of Engineers has applied for a water quality permit for McNary Lock and Dam located at 82925 Devore Road in Umatilla. This will be the first permit issuance for this facility. This facility discharges non-contact cooling water and industrial wastewater from operations at McNary Lock and Dam into the Columbia River near Umatilla.

The Columbia River is listed as impaired (category 4 or 5) for several pollutants according to the most recent U.S. Environmental Protection Agency-approved integrated report for Oregon. The proposed permit reflects effluent limits established through reasonable potential analysis, best available technology or the Columbia and Lower Snake Rivers Total Maximum Daily Load, or TMDL, for temperature.

The facility holds no other permits from DEQ.

### What types of pollutants does the permit regulate?

### Translation or other formats

[Español](#) | [한국어](#) | [繁體中文](#) | [Русский](#) | [Tiếng Việt](#) | [العربية](#)

800-452-4011 | TTY: 711 | [deqinfo@deq.oregon.gov](mailto:deqinfo@deq.oregon.gov)

This permit sets conditions for how the facility deals with the following pollutants: thermal load (temperature), pH, oil and grease, and total residual chlorine.

### **Would the draft permit change the amount of pollution the facility is allowed to release?**

No, this is the first permit issuance for this facility.

### **How did DEQ determine permit requirements?**

DEQ evaluates types and amounts of pollutants and the water quality of the surface water or groundwater where the pollutants are proposed to be discharged and determines permit requirements to ensure the proposed discharges will meet applicable statutes, rules, regulations and effluent guidelines of Oregon and the Clean Water Act.

For this proposed permit action, DEQ reviewed the application, the Washington state permits and fact sheets, regional water quality data and research, supplemental monitoring reports and attachments submitted by the permittee, all available mixing zone studies and memos, records of communications with the permittee and other documents contained within the administrative record. DEQ relied solely on these documents and made no other discretionary decisions for the permit action.

### **How does DEQ monitor compliance with the permit requirements?**

This permit will require the facility to monitor pollutants discharged using approved monitoring practices and standards. DEQ reviews the facility's discharge monitoring reports to check for compliance with permit limits.

### **What happens next?**

Submit comments by sending an email or using mail service addressed to the permit coordinator listed in the "how to provide public comment" box above.

DEQ will consider and respond to all comments received and may modify the proposed permit based on comments. DEQ gives equal weight to written and verbal comments.

### **For more information**

Find more information by reviewing draft permit documents attached to this notice, or contact Patty Isaak at 541-613-1125 or [patty.isaak@deq.oregon.gov](mailto:patty.isaak@deq.oregon.gov) with questions or to view documents in person at a DEQ office.

### **Non-discrimination statement**

DEQ does not discriminate on the basis of race, color, national origin, disability, age, sex, religion, sexual orientation, gender identity, or marital status in the administration of its programs and activities. Visit DEQ's [Civil Rights and Environmental Justice page](#).



# NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM WASTE DISCHARGE PERMIT

Oregon Department of Environmental Quality  
 Eastern Region – Pendleton Office  
 800 SE Emigrant, #330  
 Pendleton, OR 97801  
 Telephone: 541-276-4063

Issued pursuant to ORS 468B.050 and the federal Clean Water Act

**ISSUED TO:**

U.S. Army Corps of Engineers  
 McNary Lock and Dam Project  
 201 N 3<sup>rd</sup> Ave  
 Walla Walla, WA 99362-1876

**SOURCES COVERED BY THIS PERMIT:**

Type of Waste	Outfall Number	Outfall Location
Drainage sump, seasonal fish rearing	001, 002, 003	45.932222, -119.299444
Pump and thrust bearing non-contact cooling water	004, 005	45.931944, -119.298056
Pump and thrust bearing non-contact cooling water	006, 007	45.93197, -119.298255
Pump and thrust bearing non-contact cooling water	008, 009	45.931946, -119.29837
Drainage sump, stormwater runoff	010	45.931908, -119.298317
Drainage sump, stormwater runoff	011	45.932455, -119.297726
Unwatering sump	012	45.932312, -119.297667
Main turbine unit and thrust bearing non-contact cooling water	013	45.932222, -119.297500
Main turbine unit, thrust bearing, and HVAC non-contact cooling water	014	45.932777, -119.297500
Main turbine unit and thrust bearing non-contact cooling water	015	45.933055, -119.297777
Main turbine unit, thrust bearing, and HVAC non-contact cooling water	016	45.933611, -119.297777
Main turbine unit and thrust bearing non-contact cooling water	017	45.934166, -119.298055
Main turbine unit, thrust bearing, and HVAC non-contact cooling water	018	45.934444, -119.298055
Main turbine unit and thrust bearing non-contact cooling water	019	45.935000, -119.298055
Main turbine unit and thrust bearing non-contact cooling water	020	45.932455, -119.297726

**FACILITY LOCATION:**

McNary Lock and Dam Project  
 82925 Devore Road  
 Umatilla, OR 97882  
 County: Umatilla  
 EPA Permit Type: Minor

**RECEIVING STREAM INFORMATION:**

Receiving stream/NHD name: Columbia River  
 USGS 12-Digit HUC: 170701010207  
 OWRD Administrative Basin: Mainstem Columbia River  
 NHD Reach Code & % along reach: 17070101001342, 94.65%  
 ODEQ LLID & RM: 1240483462464, RM 287.14  
 Integrated Report AU ID: OR\_LK\_1707010106\_88\_100132

Issued in response to Application No. 958153 received June 4, 2015. This permit is issued based on the land use findings in the permit record.

<u>DRAFT</u>	<u>DRAFT</u>	<u>DRAFT</u>
Michael Hiatt, Permitting Manager Eastern Region	Issuance Date	Effective Date

**PERMITTED ACTIVITIES**

Until this permit expires or is modified or revoked, the permittee is authorized to: 1) operate a wastewater collection, treatment, control and disposal system; and 2) discharge treated wastewater to waters of the state only from the authorized discharge point or points in Schedule A in conformance with the requirements, limits, and conditions set forth in this permit.

Unless specifically authorized by this permit, by another NPDES or Water Pollution Control Facility permit, or by Oregon statute or administrative rule, any other direct or indirect discharge of pollutants to waters of the state is prohibited.

Applicant Review

## TABLE OF CONTENTS

<b>SCHEDULE A: WASTE DISCHARGE LIMITS.....</b>	<b>5</b>
1. Outfalls 001, 002, and 003 – Permit Limits .....	5
2. Outfalls 004, 005, 006, 007, 008, and 009 – Permit Limits .....	5
3. Outfalls 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020 – Permit Limits .....	5
4. Aggregate Outfalls 004, 005, 006, 007, 008, 009, 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020 – Permit Limits.....	6
5. Additional Permit Limits.....	6
6. Regulatory Mixing Zone .....	6
<b>SCHEDULE B: MINIMUM MONITORING AND REPORTING REQUIREMENTS.....</b>	<b>7</b>
1. Reporting Requirements.....	7
2. Monitoring and Reporting Protocols.....	8
3. Monitoring and Reporting Requirements.....	12
4. Thermal Load Monitoring.....	19
5. Copper Biotic Ligand Model and Aluminum Parameters.....	20
6. Effluent Toxics Characterization Monitoring .....	21
7. Additional Receiving Stream and Effluent Characterization Monitoring.....	22
<b>SCHEDULE C: COMPLIANCE SCHEDULE.....</b>	<b>23</b>
1. Compliance Schedule to Meet Final Effluent Limits .....	23
2. Responsibility to Meet Compliance Dates .....	23
<b>SCHEDULE D: SPECIAL CONDITIONS.....</b>	<b>24</b>
1. Mixing Zone Study .....	24
2. Emergency Response and Public Notification Plan.....	24
3. Spill/Emergency Response Plan.....	24
4. Outfall Inspection.....	24
5. pH Criteria Exceedance Report.....	24
6. Best Management Practices (BMP) Plan .....	25
7. Environmentally Acceptable Lubricants (EALs).....	29
8. Cooling Water Intake Structure (CWIS) Requirements.....	30
9. Juvenile Fish Facility Best Management Practices .....	31
<b>SCHEDULE E: PRETREATMENT ACTIVITIES.....</b>	<b>32</b>
<b>SCHEDULE F: NPDES GENERAL CONDITIONS.....</b>	<b>33</b>

## LIST OF TABLES

Table A1: Outfalls 001, 002, and 003 Permit Limits .....	5
Table A2: Outfalls 004, 005, 006, 007, 008, and 009 Permit Limits .....	5
Table A3: Outfalls 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020 Permit Limits .....	5
Table A4: Outfalls 004, 005, 006, 007, 008, 009, 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020 Thermal Load Limit .....	6
Table B1: Reporting Requirements and Due Dates .....	7
Table B2: Effluent Monitoring Requirements – Outfalls 001, 002, and 003 .....	12
Table B3: Effluent Monitoring Requirements – Outfalls 004, 005, 006, 007, 008, and 009 .....	12
Table B4: Effluent Monitoring Requirements – Outfalls 010 and 012.....	14
Table B5: Effluent Monitoring Requirements – Outfall 011 .....	15
Table B6: Effluent Monitoring Requirements – Outfalls 013, 014, 015, 016, 017, 018, 019, and 020 .....	17

Table B7: Outfalls 004, 005, 006, 007, 008, 009, 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020 – Thermal Load Effluent Monitoring Requirements..... 20  
Table B8: Copper Biotic Ligand Model and Aluminum Sampling Requirements ..... 21  
Table B9: Metals ..... 22  
Table C1: Total Residual Chlorine Compliance Schedule..... 23

Applicant Review

## SCHEDULE A: WASTE DISCHARGE LIMITS

### 1. Outfalls 001, 002, and 003 – Permit Limits

During the term of this permit, the permittee must comply with the limits in the following table:

**Table A1: Outfalls 001, 002, and 003 Permit Limits**

Parameter	Units	Average Monthly	Average Weekly	Daily Maximum
pH	SU	Instantaneous limit between a daily minimum of 7.0 and a daily maximum of 8.5		

- a. The permittee is only authorized to discharge pass through river water effluent from the juvenile fish facility through Outfalls 001, 002, and 003. The permittee is not authorized to discharge any other process-related waters, including fish anesthetics such as tricane (MS-222), non-contact cooling water, or other facility operations effluent, from Outfalls 001, 002, and 003.

### 2. Outfalls 004, 005, 006, 007, 008, and 009 – Permit Limits

During the term of this permit, the permittee must comply with the limits in the following table:

**Table A2: Outfalls 004, 005, 006, 007, 008, and 009 Permit Limits**

Parameter	Units	Average Monthly	Average Weekly	Daily Maximum
Chlorine, Total Residual (Final) (See note a and b.)	mg/L	0.01	-	0.02
Oil and Grease	mg/L	-	-	5
pH	SU	Instantaneous limit between a daily minimum of 7.0 and a daily maximum of 8.5		

Notes:

- a. DEQ has established a Quantitation Limit of 0.05 mg/L for Total Residual Chlorine. Any analysis done for Total Residual Chlorine must have a quantitation limit that is either equal to or less than 0.05 mg/L. In cases where the average monthly or maximum daily limit for Total Residual Chlorine is lower than the Quantitation Limit, DEQ will use the reported Quantitation Limit as the compliance evaluation level.
- b. The final Total Residual Chlorine limit is effective after completion of the compliance schedule in Schedule C.

### 3. Outfalls 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020 – Permit Limits

During the term of this permit, the permittee must comply with the limits in the following table:

**Table A3: Outfalls 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020 Permit Limits**

Parameter	Units	Average Monthly	Average Weekly	Daily Maximum
Oil and Grease	mg/L	-	-	5

Parameter	Units	Average Monthly	Average Weekly	Daily Maximum
pH	SU	Instantaneous limit between a daily minimum of 7.0 and a daily maximum of 8.5		

**4. Aggregate Outfalls 004, 005, 006, 007, 008, 009, 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020 – Permit Limits**

During the term of this permit, the permittee must comply with the limits in the following table:

**Table A4: Outfalls 004, 005, 006, 007, 008, 009, 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020 Thermal Load Limit**

Parameter	Units	Average Monthly	Average Weekly	Daily Maximum
Thermal Load (June 1 – October 31) (See note a.)	million kcal/day	2,830	-	-

a. The aggregate thermal load is the sum of the thermal load discharge for Outfalls 004, 005, 006, 007, 008, 009, 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020 (Tables B3 – B6).

**5. Additional Permit Limits**

a. The permittee is prohibited from discharging a visible sheen from any outfall.

**6. Regulatory Mixing Zone**

There is no regulatory mixing zone for this discharge.

## SCHEDULE B: MINIMUM MONITORING AND REPORTING REQUIREMENTS

### 1. Reporting Requirements

The permittee must submit to DEQ monitoring results and reports as listed below.

**Table B1: Reporting Requirements and Due Dates**

Reporting Requirement	Frequency	Due Date (See note a.)	Report Form (See note b.)	Submit To:
Tables B2, B3, B4, B5, B6 and B7 Effluent Monitoring and Thermal Load Monitoring	Monthly	By the 15th of the following month	Specified in Schedule B. Section 2 of this permit	Electronic reporting as directed by DEQ
Table B8: Copper Biotic Ligand Model and Aluminum Sampling Requirements	Monthly for 2 years beginning 10/1/20XX until 24 samples are collected	By the 15th of the following month	Electronic copy in a DEQ-approved format	Attached via electronic reporting as directed by DEQ
Tables B9: Metals	Quarterly for 3 years starting QX of YYYY (permit writer to fill in the start quarter and year before permit issuance) until 12 samples are collected (see note c.)	By the 15th of the month following each quarter	Electronic copy in a DEQ-approved format	Attached via electronic reporting as directed by DEQ
Mixing Zone Study (see Schedule D)	One time	Submit before requesting a regulatory mixing zone	Electronic copy in a DEQ-approved format	Attached via electronic reporting as directed by DEQ
Outfall Inspection Report (see Schedule D)	Once per permit cycle	Submit by XX/15/20XX In the 3 <sup>rd</sup> year of the permit.	Electronic copy in a DEQ-approved format	Attached via electronic reporting as directed by DEQ
pH Criteria Exceedance Report (see Schedule D)	Annually	April 15	Electronic copy in a DEQ-approved format	Attached via electronic reporting as directed by DEQ
Best Management (BMP) Plan (see Schedule D)	One time	Submit by XX/XX/20XX within 180 days of effective date	Electronic copy in a DEQ-approved format	Attached via electronic reporting as directed by DEQ
BMP Annual Report (see Schedule D)	Annually	April 15	Electronic copy in a DEQ-approved format	Attached via electronic reporting as directed by DEQ

Reporting Requirement	Frequency	Due Date (See note a.)	Report Form (See note b.)	Submit To:
Environmentally Acceptable Lubricants (EALs) Annual Report (see Schedule D)	Annually	April 15	Electronic copy in a DEQ-approved format	Attached via electronic reporting as directed by DEQ
Cooling Water Intake Structure (CWIS) Operations and Maintenance Manual (see Schedule D)	One-time	Submit by XX/XX/20XX within a year of effective date	Electronic copy in a DEQ-approved format	Attached via electronic reporting as directed by DEQ
CWIS Annual Report (see Schedule D)	Annually	April 15	Electronic copy in a DEQ-approved format	Attached via electronic reporting as directed by DEQ
Notes: a. For submittals that are provided to DEQ by mail, the postmarked date must not be later than the due date. b. All reporting requirements are to be submitted in a DEQ approved format, unless otherwise specified in writing. c. Quarters are defined as: Q1: Jan – Mar, Q2: Apr – June, Q3: Jul – Sept, Q4: Oct – Dec. If no discharge occurs during the quarter, collect the sample in the following quarter.				

## 2. Monitoring and Reporting Protocols

### a. Electronic Submissions

The permittee must submit to DEQ the results of monitoring indicated in Schedule B in an electronic format as specified below.

- i. The permittee must submit monitoring results required by this permit via DEQ-approved web-based Discharge Monitoring Report (DMR) forms to DEQ via electronic reporting. Any data used to calculate summary statistics must be submitted as a separate attachment approved by DEQ via electronic reporting.
- ii. The reporting period is the calendar month.
- iii. The permittee must submit monitoring data and other information required by this permit for all compliance points by the 15th day of the month following the reporting period unless specified otherwise in this permit or as specified in writing by DEQ.

### b. Test Methods

The permittee must conduct monitoring according to test procedures in 40 CFR 136 and 40 CFR 503 for biosolids or other approved procedures as per Schedule F.

### c. Detection and Quantitation Limits

- i. Detection Level (DL) – The DL is defined as the minimum measured concentration of a substance that can be distinguished from method blank results with 99% confidence. The DL is derived using the procedure in 40 CFR 136 Appendix B and evaluated for reasonableness relative to method blank concentrations to ensure results reported above the DL are not a result of routine background contamination. The DL is also known as the Method Detection Limit (MDL) or Limit of Detection (LOD).

- ii. Quantitation Limits (QLs) – The QL is the minimum level, concentration or quantity of a target analyte that can be reported with a specified degree of confidence. It is the lowest level at which the entire analytical system gives a recognizable signal and acceptable calibration for the analyte. It is normally equivalent to the concentration of the lowest calibration standard adjusted for sample weights, volumes, preparation and cleanup procedures employed. The QL as reported by a laboratory is also sometimes referred to as the Method Reporting Limit (MRL) or Limit of Quantitation (LOQ).
- d. Sufficient Sensitivity of Quantitation Limits
- i. The Laboratory QLs (adjusted for any dilutions) for analyses performed to demonstrate compliance with permit limits or as part of effluent characterization, must meet at least one of the requirements below:
    - (A) The QL is at or below the level of the water quality criterion for the measured parameter.
    - (B) The QL is above the water quality criterion but the amount of the pollutant in a facility's discharge is high enough that the method detects and quantifies the level of the parameter in the discharge.
    - (C) The QL has the lowest sensitivity of the analytical methods procedure specified in 40 CFR 136.
    - (D) The QL is at or below those defined in Oregon DEQ list of quantitation limits posted online at [DEQ permitting website](#).
- e. Quality Assurance and Quality Control
- i. Quality Assurance Plan – The permittee must develop and implement a written Quality Assurance Plan that details the facility sampling procedures, equipment calibration and maintenance, analytical methods, quality control activities and laboratory data handling and reporting. The QA/QC program must conform to the requirements of 40 CFR 136.7.
  - ii. If QA/QC requirements are not met for any analysis, the permittee must re-analyze the sample. If the sample cannot be re-analyzed, the permittee must re-sample and analyze at the earliest opportunity. If the permittee is unable to collect a sample that meets QA/QC requirements, then the permittee must include the result in the discharge monitoring report (DMR) along with a notation (data qualifier). In addition, the permittee must explain how the sample does not meet QA/QC requirements. With the exception of BOD<sub>5</sub>/CBOD<sub>5</sub>, the permittee may not use the result that failed the QA/QC requirements in any calculation required by the permit unless authorized in writing by DEQ. For BOD<sub>5</sub>/CBOD<sub>5</sub>, the permittee may not use the result that failed the QA/QC requirement in any calculation except as follows:
    - (A) When the glucose-glutamic acid, dilution water, and/or seed control check are not met, the values are reported with the “E” (estimate) data qualifier. The estimated values are not used in the calculations.
    - (B) When the minimum DO depletion or the minimum residual DO is not met, the values are reported with the “<” or “>” data qualifiers as appropriate. The data must be used in the calculations. It is not acceptable to report “non-detect” on the discharge monitoring report. The data qualifiers carry to the summary statistic.

For example, when calculating the loading, the data qualifiers are added to the value.

- iii. Flow measurement, field measurement, and continuous monitoring devices - The permittee must:
  - (A) Establish verification and calibration frequency for each device or instrument in the quality assurance plan that conforms to the frequencies recommended by the manufacturer.
  - (B) Verify at least once per year that flow-monitoring devices are functioning properly according to manufacturer's recommendation. Calibrate as needed according to manufacturer's recommendations.
  - (C) Verify at least weekly that the continuous monitoring instruments are functioning properly according to manufacturer's recommendation unless the permittee demonstrates a longer period is sufficient and such longer period is approved by DEQ in writing.
- iv. The permittee must develop a receiving water sampling and analysis plan that incorporates QA/QC prior to sampling. This plan must be kept at the facility and made available to DEQ upon request.
- f. Reporting Sample Results
  - i. The permittee must report the laboratory DL and QL as defined above for each analyte, with the following exceptions: pH, temperature, BOD, CBOD, TSS, Oil & Grease, hardness, alkalinity, bacteriological analytes and nitrate-nitrite. For temperature and pH, neither the QL nor the DL need to be reported. For the other parameters listed above, the permittee is only required to report the QL and only when the result is ND.
  - ii. The permittee must report the same number of significant digits as the permit limit for a given parameter.
  - iii. Chemical Abstracts Service (CAS) Numbers. CAS numbers (where available) must be reported along with monitoring results.
  - iv. (For Discharge Monitoring Reports) If a sample result is above the DL but below the QL, the permittee must report the result as the DL preceded by DEQ's data code "E". For example, if the DL is 1.0 µg/l, the QL is 3.0 µg/L and the result is estimated to be between the DL and QL, the permittee must report "E1.0 µg/L" on the DMR. This requirement does not apply in the case of parameters for which the DL does not have to be reported.
  - v. (For Discharge Monitoring Reports) If the sample result is below the DL, the permittee must report the result as less than the specified DL. For example, if the DL is 1.0 µg/L and the result is ND, report "<1.0" on the discharge monitoring report (DMR). This requirement does not apply in the case of parameters for which the DL does not have to be reported.
- g. Calculating and Reporting Mass Loads

The permittee must calculate mass loads on each day the parameter is monitored using the following equation:

Example calculation: Flow (in MGD) X Concentration (in mg/L) X 8.34 = Pounds per day

- i. Mass load limits all have two significant figures unless otherwise noted.
- ii. When concentration data are below the DL: To calculate the mass load from this result, use the DL. Report the mass load as less than the calculated mass load. For example, if flow is 2 MGD and the reported sample result is  $<1.0 \mu\text{g/L}$ , report “ $<0.017 \text{ lb/day}$ ” for mass load on the DMR ( $1.0 \mu\text{g/L} \times 2 \text{ MGD} \times \text{conversion factor} = 0.017 \text{ lb/day}$ ).
- iii. When concentration data are above the DL, but below the QL: To calculate the mass load from this result, use the DL. Report the mass load as the calculated mass load preceded by “E”. For example, if flow is 2 MGD, the DL is  $1.0 \mu\text{g/L}$ , the QL is  $5 \mu\text{g/L}$  and the reported sample result is  $E3.5 \mu\text{g/L}$ , report “ $E0.017 \text{ lb/day}$ ” for mass load on the DMR ( $1.0 \mu\text{g/L} \times 2 \text{ MGD} \times \text{conversion factor} = 0.017 \text{ lb/day}$ ).

Applicant Review

### 3. Monitoring and Reporting Requirements

- a. The permittee must monitor effluent for Outfalls 001, 002, and 003 after all waste streams enter the discharge pipes before discharge and report results in accordance with Table B1 and the table below:

**Table B2: Effluent Monitoring Requirements – Outfalls 001, 002, and 003**

Item or Parameter	Units	Time Period	Minimum Frequency	Sample Type/ Required Action	Report Statistic (See note a.)
pH (00400)	SU	Year-round	1/month	Grab	1. Daily Maximum 2. Daily Minimum
Notes: a. When submitting DMRs electronically, all data used to determine summary statistics must be submitted in a DEQ-approved format as a spreadsheet via electronic reporting unless otherwise directed by DEQ.					

- b. The permittee must monitor effluent for Outfalls 004, 005, 006, 007, 008, and 009 after all waste streams enter the discharge pipes before discharge and report results in accordance with Table B1 and the table below:

**Table B3: Effluent Monitoring Requirements – Outfalls 004, 005, 006, 007, 008, and 009**

Item or Parameter	Units	Time Period	Minimum Frequency	Sample Type/ Required Action (See note a.)	Report Statistic (See note b.)
Flow (50050)	MGD	Year-round	Daily	Measurement/ Calculation	1. Monthly Average 2. Daily Maximum
pH (00400)	SU	Year-round for the first year of the permit	1/week	Grab	1. Daily Maximum 2. Daily Minimum
pH (00400)	SU	Year-round for the entire permit term excluding the first year	1/month	Grab	1. Daily Maximum 2. Daily Minimum
Temperature (00010)	°C	Year-round	Daily or Monthly	Continuous or Grab (See note c. and d.)	1. Daily Maximum 2. Monthly Average 3. 7-day Rolling Average of Daily Maximum
Thermal Load Discharge (00015)	million kcal/day	June 1 – October 31	Daily	Calculation (See note e.)	1. Daily Maximum 2. Monthly Average
Chlorine, Total Residual (50060)	mg/L	Year-round	1/week	Grab	1. Daily Maximum 2. Monthly Average
Oil and Grease (00556)	mg/L	Year-round for the first year of the permit term	1/week	Grab	1. Daily Maximum 2. Monthly Average

Item or Parameter	Units	Time Period	Minimum Frequency	Sample Type/ Required Action (See note a.)	Report Statistic (See note b.)
Oil and grease (00556)	mg/L	Year-round for the entire permit term excluding the first year	1/month	Grab	Daily Maximum
Oil & Grease Sheen (84066)	Y/N	Year-round	1/week (see note f.)	Visual	Presence or Absence
Oil and grease (00556)	mg/L	Year-round	Conditional (see note f.)	Grab	Daily Maximum

Notes:

- a. In the event of equipment failure or loss, the permittee must notify DEQ and deploy new equipment to minimize interruption of data collection. If new equipment cannot be immediately deployed, the permittee must perform grab measurements. If the failure or loss is for continuous temperature monitoring equipment, the permittee must collect one grab sample daily between 12 PM and 5 PM until continuous monitoring equipment is redeployed.
- b. When submitting DMRs electronically, all data used to determine summary statistics must be submitted in a DEQ-approved format as a spreadsheet via electronic reporting unless otherwise directed by DEQ.
- c. Representative monitoring – The permittee must select one outfall from each of the following lists for continuous monitoring: 1) 004, 006, 008 and 2) 005, 007, 009. The two selected outfalls will be representative monitoring locations. The remaining four outfalls will be represented monitoring locations. For the represented outfalls, the permittee must perform temperature grab measurements once per month between 12 PM and 5 PM.
- d. When determining the daily maximum temperature, the permittee may report the hourly average maximum temperature if continuous monitoring of temperature is performed at less than hourly intervals.
- e. The monthly average is then calculated from the daily TLs.  
 The daily TL is calculated as follows:  

$$TL = 3.78 * Q_e * T_e$$
 Where:  
 TL = Daily Thermal Load (million kcal/day)  
 Q<sub>e</sub> = Estimated Daily Average Effluent Flow (MGD)  
 T<sub>e</sub> = Daily Average Effluent Temperature (°C)  
 For outfalls with representative monitoring (see note c.), the daily average temperature must be calculated using only the continuous temperature monitoring data from representative outfalls and applied to the represented outfalls.
- f. The permittee must observe the surface of the receiving water in the vicinity of where the effluent enters the surface water at a minimum of once per week. If a visible sheen is observed, take corrective action to stop the sheen. Sample the effluent for oil and grease once and report the results in the next monthly monitoring report. If the required oil and grease weekly or monthly sampling has been conducted at a time when visible sheen was not present, the facility must collect an additional Oil and Grease sample when visual sheen is observed to satisfy this requirement.

- c. The permittee must monitor effluent for Outfalls 010 and 012 after all waste streams enter the sumps and before discharge and report results in accordance with Table B1 and the table below:

**Table B4: Effluent Monitoring Requirements – Outfalls 010 and 012**

<b>Item or Parameter</b>	<b>Units</b>	<b>Time Period</b>	<b>Minimum Frequency</b>	<b>Sample Type/ Required Action</b> (See note a.)	<b>Report Statistic</b> (See note b.)
Flow (50050)	MGD	Year-round	Daily	Measurement/ Calculation	1. Monthly Average 2. Daily Maximum
pH (00400)	SU	Year-round for the first year of the permit	1/week	Grab	1. Daily Maximum 2. Daily Minimum
pH (00400)	SU	Year-round for the entire permit term excluding the first year	1/month	Grab	1. Daily Maximum 2. Daily Minimum
Temperature (00010)	°C	Year-round	Daily	Continuous (See note c.)	1. Daily Maximum 2. Monthly Average 3. 7-day Rolling Average of Daily Maximum
Thermal Load Discharge (00015)	million kcal/day	June 1 – October 31	Daily	Calculation (See note d.)	1. Daily Maximum 2. Monthly Average
Oil and Grease (00556)	mg/L	Year-round for the first year of the permit term	1/week	Grab	1. Daily Maximum 2. Monthly Average
Oil and grease (00556)	mg/L	Year-round for the entire permit term excluding the first year	1/month	Grab	Daily Maximum
Oil & Grease Sheen (84066)	Y/N	Year-round	1/week (see note e.)	Visual	Presence or Absence
Oil and grease (00556)	mg/L	Year-round	Conditional (see note e.)	Grab	Daily Maximum

Item or Parameter	Units	Time Period	Minimum Frequency	Sample Type/ Required Action (See note a.)	Report Statistic (See note b.)
<p>Notes:</p> <p>a. In the event of equipment failure or loss, the permittee must notify DEQ and deploy new equipment to minimize interruption of data collection. If new equipment cannot be immediately deployed, the permittee must perform grab measurements. If the failure or loss is for continuous temperature monitoring equipment, the permittee must collect one grab sample daily between 12 PM and 5 PM until continuous monitoring equipment is redeployed.</p> <p>b. When submitting DMRs electronically, all data used to determine summary statistics must be submitted in a DEQ-approved format as a spreadsheet via electronic reporting unless otherwise directed by DEQ.</p> <p>c. When determining the daily maximum temperature, the permittee may report the hourly average maximum temperature if continuous monitoring of temperature is performed at less than hourly intervals.</p> <p>d. The monthly average is then calculated from the daily TLs.          The daily TL is calculated as follows:  <math display="block">TL = 3.78 * Q_e * T_e</math>         Where:          TL = Daily Thermal Load (million kcal/day)          Q<sub>e</sub> = Estimated Daily Average Effluent Flow (MGD)          T<sub>e</sub> = Daily Average Effluent Temperature (°C)</p> <p>e. The permittee must observe the surface of the receiving water in the vicinity of where the effluent enters the surface water at a minimum of once per week. If a visible sheen is observed, take corrective action to stop the sheen. Sample the effluent for oil and grease once and report the results in the next monthly monitoring report. If the required oil and grease weekly or monthly sampling has been conducted at a time when visible sheen was not present, the facility must collect an additional Oil and Grease sample when visual sheen is observed to satisfy this requirement.</p>					

- d. The permittee must monitor effluent for Outfall 011 after all waste streams enter the sump and before discharge and report results in accordance with Table B1 and the table below:

**Table B5: Effluent Monitoring Requirements – Outfall 011**

Item or Parameter	Units	Time Period	Minimum Frequency	Sample Type/ Required Action (See note a.)	Report Statistic (See note b.)
Flow (50050)	MGD	Year-round	Daily	Measurement/ Calculation	1. Monthly Average 2. Daily Maximum
pH (00400)	SU	Year-round for the first year of the permit	1/week	Grab	1. Daily Maximum 2. Daily Minimum
pH (00400)	SU	Year-round for the entire permit term excluding the first year	1/month	Grab	1. Daily Maximum 2. Daily Minimum

Item or Parameter	Units	Time Period	Minimum Frequency	Sample Type/ Required Action (See note a.)	Report Statistic (See note b.)
Temperature (00010)	°C	Year-round	Daily	Continuous (See note c.)	1. Daily Maximum 2. Monthly Average 3. 7-day Rolling Average of Daily Maximum
Thermal Load Discharge (00015)	million kcal/day	June 1 – October 31	Daily	Calculation (See note d.)	1. Daily Maximum 2. Monthly Average
Oil and Grease (00556)	mg/L	Year-round for the first year of the permit term	1/week	Grab	1. Daily Maximum 2. Monthly Average
Oil and grease (00556)	mg/L	Year-round for the entire permit term excluding the first year	1/month	Grab	Daily Maximum
Oil & Grease Sheen (84066)	Y/N	Year-round	1/week (see note e.)	Visual	Presence or Absence
Oil and grease (00556)	mg/L	Year-round	Conditional (see note e.)	Grab	Daily Maximum
Chlorine, Total Residual (50060)	mg/L	Year-round	1/week	Grab	1. Daily Maximum 2. Monthly Average

Item or Parameter	Units	Time Period	Minimum Frequency	Sample Type/ Required Action (See note a.)	Report Statistic (See note b.)
<p>Notes:</p> <p>a. In the event of equipment failure or loss, the permittee must notify DEQ and deploy new equipment to minimize interruption of data collection. If new equipment cannot be immediately deployed, the permittee must perform grab measurements. If the failure or loss is for continuous temperature monitoring equipment, the permittee must collect one grab sample daily between 12 PM and 5 PM until continuous monitoring equipment is redeployed.</p> <p>b. When submitting DMRs electronically, all data used to determine summary statistics must be submitted in a DEQ-approved format as a spreadsheet via electronic reporting unless otherwise directed by DEQ.</p> <p>c. When determining the daily maximum temperature, the permittee may report the hourly average maximum temperature if continuous monitoring of temperature is performed at less than hourly intervals.</p> <p>d. The monthly average is then calculated from the daily TLs.          The daily TL is calculated as follows:  <math display="block">TL = 3.78 * Q_e * T_e</math>         Where:          TL = Daily Thermal Load (million kcal/day)          Q<sub>e</sub> = Estimated Daily Average Effluent Flow (MGD)          T<sub>e</sub> = Daily Average Effluent Temperature (°C)</p> <p>e. The permittee must observe the surface of the receiving water in the vicinity of where the effluent enters the surface water at a minimum of once per week. If a visible sheen is observed, take corrective action to stop the sheen. Sample the effluent for oil and grease once and report the results in the next monthly monitoring report. If the required oil and grease weekly or monthly sampling has been conducted at a time when visible sheen was not present, the facility must collect an additional Oil and Grease sample when visual sheen is observed to satisfy this requirement.</p>					

- e. The permittee must monitor effluent for Outfalls 013, 014, 015, 016, 017, 018, 019, and 020 after all waste streams enter the pipes and before discharge and report results in accordance with Table B1 and the table below:

**Table B6: Effluent Monitoring Requirements – Outfalls 013, 014, 015, 016, 017, 018, 019, and 020**

Item or Parameter	Units	Time Period	Minimum Frequency	Sample Type/ Required Action (See note a.)	Report Statistic (See note b.)
Flow (50050)	MGD	Year-round	Daily	Measurement/ Calculation	1. Monthly Average 2. Daily Maximum
pH (00400)	SU	Year-round for the first year of the permit	1/week	Grab	1. Daily Maximum 2. Daily Minimum
pH (00400)	SU	Year-round for the entire permit term excluding the first year	1/month	Grab	1. Daily Maximum 2. Daily Minimum

Item or Parameter	Units	Time Period	Minimum Frequency	Sample Type/ Required Action (See note a.)	Report Statistic (See note b.)
Temperature (00010)	°C	Year-round	Daily or 1/month (see note c. and d.)	Continuous or Grab (See note c. and d.)	1. Daily Maximum 2. Monthly Average 3. 7-day Rolling Average of Daily Maximum
Thermal Load Discharge (00015)	million kcal/day	June 1 – October 31	Daily	Calculation (See note e.)	1. Daily Maximum 2. Monthly Average
Oil and Grease (00556)	mg/L	Year-round for the first year of the permit term	1/week	Grab	Daily Maximum
Oil and grease (00556)	mg/L	Year-round for the entire permit term excluding the first year	1/month	Grab	Daily Maximum
Oil & Grease Sheen (84066)	Y/N	Year-round	1/week (see note f.)	Visual	Presence or Absence
Oil and grease (00556)	mg/L	Year-round	Conditional (see note f.)	Grab	Daily Maximum
Chlorine, Total Residual (50060)	mg/L	Year-round	1/week or 1/month (see note g.)	Grab	1. Daily Maximum 2. Monthly Average

Item or Parameter	Units	Time Period	Minimum Frequency	Sample Type/ Required Action (See note a.)	Report Statistic (See note b.)
<p>Notes:</p> <p>a. In the event of equipment failure or loss, the permittee must notify DEQ and deploy new equipment to minimize interruption of data collection. If new equipment cannot be immediately deployed, the permittee must perform grab measurements. If the failure or loss is for continuous temperature monitoring equipment, the permittee must collect one grab sample daily between 12 PM and 5 PM until continuous monitoring equipment is redeployed.</p> <p>b. When submitting DMRs electronically, all data used to determine summary statistics must be submitted in a DEQ-approved format as a spreadsheet via electronic reporting unless otherwise directed by DEQ.</p> <p>c. Temperature representative monitoring – The permittee must select two outfalls from the following list for continuous monitoring: 013, 014, 015, 016, 017, 018, 019, and 020. The two selected outfalls will be representative monitoring locations. The remaining five outfalls will be represented monitoring locations. For the represented outfalls, the permittee must perform temperature grab measurements once per month between 12 PM and 5 PM.</p> <p>d. When determining the daily maximum temperature, the permittee may report the hourly average maximum temperature if continuous monitoring of temperature is performed at less than hourly intervals.</p> <p>e. The monthly average is then calculated from the daily TLs.          The daily TL is calculated as follows:  <math display="block">TL = 3.78 * Q_e * T_e</math>         Where:          TL = Daily Thermal Load (million kcal/day)          Q<sub>e</sub> = Estimated Daily Average Effluent Flow (MGD)          T<sub>e</sub> = Daily Average Effluent Temperature (°C)          For outfalls with representative monitoring (see note c.), the daily average temperature must be calculated using only the continuous temperature monitoring data from representative outfalls and applied to the represented outfalls.</p> <p>f. The permittee must observe the surface of the receiving water in the vicinity of where the effluent enters the surface water at a minimum of once per week. If a visible sheen is observed, take corrective action to stop the sheen. Sample the effluent for oil and grease once and report the results in the next monthly monitoring report. If the required oil and grease weekly or monthly sampling has been conducted at a time when visible sheen was not present, the facility must collect an additional Oil and Grease sample when visual sheen is observed to satisfy this requirement.</p> <p>g. Chlorine representative monitoring – The permittee must select one outfall from the following list for weekly monitoring: 013, 014, 015, 016, 017, 018, 019, and 020. The selected outfalls will be the representative monitoring location. The remaining six outfalls will be represented monitoring locations. For the represented outfalls, the permittee must perform chlorine grab samples once per month on the same day as the representative weekly sample.</p>					

#### 4. Thermal Load Monitoring

The permittee must monitor the effluent from Outfalls 004, 005, 006, 007, 008, 009, 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020 and report the results in accordance with Table B1 and the table below:

**Table B7: Outfalls 004, 005, 006, 007, 008, 009, 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020 – Thermal Load Effluent Monitoring Requirements**

Item or Parameter	Units	Time Period	Minimum Frequency	Sample Type / Required Action	Report Statistic (See note a.)
Thermal Load Discharge (00015) (See note b.)	million kcal/day	June 1 – October 31	1/month	Calculation (See note b.)	Monthly Average
Note: a. When submitting DMRs electronically, all data used to determine summary statistics must be submitted in a DEQ-approved format as a spreadsheet via electronic reporting unless otherwise directed by DEQ. b. The aggregate thermal load discharge is the sum of the thermal load discharge values from Outfalls 004, 005, 006, 007, 008, 009, 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020, calculated on a monthly basis.					

**5. Copper Biotic Ligand Model and Aluminum Parameters**

The permittee must monitor the Columbia River and Outfalls 010 and 011 for copper biotic ligand model and aluminum parameters per the table below. Samples must be collected according to Table B1. Effluent and ambient monitoring must be conducted concurrently. The permittee must collect upstream samples such that the effluent does not impact the samples (e.g., upstream for riverine discharges). It is the responsibility of the permittee to ensure safe and practical sampling techniques and procedures are used. DEQ recommends that these procedures be included in a sample and analysis plan that can be reviewed by DEQ when necessary.

**Table B8: Copper Biotic Ligand Model and Aluminum Sampling Requirements**

Parameter (See note a.)	CAS (See note b.)	Units	Sampling Frequency (see note c.)	Sampling Location (See note d.)
Copper, total and dissolved	7440508	µg/L	1/month	Upstream and Effluent
Aluminum, (see note e.)	7429905	µg/L	1/month	Upstream and Effluent
Hardness (as CaCO <sub>3</sub> )	–	mg/L	1/month	Upstream and Effluent
Dissolved organic carbon	–	mg/L	1/month	Upstream and Effluent
pH (see note f.)	–	S.U.	1/month	Upstream and Effluent
Temperature	–	°C	1/month	Upstream and Effluent
Calcium, dissolved (see note g.)	7440702	mg/L	1/month	Upstream and Effluent
Magnesium, dissolved (see note g.)	7439954	mg/L	1/month	Upstream and Effluent
Sodium, dissolved (see note g.)	7440235	mg/L	1/month	Upstream and Effluent
Potassium, dissolved (see note g.)	7440097	mg/L	1/month	Upstream and Effluent
Sulfate, dissolved (see note g.)	14808798	mg/L	1/month	Upstream and Effluent
Chloride, dissolved (see note g.)	16887006	mg/L	1/month	Upstream and Effluent
Alkalinity, dissolved (see note g.)	–	mg/L	1/month	Upstream and Effluent

Notes:

- a. All effluent samples must be 24-hr composite samples except grab samples must be collected for pH, alkalinity and temperature. All receiving stream samples must be grab samples.
- b. Chemical Abstract Service
- c. Permittee to sample for duration specified in Table B1.
- d. Samples must be collected upstream (outside the influence of the effluent) and from the effluent on the same day.
- e. Effluent samples must be in Total Recoverable fraction. Upstream samples must be in the Bioavailable fraction.
- f. Ambient pH measurements in receiving waters where specific conductivity < 200 µS/cm may require additional sampling practices to achieve accurate measurement. Refer to USGS (2021) “Measurement of pH In Techniques and Methods (Vol. 9)” or another 40 CFR 136 approved method for measuring pH in low ionic strength solutions. The permittee must account for low ionic strength when sampling ambient pH.
- g. These analytes may be calculated from specific conductance measurements according to equations outlined in OAR 340-041-8033 Endnote N(1)(b). Specific conductance data may be used as a substitute for monitoring and analysis of these parameters only if it is concurrent with other BLM input parameters. If neither the analytes nor concurrent specific conductance is measured, regional defaults will be used in data analysis according to OAR 340-041-8033 Endnote N(2)(a).

**6. Effluent Toxics Characterization Monitoring**

The permittee must collect and analyze effluent samples for the parameters listed in the tables below. The permittee must collect effluent samples for Outfalls 010 and 011 after all wastestreams enter the sumps and before discharge on the dates in Table B1.

Samples must be 24-hour composites. Sample results must be reported in µg/L unless otherwise specified and submitted to DEQ using approved electronic format.

**Table B9: Metals**

<b>Pollutant</b> (See note a.)	<b>CAS</b> (See note b.)
Lead, total and dissolved	7439921
Zinc, total and dissolved	7440666
Notes: a. The term “total” used in reference to metals is intended to cover all EPA-accepted standard digestion methods and is considered to be equivalent to the term “total recoverable”. b. Chemical Abstract Service	

## 7. Additional Receiving Stream and Effluent Characterization Monitoring

If additional ambient or effluent monitoring is needed, DEQ will notify the permittee through a request for supplemental information/data.

## SCHEDULE C: COMPLIANCE SCHEDULE

### 1. Compliance Schedule to Meet Final Effluent Limits

The permittee must comply with the following schedule:

**Table C1: Total Residual Chlorine Compliance Schedule**

Compliance Date:	Requirement:
By XX/XX/2025 Within 3 months of permit effective date	The permittee must submit to DEQ an optimization study outlining feasible operational changes that can be made to the current treatment process at McNary Lock and Dam to maximize reductions of total residual chlorine.
By XX/XX/2025 Within 6 months of permit effective date	The permittee must begin implementation of the planned changes outlined in the optimization study and must notify DEQ regarding implementation.
By XX/XX/2026 Within 12 months of permit effective date	The permittee must submit to DEQ a written progress report outlining the progress made towards achieving final effluent limitations. The permittee must include in the report a draft plan and timeline for achieving final effluent limits based on the results of the implementation of the optimization study. If needed, the draft plan must also include a design memorandum for necessary facilities upgrades in order to achieve final effluent limits for total residual chlorine.  Permittee must revise the draft plan and timeline in accordance with DEQ comments within 60 days of receiving DEQ comments.
By XX/XX/2026 Within 18 months of permit effective date	The permittee must submit to DEQ a written progress report outlining the progress made towards achieving final effluent limitations and the permittee must begin implementation of the final plan for achieving final effluent limits.
By XX/XX/2027 Within 2 years of permit effective date	The permittee must achieve compliance with the final effluent limits for total residual chlorine in Schedule A of this permit.

### 2. Responsibility to Meet Compliance Dates

No later than 14 days following each compliance date listed in the table above, the permittee must notify DEQ in writing of its compliance or noncompliance with the requirements. Any reports of noncompliance must include the cause of noncompliance, any remedial actions taken, and a discussion of the likelihood of meeting the next scheduled requirement(s).

## **SCHEDULE D: SPECIAL CONDITIONS**

### **1. Mixing Zone Study**

In order to request a regulatory mixing zone for any outfall, the permittee must submit a level 1 mixing zone study. The study must specify which outfalls the permittee wants to be covered by a regulatory mixing zone. (Level 1 mixing zone study requirements are described in DEQ's Mixing Zone Internal Management Directive).

### **2. Emergency Response and Public Notification Plan**

The permittee must develop an Emergency Response and Public Notification Plan ("plan"), or ensure the facility's existing plan is current and accurate, per Schedule F, Section B, and Condition 7 within 6 months of permit effective date. The permittee must update the plan annually to ensure all information contained in the plan, including telephone and email contact information for applicable public agencies, is current and accurate. An updated copy of the plan must be kept on file at the facility for DEQ review. The latest plan revision date must be listed on the plan cover along with the reviewer's initials or signature.

### **3. Spill/Emergency Response Plan**

The permittee must have an up-to-date spill response plan for prevention and handling of spills and unplanned discharges. This plan must be available for review during a DEQ inspection. The spill response plan must include all of the following:

- a. A description of the reporting system that will be used to alert responsible managers and legal authorities in the event of a spill.
- b. A description of preventive measures and facilities (including an overall facility plot showing drainage patterns) to prevent, contain, or treat spills.
- c. A description of the permittee's training program to ensure that employees are properly trained at all times to respond to unplanned and emergency incidents.
- d. A description of the applicable reporting requirements. These must be consistent with the reporting requirements found in Schedule F, condition D.5.

### **4. Outfall Inspection**

The permittee must inspect Outfall 001, 002, 003, 004, 005, 006, 007, 008, 009, 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 20 including the submerged portion of the outfall line and diffuser to document its integrity and to determine whether it is functioning as designed. The inspection must determine whether all ports are intact, clear and fully functional. The inspection must verify the latitude and longitude of the outfall end pipe and/or diffuser ports. The permittee must submit a written report to DEQ regarding the results of the outfall inspection by the date in Table B1. The report must include a description of the outfall as originally constructed, the condition of the current outfall and identify any repairs needed to return the outfall to satisfactory condition.

### **5. pH Criteria Exceedance Report**

The permittee must submit an annual pH Criteria Exceedance report by the date specified in Table B1. This report must document all pH criteria exceedances from all outfalls, the pH value in the impoundment on the same day of the exceedance to document whether the impoundment was the cause of the exceedance, and the practicable measures the permittee is taking in the impoundment to ensure compliance with the pH criteria in OAR 340-041-0104.

## 6. Best Management Practices (BMP) Plan

- a. The permittee shall develop and implement a BMP Plan which incorporates practices that achieve the objectives and specific requirements listed below. The permittee must operate the hydroelectric generating facility in accordance with this BMP Plan and with subsequent amendments to the Plan. The BMP Plan shall be prepared in accordance with good engineering practices.
- i. Pollution Prevention Team. The BMP Plan shall identify a specific individual or individuals within the facility organization as members of the Pollution Prevention Team who are responsible for developing the BMP Plan and for assisting the facility manager in the implementing, maintaining, and revising of this plan. The responsibilities of each team member must be listed. The activities and responsibilities of the Pollution Prevention Team shall address all aspects of the facility's BMP Plan.
- ii. Prevention and Minimization of Oil and Wastewater Discharges. The BMP Plan shall establish specific best management practices or other measures that prevent and minimize oil, grease, and hydraulic fluids from all sources from entering the river, including at a minimum, the following:
1. Maintain protective seals on all equipment with oil-to-water interfaces in good operating order to minimize the leaking of hydraulic oil or other oils
  2. Minimize lubricants for all facility equipment that come in contact with river water such as spill gate mechanisms, turbine gate mechanisms, etc.
  3. Use lubricants, paint and caulk free of PCBs, unless technically infeasible.
  4. Use preventative maintenance and cleaning programs for turbine and wicket gate parts.
  5. Regularly inspect fuel hoses, oil drums, oil or fuel transfer valves and fittings, etc. to prevent drips or leaks.
  6. Use proper operation of the oil/water separators through inspections at appropriate intervals, regularly scheduled maintenance, and by review of sampling data.
  7. A preventive maintenance program for internal facility drainage water management devices (e.g., cleaning oil/water separators, pits, sumps) that includes inspection and testing to uncover conditions that could cause breakdowns or failures resulting in discharges of pollutants to surface waters and ensuring appropriate maintenance of such equipment and systems.
  8. Good housekeeping practices that require the maintenance of areas, which may contribute pollutants to internal facility drainage water discharges, to be clean and orderly.
  9. Site-specific spill prevention and response procedures in areas where potential spills, which can contribute pollutants to internal facility drainage water discharges, can occur and their accompanying drainage points shall be identified clearly in the BMP Plan. When containment is impracticable, the procedures should outline site-specific contingency plans to prevent oil releases. Procedures and site-specific BMPs shall be developed and implemented to eliminate and/or minimize the opportunity for oil leakage to enter the drainage system at the facility. Where appropriate, specifying material handling procedures, storage requirements, and use of equipment in the BMP Plan should be considered. Procedures for cleaning up spills shall be identified in the BMP Plan and made

available to the appropriate personnel. The necessary equipment to implement a clean-up should be available to personnel.

10. Inspections with qualified personnel for designated equipment and areas of the facility at appropriate intervals specified in the BMP Plan. A set of tracking or follow-up procedures shall be used to ensure that appropriate actions are taken in response to the inspections. Records of inspection shall be maintained.
  11. Employee training programs to inform personnel responsible for implementing activities identified in the BMP Plan or otherwise responsible for internal facility drainage water management, at all levels of responsibility, of the components and goals of the BMP Plan.
  12. Record-keeping and internal reporting procedures with a description of incidents (such as spills, or other discharges), along with other information describing the quality and quantity of internal facility drainage water discharges shall be included in the BMP Plan. Inspections and maintenance activities shall be documented, and records of such activities shall be incorporated into the BMP Plan.
- iii. Prevention and Minimization of HVAC Refrigerant Discharges. The BMP Plan shall establish specific best management practices or other measures that prevent and minimize refrigerant from HVAC units from entering the river, including at a minimum, the following:
1. Regularly inspect HVAC units and lines for leaks.
  2. Use proper operation of HVAC units through inspections at appropriate intervals and regularly scheduled maintenance.
  3. Inspections with qualified personnel for designated equipment and areas of the facility at appropriate intervals specified in the BMP Plan. A set of tracking or follow-up procedures shall be used to ensure that appropriate actions are taken in response to the inspections. Records of inspection shall be maintained.
  4. Employee training programs to inform personnel responsible for implementing activities identified in the BMP Plan or otherwise responsible for internal facility drainage water management, at all levels of responsibility, of the components and goals of the BMP Plan.
  5. Record-keeping and internal reporting procedures with a description of incidents (such as leaks, or other discharges), along with other information describing the quality and quantity of internal facility drainage water discharges shall be included in the BMP Plan. Inspections and maintenance activities shall be documented, and records of such activities shall be incorporated into the BMP Plan.
- iv. Oil Accountability, Tracking, and Reporting. The BMP Plan will describe the quantity and type of all oil products used on-site and how they are monitored and tracked using guidelines from the facility's Oil Accountability Plan. If the Oil Accountability Plan covers all elements of this permit requirement, the BMP Plan may reference the Oil Accountability Plan. Records are to be kept on-site and available for inspection by DEQ. Oil gauges should be used that provide appropriate level of markings to ensure operators and maintenance personnel can easily identify an unusual condition. The permittee must notify DEQ if there is an unaccounted oil release into the environment consistent with the facility's Oil Accountability Plan.

- v. Drainage: The BMP plan shall include the following:
1. All facility-specific activities and significant materials which may be potentially significant pollutant sources.
  2. Other potential sources which may reasonably be expected to add significant amounts of pollutants to internal facility drainage water discharges. Factors to consider include the toxicity of pollutants; quantity of pollutants used; the likelihood of contact with internal facility drainage water discharges; and history of significant leaks or spills.
  3. A plot of the floor drainage of the facility's interior including sumps and oil/water separators and locations where major spills or leaks have occurred.
- vi. Inventory of Exposed Materials. The BMP Plan shall include an inventory of the types of materials handled at the facility that potentially may be inadvertently spilled. Such inventory shall include a narrative description of significant materials (quantities over 55 gallons) that are or have been handled, treated, stored or disposed in a manner to allow exposure to internal facility drainage water between the time of three years before the effective date of the permit coverage and the present; method and location of on-site storage or disposal; materials management practices employed to minimize contact of materials with internal facility drainage water; the location and description of existing structural and non-structural control measures to reduce pollutants in the internal facility drainage water discharges; and a description of any treatment these discharges receive.
- vii. Spills and Leaks. The BMP Plan shall include a list of significant spills and significant leaks of toxic or hazardous pollutants that occurred, during the three-year period prior to the active date of permit coverage, at areas that drain to an outfall associated with floor drains. Such a list shall be updated as appropriate during the term of the permit. The spill and leak documentation should also document why the spill occurred, the volume of the spill, and how the spill was addressed. This should be part of the BMP Annual Report if a spill occurs during the permit term.
- viii. Risk Identification and Summary of Potential Pollutant Sources. A narrative description of the potential pollutant sources from the following activities: loading and unloading operations; maintenance programs; and on-site waste disposal practices. The description shall specifically list any significant potential source of pollutants at the facility and for each potential source, any pollutant or pollutant parameter (e.g. biochemical oxygen demand, etc.) of concern shall be identified.
- ix. Trash Racks, Strainers, or Intake Screens. The permittee shall develop and implement procedures to remove solid materials from the trash racks, strainers or intake screens. The solid materials exclude naturally occurring materials such as leaves, branches, grass, and so forth. Inspections and maintenance of the trash racks and intake screens shall be scheduled and documented with the record-keeping included with the BMP Plan and summarized in the Annual Report required under Schedule D, condition 5.e. The permittee shall amend the removal procedures whenever there is a change in the design, construction, operation, or maintenance which has a significant effect on the deposition of solid material on the trash racks or intake screens.
- The trash removal activities are to be performed where it is reasonable and feasible at the facility. These trash removal procedures are to include appropriate safety practices because the permittee is responsible for employee safety at the facility.
- x. Flood/High Water Discharges. Identify potential for flood/high water discharges. Develop and implement specific flood/high water practices and procedures to eliminate pollutants

from areas of the facility that would be inundated during flood/high water events and that would reasonably be expected to add significant amounts of pollutants to the identified flood/high water discharges at the facility. Areas of the facility inundated by flood or high waters should be maintained to prevent pollutants from entering the surrounding surface waters during flood or high-water events.

- b. The BMP Plan must be consistent with the objectives listed in the general guidance contained in the publication entitled Guidance Manual for Developing Best Management Practices (BMPs) (EPA-833-93-004, 1993) and any subsequent revisions to this guidance document.
- c. Deadlines for BMP Plan Preparation and Compliance
  - i. The BMP Plan for this facility shall be prepared, and except as provided elsewhere in this permit, shall provide for compliance with the terms of the permit and the BMP Plan, no later than the date specified in Table B1.
  - ii. The permittee must submit a BMP Plan to DEQ for review and approval by the date specified in Table B1. The permittee may submit the BMP Plan as an electronic attachment to the DMR. The file name of the electronic attachment must be as follows: YYYY\_MM\_DD\_ORXXXXXXXX\_BMP\_XXXXXX, where YYYY\_MM\_DD is the date that the permittee submits the BMP Plan.
- d. Signature and BMP Plan Review
  - i. The BMP Plan shall be signed in accordance with Schedule F, condition D.8 and be retained onsite at the facility in accordance with Schedule F, condition C.8.
  - ii. DEQ may notify the permittee at any time that the BMP Plan does not meet one or more of the minimum requirements of this Part. Such notification shall identify those provisions of the permit which are not being met by the BMP Plan and identify which provisions of the BMP Plan require modifications in order to meet the minimum requirements of this Part. Within 30 days of such notification from DEQ, (or as otherwise provided by DEQ), the permittee shall make the required changes to the BMP Plan and shall submit to DEQ a revised BMP Plan with the requested changes for review and approval.
- e. BMP Plan Modification
  - i. The permittee shall amend the BMP Plan whenever there is a change in design, construction, operation, or maintenance, which has a significant effect on the potential for the discharge of pollutants to the waters of the United States or if the BMP Plan proves to be ineffective in eliminating or significantly minimizing pollutants, or in otherwise achieving the general objectives of controlling pollutants in the internal facility drainage water discharges. Any changes to the BMP Plan must be consistent with the objectives and specific requirements listed above. The permittee must submit the revised BMP plan to DEQ for review and approval.
  - ii. The permittee must prepare a BMP Annual Report documenting the effectiveness of all BMPs implemented onsite, including the measures that were effective or ineffective, and the adaptive management that has occurred as a result.
  - iii. The BMP Annual Report must report sampling data that is designed in a way to quantify source identification and reductions in order to substantiate the adaptive management process. The sample and design and data analysis including methods and method reporting levels, must be included in the quality assurance plan (Schedule B, condition 2.e) and updated as necessary.

- iv. The BMP Annual Report must include the adaptive management procedures implemented based on the results of all monitoring used to evaluate BMPs.
- v. The permittee must submit the BMP Annual Report by the date specified in Table B1.
- vi. The permittee may submit the Report as an electronic attachment to the DMR. The file name of the electronic attachment must be as follows: YYYY\_MM\_DD\_ORXXXXXXXX\_BMP\_XXXXXX, where YYYY\_MM\_DD is the date that the permittee submits the Report.
- f. Reporting of BMP incidents. Prepare and submit a written report to DEQ after the incident has been successfully addressed, describing the circumstances leading to the incident, corrective actions taken, and recommended changes to operation and maintenance practices and procedures to prevent incident recurrence.
- g. The permittee must maintain a copy of the BMP Plan on-site at the facility and make it available to DEQ upon request.

## 7. Environmentally Acceptable Lubricants (EALs)

- a. The permittee must select EALs for all oil to water interfaces including wicket gates, bearings, lubricated wire ropes, Kaplan runners and other in-line equipment, unless technically infeasible. EALs should be consistent with the definition of EPA's 2011 report, Environmentally Acceptable Lubricants. For purposes of requirements related to EALs, technically infeasible means that no EAL products are approved for use in a given application that meet manufacturer specifications for that equipment; products which come pre-lubricated (e.g., wire ropes) and have no available alternatives manufactured with EALs; or products meeting a manufacturer's specifications are not available.
- b. The permittee must prepare an EAL Annual Report on equipment under Schedule D, condition 7a. and describe the implementation and feasibility of EALs.
- c. The EAL Annual Report shall include:
  - i. A list of all equipment that have oil to water interfaces;
  - ii. An evaluation of the technical feasibility for using EALs for each equipment;
  - iii. Timeline for using EALs for equipment, where technically feasible; and
  - iv. An annual update on progress towards implementing EALs.

The EAL Annual Report may use other EAL reports and studies that have been completed or will be completed to satisfy all or part of the EAL Annual Report requirement so long as the items listed above in this section are included. If other reports satisfy part of the items listed above, the permittee must supplement these reports with additional information to satisfy the EAL Annual Report requirement.

- d. The permittee must submit the EAL Annual Reports by the date specified in Table B1 to DEQ for review and approval. The EAL Annual Reports must be comprehensive, complete, accurate, and concur with the state's interpretation of technical feasibility. Annual EAL reports must be signed in accordance with Schedule F, condition D.8.
- e. The permittee may submit the EAL Annual Report as an electronic attachment to the DMR. The file name of the electronic attachment must be as follows: YYYY\_MM\_DD\_ORXXXXXXXX\_EAL\_XXXXXX, where YYYY\_MM\_DD is the date that the permittee submits the EAL Annual Report.

## 8. Cooling Water Intake Structure (CWIS) Requirements

- a. Best Technology Available. The design, location, construction, and capacity of the permittee's CWISs shall reflect the best technology available (BTA) for minimizing adverse environmental impacts from the impingement and entrainment of various life stages of fish (e.g., eggs, larvae, juveniles, adults) by the CWISs.
- b. EPA has determined and DEQ has agreed that the following existing requirements are sufficient to satisfy the BTA requirement to minimize entrainment and to minimize impingement mortality:
  - i. Conduct spill releases over dam spillways according to schedules and guidelines in the most recent Fish Operating Plans and Fish Passage Plan.
  - ii. Keep juvenile fish passage structures, submersible traveling screens, vertical bar screens, and trash racks free of debris or other material through regular and preventive maintenance and inspections.
  - iii. Operate turbines within +/- 1% peak efficiency, or as specified in the most recent Fish Passage Plan, including the most recent Fish Operations Plan and in-season Technical Management Team meetings.
  - iv. Operate turbines in priority order to maximize fish passage as described in the most recent Fish Passage Plan, including the most recent Fish Operations Plan and in-season Technical Management Team meetings.
  - v. Maintain a physical screening or exclusion technology that is consistent with the objectives of National Marine Fisheries Service (NMFS) guidelines found in NMFS Northwest Region's Anadromous Salmonid Passage Facility Design, Chapter 11: Fish Screen and Bypass Facilities.
- c. The permittee must properly operate and maintain the technologies identified above as described in the most recent Fish Passage Plan, including the most recent Fish Operations Plan and in-season Technical Management Team meetings.
- d. The permittee must conduct regular visual inspections at a frequency specified in the most recent Fish Passage Plan, including the most recent Fish Operations Plan and in-season Technical Management Team meetings or employ remote monitoring devices to ensure that the technologies listed above are maintained and operated to function as designed.
- e. The permittee must maintain a copy of the most recent Fish Passage Plan, including the most recent Fish Operations Plan on-site at the facility and make it available to DEQ upon request.
- f. The permittee must prepare a CWIS Annual Report. The first annual report must include information on all cooling water intake structures that address the missing application submittal requirements of 40 CFR 122.21(r)(2) and (3) and applicable provisions of paragraphs (4), (5), (6), (7) and (8). The permittee must submit the CWIS Annual Reports by the date specified in Table B1 to DEQ for review and approval. The CWIS Annual Reports must document implementation, operations, and maintenance of the listed technologies. The Reports must include a certification statement that the facility has been properly operated and maintained and that no changes to the facility have been made unless documented. The permittee may submit the report as an electronic attachment to the DMR. The file name of the electronic attachment must be as follows: YYYY\_MM\_DD\_ORXXXXXXX\_CWIS\_XXXXXXX, where YYYY\_MM\_DD is the date that the permittee submits the report.
- g. The permittee must develop a CWIS operations and maintenance manual that includes procedures for evaluating both impingement and entrainment related to the CWIS by the date specified in Table B1. This does not include the intake for hydroelectric generating waters. The permittee

must maintain a copy of the manual on-site at the facility and make it available to DEQ upon request.

- h. Within 30 days of making any substantial modifications to the intake structure that impact cooling water withdrawals or operation of the intake structure, the permittee must notify DEQ in writing of the modification.
- i. Nothing in this permit authorizes take for the purposes of a facility's compliance with the Endangered Species Act.

## **9. Juvenile Fish Facility Best Management Practices**

The permittee must:

- a. Develop and maintain a plan on site describing how the permittee will ensure Juvenile Fish Facility practices do not impact surface waters or degrade the soil profile of the land application site. This plan should identify treatment chemicals used at the facility in addition to historical and current management practices of these chemicals including the land application sites.
- b. Make the plan available to DEQ upon request.
- c. Collect and land apply effluent containing Juvenile Fish Facility treatment chemicals such as anesthetic that are not to be discharged to waters of the state. This effluent must be dispersed at the identified land application site in a manner that ensures the moisture is absorbed into the soil profile without ponding on the surface, adversely affecting the vegetation, causing erosion, flowing offsite or into surface water bodies.

## **SCHEDULE E: PRETREATMENT ACTIVITIES**

A pretreatment program is not part of this permit.

Applicant Review

## SCHEDULE F: NPDES GENERAL CONDITIONS

### INDUSTRIAL FACILITIES July 31, 2016 Version

#### SECTION A. STANDARD CONDITIONS

##### A1. Duty to Comply with Permit

The permittee must comply with all conditions of this permit. Failure to comply with any permit condition is a violation of Oregon Revised Statutes (ORS) 468B.025 and the federal Clean Water Act and is grounds for an enforcement action. Failure to comply is also grounds for DEQ to terminate, modify and reissue, revoke, or deny renewal of a permit.

##### A2. Penalties for Water Pollution and Permit Condition Violations

The permit is enforceable by DEQ or EPA, and in some circumstances also by third-parties under the citizen suit provisions of 33 USC § 1365. DEQ enforcement is generally based on provisions of state statutes and Environmental Quality Commission (EQC) rules, and EPA enforcement is generally based on provisions of federal statutes and EPA regulations.

ORS 468.140 allows DEQ to impose civil penalties up to \$25,000 per day for violation of a term, condition, or requirement of a permit.

Under ORS 468.943, unlawful water pollution in the second degree, is a Class A misdemeanor and is punishable by a fine of up to \$25,000, imprisonment for not more than one year, or both. Each day on which a violation occurs or continues is a separately punishable offense.

Under ORS 468.946, unlawful water pollution in the first degree is a Class B felony and is punishable by a fine of up to \$250,000, imprisonment for not more than 10 years, or both.

The Clean Water Act provides that any person who violates permit condition, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil penalty not to exceed \$25,000 per day for each violation.

The Clean Water Act provides that any person who negligently violates any condition, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than 1 year, or both.

In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than 2 years, or both.

Any person who knowingly violates such sections, or such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than 3 years, or both.

In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both.

Any person who knowingly violates section any permit condition, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both.

In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both.

An organization, as defined in section 309(c)(3)(B)(iii) of the CWA, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions.

Any person may be assessed an administrative penalty by the Administrator for violating any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act.

Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$25,000.

Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000.

A3. Duty to Mitigate

The permittee must take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit. In addition, upon request of DEQ, the permittee must correct any adverse impact on the environment or human health resulting from noncompliance with this permit, including such accelerated or additional monitoring as necessary to determine the nature and impact of the noncomplying discharge.

A4. Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and have the permit renewed. The application must be submitted at least 180 days before the expiration date of this permit.

DEQ may grant permission to submit an application less than 180 days in advance but no later than the permit expiration date.

A5. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause including, but not limited to, the following:

- a. Violation of any term, condition, or requirement of this permit, a rule, or a statute.
- b. Obtaining this permit by misrepresentation or failure to disclose fully all material facts.
- c. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.
- d. The permittee is identified as a Designated Management Agency or allocated a wasteload under a total maximum daily load (TMDL).
- e. New information or regulations.
- f. Modification of compliance schedules.
- g. Requirements of permit reopener conditions.
- h. Correction of technical mistakes made in determining permit conditions.
- i. Determination that the permitted activity endangers human health or the environment.
- j. Other causes as specified in 40 CFR §§ 122.62, 122.64, and 124.5.

The filing of a request by the permittee for a permit modification, revocation or reissuance, termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

A6. Toxic Pollutants

The permittee must comply with any applicable effluent standards or prohibitions established under Oregon Administrative Rules (OAR) 340-041-0033 and 307(a) of the federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the federal Clean Water Act within the time provided in the regulations that establish those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

A7. Property Rights and Other Legal Requirements

The issuance of this permit does not convey any property rights of any sort, or any exclusive privilege, or authorize any injury to persons or property or invasion of any other private rights, or any infringement of federal, tribal, state, or local laws or regulations.

A8. Permit References

Except for effluent standards or prohibitions established under section 307(a) of the federal Clean Water Act and OAR 340-041-0033 for toxic pollutants, and standards for sewage sludge use or disposal established under section 405(d) of the federal Clean Water Act, all rules and statutes referred to in this permit are those in effect on the date this permit is issued.

A9. Permit Fees

The permittee must pay the fees required by OAR.

**SECTION B. OPERATION AND MAINTENANCE OF POLLUTION CONTROLS**

B1. Proper Operation and Maintenance

The permittee must at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems that are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

B2. Need to Halt or Reduce Activity Not a Defense

For industrial or commercial facilities, upon reduction, loss, or failure of the treatment facility, the permittee must, to the extent necessary to maintain compliance with its permit, control production or all discharges or both until the facility is restored or an alternative method of treatment is provided. This requirement applies, for example, when the primary source of power of the treatment facility fails or is reduced or lost. It is not a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

B3. Bypass of Treatment Facilities

a. Definitions

- (1) "Bypass" means intentional diversion of waste streams from any portion of the treatment facility.

The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, provided the diversion is to allow essential maintenance to assure efficient operation.

These bypasses are not subject to the provisions of paragraphs b and c of this section.

- (2) "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

b. Prohibition of bypass.

- (1) Bypass is prohibited and DEQ may take enforcement action against a permittee for bypass unless:
- i. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;

- ii. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate backup equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventative maintenance; and
  - iii. The permittee submitted notices and requests as required under General Condition B3.c.
- (2) DEQ may approve an anticipated bypass, after considering its adverse effects and any alternatives to bypassing, when DEQ determines that it will meet the three conditions listed above in General Condition B3.b(1).
- c. Notice and request for bypass.
- (1) Anticipated bypass. If the permittee knows in advance of the need for a bypass, a written notice must be submitted to DEQ at least ten days before the date of the bypass.
  - (2) Unanticipated bypass. The permittee must submit notice of an unanticipated bypass as required in General Condition D5.

#### B4. Upset

- a. Definition. "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operation error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventative maintenance, or careless or improper operation.
- b. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of General Condition B4.c are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- c. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset must demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
  - (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
  - (2) The permitted facility was at the time being properly operated;
  - (3) The permittee submitted notice of the upset as required in General Condition D5, hereof (24-hour notice); and
  - (4) The permittee complied with any remedial measures required under General Condition A3 hereof.
- d. Burden of proof. In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof.

#### B5. Treatment of Single Operational Upset

For purposes of this permit, a single operational upset that leads to simultaneous violations of more than one pollutant parameter will be treated as a single violation. A single operational upset is an exceptional incident that causes simultaneous, unintentional, unknowing (not the result of a knowing act or omission), temporary noncompliance with more than one federal Clean Water Act effluent discharge pollutant parameter. A single operational upset does not include federal Clean Water Act violations involving discharge without a NPDES permit or noncompliance to the extent caused by improperly designed or inadequate treatment facilities. Each day of a single operational upset is a violation.

#### B6. Public Notification of Effluent Violation

If effluent limitations specified in this permit are exceeded or an overflow occurs that threatens public health, the permittee must take such steps as are necessary to alert the public, health agencies and other affected entities (for example, public water systems) about the extent and nature of the discharge in accordance with the notification procedures developed under General Condition B7. Such steps may include, but are not limited to,

posting of the river at access points and other places, news releases, and paid announcements on radio and television.

**B7. Emergency Response and Public Notification Plan**

The permittee must develop and implement an emergency response and public notification plan that identifies measures to protect public health from bypasses or upsets that may endanger public health. At a minimum the plan must include mechanisms to:

- a. Ensure that the permittee is aware (to the greatest extent possible) of such events;
- b. Ensure notification of appropriate personnel and ensure that they are immediately dispatched for investigation and response;
- c. Ensure immediate notification to the public, health agencies, and other affected entities (including public water systems). The response plan must identify the public health and other officials who will receive immediate notification;
- d. Ensure that appropriate personnel are aware of and follow the plan and are appropriately trained;
- e. Provide emergency operations; and
- f. Ensure that DEQ is notified of the public notification steps taken.

**B8. Removed Substances**

Solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters must be disposed of in such a manner as to prevent any pollutant from such materials from entering waters of the state, causing nuisance conditions, or creating a public health hazard.

**SECTION C. MONITORING AND RECORDS**

**C1. Representative Sampling**

Sampling and measurements taken as required herein must be representative of the volume and nature of the monitored discharge. All samples must be taken at the monitoring points specified in this permit, and must be taken, unless otherwise specified, before the effluent joins or is diluted by any other waste stream, body of water, or substance. Monitoring points must not be changed without notification to and the approval of DEQ. Samples must be collected in accordance with requirements in 40 CFR part 122.21 and 40 CFR part 403 Appendix E.

**C2. Flow Measurements**

Appropriate flow measurement devices and methods consistent with accepted scientific practices must be selected and used to ensure the accuracy and reliability of measurements of the volume of monitored discharges. The devices must be installed, calibrated and maintained to insure that the accuracy of the measurements is consistent with the accepted capability of that type of device. Devices selected must be capable of measuring flows with a maximum deviation of less than  $\pm 10$  percent from true discharge rates throughout the range of expected discharge volumes.

**C3. Monitoring Procedures**

Monitoring must be conducted according to test procedures approved under 40 CFR part 136 or, in the case of sludge (biosolids) use and disposal, approved under 40 CFR part 503 unless other test procedures have been specified in this permit.

For monitoring of recycled water with no discharge to waters of the state, monitoring must be conducted according to test procedures approved under 40 CFR part 136 or as specified in the most recent edition of Standard Methods for the Examination of Water and Wastewater unless other test procedures have been specified in this permit or approved in writing by DEQ.

C4. Penalties for Tampering

The federal Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit may, upon conviction, be punished by a fine of not more than \$10,000 per violation, imprisonment for not more than two years, or both. If a conviction of a person is for a violation committed after a first conviction of such person, punishment is a fine not more than \$20,000 per day of violation, or by imprisonment of not more than four years, or both.

C5. Reporting of Monitoring Results

Monitoring results must be summarized each month on a discharge monitoring report form approved by DEQ. The reports must be submitted monthly and are to be mailed, delivered or otherwise transmitted by the 15th day of the following month unless specifically approved otherwise in Schedule B of this permit.

C6. Additional Monitoring by the Permittee

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR part 136 or, in the case of sludge (biosolids) use and disposal, approved under 40 CFR part 503 or as specified in this permit, the results of this monitoring must be included in the calculation and reporting of the data submitted in the discharge monitoring report. Such increased frequency must also be indicated. For a pollutant parameter that may be sampled more than once per day (for example, total residual chlorine), only the average daily value must be recorded unless otherwise specified in this permit.

C7. Averaging of Measurements

Calculations for all limitations that require averaging of measurements must utilize an arithmetic mean, except for bacteria which must be averaged as specified in this permit.

C8. Retention of Records

Records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities must be retained for a period of at least 5 years (or longer as required by 40 CFR part 503). Records of all monitoring information including all calibration and maintenance records, all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit and records of all data used to complete the application for this permit must be retained for a period of at least 3 years from the date of the sample, measurement, report, or application. This period may be extended by request of DEQ at any time.

C9. Records Contents

Records of monitoring information must include:

- a. The date, exact place, time, and methods of sampling or measurements;
- b. The individual(s) who performed the sampling or measurements;
- c. The date(s) analyses were performed;
- d. The individual(s) who performed the analyses;
- e. The analytical techniques or methods used; and
- f. The results of such analyses.

C10. Inspection and Entry

The permittee must allow DEQ or EPA upon the presentation of credentials to:

- a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and

- d. Sample or monitor at reasonable times, for the purpose of assuring permit compliance or as otherwise authorized by state law, any substances or parameters at any location.

#### C11. Confidentiality of Information

Any information relating to this permit that is submitted to or obtained by DEQ is available to the public unless classified as confidential by the Director of DEQ under ORS 468.095. The permittee may request that information be classified as confidential if it is a trade secret as defined by that statute. The name and address of the permittee, permit applications, permits, effluent data, and information required by NPDES application forms under 40 CFR § 122.21 are not classified as confidential [40 CFR § 122.7(b)].

### **SECTION D. REPORTING REQUIREMENTS**

#### D1. Planned Changes

The permittee must comply with OAR 340-052, "Review of Plans and Specifications" and 40 CFR § 122.41(l)(1). Except where exempted under OAR 340-052, no construction, installation, or modification involving disposal systems, treatment works, sewerage systems, or common sewers may be commenced until the plans and specifications are submitted to and approved by DEQ. The permittee must give notice to DEQ as soon as possible of any planned physical alternations or additions to the permitted facility.

#### D2. Anticipated Noncompliance

The permittee must give advance notice to DEQ of any planned changes in the permitted facility or activity that may result in noncompliance with permit requirements.

#### D3. Transfers

This permit may be transferred to a new permittee provided the transferee acquires a property interest in the permitted activity and agrees in writing to fully comply with all the terms and conditions of the permit and EQC rules. No permit may be transferred to a third party without prior written approval from DEQ. DEQ may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under 40 CFR § 122.61. The permittee must notify DEQ when a transfer of property interest takes place.

#### D4. Compliance Schedule

Reports of compliance or noncompliance with, or any progress reports on interim and final requirements contained in any compliance schedule of this permit must be submitted no later than 14 days following each schedule date. Any reports of noncompliance must include the cause of noncompliance, any remedial actions taken, and the probability of meeting the next scheduled requirements.

#### D5. Twenty-Four Hour Reporting

The permittee must report any noncompliance that may endanger health or the environment. Any information must be provided orally (by telephone) within 24 hours from the time the permittee becomes aware of the circumstances, unless a shorter time is specified in the permit. During normal business hours, the DEQ regional office must be called. Outside of normal business hours, DEQ must be contacted at 1-800-452-0311 (Oregon Emergency Response System).

- a. The following must be included as information that must be reported within 24 hours under this paragraph:
  - (1) Any unanticipated bypass that exceeds any effluent limitation in this permit;
  - (2) Any upset that exceeds any effluent limitation in this permit;
  - (3) Violation of maximum daily discharge limitation for any of the pollutants listed by DEQ in this permit; and
  - (4) Any noncompliance that may endanger human health or the environment.

- b. A written submission must also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission must contain:
- (1) A description of noncompliance and its cause;
  - (2) The period of noncompliance, including exact dates and times;
  - (3) The estimated time noncompliance is expected to continue if it has not been corrected;
  - (4) Steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and
  - (5) Public notification steps taken, pursuant to General Condition B7.

DEQ may waive the written report on a case-by-case basis if the oral report has been received within 24 hours.

**D6. Other Noncompliance**

The permittee must report all instances of noncompliance not reported under General Condition D4 or D5, at the time monitoring reports are submitted. The reports must contain:

- a. A description of the noncompliance and its cause;
- b. The period of noncompliance, including exact dates and times;
- c. The estimated time noncompliance is expected to continue if it has not been corrected; and
- d. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

**D7. Duty to Provide Information**

The permittee must furnish to DEQ within a reasonable time any information that DEQ may request to determine compliance with the permit or to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit. The permittee must also furnish to DEQ, upon request, copies of records required to be kept by this permit.

Other Information: When the permittee becomes aware that it has failed to submit any relevant facts or has submitted incorrect information in a permit application or any report to DEQ, it must promptly submit such facts or information.

**D8. Signatory Requirements**

All applications, reports or information submitted to DEQ must be signed and certified in accordance with 40 CFR § 122.22.

**D9. Falsification of Information**

Under ORS 468.953, any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance, is subject to a Class C felony punishable by a fine not to exceed \$125,000 per violation and up to 5 years in prison per ORS chapter 161. Additionally, according to 40 CFR § 122.41(k)(2), any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit including monitoring reports or reports of compliance or non-compliance will, upon conviction, be punished by a federal civil penalty not to exceed \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by both.

**D10. Changes to Discharges of Toxic Pollutant**

The permittee must notify DEQ as soon as it knows or has reason to believe the following:

- a. That any activity has occurred or will occur that would result in the discharge, on a routine or frequent basis, of any toxic pollutant that is not limited in the permit, if that discharge will exceed the highest of the following “notification levels:
  - (1) One hundred micrograms per liter (100 µg/l);
  - (2) Two hundred micrograms per liter (200 µg/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/l) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;

- (3) Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR § 122.21(g)(7); or
  - (4) The level established by DEQ in accordance with 40 CFR § 122.44(f).
- b. That any activity has occurred or will occur that would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant that is not limited in the permit, if that discharge will exceed the highest of the following “notification levels”:
- (1) Five hundred micrograms per liter (500 µg/l);
  - (2) One milligram per liter (1 mg/l) for antimony;
  - (3) Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR § 122.21(g)(7); or
  - (4) The level established by DEQ in accordance with 40 CFR § 122.44(f).

### SECTION E. DEFINITIONS

- E1. *BOD* or *BOD<sub>5</sub>* means five-day biochemical oxygen demand.
- E2. *CBOD* or *CBOD<sub>5</sub>* means five-day carbonaceous biochemical oxygen demand.
- E3. *TSS* means total suspended solids.
- E4. *Bacteria* means but is not limited to fecal coliform bacteria, total coliform bacteria, *Escherichia coli* (*E. coli*) bacteria, and *Enterococcus* bacteria.
- E5. *FC* means fecal coliform bacteria.
- E6. *Total residual chlorine* means combined chlorine forms plus free residual chlorine
- E7. *Technology based permit effluent limitations* means technology-based treatment requirements as defined in 40 CFR § 125.3, and concentration and mass load effluent limitations that are based on minimum design criteria specified in OAR 340-041.
- E8. *mg/l* means milligrams per liter.
- E9. *µg/l* means microgram per liter.
- E10. *kg* means kilograms.
- E11. *m<sup>3</sup>/d* means cubic meters per day.
- E12. *MGD* means million gallons per day.
- E13. *Average monthly effluent limitation* as defined at 40 CFR § 122.2 means the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.
- E14. *Average weekly effluent limitation* as defined at 40 CFR § 122.2 means the highest allowable average of daily discharges over a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.
- E15. *Daily discharge* as defined at 40 CFR § 122.2 means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the daily discharge must be calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge must be calculated as the average measurement of the pollutant over the day.
- E16. *24-hour composite sample* means a sample formed by collecting and mixing discrete samples taken periodically and based on time or flow.
- E17. *Grab sample* means an individual discrete sample collected over a period of time not to exceed 15 minutes.
- E18. *Quarter* means January through March, April through June, July through September, or October through December.
- E19. *Month* means calendar month.
- E20. *Week* means a calendar week of Sunday through Saturday.



State of Oregon  
Department of  
Environmental  
Quality

## National Pollutant Discharge Elimination System Permit Fact Sheet USACE McNary Lock and Dam Project

<b>Permittee</b>	U.S. Army Corps of Engineers McNary Lock and Dam Project 82925 Devore Road Umatilla, OR 97882
<b>Existing Permit Information</b>	File Number: 124380 Permit Number: New EPA Reference Number: New Category: Industrial Class: Minor Expiration Date: TBD
<b>Permittee Contact</b>	Kristoffer Miller Environmental Compliance Coordinator 541-922-2219 P.O. Box 1230 Umatilla, OR 97882-1230
<b>Receiving Water Information</b>	Receiving stream/NHD name: Columbia River NHD Reach Code & % along reach: 17070101001342, 94.65% USGS 12-digit HUC: 170701010207 OWRD Administrative Basin: Mainstem Columbia River ODEQ LLID & River Mile: 1240483462464, RM 287.14 Assessment Unit ID: OR_LK_1707010106_88_100132
<b>Proposed Action</b>	New Permit Issuance Application Number: 958153 Date Application Received: 6/4/2015
<b>Permit Writer</b>	Olivia Stoken 971-867-1077 Date Prepared: (final date prior to PN)

# NPDES Permit Fact Sheet USACE McNary Lock and Dam Project

## Table of Contents

<b>1. Introduction</b> .....	<b>4</b>
<b>2. Facility Description</b> .....	<b>4</b>
2.1 Wastewater Facility .....	4
2.2 Stormwater .....	11
2.3 Industrial Rating.....	11
<b>3. Schedule A: Effluent Limit Development</b> .....	<b>11</b>
3.1 Technology-Based Effluent Limit Development.....	11
3.2 Water Quality-Based Effluent Limit Development .....	12
3.3 Antibacksliding .....	20
3.4 Antidegradation.....	20
3.5 Whole Effluent Toxicity .....	21
3.6 Groundwater .....	21
3.7 Clean Water Act Section 401(a)(2).....	21
<b>4. Schedule A: Other Limitations</b> .....	<b>21</b>
4.1 Mixing Zone.....	21
<b>5. Schedule B: Monitoring and Reporting Requirements</b> .....	<b>21</b>
<b>6. Schedule C: Compliance Schedule</b> .....	<b>22</b>
<b>7. Schedule D: Special Conditions</b> .....	<b>22</b>
7.1 Mixing Zone Study .....	22
7.2 Emergency Response and Public Notification Plan.....	22
7.3 Spill/Emergency Response Plan .....	22
7.4 Outfall Inspection.....	22
7.5 pH Criteria Exceedance Report .....	22
7.6 Best Management Practices (BMP) Plan.....	23
7.7 Environmentally Acceptable Lubricants (EALs).....	23
7.8 Cooling Water Intake Structure (CWIS) Requirements .....	23
7.9 Juvenile Fish Facility Best Management Practices.....	26
<b>8. Schedule F: NPDES General Conditions</b> .....	<b>26</b>
<b>Appendix A: Thermal Plumes RPA</b> .....	<b>27</b>

## List of Tables

Table 2-1: List of Outfalls.....	10
----------------------------------	----

Table 3-1: 303(d) and TMDL Parameters .....	12
Table 3-2: Applicable WLAs.....	13
Table 3-3: Pollutants of Concern .....	14
Table 3-4: Temperature Criteria Information .....	16
Table 3-5: Temperature Criterion Effluent Limits.....	16
Table 3-6: Thermal Plume Effluent Limit .....	18
Table 3-7: Proposed Chlorine Limits – Outfalls 004, 005, 006, 007, 008, and 009.....	19
Table 7-1: Hydropower Operations for Fish Survival .....	25

## List of Figures

Figure 2-1: Facility Site Map.....	8
Figure 2-2: Facility Line Drawing .....	9
Figure 2-3: Dam Cross Section Diagram.....	10

Applicant Review

# NPDES Permit Renewal Fact Sheet

## USACE McNary Lock and Dam Project

### 1. Introduction

As required by Oregon Administrative Rule 340-045-0035, this fact sheet describes the basis and methodology used in developing the permit. The permit is divided into several sections:

- Schedule A – Waste discharge limitations
- Schedule B – Minimum monitoring and report requirements
- Schedule C – Compliance conditions and schedules
- Schedule D – Special conditions
- Schedule E – Pretreatment conditions
- Schedule F – General conditions

### 2. Facility Description

#### 2.1 Wastewater Facility

McNary Lock and Dam Project is a run-of-the-river hydroelectric facility operated by the US Army Corps of Engineers (USACE) on the Columbia River at river mile 287.14 on the DEQ LLID (river mile 292 on NOAA charts). The facility was authorized by Congress for navigation and power generation in the 1945 River and Harbor Act. Construction of the facility was completed in 1957 and includes a navigation lock, spillway, powerhouse, fish passage facilities, and a juvenile fish research and monitoring facility. The powerhouse and the south fish ladder are in Oregon, while the navigation lock, spillway, and the north fish ladder are in Washington. Domestic wastewater from the facility is discharged to the City of Umatilla publicly owned treatment works and is covered under the City's NPDES permit (# 101059). The facility produces electricity using falling or flowing water to drive turbines and generators. The powerhouse has 14 turbine units with a total power generating capacity of 980 megawatts and 130,000 cfs maximum hydraulic capacity.

##### 2.1.1 Types of Discharges

###### 2.1.1.1 Cooling Water

McNary Lock and Dam uses river water to cool equipment resulting in discharges of non-contact cooling water to the river. Non-contact cooling water is defined as “water used for cooling which does not come into direct contact with any raw material, intermediate product, waste product or finished product” (40 CFR 401.11(n)). Non-contact cooling water is used to cool the turbine bearings, guide bearings, air compressors, generators, and HVAC chillers. The facility has the capacity to divert certain equipment-related cooling waters to the equipment and floor drain water drainage system. Hydroelectric generating facilities that use cooling water transfer heat from the equipment to cooling water. If there are holes in the pipes of the equipment being cooled, oil may enter the cooling water and be discharged. Thus, cooling water may include heat as well as oil and grease discharges.

Cooling water intake structures (CWIS) are the structures where water is extracted for equipment cooling use in the facility. CWIS in this facility are the points where water is diverted from the scroll cases to be used for cooling. Screens on the CWIS remove debris and can impinge or entrain fish. McNary Dam has screens that are manually cleaned.

#### **2.1.1.2 Equipment Drainage and Floor Drain Discharges**

Equipment drainage and floor drain discharges collect various points of internal station drainage discharges. Drainage is collected by floor drains, trench drains, wheel pit drains, station sumps, spillway sumps, and navigation lock sumps. These drainage collection systems drain water from compressor blowdowns, leakage from turbines and penstocks, grout gallery leakage, navigation lock leakage, housing leakage, packing boxes leakage, lower guide bearing and other bearing-related discharges, equipment and seal leakage, gate stems, turbine and scroll case access doors, tunnel pumpage, and water from ground water infiltration and surface water seepage. Drainage sumps and dewatering sumps are the primary sources of potential oil and grease discharges in the hydroelectric facilities in the Lower Columbia River. At some facilities, cooling water discharges may enter into equipment and floor drains, resulting in a commingled discharge, which could increase outfall water temperatures. Heat increases from commingled discharges are likely to be small or immeasurable, however, since most drainage water is leakage water or other water with temperature the same as leakage water.

#### **2.1.1.3 Equipment and Facility Maintenance-Related Discharges**

The equipment and facility maintenance-related water discharges include river water pumped from the facility during periods of equipment, station, and facility maintenance. In the Lower Columbia River hydroelectric generating facilities, maintenance operations are generally continuous, and maintenance-related waters from unwatering sumps are discharged on a regular basis. During equipment maintenance operation, discharges occur from the dewatering of equipment containing river water such as the turbine, penstock, navigation locks, and dewatering sumps, which may contain residual oil and grease, detritus, or silt.

#### **2.1.1.4 Lubricants**

Various equipment in the hydroelectric generating facilities is lubricated with grease. This includes turbine oil used to operate and lubricate turbines. The Kaplan runner is part of the turbine in the Lower Columbia River hydroelectric generating facilities that extends into the draft tube. The runner contains oil and can release oil in a similar manner as a controlled pitch propeller in vessels. Wicket gates, which control the amount of flow entering the scroll case to the turbine, and other equipment such as bearings, blocks, trucks and guides are also lubricated. Oil or grease that comes into contact with water may be released in the tailrace. Lubricated wire rope may also come into contact with water during rainfall, which can then exit the facility as stormwater runoff.

### **2.1.2 Outfalls**

#### **2.1.2.1 Juvenile Fish Facility Outfalls**

Outfalls 001, 002, and 003 discharge pass through river water from the Juvenile Fish Facility. This water assists juvenile (April 1 – October 30) and adult fish (December 1 – 15) passage around the dam turbines. Columbia River water flows continuously and moves fish throughout

the facility for various research and monitoring purposes. Discharge of pass-through river water from Outfall 001 averages 0.11 mgd, while Outfalls 002 and 003 both average 0.03 mgd.

In the 2015 application submitted by USACE, they identified seasonal discharge of a fish anesthetic called tricane (also known as MS-222) from Outfalls 002 and 003. USACE has discontinued the seasonal discharge of tricane and now diverts water from the fish facility during operations that require tricane. Diverted water is collected in totes and land applied in an area where the water will not contact waters of the state. To address this application, a special condition has been added to Schedule D which states any land applied water must be disposed of in a manner that ensures runoff or potential environmental degradation is minimized.

#### **2.1.2.2 Fish Pumphouse Outfalls**

The facility uses three electricity driven turbines to pump water into the facility fish ladder for fish passage purposes. Fish pumps #1-3 supply attraction water from April through October for seasonally migrating fish. During this season Outfalls 004-009 pump constantly, while pumps only run intermittently November through March. Outfalls 004-009 discharge to the McNary adult fish passage channel which is a large open channel that connects to the Columbia River just downstream of the dam. Groundwater pumped from the McNary Dam wells, which is chlorinated for drinking purposes, is also used as non-contact cooling water for Outfalls 004-009, as described below.

Outfall 004 discharges chlorinated groundwater used to lubricate the top plate pump on Fish Pump #3. Excess water is pumped from the main rotating shaft and discharged into the fish pump chamber. This outfall discharges at approximately 0.03 mgd from a 2-inch pipe into the adult fish passage channel.

Outfall 005 discharges chlorinated groundwater and river water used to cool bearings on Fish Pump #3. The bearing cooling pump circulates water through a heat exchanger within the oil filled thrust bearing tub to reduce oil temperature. The non-contact cooling water is then sent into the fish pump chamber where it is discharged at approximately 0.036 mgd from a 1-inch pipe into the adult fish passage channel.

Outfall 006 discharges chlorinated groundwater used to lubricate the top plate pump on Fish Pump #2. Excess water is pumped from the main rotating shaft and discharged into the fish pump chamber. This outfall discharges at approximately 0.03 mgd from a 2-inch pipe into the adult fish passage channel.

Outfall 007 discharges chlorinated groundwater and river water used to cool bearings on Fish Pump #2. The bearing cooling pump circulates water through a heat exchanger within the oil filled thrust bearing tub to reduce oil temperature. The non-contact cooling water is then sent into the fish pump chamber where it is discharged at approximately 0.036 mgd from a 1-inch pipe into the adult fish passage channel.

Outfall 008 discharges chlorinated groundwater used to lubricate the top plate pump on Fish Pump #1. Excess water is pumped from the main rotating shaft and discharged into the fish pump chamber. This outfall discharges at approximately 0.03 mgd from a 2-inch pipe into the adult fish passage channel.

Outfall 009 discharges chlorinated groundwater and river water used to cool bearings on Fish Pump #1. The bearing cooling pump circulates water through a heat exchanger within the oil filled thrust bearing tub to reduce oil temperature. The non-contact cooling water is then sent into the fish pump chamber where it is discharged at approximately 0.036 mgd from a 1-inch pipe into the adult fish passage channel.

Outfall 010 is the Fish Pumphouse drainage sump that collects seasonal rainwater and river water leakage from the floor and roof drains. The sump pump is activated by a float at a certain volume with a pump run time of approximately 10 minutes every 60 minutes. Water is discharged from a 4-inch pipe into the adult fish passage channel at approximately 0.043 mgd. In the summer, the sump is often dry and discharges intermittently.

### **2.1.2.3 Powerhouse Outfalls**

Outfall 011 is the powerhouse drainage sump which collects non-contact cooling water from Station Service turbine units 1 and 2, seasonal rainwater from the roof and floor drains, drainage water from the spillway grout gallery, condensation water from the powerhouse air compressor condensation lines, turbine head cover pump leakage and non-contact cooling/lubrication chlorinated water from all the main turbine units. An oil water/separator treats turbine head cover pump leakage before it reaches the sump. At the sump, an oil/water separator system skims oil floating on top of the drainage sump water prior to discharge. Oily water collected from the sump is stored in barrels and then disposed of off-site. The sump pump runs year-round for 10 minutes every 50 minutes and discharges at approximately 0.5 mgd from an 8-inch pipe into the adult fish passage channel.


Outfall 012 is the powerhouse unwatering sump which collects leakage and water removed from the main turbine unit draft (#1 through #14) tubes during maintenance. The three sump pumps run year-round for 10 minutes every 40-50 minutes and discharge at approximately 0.07 mgd from a 14-inch pipe to the adult fish passage channel. Pumps are operated by a level indicator or manually. If oil or grease contamination is suspected, water can be diverted from the unwatering sump to the powerhouse drainage sump (Outfall 011) for treatment by the oil/water separator system.

Outfalls 013 through 020 discharge non-contact cooling water from main turbine units #1 through #14 that is used to cool air within the units, external thrust bearing oil, and HVAC unit refrigerant. HVAC units provide air conditioning for the powerhouse using R-134a refrigerant. HVAC cooling water is only discharged at Outfalls 014, 016, and 018. Outfalls 014 through 020 intermittently discharge to the Columbia River year-round at approximately 1.5 to 2.0 mgd.

McNary's main turbine units each contain a shaft packing that utilizes chlorinated groundwater for lubrication and pressurization of the turbine shaft area to prevent river water from leaking past the shaft packing. This pressurization minimizes contamination of the lubrication zone and deterioration of the shaft packing. A small portion (~5%) of the chlorinated groundwater is discharged through the turbine draft tube. Most of the chlorinated groundwater utilized by the shaft packing drains to the turbine pit where it is pumped to the oil/water separator, and then to the powerhouse drainage sump where it is discharged through Outfall 011.



**Figure 2-1: Facility Site Map**



**Figure 2-2: Facility Line Drawing**




Figure 2-3: Dam Cross Section Diagram

Table 2-1: List of Outfalls

Outfall Number	Type of Waste	Lat/Long
001, 002, 003	Drainage sump, seasonal fish rearing	45.932222, -119.299444
004, 005	Pump and thrust bearing non-contact cooling water	45.931944, -119.298056
006, 007	Pump and thrust bearing non-contact cooling water	45.93197, -119.298255
008, 009	Pump and thrust bearing non-contact cooling water	45.931946, -119.29837
010	Drainage sump, stormwater runoff	45.931908, -119.298317
011	Drainage sump, stormwater runoff	45.932455, -119.297726
012	Unwatering and drainage sump	45.932312, -119.297667
013	Main turbine unit and thrust bearing non-contact cooling water	45.932222, -119.297500
014	Main turbine unit, thrust bearing, and HVAC non-contact cooling water	45.932777, -119.297500
015	Main turbine unit and thrust bearing non-contact cooling water	45.933055, -119.297777

Outfall Number	Type of Waste	Lat/Long
016	Main turbine unit, thrust bearing, and HVAC non-contact cooling water	45.933611, -119.297777
017	Main turbine unit and thrust bearing non-contact cooling water	45.934166, -119.298055
018	Main turbine unit, thrust bearing, and HVAC non-contact cooling water	45.934444, -119.298055
019	Main turbine unit and thrust bearing non-contact cooling water	45.935000, -119.298055
020	Main turbine unit and thrust bearing non-contact cooling water	45.932455, -119.297726

## 2.2 Stormwater

Any stormwater that infiltrates the facility is routed to the drainage sumps (Outfalls 010 and 011) which are commingled discharges. The powerhouse drainage sump (Outfall 011) is treated by an oil/water separator prior to discharge. There are no separate storm water discharges to surface waters from the facility that are covered under this permit.

## 2.3 Industrial Rating

DEQ uses EPA's non-municipal rating system to classify a permittee as a major or a minor facility. EPA developed a rating worksheet that considers factors such as type of facility, relative flow rate, potential to impact human health, and other water quality factors. DEQ completed the rating worksheet and determined the permittee is a minor facility. The rating sheet is part of the administrative record.

## 3. Schedule A: Effluent Limit Development

Effluent limits serve as the primary mechanism in NPDES permits for controlling discharges of pollutants to receiving waters. Effluent limitations are based on both the available technology to control the pollutants and the water quality standards applicable to the receiving water. DEQ refers to these two types of permit limits as technology-based effluent limitations (TBELs) and water quality-based effluent limits (WQBELs), respectively. When a TBEL is not restrictive enough to protect the receiving water, DEQ must include a WQBEL in the permit.

### 3.1 Technology-Based Effluent Limit Development

EPA is required to develop technology-based effluent limits for categories of industrial facilities. These limits are called effluent limitation guidelines (ELGs). EPA established these based on available treatment technologies for facilities within an industrial category or subcategory.

EPA has not developed ELGs for hydroelectric generating facility discharges.

## 3.2 Water Quality-Based Effluent Limit Development

40 CFR 122.44(d) requires that permits include limitations more stringent than technology-based requirements where necessary to meet water quality standards. Water quality-based effluent limits may be in the form of a wasteload allocation required as part of a Total Maximum Daily Load (TMDL). They may also be required if a site specific analysis indicates the discharge has the reasonable potential to cause or contribute to an exceedance of a water quality criterion. DEQ establishes effluent limits for pollutants that have a reasonable potential to exceed a criterion. The analyses are discussed below.

### 3.2.1 Designated Beneficial Uses

NPDES permits issued by DEQ must protect the following designated beneficial uses of the Columbia River. These uses are listed in OAR-340-041-0101 for the Main Stem Columbia River.

- Public and private domestic water supply
- Industrial water supply
- Irrigation and livestock watering
- Fish and aquatic life (including salmonid rearing, migration and spawning)
- Wildlife and hunting
- Fishing
- Boating
- Water contact recreation
- Aesthetic quality
- Hydro power
- Commercial navigation and transportation

### 3.2.2 303(d) Listed Parameters and Total Maximum Daily Loads

The following table lists the parameters that are on the 2022 303(d) list (Category 5) and also parameters with an approved TMDL (Category 4A) within the discharge's stream reach. If a parameter is listed under Category 5, the data in the assessment unit (or nearby assessment unit) indicates a designated use is not supported or a water quality standard is not attained and a TMDL is needed (Category 4A). If a parameter is listed under Category 4A, TMDLs that will result in attainment of water quality standards and support beneficial use have been approved by EPA.

**Table 3-1: 303(d) and TMDL Parameters**

<b>Water Quality Limited Parameters (Category 5)</b>	
AU ID:	OR_LK_1707010106_88_100132
AU Name:	Columbia River (Lake Umatilla upstream from Lwr Four Mile Canyon)
AU Status:	Impaired
Year Listed	1998
Year Last Assessed	2018

303d Parameters (Category 5)	Fecal coliform, methylmercury, polychlorinated biphenyls (PCBs)
<b>TMDL Parameters (Category 4)</b>	
Temperature, total dissolved gas, dioxin (2,3,7,8-TCDD)	

Polychlorinated biphenyls (PCBs) were historically used in the transformers at McNary. In 2012 and 2017, all PCB containing oil was removed from the transformers and disposed. Current transformers are considered non-PCB (40 CFR 761) and analytical results documenting non-PCB transformer oil are part of the permit administrative record. Therefore, PCBs are not a pollutant of concern for permitted discharges from the facility.

Methylmercury is produced in aquatic environments when anerobic bacteria methylate inorganic mercury. Fecal coliform are bacteria associated with human or animal wastes. McNary is not considered a source for methylmercury or fecal coliform. Therefore, these are not pollutants of concern for the facility.

### 3.2.3 TMDL Wasteload Allocations

DEQ issued TMDLs for the Columbia River in 1991 for 2,3,7,8-TCDD (dioxin) and in 2002 for total dissolved gas, while EPA issued a TMDL in 2021 for temperature. WLAs from this TMDL that are applicable to the permittees are listed in the following table.

**Table 3-2: Applicable WLAs**

Parameter	WLA	Time Period
Temperature	2,830 million kilocalories/day	June 1 – October 31
Note: The thermal load WLA is expressed as an average monthly value.		

McNary Lock and Dam Project is not considered a source for 2,3,7,8-TCDD (dioxin) and was not assigned a WLA in the 1991 TMDL. The temperature WLA is discussed in section 3.2.8.

Elevated total dissolved gas is caused by spill events, when quickly flowing water entrains total dissolved gas at high levels. In the case of hydroelectric generating facilities, these spill events are “pass through” water, which are not regulated by NPDES permits (*See National Wildlife Federation v. Consumers Power Company*, 862 F.2d 580 (6th Cir. 1988); *National Wildlife Federation v. Gorsuch*, 693 F.2d 156 (D.C. Cir. 1982)). Therefore, total dissolved gas is not a pollutant of concern for permitted discharges from the facility.

### 3.2.4 Pollutants of Concern

To ensure that a permit is protecting water quality, DEQ must identify pollutants of concern. These are pollutants that are expected to be present in the effluent at concentrations that could adversely impact water quality. DEQ uses the following information to identify pollutants of concern:

- Effluent monitoring data.
- Knowledge about the permittee’s processes.
- Knowledge about the receiving stream water quality.
- Pollutants identified by applicable federal effluent limitation guidelines.

DEQ identified the following pollutants of concern for this facility listed in the following table.

**Table 3-3: Pollutants of Concern**

<b>Pollutant</b>	<b>How was pollutant identified?</b>
pH	Effluent Monitoring
Temperature	Effluent Monitoring
Oil and Grease	Effluent Monitoring
Total Residual Chlorine	Effluent Monitoring
Dissolved Copper	Stormwater discharge
Dissolved Lead	Stormwater discharge
Dissolved Zinc	Stormwater discharge

#### **3.2.4.1 Nitrates**

McNary pumps groundwater for drinking water and non-contact cooling water uses. Chlorinated groundwater is discharged through Outfalls 004-009, Outfall 011, and Outfalls 013-020. The facility is in the Lower Umatilla Basin Groundwater Management Area which was established due to high levels of nitrates in groundwater. Well monitoring from 2003 through 2024 at McNary documented non-detect samples for nitrates with a quantitation limit of 10 mg/L (Oregon Health Authority). This is below the water quality criteria; therefore, nitrates are not a pollutant of concern for the facility.

The sections below discuss the analyses that were conducted for the pollutants of concern to determine if water quality based effluent limits are needed to meet water quality standards.

#### **3.2.5 Regulatory Mixing Zone**

A review of the Washington permit WA0026824 for the McNary Dam showed that the permit did not include a mixing zone for any outfall. A monitoring request letter from DEQ to USACOE on June 7, 2022 specified that if the permittee wished to have a mixing zone for any outfall, a level 1 mixing zone study would need to be submitted to DEQ prior to permit development. While the letter was later updated to adjust submission dates on October 3, 2022 the mixing zone requirement did not change. No mixing zone study was submitted prior to permit development. Therefore no regulatory mixing zone will be included in the proposed permit for any outfall. A dilution factor of 1 was used for all reasonable potential analyses. A provision will be included in Schedule D stating that if the permittee wants a mixing zone for a future permit renewal, a level 1 mixing zone study must be submitted. Thermal plumes analysis requires a 7Q10 value regardless of whether a mixing zone is assigned to a permittee. A 7Q10 value of 77,749 cfs for the Columbia River was calculated using data from the USGS gauge 14105700 (Columbia River at the Dalles, OR) from 1972-01-01 to 2024-11-19.

#### **3.2.6 Oil and Grease**

Oil and grease are used throughout the facility for various processes (see Section 2) and may be discharged through the outfalls. OAR 340-041-0007(12) is a water-quality based narrative criterion that prohibits a visible oily sheen.

### **3.2.6.1 Discharge Limits**

To meet this criterion, the proposed permit includes a narrative limit prohibiting discharge of a visible sheen in Schedule A. Additionally, a maximum daily limit of 5 mg/L oil and grease has been added in the proposed permit for Outfalls 004, 005, 006, 007, 008, 009, 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020. The 5 mg/L oil and grease limit for hydroelectric facilities in the Lower Columbia River was established by EPA in the USACE NPDES permits that became effective July 1, 2023, which included Bonneville, The Dalles, John Day, and McNary. This concentration is expected to prevent a visible sheen on surface waters. Therefore, DEQ believes this limit is a reasonable standard for hydroelectric facilities that have a reasonable potential for oil and grease discharges.

### **3.2.6.2 Monitoring Requirements**

For the first year of the proposed permit term, weekly monitoring of oil and grease concentration in mg/L is required. For the rest of the proposed permit term, monthly monitoring is required. These monitoring frequencies are similar to the EPA-written McNary Lock & Dam NPDES permit in Washington, except the conditional requirement to have no oil and grease exceedances in the first year of monitoring. McNary USACE staff have reported no issues meeting the oil and grease limits in Washington, so DEQ anticipates these monitoring frequencies will be sufficient for routine compliance and permit renewal purposes. The proposed permit also requires weekly visual inspection of outfalls for visible sheens. If USACE staff document a visual sheen at any outfall, the proposed permit includes a conditional requirement to collect a sample for oil and grease that must be reported on the next month's DMR.

Additionally, the permittee is required to develop and implement a Best Management Plan (BMP) and BMP Annual Reports, which include tracking and accountability of oil use in the facility, minimization of any oil spills, proper operation and maintenance of all equipment that may release oil, and identification of and contingency planning for site-specific vulnerabilities for oil spills such as lack of secondary containment. For lubricants such as oil and grease, the permit requires the use of Environmentally Acceptable Lubricants (EALs) to replace oil and grease, unless technically infeasible, to reduce the potential of oil and grease entering the river and an EAL Annual Report tracking implementation progress.

### **3.2.7 pH**

The pH criterion for this basin is 7.0 – 8.5 per OAR 340-041-0104. There are no regulatory mixing zones established for this facility. The proposed pH limits for outfalls 001, 002, 003, 004, 005, 006, 007, 008, 009, 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020 are 7.0 – 8.5 and are WQBELs.

Additionally, pH exceedances that are caused by dam impoundments existing on January 1, 1996 are not in violation of the standard if DEQ determines that the exceedance would not occur without the impoundment and all practicable measures in the impoundment have been taken to comply with the pH criteria (OAR-340-041-0021(2)). An annual pH criteria exceedance report has been included as a special condition in Schedule D to document exceedances that may be subject to this rule.

### 3.2.8 Temperature

#### 3.2.8.1 Temperature Criteria OAR 340-041-0028

The following table summarizes the temperature criteria that apply at the discharge location along with whether the receiving stream is water quality-limited for temperature and whether a TMDL wasteload allocation has been assigned. Using this information, DEQ performed several analyses to determine if effluent limits were needed to comply with the temperature criteria.

**Table 3-4: Temperature Criteria Information**

<b>Applicable Temperature Criterion</b>	Migration Corridor 20°C (OAR 340-041-0028(4)(d))
Applicable dates: Year-round	
<b>Salmon/Steelhead Spawning 13 °C?</b> OAR 340-041-0028(4)(a)	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Applicable dates: NA	
<b>WQ-limited?</b>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
<b>TMDL wasteload allocation assigned?</b>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Applicable dates: June 1 – October 31	
TMDL based on natural conditions criterion?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
<b>Cold water summer protection criterion applies?</b>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
<b>Cold water spawning protection applies?</b>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Comments: NA	

The main stem Columbia River has a year-round salmon and steelhead migration criterion of 20 °C. EPA issued a temperature TMDL addressing this criterion for the entire Columbia River on May 18, 2020, with revisions issued on August 13, 2021. With the issuance of the EPA TMDL a wasteload allocation for the facility of 2,830 million kcal/day (monthly average) applies to the discharge and is included in the proposed permit as an effluent limit for the June 1 – October 31 period. The daily thermal load discharged is calculated by multiplying the daily effluent flow by the average daily effluent temperature and a standard conversion factor from the TMDL. This calculation is done for each outfall with a thermal load (see Table 3-5). The daily thermal loads for each outfall are averaged for the month and summed. The facility-wide monthly average thermal load must be equal to or less than 2,830 million kcal/day.

Final effluent limits are listed in the following table.

**Table 3-5: Temperature Criterion Effluent Limits**

<b>Effluent limit needed?</b> <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
<b>TMDL WLA Limit:</b> 2,830 million kilocalories/day as a monthly average
Applicable time period: June 1 – October 31
<b>Temperature Criterion Limit:</b> NA

<b>Effluent limit needed?</b> <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Applicable time period: Dates <input checked="" type="checkbox"/> NA
Comments: Includes Outfalls 004, 005, 006, 007, 008, 009, 010, 011, 012, 013, 014, 015, 016, 017, 018, 019, and 020

### 3.2.8.2 Thermal Plume OAR 340-041-0053(2)(d)

In addition to compliance with the temperature criteria, OAR 340-041-0053(2)(d) contains thermal plume limitation provisions designed to prevent or minimize adverse effects to salmonids that may result from thermal plumes. The discharge was evaluated for compliance with these provisions as follows:

- OAR 340-041-0053(2)(d)(A): Impairment of an active salmonid spawning area where spawning redds are located or likely to be located. This adverse effect is prevented or minimized by limiting potential fish exposure to temperatures of 13 °C or more for salmon and steelhead, and 9 °C or more for bull trout.

This section of the Mainstem Columbia River is not designated as salmonid spawning habitat; therefore, the spawning area requirement is met.

- OAR 340-041-0053(2)(d)(B): Acute impairment or instantaneous lethality is prevented or minimized by limiting potential fish exposure to temperatures of 32 °C or more to less than 2 seconds.

The maximum daily effluent temperature recorded at all outfalls between August 2022 and September 2023 was 26.1 °C, below the criterion of 32 °C. Therefore, the discharges are not expected to cause acute impairment to salmonid species.

- OAR 340-041-0053(2)(d)(C): Thermal shock caused by a sudden increase in water temperature is prevented or minimized by limiting potential fish exposure to temperatures of 25 °C or more to less than 5% of the cross-section of 100% of the 7Q10 flow of the water body.

An analysis related to thermal shock, included in Appendix A, indicates that when both the effluent for Outfalls 004 through 020 are at their maximum measured or expected values and the upstream receiving water temperature is at the 25 °C criterion, the plume's temperature at 5% of the receiving stream's cross-sectional area will not be above 25 °C. Based on this analysis, thermal shock caused by the discharges is prevented or minimized.

- OAR 340-041-0053(2)(d)(D): Unless ambient temperature is 21 °C or greater, migration blockage is prevented or minimized by limiting potential fish exposure to temperatures of 21 °C or more to less than 25% of the cross-section of 100% of the 7Q10 flow of the water body.

An analysis related to migration blockage, included in Appendix A, indicates that when the effluent plume from Outfalls 004 through 020 are at their maximum measured or expected values and the upstream receiving water is at the 21 °C criterion, the plume's temperature at 25% of the receiving stream's cross-sectional area will not be above 21.0 °C, and migration blockage caused by the discharges is therefore prevented or minimized.

Effluent limits needed to comply with the thermal plume requirements are shown in the following table.

**Table 3-6: Thermal Plume Effluent Limit**

Effluent limit needed? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
<b>Calculated limit:</b> NA
<b>Applicable timeframe:</b> NA
Comments: NA

### 3.2.8.3 Cold Water Refugia

OAR 340-041-0028(4)(d) requires that water bodies subject to the salmonid migration criterion of 20 °C must also have cold water refugia that are sufficiently distributed to allow salmon and steelhead migration without significant adverse effects from higher water temperatures elsewhere in the water body. The 2021 EPA Columbia Cold Water Refuges (CWR) Plan identified tributaries that create CWR in the Columbia River. The Umatilla River is the closest identified CWR, located just downstream of McNary. Currently the Umatilla River CWR status is marginal as the Umatilla is only cooler than the Columbia during late August and September. Based on this status, it is unlikely that effluent from the facility's permitted discharges would have an impact on CWR in the Columbia River.

### 3.2.9 Toxic Pollutants

DEQ typically performs the reasonable potential analysis for toxics according to EPA guidance provided in the Technical Support Document for Water Quality-Based Toxics Control (TSD) (Office of Water Enforcement and Permits, U.S. EPA, March 1991). The factors incorporated into this analysis include:

1. Effluent concentrations and variability
2. Water quality criteria for aquatic life and human health
3. Receiving water concentrations
4. Receiving water dilution (if applicable)

DEQ performs these analyses using spreadsheets that incorporate EPA's statistical methodology. The following sections describe the analyses for various toxic pollutants below.

#### 3.2.9.1 Total Residual Chlorine

Chlorinated groundwater is used for lubrication and cooling in the turbine units main shaft packing assemblies (see Section 2.1) and discharged through Outfalls 004, 005, 006, 007, 008, 009, 011, 013, 014, 015, 016, 017, 018, 019 and 020.

### Fish Pumphouse Outfalls

Chlorine monitoring was requested for Outfall 009 and is considered representative of the Fish Pumphouse outfalls (004, 005, 006, 007, 008, and 009) that discharge chlorinated groundwater. An analysis was conducted to determine if the facility had the reasonable potential to exceed the chlorine criteria at the Fish Pumphouse outfalls. The maximum chlorine concentration from Outfall 009 of 0.22 mg/L was used for the analysis. The analysis indicates the discharges have the potential to exceed the chlorine criteria; therefore, chlorine limits are included in the proposed permit. Proposed limits are listed in the following table.

**Table 3-7: Proposed Chlorine Limits – Outfalls 004, 005, 006, 007, 008, and 009**

	<b>Chronic (mg/L)</b>	<b>Acute (mg/L)</b>
<b>Chlorine Criteria</b>	0.011	0.019
	<b>Average Monthly Limit (mg/L)</b>	<b>Maximum Daily Limit (mg/L)</b>
<b>Proposed Limit</b>	<b>0.01</b>	<b>0.02</b>
Effluent data source: DMRs 8/2022 – 9/2023		
Receiving water data source: Assumed to be zero		

Effluent data submitted by the permittee indicates that the permittee will not be able to meet these WQBELs upon permit issuance. Therefore, a compliance schedule will be included in the proposed permit (see Section 6).

### Powerhouse Outfalls

No chlorine monitoring data is available for the powerhouse outfalls that discharge chlorinated groundwater (011: powerhouse sump, and 013 through 020: turbine non-contact cooling water), but chlorinated water is only a small proportion of the effluent. Currently there is no evidence that chlorine levels at the powerhouse outfalls have a reasonable potential to exceed the chlorine criteria, and no limits are included. Total residual chlorine monitoring is included in the proposed permit for use in reasonable potential analyses at the next permit renewal. Due to the similarities in effluent discharged from Outfalls 013 through 020 and the small proportion of chlorinated water discharged (~5%, remaining 95% sent to Outfall 011), representative monitoring will be allowed for these outfalls.

#### **3.2.9.2 Priority Pollutant Toxics**

No monitoring data is available for the facility outfalls that discharge commingled stormwater (010 and 011), but lead and zinc are pollutants of concern. Proportionally most effluent discharged from these sumps is river water and non-contact cooling water so currently there is no evidence that these discharges have a reasonable potential to exceed lead and zinc criteria. Stormwater metals monitoring (total lead and total zinc) is included in the proposed permit for use in reasonable potential analyses during permit renewal.

#### **3.2.9.3 Copper Biotic Ligand Model**

No monitoring data is available for the facility outfalls that discharge commingled stormwater (010 and 011), but copper is a pollutant of concern. Proportionally most effluent discharged from

these sumps is river water and non-contact cooling water so currently there is no evidence that these discharges have a reasonable potential to exceed copper criteria. Copperbiotic ligand model monitoring is included in the proposed permit for use in reasonable potential analyses during permit renewal

#### **3.2.9.4 Aluminum**

No monitoring data is available for the facility outfalls that discharge commingled stormwater (010 and 011), but aluminum is a pollutant of concern. Proportionally most effluent discharged from these sumps is river water and non-contact cooling water so currently there is no evidence that these discharges have a reasonable potential to exceed aluminum criteria. Aluminum monitoring is included in the proposed permit for use in reasonable potential analyses during permit renewal.

#### **3.2.9.5 Mercury – Human Health Criterion**

DEQ determined that this facility is not a likely source of mercury. Therefore, no additional controls or monitoring will be required.

#### **3.2.9.6 HVAC refrigerant (R-134a)**

Outfalls 014, 016, and 018 discharge non-contact cooling water from the powerhouse HVAC chiller units. If holes develop in the pipes of the HVAC units, R-134a refrigerant may enter the cooling water and be discharged. R-134a, also known as 1,1,1,2-tetrafluoroethane, occurs primarily in a gas phase at normal air temperatures and atmospheric pressure, but can occur in a gas or liquid phase within an HVAC unit due to temperature and pressure gradients.

There are no water quality criteria in Oregon for R-134a and it is likely that any refrigerant discharged in the cooling water would quickly volatilize out of solution. Therefore, no monitoring will be required, but an HVAC refrigerant section has been included in Schedule D under the Best Management Plan special condition (Schedule D item 7.6). This condition requires proper operation and maintenance of HVAC units to prevent refrigerant leaks.

### **3.3 Antibacksliding**

The proposed permit is for initial issuance so antibacksliding provisions of CWA sections 402(o) and 303(d)(4) and 40 CFR 122.44(l) do not apply.

### **3.4 Antidegradation**

DEQ must ensure the permit complies with Oregon's antidegradation policy found in OAR 340-041-0004. This policy is designed to protect water quality by limiting unnecessary degradation from new or increased sources of pollution.

DEQ has performed an antidegradation review for this discharge. The proposed permit is the initial permit issuance. DEQ is not aware of any information that the proposed limits will not protect the receiving stream's designated beneficial uses. DEQ is also not aware of any existing uses present within the water body that are not currently protected by standards developed to protect the designated uses. Therefore, DEQ has determined that the proposed discharge

complies with DEQ's antidegradation policy. DEQ's antidegradation worksheet for this permit issuance is available upon request.

### **3.5 Whole Effluent Toxicity**

DEQ determined that whole effluent toxicity (WET) testing is not warranted due to the low levels of toxics present in the final effluent.

### **3.6 Groundwater**

McNary Lock and Dam is in the Lower Umatilla Basin Groundwater Management Area (GWMA) which was designated in 1990 because of high levels of nitrate in the groundwater. The facility does not have any basins, ponds or lagoons that have the potential to leach into the groundwater and nitrate is not a pollutant of concern for the facility. No groundwater monitoring or limits are required.

### **3.7 Clean Water Act Section 401(a)(2)**

When EPA issued draft Washington side permits for this facility, Oregon DEQ provided objection and comments in response to the 401(a)(2) notification. These comments detailed concerns about water temperature standard exceedances and suggested permit conditions to ensure Oregon temperature standards will be met (see EPA's 2022 Lower Columbia River Hydroelectric Generating Facilities Fact Sheet).

As a result, EPA required USACE to consult with the Washington Dept. of Ecology (ECY) and DEQ when developing a Water Quality Attainment Plan (WQAP) per Schedule D special conditions in the ECY NPDES permits. DEQ acknowledges that USACE shared summary modeling results in the June 2024 draft WQAP scope related to conditions requested in DEQ's October 2021 letter (See USACE's 2024 WQAP section 5.4). DEQ has drafted these permits to be consistent with its comments on the Washington permits.

## **4. Schedule A: Other Limitations**

### **4.1 Mixing Zone**

Schedule A describes the regulatory mixing zone as discussed above in section 3.

## **5. Schedule B: Monitoring and Reporting Requirements**

Schedule B of the permit describes the minimum monitoring and reporting necessary to demonstrate compliance with the proposed effluent limits. In addition, monitoring for other parameters is required to better characterize the effluent quality and the receiving stream. This data will be used during the next permit renewal. Detailed monitoring frequency and reporting requirements are in Schedule B of the proposed permit. The required monitoring, reporting and frequency for many of the parameters are based on DEQ's monitoring and reporting matrix

guidelines, permit writer judgment, and to ensure the needed data is available for the next permit renewal.

## **6. Schedule C: Compliance Schedule**

The proposed permit contains new effluent limits for total residual chlorine. The facility is unable to meet these new water quality based effluent limits upon permit issuance. The proposed permit contains a compliance schedule that allows time for the facility to make facility modifications in order to meet the new limits. This compliance schedule lays out a series of milestones which, upon completion, will require the permittee to meet the permit's WQBELs (see 40 CFR 122.47 and OAR 340-041-0061(12)). DEQ has determined that the proposed compliance schedule requires the permittee to meet the final effluent limits as soon as possible. The compliance schedule allows time for the permittee to assess and optimize current operations to maximize reductions of total residual chlorine and upgrade the facility if other actions are not sufficient to meet the final effluent limits.

## **7. Schedule D: Special Conditions**

The proposed permit contains the following special conditions:

### **7.1 Mixing Zone Study**

In order to request a regulatory mixing zone for any outfall, the permittee must submit a level 1 mixing zone study. The study must specify which outfalls the permittee wants to be covered by a regulatory mixing zone. (Level 1 mixing zone study requirements are described in DEQ's Mixing Zone Internal Management Directive).

### **7.2 Emergency Response and Public Notification Plan**

A requirement to develop and submit an emergency and spill response plan or ensure the existing one is current per General Condition B.7 in Schedule F.

### **7.3 Spill/Emergency Response Plan**

The permittee must have an up-to-date spill response plan for prevention and handling of spills and unplanned discharges.

### **7.4 Outfall Inspection**

A condition that requires the permittee to inspect the outfalls and submit a report regarding the condition.

### **7.5 pH Criteria Exceedance Report**

A requirement to submit an annual report documenting pH criteria exceedances from all outfalls and practicable measures the permittee is taking in the impoundment to ensure compliance with the pH criteria.

## **7.6 Best Management Practices (BMP) Plan**

A condition that requires the permittee to develop a BMP Plan to control or abate the discharge of pollutants in accordance with 40 CFR 122.44(k) and submit a BMP Annual Report.

## **7.7 Environmentally Acceptable Lubricants (EALs)**

A condition that requires the permittee to develop an EALs Plan to control or abate the discharge of pollutants in accordance with 40 CFR 122.44(k) and submit an EALs Annual Report.

## **7.8 Cooling Water Intake Structure (CWIS) Requirements**

Section 316(b) of the Clean Water Act requires that facilities with cooling water intake structures (CWIS) ensure that the location, design, construction, and capacity of the structure reflect the best technology available (BTA) to minimize adverse impacts on the environment from impingement and entrainment of fish and other aquatic organisms.

The 2014 Section 316(b) regulation for cooling water intake structures at existing facilities establishes, among other things, substantive requirements for cooling water intake structures meeting certain thresholds. Facilities that are 1) a point source 2) with a CWIS with a design intake flow greater than 2 MGD, 3) using 25 percent of the withdrawn water for cooling, meet these thresholds (40 CFR 125.91(a)). While many cooling water intake structures at hydroelectric facilities do not meet these thresholds, the McNary Lock and Dam Project does.

When issuing the Washington USACE NPDES permits for the Bonneville Project, The Dalles Lock and Dam, and the John Day Project, EPA determined that, in light of the text, structure, history and purpose of the regulation, in the case of hydroelectric facilities, the rule is ambiguous as to application of the substantive requirements and that EPA never intended that the rule's substantive provisions would apply to them. Rather, pursuant to 40 CFR 125.90(b), all CWIS at hydroelectric facilities are subject to best professional judgment (BPJ) Section 316(b) CWIS conditions. This provision provides that a CWIS not subject to substantive provisions under the existing facility rule (40 CFR 125.94-99) or another 316(b) requirements rule must meet requirements established on a case-by-case, BPJ basis. Therefore, DEQ is proposing to establish case-by-case, BPJ 316(b) conditions for McNary. EPA did not permit any outfalls with cooling water intake structures in the McNary Washington permit, so they did not establish BPJ 316(b) conditions for this facility.

To determine if BTA requirements are satisfied, DEQ used the same framework as EPA to consider various technologies currently installed at hydroelectric generating facilities to establish case-by-case BPJ conditions.

### **7.8.1 Hydroelectric Facility Technologies for Consideration by Permitting Authorities in Establishing Case-by-Case, BPJ 316(b) NPDES Permit Conditions**

DEQ generally expects that a hydroelectric facilities' existing controls are technologies that can be determined to satisfy the requirements of BTA to minimize entrainment and impingement mortality. DEQ is also aware that many hydroelectric facilities are required to implement measures that reduce the impacts of the dam, including the impacts to passage of aquatic life through the dam, as conditions of a FERC license or a Biological Opinion. While these are not technologies employed at the CWIS, these measures minimize the passage of aquatic life past the intake structures inside the penstocks of the dam and thus minimize the entrainment and impingement mortality.

The following four factors are considered "technologies" that could minimize adverse environmental impacts from the use of a CWIS at hydroelectric facilities. DEQ may use any of the four factors below, or other facility-specific factors, in its BPJ analysis to determine whether BTA requirements have been satisfied. Any combination of one or more of the factors below may be used to address entrainment and impingement. In most cases, DEQ expects existing documentation may be used to evaluate these factors.

1) Efficiency of power generation

- Water use reduction is most commonly associated with closed cycle cooling tower use, but water use reduction through other means provides the same benefit. Looking holistically at power generation and the cooling water used per megawatt generated, hydroelectric facilities are more efficient than a once-through steam electric facility as they generate less waste heat.

2) Cooling water withdrawn relative to waterbody volume or flow

- In previous rulemakings, EPA stated that using a low percentage of the waterbody flow or volume for cooling could be a factor that addresses impacts due to entrainment. In the New Facility Rule, EPA established "proportional-flow requirements" that were intended to provide protections in addition to those commensurate with closed cycle and velocity requirements. For rivers and streams, the EPA found that,

*"The 5 percent value for rivers and streams reflects an estimate that this would entrain approximately 5 percent of the river or stream's entrainable organisms and a policy judgment that a greater degree of entrainment reflects an inappropriately located facility."*

The cooling water withdrawn at each facility is a small fraction of the water passed through the dam for generating purposes, often less than 1%; DEQ expects such withdrawals will be almost always below 5%.

- Proportional flow requirements only address entrainment as most passive floating organisms that are addressed by this factor are not of impingeable size. Impingement rates might be affected by a reduced flow, but in this case, there is no water use reduction, merely an overall minimal withdrawal of water relative to the waterbody flow or volume so credit for impingement reductions is not assumed.

3) Location of the intake structure

- EPA identified that the location of an intake could be a factor that addresses impacts due to both impingement and entrainment. Location of the intake in areas with lower densities of impingeable or entrainable organisms will reduce the adverse impacts associated with the use of the CWIS.
  - For hydroelectric facilities, most of the intakes are located in the dam itself, either in the penstocks or the scroll case of the turbine. Generally, dams are designed such that the location of the penstock openings on the dam face are located at a depth with a lower density of organisms to reduce entrainment through the dam thus minimizing impacts from the operations of the turbine. As the CWIS is within the dam, there is a similar reduction in the density of organisms as compared to an intake on the face of the dam or in the waterbody itself.
  - Some dams do have intakes on the face of the dam or in the waterbody so this may not be applicable to all hydroelectric facilities. Even in these cases, the permitting authority may determine that no further controls are necessary.
- 4) Technologies at the facility
- Design of the facility can be a factor that addresses impacts due to impingement. For example, many of the hydroelectric facilities have some form of screen over the intake pipe; generally this was intended for debris protection, but it also provides a level of impingement control compared to open pipe. EPA considers organisms that would be retained on a certain mesh size to be “impinged” even if there is no comparable screen on the intake pipe and the organism may actually pass through the cooling system.
  - Most hydroelectric facility intakes use a passive gravity feed which in some cases might lead to a lower intake velocity than a pumped system. Given that water is moving through the system to drive turbines, the velocity may be higher than would be experienced in normal flow velocity in a waterbody. However, this higher velocity results in a higher sweeping velocity past the opening of the intake thus minimizing the time in which an organism can be “impinged.” Impinged organisms are often of a size that they have enough motility that when they sense a screen or the opening of the intake, they have an avoidance response and swim away. Combined with the sweeping velocity that carries the organism past the intake rapidly, this can minimize the actual impingement of organisms.

For McNary, DEQ relied on factor 4, the technologies at the facility, in its BPJ evaluation for BTA. Existing technologies at this facility include measures to deter fish from intakes, encourage fish to travel through fish passage structures or over spillways, and decrease velocities through turbines to minimize impingement and entrainment of aquatic life at cooling water intakes.

Table 7-1 summarizes the general technologies used at McNary to maximize fish survivability from hydroelectric operations, described in the 2024 USACE Fish Passage Plan and 2020 Federal Columbia River Power System Biological Opinion. It also summarizes dam passage survival rates from the 2016 Biological Opinion Comprehensive Evaluation Report.

**Table 7-1: Hydropower Operations for Fish Survival**

Best Technology Available (BTA)	Average Fish Survival Rates
---------------------------------	-----------------------------

<p><i>Non-turbine routes:</i> spill to maximize fish passage for adult and juvenile salmonids, fish passage structures, extended-length submersible bar screens to deter fish from entering main turbine units, vertical barrier screens near intakes, enhanced debris management on screens and trash racks</p> <p><i>Turbine routes:</i> operate turbines at +/- 1% peak efficiency flows, operate turbines in priority order to maximize fish passage, implement turbine unit runner replacement</p>	<p>95-98% (2010-2014 for yearling chinook, steelhead, and subyearling chinook)</p>
---	--

As described above, DEQ generally expects that McNary’s existing controls are technologies that can be determined to satisfy the BTA requirement to minimize entrainment and impingement mortality. These existing technologies include the requirements in Table 7-1.

This condition requires the permittee to comply with Section 316(b) of the Clean Water Act by developing a CWIS operations and maintenance manual and submitting a CWIS annual report. The first CWIS annual report must include information on all cooling water intake structures that address the missing application submittal requirements of 40 CFR 122.21(r)(2) and (3) and applicable provisions of paragraphs (4), (5), (6), (7) and (8).

## 7.9 Juvenile Fish Facility Best Management Practices

A condition that requires the permittee to develop a best management practices plan for the Juvenile Fish Facility to control or abate the discharge of pollutants from fish facility treatment chemicals such as anesthetic.

## 8. Schedule F: NPDES General Conditions

Schedule F contains the following general conditions that apply to all NPDES permittees. These conditions are reviewed by EPA on a regular basis.

- Section A. Standard Conditions
- Section B. Operation and Maintenance of Pollution Controls
- Section C. Monitoring and Records
- Section D. Reporting Requirements
- Section E. Definitions

# Appendix A: Thermal Plumes RPA

Temperature Thermal Plume Limitations within the Mixing Zone Rule (OAR 340-041-0053(2)(d))			
Sections 5.6 and 6.5 of Temperature IMD			
This rule only applies to receiving streams with salmonid uses. For migration blockage, applies to upstream migration of anadromous salmonids (See associated notes in the "Thermal Plumes Instructions".) This spreadsheet assesses compliance with OAR 340-042-0053(2)(d) subparts C and D. Subparts A and B need to be assessed separately (see Thermal Plumes Instructions).			
Facility Name: McNary Lock & Dam Project Date: 11/25/2024			
<b>OAR 340-041-0053(2)(d)(C): Thermal Shock</b> <b>25 deg C at 5% of the stream cross section</b>		<b>OAR 340-041-0053(2)(d)(D): Migration Blockage</b> <b>21 deg C at 25% of the stream cross section</b>	
Enter data into white cells below:		Enter data into white cells below:	
7Q10 = 77749 cfs	Data Metric/Source	7Q10 = 77749 cfs	Data Metric/Source
Ambient Temperature = 25 °C	7Q10 flow from mixing zone memo	Ambient Temperature = 21 °C	7Q10 flow from mixing zone memo
Effluent Flow = 16.811 mgd	Ambient criterion	Effluent Flow = 16.811 mgd	Ambient criterion
Max Daily Effluent Temperature = 26.1 °C	Total effluent flow outfalls 004 through 020	Max 7dAM Effluent Temperature = 26.1 °C	Total effluent flow outfalls 004 through 020
	Maximum effluent temperature outfalls 004-020 (2022-2023)		Maximum effluent temperature outfalls 004-020 (2022-2023)
5% of 7Q10 = 3887.5 cfs		25% of 7Q10 = 19437.3 cfs	
5% dilution = 150 dilution = (Qr*0.05)/Qe + 1		25% dilution = 748 dilution = (Qr*0.25)/Qe + 1	
Temperature at 5% cross section = 25.0 °C	No Reasonable Potential	Temperature at 25% cross section = 21.0 °C	No Reasonable Potential
		ΔT at 25% Stream Flow = 0.0 °C	No Reasonable Potential
Notes:			

Equation used to calculate ΔT at edge of MZ

$$\Delta T_{mz} = \frac{T_e + (S - 1)T_a}{S} - T_a$$

Equation used to calculate thermal load limit

$$TLL = 3.7854 Q_e S \Delta T_{all} C_p \rho$$

Where:

- Qe = Effluent Flow in mgd
- S = Dilution
- ΔT<sub>all</sub> = Allowable temperature increase at edge of MZ (°C)
- Cp = Specific Heat of Water (1 cal/g °C)
- ρ = Density of Water (1 g/cm<sup>3</sup>)
- 3785.41 = Flow conversion from mgd to m<sup>3</sup>/day

Applicant Review