

Certificate of Satisfactory Completion

Repair (Major) - Residential - New

463-21-000434-PRMT

Primary Contractor: Beeler Excavation, LLC

109 Cumberland Dr

(541) 660-2953

Grants Pass OR 97527

dominic@beelerexcavation.com

OR 97527

455 Pickett Creek Rd, Grants Pass,

Installer License: 37834

Property Address:

Water Supply:

City/County/UGB:

Address:

Phone:

Email:

Josephine Onsite Septic Program 700 NW Dimmick Street Suite A

> Grants Pass, OR 97526 541-474-5444

Fax: 541-474-5422 onsiteseptic@josephinecounty.gov

Website: josephine.or.us

Well

Yes

County

Date Certificate Issued: 07/20/2022 **MAJOR REPAIR** Work Description:

FARR. NICOLE Applicant:

Address: 455 PICKETT CREEK RD

> 455 PICKETT CREEK RD **GRANTS PASS OR 97527**

541-441-4097 Phone:

Email: COWGRLUP@GMAIL.COM

Rolando Hernandez Applicant: Address: 109 Cumberland Drive

Grants Pass OR 97527

5416602953 Phone:

Email: rolando@beelerexcavation.com

BENTLEY, CONSTANCE Owner:

Address: 455 PICKETT CREEK RD

455 PICKETT CREEK RD **GRANTS PASS OR 97527**

Parcel: 3507260000100000 - Primary

7 ACRES Lot Size:

N/A Zoning:

N/A Land Use Approval:

Category of Construction:

Single Family Dwelling

	Existing	Proposed
Use of Structure:	SFR	SFR
Number of Bedrooms:	2	2

System Specifications

Alternative Treatment Technology (ATTs) Type: **ATT Description:** AS600+4NR with UV disinfection 450 gpd. 300 gpd. Max Peak Design Flow: Proposed Flow: 1000 gal. 500 gal. Min Septic Tank Volume: Min Dosing Tank Volume:

Drain Field Specifications

Serial Standard **Drain Field Type:** System Distribution Type: **Drainfield Sizing:** 50 linear ft. **Distribution Method:** Serial EZ FLOW 1201P 12 in. Media Type: Media Depth: 150 linear ft. N/A Trench Length: **Rock Above Pipe:** 24 in. 8 ft. Max Depth: Undisturbed Soil BetweenTrenches: 18 in. N/A Min Depth: Capping Fills-Min Depth of Fill Material:

Special Requirements

Permanent N/A **Groundwater Type: Groundwater Depth:** Yes 48 in. **Groundwater Interceptor: Groundwater Interceptor Depth:**

36 in. **Groundwater Interceptor Amt of Drain Media:**

Pump to Drainfield Required: Yes Filter Fabric on Top of Drain Media:

Rake Trench Sidewalls: Yes

7/20/22:12:12:21PM ONS OnsiteCSC pr Date Certificate Issued: 07/20/2022 Work Description: MAJOR REPAIR

Conditions of Approval

7/20/22:12:12:21PM ONS_OnsiteCSC_pr

Date Certificate Issued: 07/20/2022
Work Description: MAJOR REPAIR

- 1. This repair permit is for 2 BDR SFR.
- 2. Properly decommission the old septic tank and submit appropriate documentation.
- 3.A failing system must be repaired as soon as possible. Should the repair of this system be delayed, the property owner must notify the agent and provide the reasons for delay, and propose a different completion date. Delays may be cause for formal enforcement action, which may result in civil penalty assessments.
- 4. If there are discharges of sewage or septic tank effluent onto the ground surface or into public waters, the property owner must take immediate steps to minimize the threat to public health and the environment. These steps must include at a minimum:
- 5. Having the existing septic tank pumped, the outlet plugged, and the tank utilized as a temporary holding tank until repair of the system is complete.
- 6.Securing the area of both contaminated and saturated soils with barricades, roping, caution tape and the posting of warning notices. The notice must read, "Warning This Area is Contaminated with Sewage Please Stay Out" or similar language.
- 7.Treating the affected area of contaminated/saturated soil with either a calcium carbonate compound (lime) or other type of sanitizing compound.
- 8. This permit is for the installation of an Alternative Treatment Technology (ATT) system and is to be installed by a person certified by the system manufacturer in accordance with OAR 340-071-0600 and 0650. See Alternative Treatment Technology rules at OAR 340-071-0345.
 - 9.ATT treatment standard 2 required.
- 10. The ATT system must be designed to prevent untreated waste from passing into the absorption field if the treatment system malfunctions.
- 11. The septic tank must be approved for use with the ATT system to be installed.
- 12.In addition to the As-Built and Materials List, a Start-Up checklist from the ATT maintenance provider is required to Final this permit.
- 13. The owner of an ATT system must maintain a contract with a maintenance provider certified by the manufacturer to inspect, adjust and maintain the onsite system. The maintenance provider must submit an annual report and annual evaluation fee.
- 14.Dry soil installation only (June 1 October 1 unless otherwise authorized by the agent).
- 15. The system must be installed by the property owner or a licensed sewage disposal business (installer).
- 16. Vehicular traffic and livestock must be restricted from the system area.
- 17.All roof drains must be directed away from the system
- 18.All tanks must be tested for watertightness and have a water-tight riser to the ground surface. Twenty- inch minimum diameter if less than 36-in deep. Thirty-inch minimum diameter if greater than 36-in deep. Maintain access to septic tank for pumping and service.
- 19.Meet all required setbacks
- 20. The system must be installed in the area approved during the site evaluation and in accordance with the construction plan approved by the agent, including any changes made by the agent.
- 21.All work is to conform to OAR 340, Division 71 and 73. Make no changes in system location or specifications without approval by the agent.
- 22. For product approval information and manufacturer installation requirements see DEQ website at:
- http://www.oregon.gov/deq/Residential/Pages/Onsite.aspx
- 23. The pump and alarm must be wired on separate circuits in the control panel. Pump wiring must comply with applicable building, electrical, or other codes. An electrical permit and inspection from the Department of Consumer and Business Services, Building Codes Division, or the municipality with jurisdiction, is required for pump wiring installation.
- 24.Install the pump and system components in accordance with the approved pump curve and specifications.
- 25.An anti-buoyancy device is required for the septic tank(s) and must be installed as per the manufacturer installation guidelines.
- 26.A minimum 18-gauge, green-jacketed tracer wire or green color-coded metallic tape must be placed on top of the effluent sewer or pressure transport pipe from tank to drainfield.
- 27.Effluent filter required at tank outlet.
- 28. Header pipe from Distribution or Drop Box must be minimum 4-ft length, level, and bedded.
- 29. Each drainfield trench must be level within a tolerance of plus or minus 1-inch.
- 30. Maximum length of an individual trench is 150-feet.
- 31. Serial distribution, each trench bottom to be level and on contour. Use Drop box(es).
- 32.Groundwater Interceptor, Curtain Drain required: Minimum trench width 12-inches. Minimum perf pipe diameter 4-inches; must meet the requirements in OAR 340-073-0060(4); and must be installed at least 2 inches above the bottom and along the full length of the trench with a minimum of 10 inches of drain media cover The curtain drain must be filled with drain media to within 12 inches of the ground surface with filter fabric placed over the media. The outlet pipe(s) must be rigid smooth-wall, solid PVC pipe meeting or exceeding ASTM Standard D-3034 with a minimum diameter of 4 inches. A flap gate or rodent guard must be installed. The curtain drain must extend at least 6 inches into the layer that limits effective soil depth or to a depth adequate to effectively dewater

Date Certificate Issued: 07/20/2022
Work Description: MAJOR REPAIR

the site.

- 33.A pre-cover inspection of the installed absorption facility (prior to backfill) is required.
- 34.A final inspection request and notice (FIRN) form including a detailed and accurate as-built plan of the constructed system and a list of all materials used in the construction of the system must be completed and submitted prior to requesting a final inspection.
- 35. Photos of the septic system components must be submitted along with the FIRN.

Installation of this onsite wastewater treatment system has been determined to comply with the applicable requirements in Oregon Administrative Rules Chapter 340, Divisions 071 and 073 and the Conditions of Approval above.

- 1. In accordance with Oregon Revised Statute 454,665, this Certificate of Satisfactory Completion is issued as evidence of satisfactory completion of an onsite wastewater treatment system at the location identified above.
- 2. Issuance of this Certificate does not constitute a warranty or guarantee that this onsite wastewater treatment system will function indefinitely without failure. Conditions imposed as permit requirements continue for the life of the system.
- 3. The area of the initial and the identified replacement area must not be subjected to activity that is likely to adversely affect the soil or the functioning of the system. Such activities may include, but are not limited to, vehicular traffic, livestock, covering the area with asphalt or concrete, filling, cutting, or other soil modification activities.
- 4. This onsite wastewater treatment system that be connected to the facility referenced herein within 5 years of the issuance of this Certificate of Satisfactory Completion (CSC) or rules for authorization notices, alteration permits, or construction-installation permits as outlined in OAR 340-071-0160, 340-071-0205, or 340-071-0210 apply, including payment of an additional fee.
- 5. This system must operate in compliance with OAR Chapter 340, Division 071 and must not create a public health hazard or pollute public waters.
- 6. Unless otherwise required by the agent, the system installer must backfill (cover) this system within 10 days after the issuance of this Certificate of Satisfactory Completion.

Certificate of Satisfactory Completion

System Inspection: No Operation of Law - 7 Days Notice: No Pre-Cover Inspection Waived Per 340-071: No

Comments: N/A

Joshua Daley Environmental Specialist

CALL BEFORE YOU DIG...IT'S THE LAW

ATTENTION:Oregon law requires you to follow rules adopted by the Oregon Utility Notification Center. Those rules are set forth by Oregon Administration Rules. You may obtain copies of the rules by calling the center. (Note: The telephone number for the Oregon Utility Notification Center is 1-800-332-2344.)

ONS OnsiteCSC pr

Final Inspection Request and Notice - Septic ID: 463-21-000434-PRMT


Pursuant to the requirements within ORS 454.665, OAR 340-071-0170 and OAR 340-071-0175, the system installer and/or the permittee must notify the Department of Environmental Quality (or its authorized Agent) when the construction, alteration or repair of a system for which a permit was issued is completed and prior to backfilling or covering the installation. The Department (or Agent) has 7 days to perform an inspection of the completed construction/installation following the official notice date, unless the Department (or Agent) elects to waive the inspection and authorizes the system to be backfilled. Receipt and acceptance of this completed form by the Department (or Agent) establishes the official notice date of your request for the pre-cover inspection. Faxed copies are acceptable for inspection request purposes only. Originals must be received before a Certificate of Satisfactory Completion is issued. Please complete sections 1 through 4 on the form and return it to the office that issued the permit. Forms that are determined to be incomplete will be returned.

SECTION 1: Owner	/Permittee	Inforn	nation:				Twnsh	np:	Range:	Sect:
Name: BENTLEY, CONSTANCE						Lot:				
Property 455 PIC Address:	KETT CREEK	RD, G	GRANTS	PASS,	OR 97	7527				
SECTION 2: Syste	m Compo	nent S	Specific	cation	s:					
A. Tanks/Pumps				S	ysten	п Туре:				Water tight verification*
Tanks(1) Volume:	1060 Gal	Cor	mpartme	npartments: 1 Manufacturer:			Rive	rside F	Ready Mix	Date: 7/15/22
Tanks(2) Volume:		Cor	mpartme	nts:		Manufacturer:				Date:
Pump(s) HP:	Model/Manuf.					Float(s)Type(1)	:	Model/	Manuf.	•
				7		Float(s)Type(2)	:	Model/	Manuf.	
B. Piping						P				
Effluent Sewer	(tank to drain	nfield)	Yes	No	Diam	neter:	ASTM#	#/Other:		Length:
Press	ure Transpor	t Pipe	Yes	No	Diam	neter: 1&1/4"	ASTM#	#/Other:	Schedule 40	Length: 212'
C. Secondary Treatmen	t Unit:									'
Sand Filter*	Yes N	0	Туре:						Container Dimension	is:
Underdrain pipe	Diameter:		ASTM#	ASTM#/Other:				Length:		
Manifold piping	Diameter:		ASTM#	/Other:						Length::
Internal Pump	HP: 1/2	hp	Model/	Manufad	turer	STA-RITE 2	0GPM			
Floats(1	Type: A		Model/	Manufac	turer	Orenco A	Float			
Floats(2	Type: B		Model/	Manufac	turer	Orenco B	Float			È
ATT	Yes N	0	Model:		Aerol	bic Septic Sys	tome N	JD500	Type 2	
Certified Maint			dettactions.			Service	iciiis i	VIX.300	Type 2	10 = 10 = 10 = 10 = 10 = 10 = 10 = 10 =
Operation and Maint			1	No	File	Jei vice				
D. Drainfield Media			-						ê	
Туре	(Gravel, Pip		ernative?) E.	Z Flo	w 1201				
Distribution Box										
Drop Box Yes No										
Distribution Pipe	Distribution Pipe Yes No Diameter: 4" ASTM#/Other: 3034 Length: 150'									
Commen	<u> </u>						-			
*All Tanks(s) were teste					and pa	assed in accorda	nce with	OAR 3	40-073-0025(3)	

SECTION 3 - As Built Plan

AS-BUILT PLAN OF THE CONSTRUCTED SYSTEM. Indicate the direction of NORTH. Show locations of all wells within 200 feet of the system. Show system setback distances from property lines, structures, wells, streams, etc.


see attached	
<u>.</u>	•
· ·	
*	
SECTION 4 - Construction was performed by (Sign	
the permit and the rules regulating the construction of onsite wastew	nt is correct and that the construction of this system was in accordance with water treatment systems (OAR Chapter 340, Divisions 71 and 73).
Owner/Permittee or Certified Installer w/Certification#: Print Nar	Dominic Florez of Beeler Excavation
Licensed Installer: Yes No License#: DEQ 3783	
Owner/ Certified Signature: Dominic Flore:	Phone#:541 660-2953
SECTION 5 - Office Use Only:	Installer/Owner
Notice Accepted Yes No Date:	(Permittee) Notified: No Date:
If No, Reason for Non Acceptance:	· · · · · · · · · · · · · · · · · · ·
Comment:	






























Date issued: 6/10/22

Septic Permit Repair (Major) - Residential - New

463-21-000434-PRMT

Josephine Onsite Septic Program 700 NW Dimmick Street Suite A

> Grants Pass, OR 97526 541-474-5444

Fax: 541-474-5422 onsiteseptic@josephinecounty.gov

Expiration date: 6/10/23

Website: josephine.or.us

Work description: MAJOR REPAIR

Applicant: FARR, NICOLE

Address: 455 PICKETT CREEK RD

455 PICKETT CREEK RD

GRANTS PASS OR 97527

Phone: 541-441-4097

Email: COWGRLUP@GMAIL.COM

Applicant: Rolando Hernandez **Address:** 109 Cumberland Drive

Grants Pass OR 97527

Phone: 5416602953

Email: rolando@beelerexcavation.com

Business License: N/A

Owner: BENTLEY, CONSTANCE

Address: 455 PICKETT CREEK RD

455 PICKETT CREEK RD GRANTS PASS OR 97527

Parcel: 3507260000100000 - Primary

Primary contractor: Beeler Excavation, LLC

Installer License: 37834

Address: 109 Cumberland Dr

Grants Pass OR 97527

Phone: (541) 660-2953

Email: dominic@beelerexcavation.com

Property address: 455 Pickett Creek Rd, Grants Pass, OR

97527

7 ACRES Well Lot size: Water supply: N/A County Zoning: City/County/UGB: N/A County: N/A Land use approval: New Repair (Major) - Residential Action: Type of application: Yes N/A System failing: Septic tank last pumped:

Comments: N/A

Category of construction: Single Family Dwelling

	Existing	Proposed
Use of structure:	SFR	SFR
Number of bedrooms:	2	2

System Specifications

Type: Alternative Treatment Technology (ATTs) ATT description: AS600+4NR with UV disinfection

Max peak design flow: 450 gpd.

Min septic tank volume: 1000 gal.

Min dosing tank volume: 500 gal.

Drain Field Specifications

Drain field type:StandardSystem distribution Ttpe:SerialDrainfield sizing:50 linear ft.Distribution method:SerialMedia type:Other - Indicate Product/ManufacturerMedia depth:12 in.

Media type description: EZ FLOW 1201P

Trench length: 150 linear ft. Rock above pipe: N/A

CALL BEFORE YOU DIG...IT'S THE LAW

ATTENTION:Oregon law requires you to follow rules adopted by the Oregon Utility Notification Center. Those rules are set forth by Oregon Administration Rules. You may obtain copies of the rules by calling the center. (Note: The telephone number for the Oregon Utility Notification Center is 1-800-332-2344.)

6/10/22:10:00:13AM ONS_OnsitePermit_pr

Onsite Permit 463-21-000434-PRMT

Date issued: 6/10/22			Expiration date: 6/10/23
Work description: MAJOR REPAIR			
Max depth:	24 in.	Undisturbed soil between trenches:	8 ft.
Min depth:	18 in.	Capping fills-min depth of fill material:	N/A
Special Requirements			
Stake out required:	Yes		
Groundwater type:	Permanent	Groundwater depth:	N/A
Groundwater interceptor:	Yes	Groundwater interceptor depth:	48 in.
Groundwater interceptor drain media amt:	36 in.		
Pump to drainfield reqd:	Yes	Filter fabric on top of drain media:	Yes
Rake trench sidewalls:	Yes		

ONS_OnsitePermit_pr

Date issued: 6/10/22 Expiration date: 6/10/23

Work description: MAJOR REPAIR

Conditions of approval

Date issued: 6/10/22 Expiration date: 6/10/23

Work description: MAJOR REPAIR

Conditions of approval

- 1. This repair permit is for 2 BDR SFR.
- 2. Properly decommission the old septic tank and submit appropriate documentation.
- 3.A failing system must be repaired as soon as possible. Should the repair of this system be delayed, the property owner must notify the agent and provide the reasons for delay, and propose a different completion date. Delays may be cause for formal enforcement action, which may result in civil penalty assessments.
- 4.If there are discharges of sewage or septic tank effluent onto the ground surface or into public waters, the property owner must take immediate steps to minimize the threat to public health and the environment. These steps must include at a minimum:
- 5. Having the existing septic tank pumped, the outlet plugged, and the tank utilized as a temporary holding tank until repair of the system is complete.
- 6.Securing the area of both contaminated and saturated soils with barricades, roping, caution tape and the posting of warning notices. The notice must read, "Warning This Area is Contaminated with Sewage Please Stay Out" or similar language.
- 7.Treating the affected area of contaminated/saturated soil with either a calcium carbonate compound (lime) or other type of sanitizing compound.
- 8. This permit is for the installation of an Alternative Treatment Technology (ATT) system and is to be installed by a person certified by the system manufacturer in accordance with OAR 340-071-0600 and 0650. See Alternative Treatment Technology rules at OAR 340-071-0345.
 - 9.ATT treatment standard 2 required.
- 10. The ATT system must be designed to prevent untreated waste from passing into the absorption field if the treatment system malfunctions.
- 11. The septic tank must be approved for use with the ATT system to be installed.
- 12.In addition to the As-Built and Materials List, a Start-Up checklist from the ATT maintenance provider is required to Final this permit.
- 13. The owner of an ATT system must maintain a contract with a maintenance provider certified by the manufacturer to inspect, adjust and maintain the onsite system. The maintenance provider must submit an annual report and annual evaluation fee.
 - 14.Dry soil installation only (June 1 October 1 unless otherwise authorized by the agent).
 - 15. The system must be installed by the property owner or a licensed sewage disposal business (installer).
 - 16. Vehicular traffic and livestock must be restricted from the system area.
 - 17.All roof drains must be directed away from the system
- 18.All tanks must be tested for watertightness and have a water-tight riser to the ground surface. Twenty- inch minimum diameter if less than 36-in deep. Thirty-inch minimum diameter if greater than 36-in deep. Maintain access to septic tank for pumping and service.
 - 19.Meet all required setbacks
- 20. The system must be installed in the area approved during the site evaluation and in accordance with the construction plan approved by the agent, including any changes made by the agent.
- 21.All work is to conform to OAR 340, Division 71 and 73. Make no changes in system location or specifications without approval by the agent.
- 22.For product approval information and manufacturer installation requirements see DEQ website at: http://www.oregon.gov/deg/Residential/Pages/Onsite.aspx
- 23. The pump and alarm must be wired on separate circuits in the control panel. Pump wiring must comply with applicable building, electrical, or other codes. An electrical permit and inspection from the Department of Consumer and Business Services, Building Codes Division, or the municipality with jurisdiction, is required for pump wiring installation.
 - 24. Install the pump and system components in accordance with the approved pump curve and specifications.
- 25.An anti-buoyancy device is required for the septic tank(s) and must be installed as per the manufacturer installation guidelines.
- 26.A minimum 18-gauge, green-jacketed tracer wire or green color-coded metallic tape must be placed on top of

Date issued: 6/10/22 Expiration date: 6/10/23

Work description: MAJOR REPAIR

Conditions of approval

the effluent sewer or pressure transport pipe from tank to drainfield.

- 27.Effluent filter required at tank outlet.
- 28. Header pipe from Distribution or Drop Box must be minimum 4-ft length, level, and bedded.
- 29. Each drainfield trench must be level within a tolerance of plus or minus 1-inch.
- 30. Maximum length of an individual trench is 150-feet.
- 31. Serial distribution, each trench bottom to be level and on contour. Use Drop box(es).
- 32.Groundwater Interceptor, Curtain Drain required: Minimum trench width 12-inches. Minimum perf pipe diameter 4-inches; must meet the requirements in OAR 340-073-0060(4); and must be installed at least 2 inches above the bottom and along the full length of the trench with a minimum of 10 inches of drain media cover The curtain drain must be filled with drain media to within 12 inches of the ground surface with filter fabric placed over the media. The outlet pipe(s) must be rigid smooth-wall, solid PVC pipe meeting or exceeding ASTM Standard D-3034 with a minimum diameter of 4 inches. A flap gate or rodent guard must be installed. The curtain drain must extend at least 6 inches into the layer that limits effective soil depth or to a depth adequate to effectively dewater the site.
- 33.A pre-cover inspection of the installed absorption facility (prior to backfill) is required.
- 34.A final inspection request and notice (FIRN) form including a detailed and accurate as-built plan of the constructed system and a list of all materials used in the construction of the system must be completed and submitted prior to requesting a final inspection.
- 35. Photos of the septic system components must be submitted along with the FIRN.

6/10/22:10:00:13AM ONS_OnsitePermit_pr

Onsite Permit 463-21-000434-PRMT

Date issued: 6/10/22 Expiration date: 6/10/23

Work description: MAJOR REPAIR

This Construction-Installation Permit authorizes the property owner to construct an onsite wastewater system specified above.

Rules, Approved Material Listing; and Database of Licensed Installers can be accessed at: http://www.deg.state.or.us/wq/onsite/onsite.htm

General Conditions And Requirements For All Permits: Onsite Construction-Installation Permits are valid for one year from the date of issuance. The expiration date is noted on this permit. Renewal of a permit may be granted if an application for permit renewal is received before the permit expiration date. Reinstatement of a permit may be granted if an application for permit reinstatement is received within one year after the permit expiration date. Transfer of a permit from the permittee to another person may be granted if an application for permit transfer is received before the permit expiration date and no other changes to the permit are necessary.

Installation Requirements: The drainfield must be installed in undisturbed native soil. No alterations of the natural site conditions such as soil removal or filling, or slope/topography alterations within the approval areas for both the initial and replacement systems are allowed, unless otherwise authorized by the Agent. Do not install system when soil moisture, high groundwater, adverse weather, or other conditions that could affect the quality of installation or reliability of the system are present. If such conditions are present and there is a need for sewage disposal at the site, the septic tank can be utilized as a temporary holding tank as outlined in 340-071-0160(9).

Inspection Requirements: The system installer and/or the permit holder must notify the permitting Agent when the construction, alteration, or repair of a system for which a permit was issued is completed (except for the backfilling or covering of the installation). The permitting agent has 7 days to perform an inspection of the completed construction after the official notice date, unless the permitting agent elects to waive the inspection and authorizes the system to be backfilled earlier. Receipt and acceptance of a completed Final Inspection Request and Notice form by the permitting agent establishes the official notice date of your request for the final inspection. Faxed copies are acceptable for inspection request purposes only. Originals must be received before a Certificate of Satisfactory Completion can be issued.


System Backfill Requirements: The system is to be backfilled or covered as follows: * Only after the permitting agent has approved the construction installation, * or the inspection has been waived * or the Certificate of Satisfactory Completion (CSC) has been issued by operation of law (where the inspection has not been conducted within 7 days of notification of completed installation).


Unless otherwise required, it is the system installer's responsibility to backfill the system within 10 days after inspection and issuance of the CSC. Backfill must be carefully placed to prevent damage to the system. The backfill must be free of large stones, frozen clumps of earth, masonry, stumps, waste construction materials, or other materials that could damage the system. Be sure that the untreated building paper, filter fabric, or other material approved by the agent is completely covering all drain media where required prior to backfill. The system can be connected to and placed into service once it has been properly backfilled and the CSC has been issued

Initial and Replacement Areas — Protection: The installed subsurface absorption field and designated replacement areas must be protected and kept free of development such as roadways, covering with asphalt or concrete, filling, cutting, or other soil modifications.

Gabriel Kasiah Natural Resource Specialist 6/10/22

6/10/22:10:00:13AM ONS_OnsitePermit_pr





Mike Arts Septic Service 337 Driver Valley Rd Oakland OR 97462

2-year Ecological Tanks Inc. Service Contract

For the State of Oregon

Parties: (Authorized Service Provider)

Name: Mike Arts Septic Service

Address: 337 Driver Valley Rd

City, State, Zip Code: Oakland OR 97462

Telephone: 541-580-4102

Fax: 866-283-2928

Email: Mikeartssepticservice@gmail.com

And: (Customer)

Name: Nicole A Farr

Address: 455 Pickett Creek Rd, Grants Pass, OR

Telephone: 541.441.4097

Email: cowgrlup08@gmail.com

System Location: Same

Address:

City, State, Zip Code:

Legal Description:

GPS Coordinates: N° W°

Installed by: Beeler Excavation

Serial #:

Permit #:

Agency Contact Information -

Agency: Josephine Onsite Septic Program

Address: 700 NW Dimmick Street, Suite A

City, State, Zip Code: Grants Pass, OR 97526

Telephone: 541-474-5444

Email: onsiteseptic@josephinecounty.gov

NOW, THEREFORE, in consideration of the terms, provision, covenants and conditions herein, the Parties here to agree as follows:

1.0 Performance of Basic Services

1.1 Initial Service Policy

The Authorized Service Provider shall perform the System Inspection/Service Visits during the 24-month period after installation, as marked:

Inspection/Service Visits ¹	6 th month	1
	12 th month	1
	18 th month	1
	24th month	1

'As required by NSF, these services will be included as part of the initial purchase of the system.

These services shall be performed during normal business hours Monday through Friday (excluding national holidays) on twice annual basis and as the Authorized Service Provider deems necessary or advisable.

At each service visit the System shall be inspected and serviced in accordance with the instructions in the Systems O & M Manual. Additionally, as effluent quality inspection consisting of a visual assessment of color, and scum overflow and an olfactory assessment for odor shall be performed.

The Service Provider will affix a "For Service, Call" label near the control panel's alarm signal and fill in his or her phone number.

Performance of the 2-year Inspection/Service visits shall include notification of needed repair, replacement or addition of parts used in the system.

The Service Provider shall be responsible for submitting the annual report and annual evaluation fee to the appropriate regulatory agency as required in OAR-071-0345.

The Service Provider shall notify the owner in writing if any improper system operation cannot be remedied at the time of servicing. The written notification shall include an estimated date of correction.

1.2 Extended Service Policy

The Service Provider shall make available for purchase by owner an extended service policy with terms comparable to those in the initial service policy.

1.3 Stand By Parts

In the event that a mechanical or electrical component must undergo off site repairs the local authorized representative should maintain a stock of mechanical and electrical components that may be temporally installed until repairs are completed.

1.4 Availability of Service

The service provider shall provide emergency service within 48 hours of service request.

2.0 Term of Agreement

The agreement shall be for the period 24 months from the date of the system start up unless otherwise terminated or cancelled by either party as provided herein

3.0 Definitions

For proposes of theist agreement the following definitions shall apply:

- 3.1 System shall mean a ANS/NSF 40 certified wastewater treatment system.
- 3.2 "System Start-Up Date" shall mean the date the System begins operating for its intended purpose.

4.0 Charges

The basic services including service, inspection, effluent quality evaluation, and service, shall be included with the purchase of the System, Optional, additional services shall be provided at the agreed upon contract price and terms. The annual report and annual evaluation fee required by DEQ is not optional, and may or may not be included in the cost of basic services. Refer to Service Providers fee schedule for an outline of the cost of basic services and optional services to be provided under this contract.

5.0 Warranty

The Ecological Tanks provider warrants that all services shall be performed in a good and workman like manner and that service provider will correct any system errors, malfunctions, defects directly caused by service provider's failure to perform the services and additional services in such manner.

6.0 Limitation of Liability

The sole liability of the Service Provider under this agreement shall be to correct any errors, malfunctions, or defects in the system directly caused by the Ecological Tanks Providers failure to perform any services in good and workmanlike manner pursuant to section 4 above. In no event should the Service provider's liability to the customer hereunder exceed the total of the amounts paid to the service provider hereunder by the customer. In no event shall the Service Provider be liable to the customer or any other third party claimant for any indirect, special, punitive, consequential or incidental damages or lost profits arising out of or related to this agreement or the performance or breach thereof, whether based upon a claim or action of contract, warranty, negligence, or strict liability or other tort. Breach of any statutory duty, indemnity or contribution or otherwise, even if the service provider has been advised of the possibility of such damage.

7.0 Termination/Cancellation

This agreement may be terminated or cancelled only upon:

- Written notice by one Party effective as of the effective date thereof if the other Party is in default of
 any provision of this Agreement and such default is not cured by the defaulting Party within fifteen
 (15) days after the effective date of said notice from the non-defaulting party, or by the mutual
 agreement of both Parties.
- Copy of such written notice shall be forwarded to the regulatory agency.

8.0 Miscellaneous Provisions

This agreement is personal in nature and may not be delegated, assigned or transferred by either Party without the prior written consent of the other Party.

The laws of the State of Oregon shall govern the Agreement.

The homeowner shall be responsible for complying with the Ecological Tanks inc Installation, Operation & Maintenance Manual provided to them with the purchase of the system.

Any notice or other communication required or permitted to be given under this Agreement shall be in writing and shall be mailed by certified mail, return receipt requested, postage prepaid, addressed to the Parties at the addresses shown on the first page of the Agreement. Any notice or other communication shall be deemed given at the expiration of the second day after the date of deposit in the United States mail. The addresses to which notices or other communications shall be mailed may be changed from time to time by giving written notice to the other Party as provided in this Section.

This two year maintenance contract only valid when system is purchased thru <u>Aerobic Septic Systems- Mike Arts Septic Service</u>.


Ecological Tanks Service Provider

Name: Mike Arts DEQ# M-304

Title: Oregon Certified Service Provider

Phone: 541-580-4102

Signature:




Customer


DocuSigned by:	5/12/2022
Signature 95E804BD	Date

FIELD WORKSHEET

Name: VICOLU FARR Applie RE: SITE EVALUATION REPORT for Parcel #: 350 726	eation No.: 413-21-000 434-PRMTDate:
Commercial Facility: Yes No Parcel Size: 7 ACRE	25
APPROVED SYSTEM	SPECIFICATIONS
Design flow: 450 gpd Max Number of bedrooms:	Max Number of Employees;
Initial System	Replacement System
Standard Capping Fill Bottomless Sand Filter Conventional Sand Filter/ATT Other	Standard Capping Fill Bottomless Sand Filter Conventional Sand Filter/ATT Other 152
Tank: 1,000 gal. 1,500 gal 2 compartment Other effluent pump required effluent filter required	Tank: №1,000 gal. ☐ 1,500 gal. ☐ 2 compartment ☑ Othe ☐ effluent pump required ☐ effluent filter required
Distribution Method:	Distribution Method: ☐ Equal ☑ Serial ☐ Pressurized
Absorption facility:total linear feet	Absorption facility: 150 total linear feet
linear feet per 150 gallons projected daily sewage flow	bo linear feet per 150 gallons projected daily sewage flow
" Max Depth " Min Depth	
 3. The area must not be subjected to excessive saturation due surfaces, roads, driveways, and building down spouts. 4. Placement of a well within 100 feet of the approved areas of the curtain drain is required, a minimum of feet. The curtain drain must be a minimum of finche one of the curtain drain must be a minimum of finche one of the curtain drain must be a minimum of finche one of the curtain drain must be installed during dry soil conditions. The system must be installed during dry soil conditions of system must be installed between June 1 and October 100 of the curtain drain for the curtain drain must be installed between June 1 and October 100 of the curtain drain for the curtain drain must be installed between June 1 and October 100 of the curtain drain for the curtain drain must be a minimum of finched for the curtain drain for the curtain	may invalidate this approval. above the highest disposal trench. s deep, and installed in accordance with OAR 340-071- only. , unless otherwise approved by DEQ.
Inspector:	

PIT No.	DEPTH	TEXTURE	SOIL MATRIX COLOR AND CONDITIONS ASSOCIATED WITH SATURATION, ROOTS, STRUCTURE, EFFECTIVE SOIL DEPTH, ETC.
	0-8	SiaL	10yR 2/1, GR, ROOTS 2M, LVF, F 10yR 2/1, WSBK, ROOTS 1VF, F,M, APPEARS TO HAVE DCP. 10yR 5/1, WSBK, ROOTS 1VF +030", CONC. 7.5 yR 5/8, 35% CF CAS A 20" SIMILAR TO THI
Fest Pit 1	8-20	SILL	10/R 2/1, WSBK, ROOTS IVE, F,M, APPEARS TO HAVE DEP.
Test	20-40	sic	10 yr 5/1, WSBK, ROOTS 1 UF to 30", CONC. 7.5 ye 5/8, 35% CF
			CAS AZO"
_			SIMILAR TO THI
Test Pit 2			
Tes			
Test Pit 3			
Tes			
_			
Test Pit 4			
Les			
w			
Test Pit			
E E			
9			
Test Pit 6			
<u>۽</u>			
		0. 4	
			FORMER BLACK BERKEES
	5-10	%	
ope:	Site Notes:	UNKNO	Aspect: SE Groundwater Type: Permanent Temporar Wo location of Existing System, Pump From Creek NTN:3
7	5 / Males.	COLL RATI	NENIS







NOTICE AUTHORIZING REPRESENTATIVE

	Dominic Florez
I, Nicole A Farr, have authorized (Property Owner/Print Name)	of Beeler Excavation to act as my
(Property Owner/Print Name) (A	uthorized Representative/Print Name)
agent in performing the activities necessary to obtain	all onsite wastewater treatment program
services provided by the Department of Environmenta	
accordance with OAR chapter 340, division 071. I agr	ee that any costs not satisfied by the Authorized
Representative are my responsibility and I authorized	DEQ agents to conduct required business
activities on said property.	
DDODEDTY IDENTIFICATION	
PROPERTY IDENTIFICATION:	
455 Pickett Creek Rd, Grants Pass, Orego	
(Property Situs or Road Address	s)
And described in the records of Josephi	ne County as:
Township 35 Range 07 Section 26	_ Map ID Tax Lot #(s)1000
PROPERTY OWNER:	
Printed Name: Nicole A Farr	
Address: 455 Pickett Creek Rd	
City, State, Zip: Grants Pass, OR 97527	
Phone: 541.441.4097	ı: cowgrlup08@gmail.com
DocuSigned by:	
Signature: 5582AD395E804BD	
AUTHORIZED REPRESENTATIVE:	
Printed Name: Dominic Florez of Beeler Exca	avation
Address: 109 Cumberland Drive	
City, State, Zip: Grants Pass, OR 97527	
Phone: <u>541-660-2953</u> Emai	dominic@beelerexcavation.com
Signature: Dominic Florez	



Application for Onsite Sewage Treatment System

700 NW Dimmick Street, Suite B Grants Pass, OR 97526 541-474-5444


 $\square Authorization$

Attached

For ONSITE SEPTIC Use Only: Date received	Date Stamp
Fee paid	
Receipt number	
Application number	
Date of 1st response	
Date of 2 nd response	
Date of final response	
Date of completion	
Scanned Data Entry	

	A. Property	Owner Information		
Nicolo A E	HSS Pickatt Co	reek Rd Chants Pa	SS OR97527	5-11-441-409
Name	Mailing Address (Street or PO Box	x, City, State, Zip Code)		e Number
	B. Legal Pr	operty Description		
35 67	26 100	D		7 Acres
Township Range	Section Tax Lot	Tax Accou	unt Number A	Acreage or Lot Size
County	Subdivision Name		Lot	Block
Property Address: 455 Pic	kett Creek Rd	City City	Sta	2 97527 zip Code
Directions to Property:				
	1 Projections Possilitas / Drope	and Callity / Water In	famantian	
Existing Facility:	C. Existing Facility / Proposed Facility	Market Market Anna Contract Act of Colors Angle and Autobase Antion Security Security (1997)	ater Supply:	
Single Family Residence	□Single Fam	ily Residence	□Public	
2 bedroom			Name	
Number of Bedrooms	Number of Bedro	ooms	PrivateWell, Sprii	ng Shared
□Other	□Other		wen, spin	ng, omaru
		of Application		
	12, турс	от друпсацоп		
Site Evaluation	□Renewal Permit	□Authoriza	ation Notice for:	
□Construction	□Existing System		Connecting to an Existin Replacing a Mobile Hon	ng System Not in Use ne or House with Another
Permit Repair	Evaluation	Mo	obile Home or House The Addition of One or 1	
☐ Major ☐ Minor ☐ Alteration Permit	□Permit Transfer		Personal Hardship	
□Major □Minor	□Permit Reinstatement		Temporary Housing ease specify	
If the required fee and attachment with your name and address at the By my signature, I certify that the it's authorized agents permission	e entrance to the property. Fla	is correct, and hereby grant t	the Josephine County	y Onsite Septic and
Signature Signature		10-14-21 Date		
Applicant's Name - Please Print Legibly		541-441-4097 Applicant's Phone Number	Applicant's	SE-mail Address
Applicant's Mailing Address	- Rd Grants Pass	OR 97527		
Applicant is the Wowner	☐ Authorized Representative	e □Licensed Septic	Installer	

Installer's Name



	SECTION 1 - TO BE COMPLETED BY APPLICANT (may be filled in electronically by tabbing to each field)
1.	Applicant Name/Property Owner: Nicole A. Fary
	Mailing Address: 455 Pickett Creek Rd RECEIVED
	City, State, Zip: Crants Pass OR 97527
	Telephone: 541-441-4097 OCT 14 2021
2.	Property Information: County: 1000 - PLANNING Tax Lot No.: 1000
	Township: 35 Range: 07 Section: 26
	Physical Address: 455 Pickett Creek R. Grants Pass OR, 97527
	Block: Lot: 1000
	Subdivision Name (if applicable):
3.	This proposed facility is for:
	Other. Describe the type of development, business, or facility and the provided services or products:
4.	Permit or approval being requested:
	☐ Construction-Installation permit for: ☐ New Construction ☐ Repair ☐ Alteration
	Non-water -carried facility requests (for example, pit privy/vault toilet for campgrounds).
	☐ Authorization Notice for: ☐ Replacement of dwelling ☐ Bedroom addition
	Other changes in land use involving potential sewage flow increases
	SECTION 2 - TO BE COMPLETED BY CITY OR COUNTY PLANNING OFFICIAL
_	1410
6.	The facility is located: inside city limits inside UGB inside UGB inside UGB
	If inside UGB, the proposed facility is subject to: City jurisdiction County jurisdiction Shared City/County jurisdiction
7.	Does the proposed facility comply with all applicable local land use requirements: X Yes No
	If you answered "Yes" above, was this compliance based on: Outright compliance with local comprehensive plans and land use requirements (provide a citation to the
	applicable provisions)
	Conditional approval (provide findings and citation or attach a copy of the applicable land use decision)
	■ Measure 49 waiver (provide Department of Land Conservation and Development approval number)
	Either provide reasons for affirmative compliance decision or attach findings of fact: Section 19.13.030.A JC
	allows for nonconforming structures to be altered OR maintained. No
	work allowed in Approximate Flood zone area.
8.	Planning Official Signature: William Faller
	Print Name: Verenice Brown Title: Assistant Planner
	Telephone: 541-474-5109 ext 2423 Date: 10/8/21
	•

Josephine County Planning 700 NW Dimmick Street Suite C Grants Pass, OR 97526



After recording return to: Nicole A. Farr 455 Pickett Creek Road Grants Pass, OR 97527

Until a change is requested all tax statements shall be sent to the following address: Nicole A. Farr 455 Pickett Creek Road Grants Pass, OR 97527

File No.: 7151-3787268 (td) Date: July 20, 2021

THIS SPACE RESERVED FOR RECORDER'S USE

JOSEPHINE COUNTY OFFICIAL RECORDS

RHIANNON HENKELS, COUNTY CLERK

2021-014755

DED-WRD

08/20/2021 01:29 PM Cnt=1 Pgs=2 Stn=9 JCOX \$10.00 \$11.00 \$10.00 \$60.00 \$5.00

\$96.00

I, Rhiannon Henkels, County Clerk, certify that the within document was received and duly recorded in the official records of Josephine County.

STATUTORY WARRANTY DEED

Constance E. Bentley, Grantor, conveys and warrants to Nicole A. Farr, Grantee, the following described real property free of liens and encumbrances, except as specifically set forth herein:

LEGAL DESCRIPTION: Real property in the County of Josephine, State of Oregon, described as follows:

All that portion of the Southeast Quarter of the Northwest Quarter of Section 26, Township 35 South, Range 7 West of the Willamette Meridian, Josephine County, Oregon, lying North of Pickett Creek.

NOTE: This Legal Description was created prior to January 01, 2008.

Subject to:

- 1. Covenants, conditions, restrictions and/or easements, if any, affecting title, which may appear in the public record, including those shown on any recorded plat or survey.
- 2. The 2021-2022 Taxes, a lien not yet payable.

The true consideration for this conveyance is \$199,000.00. (Here comply with requirements of ORS 93.030)

BEFORE SIGNING OR ACCEPTING THIS INSTRUMENT, THE PERSON TRANSFERRING FEE TITLE SHOULD INQUIRE ABOUT THE PERSON'S RIGHTS, IF ANY, UNDER ORS 195.300, 195.301 AND 195.305 TO 195.336 AND SECTIONS 5 TO 11, CHAPTER 424, OREGON LAWS 2007, SECTIONS 2 TO 9 AND 17, CHAPTER 855, OREGON LAWS 2009, AND SECTIONS 2 TO 7, CHAPTER 8, OREGON LAWS 2010. THIS INSTRUMENT DOES NOT ALLOW USE OF THE PROPERTY DESCRIBED IN THIS INSTRUMENT IN VIOLATION OF APPLICABLE LAND USE LAWS AND REGULATIONS. BEFORE SIGNING OR ACCEPTING THIS INSTRUMENT, THE PERSON ACQUIRING FEE TITLE TO THE PROPERTY SHOULD CHECK WITH THE APPROPRIATE CITY OR COUNTY PLANNING DEPARTMENT TO VERIFY THAT THE UNIT OF LAND BEING TRANSFERRED IS A LAWFULLY ESTABLISHED LOT OR PARCEL, AS DEFINED IN ORS 92.010 OR 215.010, TO VERIFY THE APPROVED USES OF THE LOT OR PARCEL, TO DETERMINE ANY LIMITS ON LAWSUITS TO VERIFY THE APPROVED USES OF THE LOT OR PARCEL, TO DETERMINE ANY LIMITS ON LAWSUITS OF NEIGHBORING PROPERTY OWNERS, IF ANY, UNDER ORS 195.300, 195.301 AND 195.305 RIGHTS OF NEIGHBORING PROPERTY OWNERS, IF ANY, UNDER ORS 195.300, 195.301 AND 195.305 TO 195.336 AND SECTIONS 5 TO 11, CHAPTER 424, OREGON LAWS 2007, SECTIONS 2 TO 9 AND 17, CHAPTER 855, OREGON LAWS 2009, AND SECTIONS 2 TO 7, CHAPTER 8, OREGON LAWS 2010.

a the	٨	21
Dated this 18 day of	<u>flugust</u>	, 20
Comstonce	& Bentle	4-
Constance E. Bentley		

This instrum	ent was acknowledged be ace E. Bentley.	fore me on this	iO_ day of _	- Nuscra (
County of	ent was acknowledged be)	18 1	ALDIRT	. 20 2 (
STATE OF	Oregon))ss.			

OFFICIAL STAMP
SHERYL HULSEY
NOTARY PUBLIC - OREGON
COMMISSION NO. 999454
MY COMMISSION EXPIRES MAY 11, 2024


Notary Public for Oregon My commission expires:

5/11/202A

SECTION 26 T.35S. R.7W. W. M. JOSEPHINE COUNTY

1"= 400"

This man was prepared for assessment purpose only.





Application for Onsite Sewage Treatment System

700 NW Dimmick Street, Suite B Grants Pass, OR 97526 541-474-5444


 $\square Authorization$

Attached

For ONSITE SEPTIC Use Only: Date received	Date Stamp
Fee paid	
Receipt number	
Application number	
Date of 1st response	
Date of 2 nd response	
Date of final response	
Date of completion	
Scanned Data Entry	

	A. Property	Owner Information			
Nicolo A E	455 Pickett C	reck Rd Court	s Pass ORg	7527 \$	541-441-409
Name	Mailing Address (Street or PO Bo	ox, City, State, Zip Code)	7	Phone Numb	
	B. Legal Pr	operty Description			
35 67	26 100	D		7	Acres
Township Range	Section Tax Lot	Tax	Account Number	Acreage	or Lot Size
County	Subdivision Name		Lot	Blo	ck
Property Address: 455 Pic	kett Creek Rd	City City	cr2	State	97527 Zip Code
Directions to Property:					
	1 Paristina Parility / Pro-	and Cadility / Wata	u Information	VIII.	
Existing Facility:	C. Existing Facility / Prop Proposed Facilit		Water Supply		
Single Family Residence	□Single Fam	nily Residence	□Public _		
2 bedroom				lame	
Number of Bedrooms	Number of Bedro	ooms	Private _	Well, Spring, Sha	red
□Other	□Other			ven, spring, sin	
		of Application			
	D. Type	of Application		magnetic to the control of the contr	
Site Evaluation	□Renewal Permit	□Auth	orization Notice	for:	
□Construction	□Existing System		☐ Connecting to a ☐ Replacing a Me		
Permit Repair	Evaluation		Mobile Home or H ☐ The Addition o	louse	
☐ Major ☐ Minor ☐ Alteration Permit	□Permit Transfer □Permit Reinstatement		☐ Personal Hards	hip	
□Major □Minor	□Permit Remstatement	□ Oth	☐ Temporary Hother-please specify	using	
If the required fee and attachmen with your name and address at the By my signature, I certify that the it's authorized agents permission	e entrance to the property. Fla e information I have furnished to enter onto the above describ	is correct, and hereby gr	oles. rant the Josephine	County Ons	
Signature		10-14-21 Date			
Applicant's Name - Please Print Legibly		541-441-4097 Applicant's Phone Number	r C	pplicant's E-mai	80 gmail. Con
Applicant's Mailing Address	- Rd Grants Pass	OR 97527)		
Applicant is the Wowner	☐ Authorized Representativ	e □Licensed Se	eptic Installer		

Installer's Name



	SECTION 1 - TO BE COMPLETED BY APPLICANT (may be filled in electronically by tabbing to each field)
1.	Applicant Name/Property Owner: Nicole A. Fary
	Mailing Address: 455 Pickett Creek Rd RECEIVED
	City, State, Zip: Crants Pass OR 97527
	Telephone: 541-441-4097 OCT 14 2021
2.	Property Information: County: 1000 - PLANNING Tax Lot No.: 1000
	Township: 35 Range: 07 Section: 26
	Physical Address: 455 Pickett Creek R. Grants Pass OR, 97527
	Block: Lot: 1000
	Subdivision Name (if applicable):
3.	This proposed facility is for:
	Other. Describe the type of development, business, or facility and the provided services or products:
4.	Permit or approval being requested:
	☐ Construction-Installation permit for: ☐ New Construction ☐ Repair ☐ Alteration
	Non-water -carried facility requests (for example, pit privy/vault toilet for campgrounds).
	☐ Authorization Notice for: ☐ Replacement of dwelling ☐ Bedroom addition
	Other changes in land use involving potential sewage flow increases
	SECTION 2 - TO BE COMPLETED BY CITY OR COUNTY PLANNING OFFICIAL
_	1410
6.	The facility is located: inside city limits inside UGB inside UGB inside UGB
	If inside UGB, the proposed facility is subject to: City jurisdiction County jurisdiction Shared City/County jurisdiction
7.	Does the proposed facility comply with all applicable local land use requirements: X Yes No
	If you answered "Yes" above, was this compliance based on: Outright compliance with local comprehensive plans and land use requirements (provide a citation to the
	applicable provisions)
	Conditional approval (provide findings and citation or attach a copy of the applicable land use decision)
	■ Measure 49 waiver (provide Department of Land Conservation and Development approval number)
	Either provide reasons for affirmative compliance decision or attach findings of fact: Section 19.13.030.A JC
	allows for nonconforming structures to be altered OR maintained. No
	work allowed in Approximate Flood zone area.
8.	Planning Official Signature: William Faller
	Print Name: Verenice Brown Title: Assistant Planner
	Telephone: 541-474-5109 ext 2423 Date: 10/8/21
	•

Josephine County Planning 700 NW Dimmick Street Suite C Grants Pass, OR 97526



After recording return to: Nicole A. Farr 455 Pickett Creek Road Grants Pass, OR 97527

Until a change is requested all tax statements shall be sent to the following address: Nicole A. Farr 455 Pickett Creek Road Grants Pass, OR 97527

File No.: 7151-3787268 (td) Date: July 20, 2021

THIS SPACE RESERVED FOR RECORDER'S USE

JOSEPHINE COUNTY OFFICIAL RECORDS

RHIANNON HENKELS, COUNTY CLERK

2021-014755

DED-WRD

08/20/2021 01:29 PM Cnt=1 Pgs=2 Stn=9 JCOX \$10.00 \$11.00 \$10.00 \$60.00 \$5.00

\$96.00

I, Rhiannon Henkels, County Clerk, certify that the within document was received and duly recorded in the official records of Josephine County.

STATUTORY WARRANTY DEED

Constance E. Bentley, Grantor, conveys and warrants to Nicole A. Farr, Grantee, the following described real property free of liens and encumbrances, except as specifically set forth herein:

LEGAL DESCRIPTION: Real property in the County of Josephine, State of Oregon, described as follows:

All that portion of the Southeast Quarter of the Northwest Quarter of Section 26, Township 35 South, Range 7 West of the Willamette Meridian, Josephine County, Oregon, lying North of Pickett Creek.

NOTE: This Legal Description was created prior to January 01, 2008.

Subject to:

- 1. Covenants, conditions, restrictions and/or easements, if any, affecting title, which may appear in the public record, including those shown on any recorded plat or survey.
- 2. The 2021-2022 Taxes, a lien not yet payable.

The true consideration for this conveyance is \$199,000.00. (Here comply with requirements of ORS 93.030)

BEFORE SIGNING OR ACCEPTING THIS INSTRUMENT, THE PERSON TRANSFERRING FEE TITLE SHOULD INQUIRE ABOUT THE PERSON'S RIGHTS, IF ANY, UNDER ORS 195.300, 195.301 AND 195.305 TO 195.336 AND SECTIONS 5 TO 11, CHAPTER 424, OREGON LAWS 2007, SECTIONS 2 TO 9 AND 17, CHAPTER 855, OREGON LAWS 2009, AND SECTIONS 2 TO 7, CHAPTER 8, OREGON LAWS 2010. THIS INSTRUMENT DOES NOT ALLOW USE OF THE PROPERTY DESCRIBED IN THIS INSTRUMENT IN VIOLATION OF APPLICABLE LAND USE LAWS AND REGULATIONS. BEFORE SIGNING OR ACCEPTING THIS INSTRUMENT, THE PERSON ACQUIRING FEE TITLE TO THE PROPERTY SHOULD CHECK WITH THE APPROPRIATE CITY OR COUNTY PLANNING DEPARTMENT TO VERIFY THAT THE UNIT OF LAND BEING TRANSFERRED IS A LAWFULLY ESTABLISHED LOT OR PARCEL, AS DEFINED IN ORS 92.010 OR 215.010, TO VERIFY THE APPROVED USES OF THE LOT OR PARCEL, TO DETERMINE ANY LIMITS ON LAWSUITS TO VERIFY THE APPROVED USES OF THE LOT OR PARCEL, TO DETERMINE ANY LIMITS ON LAWSUITS OF NEIGHBORING PROPERTY OWNERS, IF ANY, UNDER ORS 195.300, 195.301 AND 195.305 RIGHTS OF NEIGHBORING PROPERTY OWNERS, IF ANY, UNDER ORS 195.300, 195.301 AND 195.305 TO 195.336 AND SECTIONS 5 TO 11, CHAPTER 424, OREGON LAWS 2007, SECTIONS 2 TO 9 AND 17, CHAPTER 855, OREGON LAWS 2009, AND SECTIONS 2 TO 7, CHAPTER 8, OREGON LAWS 2010.

a the	٨	21
Dated this 18 day of	<u>flugust</u>	, 20
Comstonce	& Bentle	4-
Constance E. Bentley		

This instrum	ent was acknowledged be ace E. Bentley.	fore me on this	iO_ day of _	- Nuscra (
County of	ent was acknowledged be)	18 1	ALDIRT	. 20 2 (
STATE OF	Oregon))ss.			

OFFICIAL STAMP
SHERYL HULSEY
NOTARY PUBLIC - OREGON
COMMISSION NO. 999454
MY COMMISSION EXPIRES MAY 11, 2024

Notary Public for Oregon My commission expires:

5/11/202A

SECTION 26 T.35S. R.7W. W. M. JOSEPHINE COUNTY

1"= 400"

This man was prepared for assessment purpose only.

