

PERMITTEE NAME/ADDRESS:

NAME: James Miller, G-I Holdings Inc.

ADDRESS: One Campus Drive
Parsippany, NJ 07054

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

PERMIT NUMBER	DISCHARGE NUMBER
---------------	------------------

FACILITY: GAF/Mattel Site Groundwater Treatment System

LOCATION: 8585 SW Hall Blvd
Beaverton, OR

MONITORING PERIOD			
FROM	25 02 01	TO	25 02 28

NO DISCHARGE ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNIT			
Flow (discharge)	SAMPLE MEASUREMENT		4,513,968	Gallons this period	0 (a)	112	140	Gallons per minute	0	1/30	N/A
	PERMIT REQUIREMENT				----	----	----				
Temperature	SAMPLE MEASUREMENT						12.40	°C	0	1/30	Grab
	PERMIT REQUIREMENT				----	----	----				
pH	SAMPLE MEASUREMENT						8.12	pH units	0	1/30	Grab
	PERMIT REQUIREMENT				6	----	9				
Phosphate	SAMPLE MEASUREMENT						ND (100)	µg/L	0	1/90	Grab
	PERMIT REQUIREMENT				----	----	130				
Trichloroethene (TCE)	SAMPLE MEASUREMENT						1.47	µg/L	0	1/90	Grab
	PERMIT REQUIREMENT				----	----	50				
Other VOCs	SAMPLE MEASUREMENT						0.470	µg/L	0	1/90	Grab
	PERMIT REQUIREMENT				----	----	70				
Free (WAD) Cyanide (Weak Acid Dissociable)	SAMPLE MEASUREMENT						ND (5.0)	µg/L	0	1/30	Grab
	PERMIT REQUIREMENT				----	----	5.2				
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		<small>I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.</small>					TELEPHONE		DATE		
James Miller							(470) 599-7019		25 03 10		
TYPED OR PRINTED							AREA CODE NUMBER		YEAR MO DAY		

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

(a) Leak detection alarms occurred during the month due to storm events. The alarm was resolved after each storm event by pumping the stormwater out of the vaults.

ND = Not detected above laboratory reporting limit.