

PERMITTEE NAME/ADDRESS:

NAME: James Miller, G-I Holdings Inc.  
 ADDRESS: One Campus Drive  
 Parsippany, NJ 07054

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

**DISCHARGE MONITORING REPORT (DMR)**


PERMIT NUMBER	DISCHARGE NUMBER

FACILITY: GAF/Mattel Site Groundwater Treatment System  
 LOCATION: 8585 SW Hall Blvd  
 Beaverton, OR

MONITORING PERIOD		
FROM	24   11   01	TO
	24   11   30	

NO DISCHARGE

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNIT			
Flow (discharge)	SAMPLE MEASUREMENT		5,969,495	Gallons this period	128	138	268	Gallons per minute	0	1/30	N/A
	PERMIT REQUIREMENT				---	---	---				
Temperature	SAMPLE MEASUREMENT						13.70	°C	0	1/30	Grab
	PERMIT REQUIREMENT				---	---	---				
pH	SAMPLE MEASUREMENT						8.31	pH units	0	1/30	Grab
	PERMIT REQUIREMENT				6	---	9				
Phosphate	SAMPLE MEASUREMENT						ND (100)	µg/L	0	1/90	Grab
	PERMIT REQUIREMENT				---	---	130				
Trichloroethene (TCE)	SAMPLE MEASUREMENT						0.760	µg/L	0	1/90	Grab
	PERMIT REQUIREMENT				---	---	50				
Other VOCs	SAMPLE MEASUREMENT						0.600	µg/L	0	1/90	Grab
	PERMIT REQUIREMENT				---	---	70				
Free (WAD) Cyanide (Weak Acid Dissociable)	SAMPLE MEASUREMENT						ND (5.0)	µg/L	0	1/30	Grab
	PERMIT REQUIREMENT				---	---	5.2				

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.	TELEPHONE	DATE	
<b>James Miller</b>		 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	(470) 599-7019	24   12   10
TYPED OR PRINTED			AREA CODE NUMBER	YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

ND = Not detected above laboratory reporting limit.