

PERMITTEE NAME/ADDRESS:

NAME: James Miller, G-I Holdings Inc.

ADDRESS: One Campus Drive
Parsippany, NJ 07054

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

PERMIT NUMBER

DISCHARGE NUMBER

FACILITY: GAF/Mattel Site Groundwater Treatment System

LOCATION: 8585 SW Hall Blvd
Beaverton, OR

MONITORING PERIOD

FROM

24 | 06 | 01

TO

24 | 06 | 30

NO DISCHARGE ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNIT				
Flow (discharge)	SAMPLE MEASUREMENT		5,850,070	Gallons this period	125	135	146	Gallons per minute	0	1/30	N/A	
	PERMIT REQUIREMENT				----	----	----					
Temperature	SAMPLE MEASUREMENT						16.60	°C	0	1/30	Grab	
	PERMIT REQUIREMENT				----	----	----					
pH	SAMPLE MEASUREMENT						7.20	pH units	0	1/30	Grab	
	PERMIT REQUIREMENT				6	----	9					
Phosphate	SAMPLE MEASUREMENT							µg/L	0	1/90	Grab	
	PERMIT REQUIREMENT				----	----	130					
Trichloroethene (TCE)	SAMPLE MEASUREMENT							µg/L	0	1/90	Grab	
	PERMIT REQUIREMENT				----	----	50					
Other VOCs	SAMPLE MEASUREMENT							µg/L	0	1/90	Grab	
	PERMIT REQUIREMENT				----	----	70					
Free (WAD) Cyanide (Weak Acid Dissociable)	SAMPLE MEASUREMENT						ND (5.0)	µg/L	0	1/30	Grab	
	PERMIT REQUIREMENT				----	----	5.2					
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.					TELEPHONE		DATE			
James Miller							 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(470) 599-7019		24 07 10	
TYPED OR PRINTED									AREA CODE NUMBER		YEAR MO DAY	

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

ND = Not detected above laboratory reporting limit.