



State of Oregon
Department of
Environmental
Quality

Program Enforcement No. 2024-FC-9608

Department of Environmental Quality Underground Storage Tank Program

Field Citation For UST Violations

This section for
DEQ use only

Page 1 of 3

DEQ Information		UST Facility Information	
Inspection Date:	08/30/2024	Facility ID#:	4091
Inspector:	Dylan Eckert	Facility Name:	Gas And Snack
DEQ Office:	165 E 7th Ave #100	Facility Address:	2212 10th ST
	Eugene, OR 97401		Baker City, OR 97814
Phone #:	503-229-5034	County:	Baker

Oregon DEQ inspected the facility listed above and identified the UST violations listed on page 3 of this Field Citation.

Field Citation Issued: ☐ In Person ☒ By Email ☐ Both Date Issued: **03/21/2025**

Facility Representative Present During Inspection:

☐ Permittee ☐ Owner ☐ Other

Name of Permittee or Owner: Fletcher Petroleum, Marla Gardner

Mailing Address: 471 N Curtis Rd Boise, ID83706

Field Citation Penalty – See Page 3 for detailed listing of each violation. \$ 1100 .00

This Field Citation is issued in accordance with the requirements for the expedited enforcement of underground storage tank (UST) violations, OAR 340-150-0250.

Owner or Permittee should select Option 1 or Option 2 below and

return a signed copy of this form to DEQ by the following date: 03/21/2025

DEQ Revenue Section

700 NE Multnomah St. #600
Portland, Oregon 97232

Check one option

- ☐ **Option 1** - I acknowledge that the listed violation(s) have occurred and I am remitting the listed field citation penalty.
- ☐ **Option 2** - I do not want to participate in the expedited enforcement process and understand that my file will be referred to the Department's Office of Compliance and Enforcement for formal enforcement action.

Name:	Owner / Permittee
Signature:	Date:

Important

Read pages 2 and 3 for more information about your options and a detailed listing of violations and compliance requirements.

Field Citation Requirements

The permittee or owner should select Option 1 or Option 2 and return a signed copy of Page 1 of the Field Citation form within thirty (30) days of issuance of the Field Citation. If the permittee or owner fails to sign and send Page 1 of the Field Citation form back or pay the penalty within thirty days, Option 1 expires, the Field Citation will serve as a Pre-Enforcement Notice (PEN) and the permittee and owner will be subject to formal enforcement including the imposition of civil penalties in accordance with OAR Chapter 340, Division 12.

The permittee or owner must complete the actions required to correct the violations listed on the Field Citation by the date specified to prevent further enforcement action by DEQ.

Option 1:

By checking Option 1 the permittee or owner acknowledges that the violations listed on Page 3 of this Field Citation have occurred and agrees to pay the established penalty.

By submitting payment of the penalty amount, the responding permittee or owner agrees to accept the field citation as a final order of the Environmental Quality Commission (commission) and waives any and all rights and objections to the form, content, manner of service and timeliness of the Field Citation; to a contested case hearing and judicial review of the Field Citation [OAR 340-150-0250(6)]; and to service of a copy of this Final Order (*i.e.*, no other copy will be provided).

Upon the Department's receipt of payment of the penalty amount set forth in the Field Citation, the Field Citation becomes a Final Order of the Commission that:

1. Imposes upon the permittee or owner a civil penalty in the amount listed on Page 1 of this Field Citation; and
2. Requires the permittee or owner to satisfactorily complete the requirements and actions necessary to correct the violations documented by the dates set forth on Page 3 of this Field Citation.

Failure by the permittee or owner to complete the actions set forth on Page 3 of the Field Citation by the specified date violates the Commission Order and subjects the permittee and owner to a formal enforcement action including the imposition of additional civil penalties.

Option 2:

The permittee or owner may deny that the violations as listed on Page 3 of this Field Citation have occurred or contest the Field Citation process by checking Option 2 and submitting to the Department a signed copy of Page 1 of the Field Citation. In that event, the Field Citation will serve as a Pre-Enforcement Notice (PEN) and the permittee and owner will be subject to formal enforcement for those violations set forth in the Field Citation, including the imposition of civil penalties in accordance with OAR Chapter 340, Division 12. Civil penalties that will be imposed by the formal enforcement process will exceed the Field Citation penalties for the same violation(s).

The Department appreciates your cooperation and efforts to comply with the regulations for underground storage tank systems.

UST FIELD CITATION

DATE ISSUED: 10/08/2024

PROGRAM ENFORCEMENT No.: 2024-FC-9608

FACILITY ID: 4091

Page 3 of 3

Violation #1: *TCR: <input type="radio"/> Y <input type="radio"/> N	Failure to test spill prevention equipment at least once every 3 years		
Corrective Action:	Submit spill prevention testing records to DEQ		
Rule Citation: OAR 340-150- 0310(8)(b)	Penalty Amount: \$ 300 .00	Correct Violation by: 11/9/24	Date Corrected:
Violation #2: *TCR: <input type="radio"/> Y <input type="radio"/> N	Failure to complete initial overfill, spill prevention or sump testing requirements by October 1, 2020		
Corrective Action:	N/A		
Rule Citation: OAR 340-150- 0310(10)	Penalty Amount: \$.00	Correct Violation by: n/a	Date Corrected:
Violation #3: *TCR: <input type="radio"/> Y <input type="radio"/> N	Failure to inspect overfill equipment at least once every 3 years.		
Corrective Action:	Records received for testing in July 2023. No additional response required		
Rule Citation: OAR 340-150- 0310(1)	Penalty Amount: \$ 300 .00	Correct Violation by: n/a	Date Corrected:
Violation #4: *TCR: <input type="radio"/> Y <input type="radio"/> N	Failure to perform annual line tightness test on pressurized piping in 2022		
Corrective Action:	Missing 2022 testing records. No additional response required		
Rule Citation: OAR 340-150- -410(3)	Penalty Amount: \$ 200 .00	Correct Violation by: n/a	Date Corrected:
Violation #5: *TCR: <input type="radio"/> Y <input type="radio"/> N	Failure to perform an annual test of operation of line leak detector in 2022		
Corrective Action:	Missing 2022 testing records. No additional response required		
Rule Citation: OAR 340-150- 410(2)(c)	Penalty Amount: \$ 200 .00	Correct Violation by: n/a	Date Corrected:
Violation #6: *TCR: <input type="radio"/> Y <input type="radio"/> N	Failure to install, operate, maintain or calibrate RD equipment per manufacturer's instructions, including service checks for operability or running condition		
Corrective Action:	Missing 2022 testing records. No additional response required		
Rule Citation: OAR 340-150- 0400(1)	Penalty Amount: \$ 100 .00	Correct Violation by: n/a	Date Corrected:
Total Penalty Amount (This Page): \$ 1100 .00		Total Penalty Amount (All Pages): \$ 1100 .00	

YOU MUST CORRECT THE VIOLATIONS AS REQUIRED, ENTER THE DATES CORRECTED, SIGN THE STATEMENT BELOW AND RETURN THIS FORM TO THE DEQ INSPECTOR LISTED ON PAGE 1 ON OR BEFORE: 11/09/2024

Retain a copy of this form and all documentation of corrective actions for your records.

I hereby certify that the UST violations noted above have been corrected: _____ / _____
Permittee/Owner Signature
Date

*TCR: Technical Compliance Rate

Full Compliance Inspection

Submitted by: dylan.eckert_deq

Submitted time: Aug 30, 2024, 12:55:03 PM

Facility Number


4091

Address

2212 10th Street, Baker City, OR, 97814

Map

Lat: 44.779016 Lon: -117.840558



Esri, TomTom, Garmin, FAO, NOAA, USGS, EPA, USFWS

Powered by Esri

Date

Aug 30, 2024

Time

11:51

Compliance Determination

Financial Responsibility

Pass

IMPRESSED CURRENT CATHODIC PROTECTION SYSTEM EVALUATION
Underground Storage Tank Program

1. Access to the soil directly under the cathodically protected structure that is being evaluated must be provided.
2. A site drawing showing the UST cathodic protection system and all reference electrode placements must be completed.

I. UST OWNER		II. UST FACILITY	
NAME: FLETCHER OIL, NORTHWEST LEASE & CATTLE CO.	NAME: GAGE & WATSON - BAKER CITY, OR	R-4 OR 4091	
ADDRESS: 4715 NORTH CUMING ROAD	ADDRESS: 3215 10TH STREET		
CITY: BURNS	STATE: OR	CITY: BAKER CITY	COUNTY: WAHOO
III. CP TESTER		IV. CP TESTER'S QUALIFICATIONS	
TESTER'S NAME: ROBERT RUTHER		CP TESTER'S CERTIFICATION NUMBER: NAACE CP-10001 (975-CP-10001)	
COMPANY NAME: R&W CATHODIC PROTECTION SERVICE, INC.		EXPIRATION DATE: NAACE AUG 2021 (975-SEP 2021)	
ADDRESS: 301 REEDERBY RD		PHONE NUMBER: (503) 750-0401	
CITY: DRAPER	STATE: UT		
V. REASON SURVEY WAS CONDUCTED (check one)			
<input type="checkbox"/> Routine - 1 year <input type="checkbox"/> Routine - within 6 months of installation <input type="checkbox"/> 30-day re-survey after fail <input checked="" type="checkbox"/> Re-survey after requalification			
Note: re-survey cathodic protection survey must be conducted 1-19-2022 (regardless of requalification) & every 6 years thereafter.			
VI. CATHODIC PROTECTION TESTER'S EVALUATION (check one)			
<input checked="" type="checkbox"/> PASS All protected structures at this facility pass the cathodic protection survey and it is judged that adequate cathodic protection has been provided to the UST system. (Indicate all criteria applicable by completion of Section VII).			
<input type="checkbox"/> FAIL One or more protected structures at this facility fail the cathodic protection survey and it is judged that adequate cathodic protection has not been provided to the UST system (complete Section VII).			
<input type="checkbox"/> INDISCUSSIBLE The cathodic protection survey of an impressed current system must be evaluated by a corrosion expert. (complete Section VII).			
CP TESTER'S SIGNATURE: 		DATE OF SURVEY PERFORMED: JULY 15, 2021	
VII. CORROSION EXPERT'S EVALUATION (check one)			
The survey must be conducted and/or evaluated by a corrosion expert when: 1) replacement anodes or other changes to the construction of the impressed current system are made; 2) the current may be affecting nearby metallic structures; 3) CP system has not been installed in Section VI.			
<input checked="" type="checkbox"/> PASS All protected structures at this facility pass the cathodic protection survey and it is judged that adequate cathodic protection has been provided to the UST system. (Indicate all criteria applicable by completion of Section VII).			
<input type="checkbox"/> FAIL One or more protected structures at this facility fail the cathodic protection survey and it is judged that adequate cathodic protection has not been provided to the UST system. (Indicate all criteria applicable by completion of Section VII).			
CORROSION EXPERT'S NAME: DALE CLAMBERG, P.E., NAACE CP-1		COMPANY NAME: R&W CATHODIC PROTECTION SERVICE, INC.	
NAACE INTERNATIONAL CERTIFICATION: CATHODIC PROTECTION SPECIALIST (CPE)		NAACE INTERNATIONAL CERTIFICATION NUMBER: CP-15178	
CORROSION EXPERT'S SIGNATURE: 		DATE: JULY 21, 2021	
VIII. CRITERIA APPLICABLE TO EVALUATION (check all that apply)			
<input checked="" type="checkbox"/> NO OFF Structure-to-soil potential more negative than -850 mV with respect to a Cu/CuSO ₄ reference electrode with protective current temporarily interrupted (instant-off).			
<input type="checkbox"/> NO AN POLARIZATION (Structure) within at least 100 mV of cathodic polarization.			
IX. ACTION REQUIRED AS A RESULT OF THIS EVALUATION (check one)			
<input checked="" type="checkbox"/> NONE Cathodic protection is adequate. No further action is necessary at this time. Test again by no later than (see Section VI).			
<input type="checkbox"/> RETEST Cathodic protection may not be adequate. Retest during the next 90 days to determine if passing results can be achieved.			
<input type="checkbox"/> REPAIR & RETEST Cathodic protection is not adequate. Requalification is necessary as soon as practical but within the next 90 days.			

Facility_4091_240830122922_.jpg

12 Aug 2021

Wheeler Tank Testing Inc. Tank Tightness Test Estabrook's EZY 3 Locator Plus

Station Fletcher Oil-Gas and Snack

Address 2212 10th St

City/State Baker City, OR

Zip Code

UST Compliance
☐ Suspensions
☐ Leak Detectors
☐ Line Tightness
☐ Cathodic Protection
☐ Tank Tightness

Wheeler Tank Testing
 P.O. Box 1004
 Medford, OR 97504
 531-4521
 Kanto 208-231-1462
wheeler-tank-testing-inc@gmail.com

Date: Nov 21, 2021

Product Type Diesel

Capacity 30,000

Tank Tests

Tank Type Steel

Height Of Product 43.75'

Grade To Ground Water NA


Water Around Tank NO

Acoustic Test Results Pass

Water Test Results NA

Comments: Tank passed acoustic testing.

Technician Name and Number Kevin Wheeler 13713

Signature 

Facility_4091_240830122808_.jpg

13 Aug 2017, 4 PM

Measured CP Frequency (Previous Location)	Measured CP Frequency (New Location)	Notes	Notes
-1500	-1500	OK	OK
-1000	-1000	OK	OK
-775	-775	OK	OK
-500	-500	OK	OK
-250	-250	OK	OK
-125	-125	OK	OK
-62.5	-62.5	OK	OK
-31.25	-31.25	OK	OK
-15.625	-15.625	OK	OK
-7.8125	-7.8125	OK	OK
-3.90625	-3.90625	OK	OK
-1.953125	-1.953125	OK	OK
-0.9765625	-0.9765625	OK	OK
-0.48828125	-0.48828125	OK	OK
-0.244140625	-0.244140625	OK	OK
-0.1220703125	-0.1220703125	OK	OK
-0.06103515625	-0.06103515625	OK	OK
-0.030517578125	-0.030517578125	OK	OK
-0.0152587890625	-0.0152587890625	OK	OK
-0.00762939453125	-0.00762939453125	OK	OK
-0.003814697265625	-0.003814697265625	OK	OK
-0.0019073486328125	-0.0019073486328125	OK	OK
-0.00095367431640625	-0.00095367431640625	OK	OK
-0.000476837158203125	-0.000476837158203125	OK	OK
-0.0002384185791015625	-0.0002384185791015625	OK	OK
-0.00011920928955078125	-0.00011920928955078125	OK	OK
-0.000059604644775390625	-0.000059604644775390625	OK	OK
-0.0000298023223876953125	-0.0000298023223876953125	OK	OK
-0.00001490116119384765625	-0.00001490116119384765625	OK	OK
-0.000007450580596923828125	-0.000007450580596923828125	OK	OK
-0.0000037252902984619140625	-0.0000037252902984619140625	OK	OK
-0.00000186264514923095703125	-0.00000186264514923095703125	OK	OK
-0.000000931322574615478515625	-0.000000931322574615478515625	OK	OK
-0.0000004656612873077392578125	-0.0000004656612873077392578125	OK	OK
-0.00000023283064365386962890625	-0.00000023283064365386962890625	OK	OK
-0.000000116415321826934814453125	-0.000000116415321826934814453125	OK	OK
-0.0000000582076609134674072265625	-0.0000000582076609134674072265625	OK	OK
-0.00000002910383045673370361328125	-0.00000002910383045673370361328125	OK	OK
-0.000000014551915228366851806640625	-0.000000014551915228366851806640625	OK	OK
-0.0000000072759576141834259033203125	-0.0000000072759576141834259033203125	OK	OK
-0.00000000363797880709171295166015625	-0.00000000363797880709171295166015625	OK	OK
-0.000000001818989403545856475830078125	-0.000000001818989403545856475830078125	OK	OK
-0.0000000009094947017729282379150390625	-0.0000000009094947017729282379150390625	OK	OK
-0.00000000045474735088646411895751953125	-0.00000000045474735088646411895751953125	OK	OK
-0.000000000227373675443232059478759765625	-0.000000000227373675443232059478759765625	OK	OK
-0.0000000001136868377216160297393798828125	-0.0000000001136868377216160297393798828125	OK	OK
-0.00000000005684341886080801486968994140625	-0.00000000005684341886080801486968994140625	OK	OK
-0.00000000002842170943040400743484497072265625	-0.00000000002842170943040400743484497072265625	OK	OK
-0.000000000014210854715202003717422485361328125	-0.000000000014210854715202003717422485361328125	OK	OK
-0.0000000000071054273576010018587112426806640625	-0.0000000000071054273576010018587112426806640625	OK	OK
-0.00000000000355271367880050092935562134033203125	-0.00000000000355271367880050092935562134033203125	OK	OK
-0.000000000001776356839400250464677810670166015625	-0.000000000001776356839400250464677810670166015625	OK	OK
-0.0000000000008881784197001252323389053350078125	-0.0000000000008881784197001252323389053350078125	OK	OK
-0.00000000000044408920985006261616945266750390625	-0.00000000000044408920985006261616945266750390625	OK	OK
-0.000000000000222044604925031308084726333751953125	-0.000000000000222044604925031308084726333751953125	OK	OK
-0.0000000000001110223024625156440423631668759765625	-0.0000000000001110223024625156440423631668759765625	OK	OK
-0.0000000000000555111512312578220211815834398828125	-0.0000000000000555111512312578220211815834398828125	OK	OK
-0.00000000000002775557561562891101059079171994140625	-0.00000000000002775557561562891101059079171994140625	OK	OK
-0.00000000000001387778780781445550529539585997072265625	-0.00000000000001387778780781445550529539585997072265625	OK	OK
-0.000000000000006938893903907227777547697929985361328125	-0.000000000000006938893903907227777547697929985361328125	OK	OK
-0.0000000000000034694469519536138887738489649926806640625	-0.0000000000000034694469519536138887738489649926806640625	OK	OK
-0.00000000000000173472347597680694438692322499634033203125	-0.00000000000000173472347597680694438692322499634033203125	OK	OK
-0.000000000000000867361737988403472193461162498170166015625	-0.000000000000000867361737988403472193461162498170166015625	OK	OK
-0.000000000000000433680868994201736096730581249085078125	-0.000000000000000433680868994201736096730581249085078125	OK	OK
-0.00000000000000021684043449710086804836529062454296875	-0.00000000000000021684043449710086804836529062454296875	OK	OK
-0.000000000000000108420217248550434024182645312272734375	-0.000000000000000108420217248550434024182645312272734375	OK	OK
-0.0000000000000000542101086242752170120913227656113671875	-0.0000000000000000542101086242752170120913227656113671875	OK	OK
-0.000000000000000027105054312137608506045637805656839375	-0.000000000000000027105054312137608506045637805656839375	OK	OK
-0.0000000000000000135525271560688042530228169028284196875	-0.0000000000000000135525271560688042530228169028284196875	OK	OK
-0.000000000000000006776263578034402126511408451414209375	-0.000000000000000006776263578034402126511408451414209375	OK	OK
-0.0000000000000000033881317890172010632570422257071046875	-0.0000000000000000033881317890172010632570422257071046875	OK	OK
-0.00000000000000000169406589450860053162852111285355234375	-0.00000000000000000169406589450860053162852111285355234375	OK	OK
-0.000000000000000000847032947254300265814260556426777619375	-0.000000000000000000847032947254300265814260556426777619375	OK	OK
-0.0000000000000000004235164736271501329071302782133888096875	-0.0000000000000000004235164736271501329071302782133888096875	OK	OK
-0.00000000000000000021175823681357506645356513910669440484375	-0.00000000000000000021175823681357506645356513910669440484375	OK	OK
-0.000000000000000000105879118406787533222677809553347202421875	-0.000000000000000000105879118406787533222677809553347202421875	OK	OK
-0.0000000000000000000529395592033937666113388937766736012109375	-0.0000000000000000000529395592033937666113388937766736012109375	OK	OK
-0.00000000000000000002646977960169688330566944888333680060546875	-0.00000000000000000002646977960169688330566944888333680060546875	OK	OK
-0.000000000000000000013234889800848441652834724441668400302734375	-0.000000000000000000013234889800848441652834724441668400302734375	OK	OK
-0.000000000000000000006617444900424220826417362220834201513671875	-0.000000000000000000006617444900424220826417362220834201513671875	OK	OK
-0.000000000000000000003308722450212110413208681110417100756839375	-0.000000000000000000003308722450212110413208681110417100756839375	OK	OK
-0.0000000000000000000016543612251055552066043405552085503784196875	-0.0000000000000000000016543612251055552066043405552085503784196875	OK	OK
-0.000000000000000000000827180612527777603302170277760275189209375	-0.000000000000000000000827180612527777603302170277760275189209375	OK	OK
-0.0000000000000000000004135903062638888016510851388801375946046875	-0.0000000000000000000004135903062638888016510851388801375946046875	OK	OK
-0.00000000000000000000020679515313194440082554256944006879730234375	-0.00000000000000000000020679515313194440082554256944006879730234375	OK	OK
-0.000000000000000000000103397576565972200412771284720034398651171875	-0.000000000000000000000103397576565972200412771284720034398651171875	OK	OK
-0.00000000000000000000005169878828298610020638564236001719932589375	-0.00000000000000000000005169878828298610020638564236001719932589375	OK	OK
-0.000000000000000000000025849394141493050103192821180008599662946875	-0.000000000000000000000025849394141493050103192821180008599662946875	OK	OK
-0.00000000000000000000001292469707074652505155941090004299831473046875	-0.00000000000000000000001292469707074652505155941090004299831473046875	OK	OK
-0.000000000000000000000006462348535373262525779705450002149915715234375	-0.000000000000000000000006462348535373262525779705450002149915715234375	OK	OK
-0.0000000000000000000000032311742676866312628889527250001074957857619375	-0.0000000000000000000000032311742676866312628889527250001074957857619375	OK	OK
-0.0000000000000000000000016155871338433156144444763625000537478928809375	-0.0000000000000000000000016155871338433156144444763625000537478928809375	OK	OK
-0.00000000000000000000000080779356692165780722223818125002687394644046875	-0.00000000000000000000000080779356692165780722223818125002687394644046875	OK	OK
-0.000000000000000000000000403896783460828903611119090625001343697220234375	-0.000000000000000000000000403896783460828903611119090625001343697220234375	OK	OK
-0.000000000000000000000000201948391730414451805559545312500067184861101171875	-0.000000000000000000000000201948391730414451805559545312500067184861101171875	OK	OK
-0.000000000000000000000000100974195865207225902779772656250003359243055559375	-0.000000000000000000000000100974195865207225902779772656250003359243055559375	OK	OK
-0.0000000000000000000000000504870979326036129511398863281250001679621527796875	-0.0000000000000000000000000504870979326036129511398863281250001679621527796875	OK	OK
-0.00000000000000000000000002524354896630180647569944316406250000839810763984375	-0.00000000000000000000000002524354896630180647569944316406250000839810763984375	OK	OK
-0.000000000000000000000000012621774483150903237834972182031250000419905381941875	-0.000000000000000000000000012621774483150903237834972182031250000419905381941875	OK	OK
-0.00000000000000000000000000631088724157545161891723609101562500002099526909709375	-0.00000000000000000000000000631088724157545161891723609101562500002099526909709375	OK	OK
-0.000000000000000000000000003155443620787725789458618045078125000010497634548546875	-0.000000000000000000000000003155443620787725789458618045078125000010497634548546875	OK	OK
-0.0000000000000000000000000015777218103938628947293090225039062500005248817272324375	-0.0000000000000000000000000015777218103938628947293090225039062500005248817272324375	OK	OK
-0.0000000000000000000000000007888609051969314473646545112519531250000262440863613671875			

-455	-455	PASS
-503	-503	PASS
-457	-457	PASS

Determination of PASS/FAIL:
PASS: Cathodic potential recorded on protected structure is above -850mV CSE.
FAIL: Cathodic potential recorded is below the minimum -850mV CSE as specified in NACE SP0169, this site requires immediate repair to return structure to protected state.
1: CSE - Electronic potentials referenced to CuSO4 (Copper-Copper Sulfate Half Cell Reference Electrode) placed in contact with the electrolyte.

CONCLUSIONS & RECOMMENDATIONS
 After reviewing the results of our tests, the following conclusions can be made:

1. Rectifier tested GOOD on all ranges utilizing 1 Ohm precision resistor to simulate ground bed.
2. Anode Grounded is depleted, not functioning. Requires replacement.
3. No other problems with the cathodic protection system are evident.

Price-Less Gas
231 Cottage Street North
Vale, OR 97918
 Federal or State Facility ID #: Oregon: 6787

We performed a series of tests and measurements to verify the measurements recorded on prior surveys and as reported. The results of our testing are shown below.

LOCATION OF TEST	POTENTIAL (mV CSE)		PASS/FAIL	COMMENTS
	ON	OFF		
Rectifier Settings/Readings	N/A	N/A	PASS	Rectifier: Universal Model: USAI Serial: 134834 Set at: 2 Coarse, 4 Fine Output Voltage Measured: 22.13VDC Output Current Measured: 1.50A 3.1mV (shunt) x .5 (shunt factor) = 1.55A

MM Cathodic Protection Services • 303 Redberry Rd. Draper, UT 84020 • Phone: (888) 763-6572 Website: CathodicProtectionJah.com

Page 2 of 4

Facility_4091_240830122716_.jpg

CONCLUSIONS & RECOMMENDATIONS

After reviewing the results of our tests, the following conclusions can be made:

1. Rectifier tested GOOD on all ranges utilizing 1 Ohm precision resistor to simulate ground bed.
2. Anode Grounded is depleted, not functioning. Requires replacement.
3. "Overaged wires" reports in previous documents refers to old CP wiring, not current system.
4. This rectifier requires a dedicated 25A circuit. Currently has 15A causing system to trip during current interruption. Fletcher should replace 15A with 25A circuit breaker ASAP.
5. CP system has jumper wiring via RANPIPE to a series of electrical conduits. These should be removed as the CP system is dedicated to providing protection to the tanks farm and piping only.
6. No other problems with the cathodic protection system are evident.

Fletcher Stores - Gas N Snack
2212 10th Street
Baker City, OR 97814
Federal or State Facility ID #: Oregon: 4091

We performed a series of tests and measurements to verify the measurements recorded on prior surveys and as reported. The results of our testing are shown below.

LOCATION OF TEST	POTENTIAL (mv CSE)		TEST TYPE	COMMENTS
	ON	OFF		
Rectifier Settings/Readings	N/A	N/A	PASS	Rectifier: Weston Model 1571457102, Serial 0011000 Set at: A-Curve, 5 Pins Output Voltage Measured: 17.2VDC Output Current Measured: 3.54A 11.8mV (ohm) x 3 (ohm factor) = 3.54A NOTE: Rectifier tested GOOD on all ranges utilizing 1 Ohm precision resistor to simulate ground bed.
Measured CP Potentials (Various Locations)	-1081 -1082 -1079 -1123 -1182 -1808	-802 -802 -808 -470 -484 -802	PASS PASS PASS PASS PASS PASS	NOTE: This cathodic protection system MEETS all minimum required standards, per federal and state standards for protection. Criteria: NACE RP-0169, CPN T19, 40

Determination of PASS (Minimum -1100mV CSE)

PASS: Cathodic potential recorded on protected structure is above -850mV CSE.

Facility_4091_240830122642_.jpg

Property Location:
Price-Less Missouri
 181 West 1st Avenue
 Glens Ferry, ID 83423
 Federal or State Facility ID #: 240830

We performed a series of tests and measurements to verify the measurements recorded on prior surveys and as required. The results of our testing are shown below.

LOCATION OF TEST	POTENTIAL LOW VOLTAGE	POTENTIAL HIGH VOLTAGE	COMMENTS
IN	OUT	TEST	
Resistor: Voltage/Resistance	500	500	Resistor: Precision Resistor 500/1000000 2.5k Ohm 50/100 Not at 10 Ohms 1.1 Ohm Output Voltage Measured: 10.1VDC Output Current Measured: 10.1mA Test (ohms) = 2.5 Ohm Resistor = 2.5k
Measured TP Resistance	500	500	NOTE: Resistor tested 10000 on all ranges utilizing 1 Ohm precision resistor to simulate ground test
Ground Resistance	500	500	NOTE: Resistor tested 10000 on all ranges utilizing 1 Ohm precision resistor to simulate ground test
500	500	500	NOTE: Resistor tested 10000 on all ranges utilizing 1 Ohm precision resistor to simulate ground test
500	500	500	NOTE: Resistor tested 10000 on all ranges utilizing 1 Ohm precision resistor to simulate ground test
500	500	500	NOTE: Resistor tested 10000 on all ranges utilizing 1 Ohm precision resistor to simulate ground test

CONCLUSIONS & RECOMMENDATIONS
 After reviewing the results of our tests, the following conclusions can be made:

1. Resistor tested GOOD on all ranges utilizing 1 Ohm precision resistor to simulate ground test.
2. Resistor Grounded is depleted, not functioning. Requires replacement.
3. No other problems with the cathodic protection system are evident.

Price-Less Gas
221 Cottage Street North
 York, OH 43086
 Federal or State Facility ID #: Oregon 6787

We performed a series of tests and measurements to verify the measurements recorded on prior surveys and as required. The results of our testing are shown below.

LOCATION OF TEST	POTENTIAL LOW VOLTAGE	POTENTIAL HIGH VOLTAGE	COMMENTS
IN	OUT	TEST	
Resistor: Voltage/Resistance	500	500	Resistor: Precision Resistor 500/1000000 2.5k Ohm 50/100 Not at 10 Ohms 1.1 Ohm Output Voltage Measured: 10.1VDC Output Current Measured: 10.1mA Test (ohms) = 2.5 Ohm Resistor = 2.5k


Web: Cathodic Protection Services • 301 Rockbury Rd. Dover, VT 05820 • Phone: (802) 362-6579 • Website: CathodicProtection.com

Page 2 of 4

Facility_4091_240830122612_.jpg



Facility_4091_240830121839_.jpg



Facility_4091_240830121823_.jpg



Facility_4091_240830121433_.jpg



Facility_4091_240830121134_.jpg



Facility_4091_240830121123_.jpg



Facility_4091_240830121113_.jpg



Facility_4091_240830120651_.jpg



Facility_4091_240830120634_.jpg



Facility_4091_240830120556_.jpg



Facility_4091_240830120546_.jpg



Facility_4091_240830120531_.jpg



Facility_4091_240830120523_.jpg



Facility_4091_240830120347_.jpg



Facility_4091_240830120311_.jpg



Facility_4091_240830115751_.jpg



Facility_4091_240830115508_diedtfv.jpg



Facility_4091_240830115445_pul.jpg



Facility_4091_240830115428_.jpg




Facility_4091_240830115330_clearspillftfv.jpg



Facility_4091_240830115310_.jpg



Facility_4091_240830115304_.jpg



Inspection conducted by: Verde-Robert Date: 10/10/2014 Facility: 4091

Site Name: gas & some Permit: rule Contact: 4091

Site Address: 2212 100 St Inspection: rule Phone:

City: Edmonton County: Edm District:

ENV #	Task Sub-section
Substance	<u>HDBL</u> <u>14DBA</u> <u>RDDBS</u>
Est. Grades	<u>10</u> <u>0</u> <u>12</u>
Task Material	<u>10</u> <u>0</u> <u>12</u>
Task Install Date	<u>10/10/2014</u>
Pipe Material	<u>24</u>
Pipe Type	<u>24" DW - need Jan?</u>
Pipe Install Date	<u>01/10/2014</u> <u>need Jan?</u>
Overflow Device	<u>10/10/2014</u>
Notes:	<u>2 HLA</u>

Need 22

Operating Certificate

Operator Training Compliance: Y N

Financial Responsibility Compliance: Y N

Walkthrough Inspections not up to log or work log Compliance: Y N

Corrosion Protection / Lining Compliance: Y N

Overflow Prevention Compliance: Y N

Spill Prevention Compliance: Y N

Release Detection Compliance: Y N

Release Detection: used to Eric

T2: ☒ Jan ☐ Feb ☐ Mar ☐ Apr ☐ May ☐ Jun ☐ Jul ☐ Aug ☐ Sep ☐ Oct ☐ Nov ☐ Dec

T3: ☒ Jan ☐ Feb ☐ Mar ☐ Apr ☐ May ☐ Jun ☐ Jul ☐ Aug ☐ Sep ☐ Oct ☐ Nov ☐ Dec

T4: ☒ Jan ☐ Feb ☐ Mar ☐ Apr ☐ May ☐ Jun ☐ Jul ☐ Aug ☐ Sep ☐ Oct ☐ Nov ☐ Dec

T5: ☐ Jan ☐ Feb ☐ Mar ☐ Apr ☐ May ☐ Jun ☐ Jul ☐ Aug ☐ Sep ☐ Oct ☐ Nov ☐ Dec

Facility_4091_240830125434_.jpg



Facility_4091_240830123715_.jpg



Facility_4091_240830123701_.jpg

Facility_4091_240830123004_.jpg

THIS SECTION IS TO BE FILLED IN BY THE INSTRUMENTSMAN OF CONTINUITY ON UNDERGROUND STORAGE TANK SYSTEMS THAT ARE PROVIDED BY SEPARATE PROTECTIVE SYSTEMS. WHEN THE PROTECTIVE SYSTEM IS A FLOODING GROUND-WATER MONITORING SYSTEM, THE PROTECTIVE STRUCTURE MUST BE PLACED IN THE SOIL AT A REMOTE LOCATION AND LEFT UNOCCUPIED. WHEN THE PROTECTIVE SYSTEM IS A FLOODING GROUND-WATER MONITORING SYSTEM, THE PROTECTIVE STRUCTURE MUST BE PLACED IN THE SOIL AT A REMOTE LOCATION AND LEFT UNOCCUPIED. WHEN THE PROTECTIVE SYSTEM IS A FLOODING GROUND-WATER MONITORING SYSTEM, THE PROTECTIVE STRUCTURE MUST BE PLACED IN THE SOIL AT A REMOTE LOCATION AND LEFT UNOCCUPIED.

REMARKS: LOCATION OF "TWO REMOTE" REFERENCE ELECTRODE PLACEMENTS. POINT TO POINT CONTINUITY TEST PERFORMED.

2. Describe the proposed structure (a) that you are attempting to demonstrate is continuous (i.e., plus 10% below).
2. Describe the "other" protected structure (b) that you are attempting to demonstrate is continuous (i.e., plus steel product fee @ 50%).
3. Record the test results obtained at structure-to-soil potential of the proposed structure (a) in millivolts (e.g., -405 mV).
4. Record the test results obtained at structure-to-soil potential of the "other" protected structure (b) in millivolts (e.g., -308 mV).
5. Record the voltage difference observed between structure "a" and structure "b" when conducting "open-circuit" testing (e.g., 16V).
6. Document either the test lead and/or wire used to point indicated the protected structure was bonded (continuous in description).

Facility_4091_240830122951_.jpg

Overfill Prevention Inspection, Spill Bucket & Containment Sump Testing

UST Facility

Person conducting the Inspection and/or Testing

Name:	Gas N Snack	ID#:	4091	Name:	Max Duffy
Street Address	2212 10th St			Company Name:	Fuel System Testing Co.
City:	Baker City	Zip:	97814	Street Address	P.O. Box 1932 - Twin Falls, ID
Site Contact:	Marla Gardner			Phone:	208-546-3063
Phone:	208-377-0024			Email:	office@theftc.net

* Overfill prevention equipment must be inspected every 3 years.

* Spill buckets and containment sumps must be tested every 3 years. Only containment sumps used for interstitial monitoring of piping require testing

* Double-walled spill buckets and containment sumps do not require testing if the integrity of both walls is monitored at least every 30 days

Overfill Prevention Inspection

Identify Tank (number, product type, etc);		1RuLe10	2DSL	3PuL			
Make and model		N/A	OPW61SO	N/A			
Flapper Valve	Shuts off flow at 95% tank capacity	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Float moves freely, proper orientation, poppet moves into flow path and operates per mfg. design	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	If present, bypass valve in the drop tube is open	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Inspection Results (P = pass, F = fail)		F	P	F	—	—	—

Overfill Alarm	Activates at no more than 90% capacity	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Alarm can be seen & heard by delivery driver	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Activates in test mode	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Float moves freely on the stem	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Fuel float level on the ATG agrees with gauge stick reading	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Inch level at which the alarm activates corresponds with value in ATG	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Inspection Results (P = pass, F = fail)		—	—	—	—	—	—
Ball Float	Restricts flow at 90% capacity	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Tank top fittings are vapor-tight	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Ball is free of holes, cracks and moves freely in cage	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Cage is free of debris and is intact	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Inspection Results (P = pass, F = fail)	—	—	—	—	—	—
Ball floats that fail an overfill inspection cannot be replaced for any reason.							

Spill Bucket Testing (passes if water level drops less than 1/8 inch, minimum test time 1 hour)

☐ Spill bucket is double-walled and monitored monthly (must be recorded on 30-day walkthrough inspection form)

Identify tank (tank number, product type, etc.)	1RuLe10	2DSL	3PuL			
Liquid and debris removed from spill bucket* <small>* Liquid and debris must be disposed of properly</small>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Water was filled 1.5 inches from top of spill bucket	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Starting water level height (inches)	8.5	15" WC	9			
Starting test time	1:37	2:32	2:11			
Ending test time	1:56	2:33	3:11			
Ending water level height (inches)	8	15" WC	9			
Level change For vacuum testing, 30-inch water column was applied and at least 26-inch water column was maintained after 1 minutes or mfg. procedures	-.5	0	0			
	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Test Results (P = pass, F = fail)	F	P	P	—	—	—

Containment Sump Testing

(passes if water level drops less than 1/8 inch, minimum test time 1 hour)

☐ Containment sump is double-walled and monitored monthly (must be recorded on 30-day walkthrough inspection form)

Describe sump (tank number, dispenser number etc.):

--	--	--	--	--	--

Liquid and debris removed from sump*

* Liquid and debris must be disposed of properly

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------

☐ DEQ Alternative Test Method used ** (fill out level change info below) ** See IDAPA 58.01.07.101.02.

All sensors were tested confirming positive shutdown

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------

☐ PEI RP 1200 Method (fill out level change info below)

Water was filled at least 4 inches above the highest penetration fitting

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------

Starting water level height (inches)

--	--	--	--	--	--

Starting test time

--	--	--	--	--	--

Ending test time

--	--	--	--	--	--

Ending water level height (inches)

--	--	--	--	--	--

Level change

--	--	--	--	--	--

Test Results

(P = pass, F = fail)

—	—	—	—	—	—
---	---	---	---	---	---

Corrective Action

Description of actions taken if items tested or inspected were not acceptable

The RuL spill bucket and flapper valve failed. The liquid level dropped a 1/2" before the test was halfway through. The flapper failed because it is untestable due to the drop tube being unremovable at this time.

The PuL spill bucket passed hydrostatic testing with no issues but the flapper failed because it's untestable. The fill adaptor is unremovable so the drop tube is stuck as well.

The DSL spill bucket is double walled and passed vacuum testing all good. The flapper valve passed as well.



Date:

February 23, 2022

Tester's Signature



OPW DOUBLE WALL SPILL CONTAINMENT MANHOLE VACUUM TEST FORM

Customer: Gas & snack

Location: Baker city oregon

Spill Containment Manhole Manufacture: X **OPW**

Date Tested: 4-12-22

We performed a Vacuum test on the Double Wall spill containment manhole, by connecting on the vacuum pump, pulling an initial vacuum of -15" of water column, allowing the spill container to sit for 30 seconds. Pulled another -15" of water column on spill container for 5 minutes and observed After 5 minutes gauge still showed more than -12" of Water Column.
(PER MANUFACTURES PROTOCOL)

Unl.	Tank #1 Fill	PASS	/	FAIL
	Tank #1 Vapor Recovery	PASS	/	FAIL
Pre	Tank #2 Fill	PASS	/	FAIL
	Tank #2 Vapor Recovery	PASS	/	FAIL
	Tank #3 Fill	PASS	/	FAIL
	Tank #3 Vapor Recovery	PASS	/	FAIL
	Tank #4 Fill	PASS	/	FAIL
	Tank #4 Vapor Recovery	PASS	/	FAIL

Leonard Equipment of Boise:

Tony Gallimore DATE 4-12-22
(Required Signature)

Tony gallimore
(Please Print Name Here)

(Signature) DATE _____

(Please Print Name Here)



OPW Installation and Maintenance Instructions

OPW DW-VAC-TEST Double Wall Spill Container Vacuum Test Instructions

IMPORTANT: Please read these warnings and use the assembly instructions completely and carefully before starting. Failure to do so may cause product failure, or result in environmental contamination due to liquid leakage into the soil, creating hazardous spill conditions.

IMPORTANT: The OPW DW-VAC-TEST Double Wall Vacuum Tester is pre-assembled for your convenience and ease of use. Check to make sure the unit is intact and undamaged and all parts have been supplied. Never substitute parts for those supplied. Doing so may cause product failure.

WARNING-DANGER: Using electrically operated equipment near gasoline or gasoline vapors may result in a fire or explosion, causing personal injury and property damage. Be sure that the working area is free from such hazards, and always use proper precautions.

NOTE: At all times when product is in the storage tank keep the riser pipe capped, so the vapors cannot escape into the environment.

Notice: OPW products must be used in compliance with applicable federal, state, and local laws and regulations. Product selection should be based on physical specifications and limitations and compatibility with the environment and material to be handled. All illustrations and specifications in this literature are based on the latest production information available at the time of publication. Prices, materials, and specification are subject to change at any time, and models may be discontinued at any time, in either case, without notice or obligation.

Standard Product Warranty

OPW warrants that products sold by it are free from defects in materials and workmanship for a period of one year from the date of manufacture by OPW (ECO products two years from date of manufacture.) Proof of purchase may be required. As the exclusive remedy under this limited warranty, OPW, will at its sole discretion, repair, replace, or issue credit for future orders for any product that may prove defective within the one year date of manufacture period (repairs, replacements, or credits may be subject to prorated warranty for remainder of the original warranty period, complete proper warranty claim documentation required.) This warranty shall not apply to any product that has been altered in any way, which has been repaired by any party other than a service representative authorized by OPW, or when failure is due to misuse, or improper installation or maintenance. OPW shall have no liability whatsoever for special, incidental or consequential damages to any party, and shall have no liability for the cost of labor, freight, excavation, clean up, downtime, removal, reinstallation, loss of profit, or any other cost or charges.

For any product certified to California 2001 standards, OPW warrants that product sold by it are free from defects in material and workmanship for a period of one year from date of manufacture or one year from date of registration of installation not to exceed 15 months from date of manufacture by OPW.

THIS WARRANTY IS IN LIEU OF ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, AND SPECIFICALLY THE WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE. THERE ARE NO WARRANTIES, WHICH EXTEND BEYOND THE DESCRIPTION ON THE FACE HEREOF.

OPERATION INSTRUCTIONS:

Step 1: (See Figure 2)

Attach vacuum pump to gauge assembly using the Quick Connect Fitting.




Figure 2

Step 2: (See Figure 3)

Make sure Test Valve is clean.

Connect Test Adaptor to Test Valve on OPW 1-3100 Series Double Wall Spill Container.

Step 3: (See Figure 2)

Make sure that the ball valve on the DW-VAC-TEST is open and use the pump to increase the vacuum to -15 inches of water column as displayed on vacuum gauge.

Step 4:

Close ball valve when -15 inches of water column is displayed on the vacuum gauge. Allow spill container to sit for 30 seconds. Refill spill container to -15 inches of water column.

Step 5:

Leave the spill container undisturbed for 5 minutes while under vacuum.

Step 6:

Check vacuum gauge after 5 minutes. If gauge does not show 12 or more inches of water column, the spill container has failed the test.




Figure 3

NOTE: Keep the temperature of the unit constant during testing. Fluctuations in temperature of the unit could result in bias results.



Fuel System Testing and Compliance
PO Box 1932
Twin Falls, ID 83303-1932

Date Created: 07/31/2023 11:30 AM

WORK ORDER

WO-5519

Customer

Name:	Leonard Petroleum Equipment of Boise	Contact:	Leonard Petroleum Equipment of Boise
Site Address:	Fletchers- Gas N Snacks 2212 10th St. Baker City, OR 97814		(208) 336-1155
Billing Address:	PO Box 170219 Boise, ID 83717		

Problem

Inspection Services DEQ Monthly Inspection/ Large conduct monthly DEQ inspection	Done
--	------

Annual Testing Services LLD Testing x 3 MLLD	Done
--	------

Annual Testing Services Precision Line Testing x 3 -	Done
--	------

Annual Testing Services Release Detection Testing EMC	Done
---	------

DEQ #: 4091

Arrival Time: 8:00 AM

Departure Time: 1:30 PM

Regular Hours: 5.5

Time Allocated to Each 3 hr Line Testing
Type of Testing for .5 hr LLD Testing
Billing: 1 hr Release Detection
1 hr Inspection, Cleanup, Misc.

Grey Absorbents: 8

Misc.Truck Supplies: 1

Additional Parts Used: 1 Nitrogen
1 PM2 Rig
1 LLD Tester

Assignment

Primary Tech:	Max Duffy
Secondary Tech(s):	Cade Jones
Priority:	Non Urgent
Work Duration:	9 hr 30 min
Appointment Type:	Scheduled
Promised Arrival Time:	08/02/2023 8:00 AM

Work Done

Description:

Fletchers Gas and Snack

Arrived and informed the employees of the testing were there to do. Setup at dispenser 1-2. Ran precision line tests on the RuL, PuL, and DSL product lines. Used the ball valves to isolate for each line test. Sent the test data off Leighton O'Brien. Tested the MLLD's for the RuL, PuL, and DSL product lines. All three leak detectors passed the testing.

Got the keys for the padlocks. Pulled the probes for all tanks and set off the overfill alarm. There are no sensors in use at this site. Obtained setup reports and alarm printouts from the ATG. Exterior Overfill Alarm is just a loud speaker box that can be heard from the tank pad. There's no light on the box. Alarm is behind a wall that was an addition onto the original c store building. It can still be heard loudly. The ATG console, tank probes, and overfill alarm passed the testing.

Inspected all of the spill buckets, STP sumps, and UDC's. Cleaned and dried some blended fuels in the spill buckets and STP sumps. Cleaned up and took pictures.

Invoice

No Invoice

[illegible]

Attachments

08/02/2023 | Signature | Work Order Signature Aug 2, 2023 2:22 PM

Times Posted

Primary Tech:	En Route	Work
Max Duffy	-	552:03
Secondary Tech(s):		
Cade Jones	-	-

IN-TANK SETUP

T 1:REGULAR
PRODUCT CODE : 1
THERMAL COEFF : .000700
TANK DIAMETER : 95.00
TANK PROFILE : 4 PTS
FULL VOL : 12000
71.3 INCH VOL : 9445
47.5 INCH VOL : 5812
23.8 INCH VOL : 2338

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0

MAX OR LABEL VOL: 12000
OVERFILL LIMIT : 90%
10800
HIGH PRODUCT : 95%
11400
DELIVERY LIMIT : 20%
2400

LOW PRODUCT : 1000
LEAK ALARM LIMIT: 8
SUDDEN LOSS LIMIT: 25
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 30%
: 3600

LEAK MIN ANNUAL : 95%
: 11400

PERIODIC TEST TYPE
STANDARDANNUAL TEST FAIL
ALARM DISABLEDPERIODIC TEST FAIL
ALARM DISABLEDGROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN
PUMP THRESHOLD : 10.00%

T 2:ULTIMA
PRODUCT CODE : 2
THERMAL COEFF : .000700
TANK DIAMETER : 95.00
TANK PROFILE : 4 PTS
FULL VOL : 10200
71.3 INCH VOL : 8264
47.5 INCH VOL : 5086
23.8 INCH VOL : 2045

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0

MAX OR LABEL VOL: 10200
OVERFILL LIMIT : 90%
9180
HIGH PRODUCT : 95%
9690
DELIVERY LIMIT : 20%
2040

LOW PRODUCT : 848
LEAK ALARM LIMIT: 8
SUDDEN LOSS LIMIT: 25
TANK TILT : 1.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 30%
: 3060

LEAK MIN ANNUAL : 95%
: 9690

PERIODIC TEST TYPE
STANDARDANNUAL TEST FAIL
ALARM DISABLEDPERIODIC TEST FAIL
ALARM DISABLEDGROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN
PUMP THRESHOLD : 10.00%

T 3:DIESEL
PRODUCT CODE : 3
THERMAL COEFF : .000450
TANK DIAMETER : 95.00
TANK PROFILE : 4 PTS
FULL VOL : 8000
71.3 INCH VOL : 6493
47.5 INCH VOL : 3996
23.8 INCH VOL : 1607

FLOAT SIZE: 4.0 IN.

WATER WARNING : 2.0
HIGH WATER LIMIT: 3.0

MAX OR LABEL VOL: 8000
OVERFILL LIMIT : 90%
7200
HIGH PRODUCT : 95%
7600
DELIVERY LIMIT : 20%
1600

LOW PRODUCT : 667
LEAK ALARM LIMIT: 8
SUDDEN LOSS LIMIT: 25
TANK TILT : 0.00
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 30%
: 2400

LEAK MIN ANNUAL : 95%
: 7600

PERIODIC TEST TYPE
STANDARDANNUAL TEST FAIL
ALARM DISABLEDPERIODIC TEST FAIL
ALARM DISABLEDGROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN
PUMP THRESHOLD : 10.00%

SYSTEM SETUP

AUG 2, 2023 11:12 AM

SYSTEM UNITS

U.S.
SYSTEM LANGUAGE
ENGLISH
SYSTEM DATE/TIME FORMAT
MON DD YYYY HH:MM:SS xM

GAS AND SNACK
2212 TENTH STREET
BAKER CITY,OR
5415236984

SHIFT TIME 1 : DISABLED
SHIFT TIME 2 : DISABLED
SHIFT TIME 3 : DISABLED
SHIFT TIME 4 : DISABLED

TANK PER TST NEEDED WRN
DISABLED
TANK ANN TST NEEDED WRN
DISABLED
LINE PER TST NEEDED WRN
DISABLED
LINE ANN TST NEEDED WRN
DISABLED

PRINT TO VOLUMES
ENABLED

TEMP COMPENSATION
VALUE (DEG F): 60.0
STICK HEIGHT OFFSET
DISABLED

H-PROTOCOL DATA FORMAT
HEIGHT
DAYLIGHT SAVING TIME
ENABLED
START DATE
APR WEEK 1 SUN
START TIME
2:00 AM
END DATE
OCT WEEK 6 SUN
END TIME
2:00 AM

RE-DIRECT LOCAL PRINTOUT
DISABLED

EURO PROTOCOL PREFIX
S

SYSTEM SECURITY
CODE : 000000

CUSTOM ALARM LABELS
DISABLED

COMMUNICATIONS SETUP

PORT SETTINGS:

COMM BOARD : 2 (RS-232)
BAUD RATE : 9600
PARITY : EVEN
STOP BIT : 1 STOP
DATA LENGTH: 7 DATA
RS-232 SECURITY
CODE : DISABLED

AUTO TRANSMIT SETTINGS:

AUTO LEAK ALARM LIMIT
DISABLED
AUTO HIGH WATER LIMIT
DISABLED
AUTO OVERFILL LIMIT
DISABLED
AUTO LOW PRODUCT
DISABLED
AUTO THEFT LIMIT
DISABLED
AUTO DELIVERY START
DISABLED
AUTO DELIVERY END
DISABLED
AUTO EXTERNAL INPUT ON
DISABLED
AUTO EXTERNAL INPUT OFF
DISABLED
AUTO SENSOR FUEL ALARM
DISABLED
AUTO SENSOR WATER ALARM
DISABLED
AUTO SENSOR OUT ALARM
DISABLED

RS-232 END OF MESSAGE
DISABLED

LEAK TEST METHOD

TEST CSLD : ALL TANK
Pd = 99%
CLIMATE FACTOR:MODERATE

REPORT ONLY:
DISABLED

TST EARLY STOP:ENABLED

LEAK TEST REPORT FORMAT
ENHANCED

LIQUID SENSOR SETUP

NONE

EXTERNAL INPUT SETUP

NONE

OUTPUT RELAY SETUP

R 1:OVERFILL ALARM
TYPE:
STANDARD
NORMALLY OPEN

IN-TANK ALARMS
ALL:OVERFILL ALARM

SOFTWARE REVISION LEVEL
VERSION 423.01
SOFTWARE# 346423-100-B
CREATED - 02.06.21.13.18

S-MODULE# 330161-003-A
SYSTEM FEATURES:
PERIODIC IN-TANK TESTS
ANNUAL IN-TANK TESTS
CSLD

GAS AND SNACK
2212 TENTH STREET
BAKER CITY,OR
5415236984

AUG 2. 2023 11:12 AM

SYSTEM STATUS REPORT

T 2:DELIVERY NEEDED

GAS AND SNACK
2212 TENTH STREET
BAKER CITY,OR
5415236984

AUG 2. 2023 11:12 AM

INVENTORY REPORT

T 1:REGULAR

VOLUME = 2769 GALS
ULLAGE = 9231 GALS
90% ULLAGE= 8031 GALS
TC VOLUME = 2755 GALS
HEIGHT = 26.81 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.4 DEG F

T 2:ULTIMA

VOLUME = 1862 GALS
ULLAGE = 8338 GALS
90% ULLAGE= 7318 GALS
TC VOLUME = 1852 GALS
HEIGHT = 22.19 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 67.4 DEG F

T 3:DIESEL

VOLUME = 3564 GALS
ULLAGE = 4436 GALS
90% ULLAGE= 3636 GALS
TC VOLUME = 3548 GALS
HEIGHT = 43.35 INCHES
WATER VOL = 12 GALS
WATER = 0.78 INCHES
TEMP = 69.9 DEG F

***** END *****

GAS AND SNACK
2212 TENTH STREET
BAKER CITY,OR
5415236984

AUG 2. 2023 11:12 AM

CSLD TEST RESULTS

AUG 2. 2023 11:12 AM

T 1:REGULAR

PROBE SERIAL NUM 811476

0.2 GAL/HR TEST

PER: AUG 2. 2023 PASS

T 2:ULTIMA

PROBE SERIAL NUM 811477

0.2 GAL/HR TEST

PER: AUG 2. 2023 PASS

T 3:DIESEL

PROBE SERIAL NUM 811478

0.2 GAL/HR TEST

PER: AUG 2. 2023 PASS

***** END *****

GAS AND SNACK
2212 TENTH STREET
BAKER CITY,OR
5415236984

AUG 2. 2023 11:12 AM

LIQUID STATUS

AUG 2. 2023 11:12 AM

NONE

***** END *****

Wayne

Vaporless Manufacturing, Inc.
LDT-890 Leak Detector Tester
Installation & Operation Protocol
October 1st, 2008

MODEL LDT-890AF/RF
LEAK DETECTOR TESTER
SERIAL NO. 15014

WARNING: DO NOT DISASSEMBLE
FACTORY RECALIBRATION REQUIRED EVERY TWO YEARS

LDT-890 / LDT-890 LAF FACTORY RECALIBRATION SERVICES
PERFORMED ON 7/23/22 BY W.E.

TO ENSURE VALID TEST RESULTS, UNIT REQUIRES FACTORY
RECALIBRATION EVERY TWO YEARS.

Gallons to Minutes Conversion Chart

Gallons Per Hour	Min. Per Minute	Min. Per 1/2 Minute
1.0	60	30
1.1	66	33
1.2	72	36
1.3	78	39
1.4	84	42
1.5	90	45
1.6	96	48
1.7	102	51
1.8	108	54
1.9	114	57
2.0	120	60
2.1	126	63
2.2	132	66
2.3	138	69
2.4	144	72
2.5	150	75
2.6	156	78
2.7	162	81
2.8	168	84
2.9	174	87
3.0	180	90
3.1	186	93
3.2	192	96
3.3	198	99
3.4	204	102
3.5	210	105
3.6	216	108
3.7	222	111
3.8	228	114
3.9	234	117
4.0	240	120
4.1	246	123
4.2	252	126
4.3	258	129
4.4	264	132
4.5	270	135
4.6	276	138
4.7	282	141
4.8	288	144
4.9	294	147
5.0	300	150

Rwl

[illegible]

LDT-890 / LDT-890 VAE FACTORY RECALIBRATION SERVICES
PERFORMED ON 7/22/22 BY WAE
TO ENSURE VALID TEST RESULTS, UNIT REQUIRES FACTORY
RECALIBRATION EVERY TWO YEARS.

Gallons to Military Conversion Chart

Gallons Per Hour	MI. Per Minute	MI. Per 1/2 Minute
1.6	101	41
1.8	112	45
2.0	123	49
2.2	134	53
2.4	145	57
2.6	156	61
2.8	167	65
3.0	178	69
3.2	189	73
3.4	200	77
3.6	211	81
3.8	222	85
4.0	233	89
4.2	244	93
4.4	255	97
4.6	266	101
4.8	277	105
5.0	288	109
5.2	299	113
5.4	310	117
5.6	321	121
5.8	332	125
6.0	343	129
6.2	354	133
6.4	365	137
6.6	376	141
6.8	387	145
7.0	398	149
7.2	409	153
7.4	420	157
7.6	431	161
7.8	442	165
8.0	453	169
8.2	464	173
8.4	475	177
8.6	486	181
8.8	497	185
9.0	508	189
9.2	519	193
9.4	530	197
9.6	541	201
9.8	552	205
100	563	209

Rwl

----- IN-TANK ALARM -----
T 1:REGULAR
HIGH WATER WARNING
AUG 2, 2023 12:11 PM

----- IN-TANK ALARM -----
T 1:REGULAR
HIGH WATER ALARM
AUG 2, 2023 12:16 PM

----- IN-TANK ALARM -----
T 1:REGULAR
OVERFILL ALARM
AUG 2, 2023 12:17 PM

----- IN-TANK ALARM -----
T 1:REGULAR
HIGH PRODUCT ALARM
AUG 2, 2023 12:17 PM

----- IN-TANK ALARM -----
T 2:ULTIMA
HIGH WATER ALARM
AUG 2, 2023 11:51 AM

----- IN-TANK ALARM -----
T 2:ULTIMA
HIGH WATER WARNING
AUG 2, 2023 11:51 AM

----- IN-TANK ALARM -----
T 2:ULTIMA
HIGH PRODUCT ALARM
AUG 2, 2023 11:51 AM

----- IN-TANK ALARM -----
T 2:ULTIMA
OVERFILL ALARM
AUG 2, 2023 11:52 AM

----- IN-TANK ALARM -----
T 3:DIESEL
HIGH WATER ALARM
AUG 2, 2023 11:37 AM

GAS AND SNACK
2212 TENTH STREET
BAKER CITY,OR
5415236984

AUG 2, 2023 11:40 AM

SYSTEM STATUS REPORT

T 2:DELIVERY NEEDED

T 3:HIGH WATER WARNING

----- IN-TANK ALARM -----
T 3:DIESEL
HIGH PRODUCT ALARM
AUG 2, 2023 11:41 AM

----- IN-TANK ALARM -----
T 3:DIESEL
OVERFILL ALARM
AUG 2, 2023 11:42 AM

GAS AND SNACK
2212 TENTH STREET
BAKER CITY,OR
5415236984

AUG 2, 2023 11:42 AM

SYSTEM STATUS REPORT

T 2:DELIVERY NEEDED

T 3:OVERFILL ALARM

T 3:HIGH PRODUCT ALARM



Wayne



MONTON O'BRIEN
PM2

Mr. Clean
NON-ETHANOL
DEGRASSANT
405100-AD

PWL







DSL

MODEL #99 LD-2000
S/N 23011351





PUL





MODEL #99 LD-2000
S/N 23011350

RUZ



RVL

MODEL #99 LD2000
S/N 22121704







1-2

Gilbarco®

AUG 2, 2023 3:37:30 PM
T 2: DELIVERY NEEDED

ALARM



WARNING



POWER



EMC™

BASIC MONITORING CONSOLE

GAS AND SNACK
2212 TENTH STREET
BAKER CITY,OR
5415236984

AUG 2. 2023 3:37 PM

SYSTEM STATUS REPORT

T 2:DELIVERY NEEDED

GAS AND SNACK
2212 TENTH STREET
BAKER CITY,OR
5415236984

AUG 2. 2023 3:37 PM

INVENTORY REPORT

T 1:REGULAR

VOLUME = 5189 GALS
ULLAGE = 6811 GALS
90% ULLAGE= 5611 GALS
TC VOLUME = 5141 GALS
HEIGHT = 43.31 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 73.1 DEG F

T 2:ULTIMA

VOLUME = 1822 GALS
ULLAGE = 8378 GALS
90% ULLAGE= 7358 GALS
TC VOLUME = 1812 GALS
HEIGHT = 21.84 INCHES
WATER VOL = 24 GALS
WATER = 1.06 INCHES
TEMP = 67.5 DEG F

T 3:DIESEL

VOLUME = 3515 GALS
ULLAGE = 4485 GALS
90% ULLAGE= 3685 GALS
TC VOLUME = 3499 GALS
HEIGHT = 42.87 INCHES
WATER VOL = 22 GALS
WATER = 1.21 INCHES
TEMP = 70.0 DEG F

* * * * * END * * * * *

GAS AND SNACK
2212 TENTH STREET
BAKER CITY,OR
5415236984

AUG 2. 2023 3:37 PM

LIQUID STATUS

AUG 2. 2023 3:37 PM

NONE

* * * * * END * * * * *

Gilbarco®

AUG 2, 2023 11:12:15 AM
T 2: DELIVERY NEEDED


ALARM



WARNING



POWER



EMC™

BASIC MONITORING CONSOLE

From: [UST Duty Officer * DEQ](#)
To: marla.fletcher@stores.com
Cc: [UST Duty Officer * DEQ](#); [FOSS Diana * DEQ](#)
Subject: Fletcher Inspections - 4091, 11826, 2019
Date: Friday, March 21, 2025 10:17:30 AM
Attachments: [image001.png](#)
[image002.png](#)
[image003.png](#)
[image004.png](#)
[Inv_283072_from_Leonard_Petroleum_Equipment_of_Boise_LLC_27732.pdf](#)
[2024-FC-9618 \(edited\) issued to 18826.pdf](#)
[2025-FC-9798 issued to 2019.pdf](#)
[2024-FC-9608 issued to 4091.pdf](#)

Howdy Marla –

It has been some time... Sorry to have been so delayed. The world keeps turning and work continues to pile up.

As things sit... I believe we have all corrective actions work completed at the Baker City locations. Besides penalties being received, DEQ has received completed corrective action documentation. Thank you.

Please see the attached document citations with reduced penalties.

4091 – Reduced penalty amounts.

11826 – Found '22 records and removed violations. Reduced penalty amounts.

2019 – Vale

After the inspection, I received all sorts of very useful information that addressed my concerns about the cathodic protection system repair, dispenser/containment sump installation, etc. Those violations have been removed from the attached citation and I appreciate your efforts in obtaining and providing me with that data.

There are two additional follow ups which are needed to complete the failed testing of equipment discovered in Feb2022. It appears testing was performed and repairs completed in April 2022 (invoice attached). Please submit post installation testing of the overfill and spill buckets and the repairs performed on the tank monitor in 2024 inspection that called out for failed indicators at the ATG.

Overfill - 25Feb2022 – Fuel System Testing co.

Overfill Prevention Inspection

Identify Tank (number, product type, etc);		1PuL	2RuLe10	3BioDSL	4DSL		
Make and model		OPW71SO	OPW71SO	EMCA1100	EMCA1100		
Flapper Valve	Shuts off flow at 95% tank capacity	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Float moves freely, proper orientation, poppet moves into flow path and operates per mfg. design	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	If present, bypass valve in the drop tube is open	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Inspection Results (P = pass, F = fail)		P	P	F	F	—	—

Spill bucket - 25Feb2022

Spill Bucket Testing (passes if water level drops less than 1/8 inch, minimum test time 1 hour)

☐ Spill bucket is double-walled and monitored monthly (must be recorded on 30-day walkthrough inspection form)

Identify tank (tank number, product type, etc.)		1PuL	2RuLe10	3BioDSL	4DSL		
Liquid and debris removed from spill bucket*		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
* Liquid and debris must be disposed of properly							
Water was filled 1.5 inches from top of spill bucket		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Starting water level height (inches)		15" WC	15" WC	15" WC	9.5		
Starting test time		2:16	2:11	2:06	3:51		
Ending test time		2:17	2:12	2:07	4:28		
Ending water level height (inches)		15" WC	15" WC	15" WC	8		
Level change		0	0	0	-1.5"		
For vacuum testing, 30-inch water column was applied and at least 26-inch water column was maintained after 1 minutes or mfg. procedures		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Test Results (P = pass, F = fail)		P	P	P	F	—	—

It appears that that failed spill bucket and overfill were replaced – please send the post installation inspection results to close this matter (refer to screenshot below)

	Net 30	JLR	4/13/2022		FLETCHERS S...	4/13/2022
--	--------	-----	-----------	--	----------------	-----------

Quantity	Description	Unit Price	Extended Price
	Diesel Spill Bucket and Bio-Diesel Flapper Valve Replacements		
1	OPW 1C-3112P Double Wall Spill Bucket	1,465.56	1,465.56T
2	OPW 61T-7368 Straight drop tube	661.93	1,323.86T
1	OPW 206122 4" Riser thread adapter long	146.00	146.00T
1	Black Pipe Riser Nipple 4" X 6"	45.00	45.00T
	Construction Labor and specialty tools include, Sawcut/Jackhammer/Concrete Removal, mobilize tow behind air compressor, jackhammer, hose and bits, to break out concrete, excavate and remove rebar. Install spill bucket, measure and field cut drop tube. Disposal of concrete and earthen materials from site. Backfill with pea gravel, pour back concrete. Mileage/Travel/Labor	3,480.97	3,480.97

There appears to have been a few LEDs that were not functional and the monitor was failed for. Did these get replaced? If so, please send those details

- ☒ All probes have been visually inspected for any damage, including kinks or breaks in the cable, floats move freely.
- ☒ ATG setup meets compliance standards for this site: (leak minimum volume and duration 0.2 gph, 0.1 gph, alarms enabled, etc.)
- ☒ All probe fuel and water float alarms and readings on ATG agree with corresponding measurement of the probe itself.
- ☒ Overfill Alarm activates at no more than 90% tank capacity.
- ☒ Overfill Alarm can be seen and heard by delivery driver .
- ☒ Overfill Alarm activates in test mode.

Test Results (P = Pass, F = Fail)

F	F	F	F	—	—	—
---	---	---	---	---	---	---


Corrections/Comments: List any issues that did not fit on page one

Description of actions taken if items tested or inspected were not acceptable

The probes and ATG console fail overall due to the power light on the console not functioning properly. The overfill alarm passed the testing. The probes are in good condition and work as they should. There are no sensors connected to or setup on the console.

Tester's Signature

Date: 13 August 2024



Page 3 of 3

Appreciate your help sorting these facilities out.

Have a nice day,

Dylan Eckert
Inspector, Underground Storage Tanks
DEQ - Eugene, Land Quality Division
165 E. 7th Ave Suite 100
Eugene, OR 97401-3049
C 541-215-2368

Messages to and from this e-mail address may be available to the public under Oregon Public Records Law.

Sign-up for UST Program Updates:

https://service.govdelivery.com/accounts/ORDEQ/subscriber/new?topic_id=ORDEQ_546

The UST Program. 60-Minute story: <https://www.youtube.com/watch?v=leYoLtsQ2WQ>

Dylan Eckert
Inspector, Underground Storage Tanks

DEQ - Eugene, Land Quality Division
165 E. 7th Ave Suite 100
Eugene, OR 97401-3049
C 541-215-2368

Messages to and from this e-mail address may be available to the public under Oregon Public Records Law.

Sign-up for UST Program Updates:

https://service.govdelivery.com/accounts/ORDEQ/subscriber/new?topic_id=ORDEQ_546

The UST Program. 60-Minute story: <https://www.youtube.com/watch?v=leYoLtsQ2WQ>

From: [UST Duty Officer * DEQ](#)
To: marla.fletcherstores.com
Subject: RE: 4091- Gas & Snack Inspection Follow-up
Date: Wednesday, October 9, 2024 11:17:00 AM
Attachments: [image001.png](#)
[2024-FC-9608 issued to 4091.pdf](#)
[image002.png](#)

Hello Marla,

I am following up on the inspection completed by Dylan Eckert on 8/30/24 for **facility 4091 Gas and Snack**.

Please review the attached field citation. **The deadline for payment of the \$1500 fine and corrective actions is 11/9/24.**



Emily Litke (she/her)
Duty Officer, Underground Storage Tanks
DEQ Headquarters, Land Quality Division
700 NE Multnomah Street, Suite 600
Portland OR 97232-4100
503-806-9516
Emily.LITKE@deq.oregon.gov

From: UST Duty Officer * DEQ <UST.DutyOfficer@DEQ.oregon.gov>
Sent: Wednesday, October 2, 2024 1:51 PM
To: UST Duty Officer * DEQ <UST.DutyOfficer@DEQ.oregon.gov>; marla.fletcherstores.com <marla@fletcherstores.com>
Cc: DROUIN Mark * DEQ <Mark.DROUIN@deq.oregon.gov>
Subject: 4091- Gas & Snack Inspection Follow-up

Good Day Marla -

Thank you for allowing me to inspect your facility. I appreciate your equipment investment / upgrade from the previous 2022 inspection which noted Tolkiem turbines with off-turbine leak detectors which was corrected in 2023.

Please direct your responses to ust.dutyofficer@deq.oregon.gov

There were some paperwork issues that need to be submitted. **Please submit these documents by this Friday the 4th of October 2024.** They will be reviewed and any “violations” noted below will be removed for a final evaluation.

Dispenser ½ - needs to be cleaned out.



Given the volume is well below any penetrations, I don't think it is necessary to perform an integrity test... unless the volume has increased from the photograph above..... this is presumably from filter replacement drips and maybe some nozzle leakage.

Please submit photographs from all dispenser sumps within 7 days to confirm they are all clean and dry.

This email has two intended recipients: you (permittee) and our enforcement/follow-up team. Because of this split audience, there might be some jargon used which is for DEQ internal purposes. I'll be asking for paperwork/documentation by a specific time and will state the violation/corrective action if the work is not submitted or was not performed. Please note the deadline for submissions.... After that deadline has passed, the inspection is closed for additional information and a determination will be assessed given the available information. By not submitting the requested documents, you might be assessed citations for items which were completed but DEQ simply does not have evidence for.

This team will work with me on documents you submit or corrective actions completed to ensure the work is sufficient to close the inspection.

Violation

- 1 – Failure to test spill prevention equipment at least every 3 years. (C1e)
- 2 – Failure to perform testing of spill and overfill prevention equipment prior to 01oct2020. (C1f)
- 3 - Failure to test overfill prevention equipment at least every 3 years after initial test. (C2c)
- 4 – Failure to perform compliance testing in 2022 – lines, leak detectors, release detection

equipment. (H2.7, H2.9, G5)

5 – Failure to provide Oregon recognized Class A/B operator training. (A5a)

Corrective Action.

1. Submit all testing documents regarding the testing of spill prevention and overfill prevention equipment prior to 04 Oct 2024. Equipment must be inspected/tested **prior to 20 Oct 2024** if currently out of compliance.
2. Same as 1.
3. Same as 1.
4. Testing of lines and leak detectors and monitor completed on 03 Aug 2023 and 13 Aug 2024. No additional testing requested.
5. Submit Class A/B operator training that is Oregon recognized **prior to 20 Oct 2024.**
<https://www.oregon.gov/deq/tanks/pages/ust-training.aspx>

I appreciate your cooperation working with DEQ to maintain your system in compliance with the UST Compliance Rules.

Dylan Eckert
Inspector, Underground Storage Tanks
DEQ - Eugene, Land Quality Division
165 E. 7th Ave Suite 100
Eugene, OR 97401-3049
C 541-215-2368

Messages to and from this e-mail address may be available to the public under Oregon Public Records Law.

Sign-up for UST Program Updates:

https://service.govdelivery.com/accounts/ORDEQ/subscriber/new?topic_id=ORDEQ_546

The UST Program. 60-Minute story: <https://www.youtube.com/watch?v=leYoLtsQ2WQ>

Dylan Eckert
Inspector, Underground Storage Tanks
DEQ - Eugene, Land Quality Division

165 E. 7th Ave Suite 100
Eugene, OR 97401-3049
C 541-215-2368

Messages to and from this e-mail address may be available to the public under Oregon Public Records Law.

Sign-up for UST Program Updates:

[https://service.govdelivery.com/accounts/ORDEQ/subscriber/new?
topic_id=ORDEQ_546](https://service.govdelivery.com/accounts/ORDEQ/subscriber/new?topic_id=ORDEQ_546)

The UST Program. 60-Minute story: <https://www.youtube.com/watch?v=leYoLtsQ2WQ>



GAS AND SNACK



Google

@ Google

2212 10TH ST, BAKER CITY, OR 97814

82472 ✓

293520

CEM_FacilityIdentifier=20746 UST (4091)

Stationary

Contact Info



Marla Gardner

Fletcher Petroleum



208-377-0024

Inspection Info



\$ 1,100.00

\$ 1,100.00

\$ 0.00

Penalty

2024-FC-9608

UST - Field Citation

\$ 1,100.00

1 Results

Add Penalty

Send to FIMS

Payment

Check by Mail 112112-3

4/22/2025

47494

\$ 1,100.00

Type

Check by Mail



Amount

1100

E-Payment Confirmation#

E-Payment Settle Date

mm/dd/yyyy



Ref#

47494

Payment Date

04/22/2025



Comments

2024-FC-9608

(Remaining Length: 3988)