

PERMITTEE NAME/ADDRESS:

NAME: James Miller, G-I Holdings Inc.

ADDRESS: One Campus Drive  
Parsippany, NJ 07054

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

## DISCHARGE MONITORING REPORT (DMR)

PERMIT NUMBER

DISCHARGE NUMBER


FACILITY: GAF/Mattel Site Groundwater Treatment System

LOCATION: 8585 SW Hall Blvd  
Beaverton, OR

## MONITORING PERIOD

FROM 25 | 04 | 01 TO 25 | 04 | 30

NO DISCHARGE ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNIT			
Flow (discharge)	SAMPLE MEASUREMENT		5,984,796	Gallons this period	137	139	140	Gallons per minute	0	1/30	N/A
	PERMIT REQUIREMENT				----	----	----				
Temperature	SAMPLE MEASUREMENT						14.60	°C	0	1/30	Grab
	PERMIT REQUIREMENT				----	----	----				
pH	SAMPLE MEASUREMENT						7.77	pH units	0	1/30	Grab
	PERMIT REQUIREMENT				6	----	9				
Phosphate	SAMPLE MEASUREMENT							µg/L	0	1/90	Grab
	PERMIT REQUIREMENT				----	----	130				
Trichloroethene (TCE)	SAMPLE MEASUREMENT							µg/L	0	1/90	Grab
	PERMIT REQUIREMENT				----	----	50				
Other VOCs	SAMPLE MEASUREMENT							µg/L	0	1/90	Grab
	PERMIT REQUIREMENT				----	----	70				
Free (WAD) Cyanide (Weak Acid Dissociable)	SAMPLE MEASUREMENT						ND (5.0)	µg/L	0	1/30	Grab
	PERMIT REQUIREMENT				----	----	5.2				
NAME / TITLE PRINCIPAL EXECUTIVE OFFICER		<small>I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.</small>				 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE	DATE		
James Miller								(470) 599-7019	25   05   10		
TYPED OR PRINTED						AREA CODE NUMBER		YEAR MO DAY			

COMMENT AND EXPLANATION OF ANY VIOLATIONS

(Reference all attachments here)

ND = Not detected above laboratory reporting limit.