



State of Oregon
Department of
Environmental
Quality

Program Enforcement No. 2025-FC-9980

This section for
DEQ use only

Department of Environmental Quality
Underground Storage Tank Program

Field Citation
For UST Violations

Page 1 of 3

DEQ Information		UST Facility Information	
Inspection Date:	09/02/2025	Facility ID#:	7143
Inspector:	Diana Foss	Facility Name:	JERRY'S GAS & FOOD MART LLC
DEQ Office:	DEQ Headquarters, Land Quality Division 700 NE Multnomah Street, Suite 600	Facility Address:	203 W Bishop Way, Brownsville, Oregon 97327-2001
Phone #:	503-869-0770	County:	Linn

Oregon DEQ inspected the facility listed above and identified the UST violations listed on page 3 of this Field Citation.

Field Citation Issued:	<input type="checkbox"/> In Person	<input checked="" type="checkbox"/> By Email	<input type="checkbox"/> Both	Date Issued: 09/04/2025
Facility Representative Present During Inspection:	<input type="checkbox"/> Permittee <input type="checkbox"/> Owner <input type="checkbox"/> Other			
Name of Permittee or Owner:	Hargun Inc			
Mailing Address:	PO Box 37 , Brownsville Oregon 97327			
Field Citation Penalty – See Page 3 for a detailed listing of each violation.				\$ 1350

Check payable to: DEQ Financial Services LBX3615; P.O. Box 3615; Portland OR 97208-3615

Or pay online through your YDO account

This Field Citation is issued in accordance with the requirements for the expedited enforcement of Underground Storage Tank (UST) violations, OAR 340-150-0250.

Owner or Permittee should select Option 1 or Option 2 below and return a signed copy of this form to DEQ by the following date: 10/06/2025

DEQ Revenue Section
700 NE Multnomah St. #600
Portland, Oregon 97232

Check one option

- ☐ **Option 1** - I acknowledge that the listed violation(s) have occurred, and I am remitting the listed field citation penalty.
- ☐ **Option 2** - I do not want to participate in the expedited enforcement process and understand that my file will be referred to the Department's Office of Compliance and Enforcement for formal enforcement action.

Name:	Owner / Permittee
Signature:	Date:

Important

Read pages 2 and 3 for more information about your options and a detailed listing of violations and compliance requirements.

Field Citation Requirements

The permittee or owner should select Option 1 or Option 2 and return a signed copy of Page 1 of the Field Citation form within thirty (30) days of issuance of the Field Citation. If the permittee or owner fails to sign and send Page 1 of the Field Citation form back or pay the penalty within thirty days, Option 1 expires, the Field Citation will serve as a Pre-Enforcement Notice (PEN) and the permittee and owner will be subject to formal enforcement, including the imposition of civil penalties in accordance with OAR Chapter 340, Division 12.

The permittee or owner must complete the actions required to correct the violations listed on the Field Citation by the date specified to prevent further enforcement action by DEQ.

Option 1:

By checking Option 1, the permittee or owner acknowledges that the violations listed on Page 3 of this Field Citation have occurred and agrees to pay the established penalty.

By submitting payment of the penalty amount, the responding permittee or owner agrees to accept the field citation as a final order of the Environmental Quality Commission (commission) and waives any and all rights and objections to the form, content, manner of service and timeliness of the Field Citation; to a contested case hearing and judicial review of the Field Citation [OAR 340-150-0250(6)]; and to service of a copy of this Final Order (*i.e.*, no other copy will be provided).

Upon the Department's receipt of payment of the penalty amount set forth in the Field Citation, the Field Citation becomes a Final Order of the Commission that:

1. Imposes upon the permittee or owner a civil penalty in the amount listed on Page 1 of this Field Citation; and
2. Requires the permittee or owner to satisfactorily complete the requirements and actions necessary to correct the violations documented by the dates set forth on Page 3 of this Field Citation.

Failure by the permittee or owner to complete the actions set forth on Page 3 of the Field Citation by the specified date violates the Commission Order and subjects the permittee and owner to a formal enforcement action, including the imposition of additional civil penalties.

Option 2:

The permittee or owner may deny that the violations as listed on Page 3 of this Field Citation have occurred or contest the Field Citation process by checking Option 2 and submitting to the Department a signed copy of Page 1 of the Field Citation. In that event, the Field Citation will serve as a Pre-Enforcement Notice (PEN) and the permittee and owner will be subject to formal enforcement for those violations set forth in the Field Citation, including the imposition of civil penalties in accordance with OAR Chapter 340, Division 12. Civil penalties that will be imposed by the formal enforcement process will exceed the Field Citation penalties for the same violation(s).

The Department appreciates your cooperation and efforts to comply with the regulations for underground storage tank systems.

UST FIELD CITATION

DATE ISSUED: 09/04/2025

PROGRAM ENFORCEMENT No.: 2025-FC-9980

FACILITY ID: 7143

Page 3 of 3

Violation #1: *TCR:	(J5.6) Failing to conduct a leak test every 30 days.		
Corrective Action:	Record tank release detection tests every month. Submit October test to DEQ.		
Rule Citation: OAR 340-150-0450(2)	Penalty Amount: \$ 150	Correct Violation by: 10/06/2025	Date Violation Corrected:
Violation #2: *TCR:	Failure to install spill prevention equipment such as a spill bucket or catchment basin. Failure to repair or replace spill prevention device that is defective, damaged or may have been tampered with in a manner that prevents proper operation.		
Corrective Action:	Replace unleaded and diesel spill buckets. Submit passing hydro tests to DEQ.		
Rule Citation: OAR 340-150-0310(1)	Penalty Amount: \$ 500	Correct Violation by: 10/06/2025	Date Violation Corrected:
Violation #3: *TCR:	Failure to install, operate, maintain or calibrate RD equipment per manufacturer's instructions, including service checks for operability or running condition (i.e. device has been incorrectly installed, is defective, damaged, or may have been tamper		
Corrective Action:	No further corrective action		
Rule Citation: OAR 340-150-0400(1)(c)	Penalty Amount: \$ 100	Correct Violation by:	Date Violation Corrected:
Violation #4: *TCR:	Failure to perform annual line tightness test on pressurized piping or test cannot detect a 0.1 gph leak rate at 1.5 times operating pressure		
Corrective Action:	No further corrective action		
Rule Citation: OAR 340-150-0410(3)	Penalty Amount: \$ 300	Correct Violation by:	Date Violation Corrected:
Violation #5: *TCR:	Failure to perform an annual test of operation of line leak detector or annual test has not been conducted in accordance with manufacturer standards.		
Corrective Action:	No further corrective action		
Rule Citation: OAR 340-150-0410(2)(c)	Penalty Amount: \$ 300	Correct Violation by:	Date Violation Corrected:
Violation #6: *TCR:			
Corrective Action:			
Rule Citation: OAR	Penalty Amount: \$	Correct Violation by:	Date Violation Corrected:
Total Penalty Amount: \$ 1350			

YOU MUST CORRECT THE VIOLATIONS AS REQUIRED, ENTER THE DATES CORRECTED, SIGN THE STATEMENT BELOW, AND**RETURN THIS FORM TO THE DEQ INSPECTOR LISTED ON PAGE 1 ON OR BEFORE: 10/06/2025****Retain a copy of this form and all documentation of corrective actions for your records.***I hereby certify that the UST violations noted above have been corrected:* _____ / _____

Permittee/Owner Signature

Date