



13600 NE 10TH AVE, VANCOUVER WA 98685
PHONE: 360-574-8400 FAX: 360-574-7607

August 29th, 2023

Tanner Wingfield
Konell Construction & Demolition Corp.
36000 Industrial Way
Sandy, OR 97055

Re: Asbestos Abatement Completion Letter for:
Tony's Building Property
401-407 East 2nd Street
The Dalles, OR 97058

Tanner,

All Asbestos containing materials, PCB containing Ballasts and Mercury Light tubes have been removed per JSE Labs, Inc. Asbestos Survey Report dated 5/21/2018. Performance Abatement Services, Inc. has removed the required Asbestos Abatement items per OR DEQ and OSHA regulations and standards. PAS removal was done utilizing 4 negative pressure enclosures (2 inside and 2 outside). Please also see attached air clearance reports for each containment.

If you have any questions regarding this matter, you may contact me at 503-519-4084

Sincerely,
PERFORMANCE ABATEMENT SERVICES

Randy Johnson

Randy Johnson
Estimator/Project Manager

Contractor DEQ license #: FSC511



The Identification Specialists

Analysis Report
prepared for
Performance Abatement Services

Report Date: 8/25/2023

Project Name: Tony's Building

Project #: 23-07240

SanAir ID#: 23045624



NVLAP LAB CODE 200870-0

10501 Trade Court | North Chesterfield, Virginia 23236

888.895.1177 | 804.897.1177 | fax: 804.897.0070 | IAQ@SanAir.com | SanAir.com



SanAir ID Number
23045624
FINAL REPORT
8/25/2023 5:34:38 PM

Name: Performance Abatement Services
Address: 13600 NE 10th Ave
Vancouver, WA 98685
Phone: 360-574-8400

Project Number: 23-07240
P.O. Number:
Project Name: Tony's Building
Collected Date: 7/24/2023 - 7/27/2023
Received Date: 8/18/2023 10:45:00 AM

Dear Francisco Tejada,

We at SanAir would like to thank you for the work you recently submitted. The 12 sample(s) were received on Friday, August 18, 2023 via UPS. The final report(s) is enclosed for the following sample(s): 1-1318, Ex-1359, 2-1325, 1-6621, Ex-6628, 2-6629, 1-6633, Ex-6603, 2-6634, 1-6612, Ex-6637, 2-6648.

These results only pertain to this job and should not be used in the interpretation of any other job. This report is only complete in its entirety. Refer to the listing below of the pages included in a complete final report.

Sincerely,

A handwritten signature in black ink that reads "Sandra Sobrino". The signature is written in a cursive, flowing style.

Sandra Sobrino
Asbestos & Materials Laboratory Manager
SanAir Technologies Laboratory

Final Report Includes:

- Cover Letter
- Analysis Pages
- Disclaimers and Additional Information

Sample conditions:

- 12 samples in Good condition.



SanAir ID Number
23045624
 FINAL REPORT
 8/25/2023 5:34:38 PM

Name: Performance Abatement Services
Address: 13600 NE 10th Ave
 Vancouver, WA 98685
Phone: 360-574-8400

Project Number: 23-07240
P.O. Number:
Project Name: Tony's Building
Collected Date: 7/24/2023 - 7/27/2023
Received Date: 8/18/2023 10:45:00 AM

Analyst: Feldman, Johnathan

Asbestos Air OSHA TWA NIOSH 7400

Sample	Location	Volume (liters)	Fibers	Fields	LOD	Fibers/ sq mm	Fibers/ cc	RSD
1-1318 23045624-001	Tile In The Building	675	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
Ex-1359 23045624-002	Tile In The Building	75	<5.5	100	0.036	7.006	<0.036	0.16 TWA: <0.002
2-1325 23045624-003	Tile In The Building	600	10.5	100	0.004	13.376	0.009	0.16 TWA: 0.004
1-6621 23045624-004	Tile In The Building	750	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
Ex-6628 23045624-005	Tile In The Building	75	<5.5	100	0.036	7.006	<0.036	0.16 TWA: <0.002
2-6629 23045624-006	Tile In The Building	600	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
1-6633 23045624-007	Tile In The Building	750	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
Ex-6603 23045624-008	Tile In The Building	75	44	100	0.036	56.051	0.288	0.17 TWA: 0.018
2-6634 23045624-009	Tile In The Building	300	38	100	0.009	48.408	0.062	0.17 TWA: 0.016
1-6612 23045624-010	Tile In The Building	225	<5.5	100	0.012	7.006	<0.012	0.16 TWA: <0.002
Ex-6637 23045624-011	Tile In The Building	75	<5.5	100	0.036	7.006	<0.036	0.16 TWA: <0.002
2-6648 23045624-012	Tile In The Building	600	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002

Analyst:

Johnathan R. Feldman

Approved Signatory:

Sandra Sobieraj

Analysis Date:

8/25/2023

Date:

8/25/2023

Disclaimer for NIOSH 7400 Version 3: June 2019, ASBESTOS and OTHER FIBERS by PCM

This report is the sole property of the client named on the SanAir Technologies Laboratory chain-of-custody (COC). Results in the report are confidential information intended only for the use by the customer listed on the chain of custody. Neither results nor reports will be discussed with or released to any third party without our client's written permission. Final reports cannot be reproduced, except in full, without written authorization from SanAir. The information provided in this report applies only to the samples submitted and is relevant only for the date, time, and exact location of sampling. The accuracy of the results of the analysis is dependent upon the method of sample procurement and information provided by the client on the COC. SanAir assumes no responsibility for the method of sample procurement. SanAir assumes no responsibility for the information provided by the client on the COC such as project number, project name, collection dates, po number, special instructions, samples collected by, sample numbers, sample identifications, sample type, selected analysis type, flow rate, total volume or area, and start stop times that may affect the validity of the results in this report. Evaluation reports are based solely on the sample(s) in the condition in which they were received at the laboratory and on the information provided by the client on the COC. Samples were received in good condition unless otherwise noted on the report. SanAir assumes no responsibility or liability for the manner in which the results are used or interpreted. RSD values (Sr values) are the relative standard deviation. SanAir does make contamination corrections to results based on field blank results, only when field blanks are provided by the client at the responsibility of the client. The identity of blank filters are known to the analyst prior to count completion. Limit of Detection is 7 fibers/mm². Fiber counts that are above 1300 fibers/mm² and fiber counts from samples with greater than 50% of the filter area covered with particulate shall be considered as uncountable or probably biased. Fiber counts that outside the 100-1300 fibers/mm² range shall be considered as having greater than optimal variability and as being probably biased.

SanAir is accredited by AIHA LAP, LLC in the IHLAP program (Laboratory ID LAP-162952). Refer to our accreditation certificate and scope or www.aihaaccreditedlabs.org for an up to date list of the Fields of Testing for which we are accredited.

This report does not constitute nor shall be used by the client to claim product, process, system, or person certification, approval, or endorsement by NVLAP, NELAC, NIST, AIHA LAP, LLC and/or any other U.S. governmental agencies; and may not be accredited by every local, state and federal regulatory agencies.

LELAP LAB ID #05088

State of Maine Department of Environmental Protection, License Number: LA-0084

The Commonwealth of Massachusetts, Certification for Asbestos Analytical Services License: AA000222

New York State Department of Health Laboratory Id Number: 11983

State of Connecticut, Department of Public Health Registration Number: PH-0105

Texas Department of State Health Services, Asbestos Laboratory, License Number: 300440

Virginia Department of Professional and Occupational Regulation Laboratory Number: 3333000323

Vermont Department of Health, Environmental Health, Asbestos Analytical License: AL166318

Washington State Department of Ecology, Environmental Laboratory ID: C989

State of West Virginia, Office of Environmental Health Services, Analytical Laboratory Number: LT000616



1551 Oakbridge Dr. STE B
 Powhatan, VA 23139
 804.897.1177 / 888.895.1177
 Fax 804.897.0070
 sanair.com

Asbestos
 Chain of Custody
 Form 140, Rev 3, 8/28/19

SanAir ID Number
 23045624

Company: <u>Performance Abatement Services</u>	Project #: <u>23-07240</u>	Collected by: <u>Francisco Tejada</u>
Address: <u>13600 NE 10th Ave</u>	Project Name: <u>Tony's building</u>	Phone #: <u>360-562-3505</u>
City, St, Zip: <u>Vancouver WA 98686</u>	Date Collected: <u>7-27-23 / 7-27-23</u>	Fax #:
State of Collection: <u>OR</u> Account#: <u>9253</u>	P.O. Number:	Email:

Bulk		Air		Soil	
ABB	PLM EPA 600/R-93/116 <input type="checkbox"/>	ABA	PCM NIOSH 7400 <input checked="" type="checkbox"/>	ABSE	PLM EPA 600/R-93/116 (Qual.) <input type="checkbox"/>
	Positive Stop <input type="checkbox"/>	ABA-2	OSHA w/ TWA* <input checked="" type="checkbox"/>	Vermiculite & Soil	
ABEPA	PLM EPA 400 Point Count <input type="checkbox"/>	ABTEM	TEM AHERA <input type="checkbox"/>	ABSP	PLM CARB 435 (LOD <1%) <input type="checkbox"/>
ABB1K	PLM EPA 1000 Point Count <input type="checkbox"/>	ABATN	TEM NIOSH 7402 <input type="checkbox"/>	ABSP1	PLM CARB 435 (LOD 0.25%) <input type="checkbox"/>
ABBN	PLM EPA NOB** <input type="checkbox"/>	ABT2	TEM Level II <input type="checkbox"/>	ABSP2	PLM CARB 435 (LOD 0.1%) <input type="checkbox"/>
ABBCH	TEM Chatfield** <input type="checkbox"/>	Other:	<input type="checkbox"/>	Dust	
ABBTM	TEM EPA NOB** <input type="checkbox"/>	New York ELAP		ABWA	TEM Wipe ASTM D-6480 <input type="checkbox"/>
ABQ	PLM Qualitative <input type="checkbox"/>	ABEPA2	NY ELAP 198.1 <input type="checkbox"/>	ABDMV	TEM Microvac ASTM D-5755 <input type="checkbox"/>
** Available on 24-hr. to 5-day TAT		ABENY	NY ELAP 198.6 PLM NOB <input type="checkbox"/>	Matrix	Other <input type="checkbox"/>
Water		ABBNY	NY ELAP 198.4 TEM NOB <input type="checkbox"/>		
ABHE	EPA 100.2 <input type="checkbox"/>				

Turn Around Times	3 HR (4 HR TEM) <input type="checkbox"/>	6 HR (8HR TEM) <input type="checkbox"/>	12 HR <input type="checkbox"/>	1 Day <input type="checkbox"/>
	<input type="checkbox"/> 2 Days	<input type="checkbox"/> 3 Days	<input type="checkbox"/> 4 Days	<input checked="" type="checkbox"/> 5 Days

Special Instructions

Sample #	Sample Identification/Location	Volume or Area	Sample Date	Flow Rate*	Start - Stop Time*
1-1318	Tile in the Building		7/24/23	2.5	7:30 12:00
EX-1359	" "		" "	" "	1:00 1:30
2-1385	" "		" "	" "	1:30 5:30
1-6621	" "		7/25/23	" "	7:00 12:00
EX-6628	" "		" "	" "	1:00 1:30
2-6629	" "		" "	" "	1:30 5:30
1-6633	" "		7/26/23	" "	7:00 12:00
EX-6603	" "		" "	" "	1:00 1:30
2-6634	" "		" "	" "	1:30 3:30
1-6612	" "		7/27/23	" "	7:00 12:00
EX-6637	" "		" "	" "	1:00 1:30
2-6648	" "		" "	" "	1:30 5:30

Relinquished by	Date	Time	Received by	Date	Time
<u>[Signature]</u>	7-27-23	5:30	<u>Sm</u>	8/18/23	10:45AM

If no technician is provided, then the primary contact for your account will be selected. Unless scheduled, the turnaround time for all samples received after 3 pm EST will be logged in the next business day. Weekend or holiday work must be scheduled ahead of time and is charged at 150% of the 3hr TAT or a minimum charge of \$150. A courier charge will be applied for same day and one-day turnaround times for offsite work. SanAir covers Standard Overnight FedEx shipping. Shipments billed to SanAir with a faster shipping rate will result in additional charges.



The Identification Specialists

Analysis Report
prepared for
Performance Abatement Services

Report Date: 8/25/2023

Project Name: Tony's Building

Project #: 23-07240

SanAir ID#: 23045691



NVLAP LAB CODE 200870-0

10501 Trade Court | North Chesterfield, Virginia 23236

888.895.1177 | 804.897.1177 | fax: 804.897.0070 | IAQ@SanAir.com | SanAir.com



SanAir ID Number
23045691
FINAL REPORT
8/25/2023 5:37:30 PM

Name: Performance Abatement Services
Address: 13600 NE 10th Ave
Vancouver, WA 98685
Phone: 360-574-8400

Project Number: 23-07240
P.O. Number:
Project Name: Tony's Building
Collected Date: 8/1/2023
Received Date: 8/18/2023 10:45:00 AM

Dear Francisco,

We at SanAir would like to thank you for the work you recently submitted. The 30 sample(s) were received on Friday, August 18, 2023 via UPS. The final report(s) is enclosed for the following sample(s): 16614, Ex 6592, 2 6595, 1-6638, Ex-6604, 2-6646, 1-6632, Ex-6624, 2-6635, 1-8616, Ex 6606, 2 6626, 1-6618, Ex-6649, 2-6620, 1-6593, Ex-6642, 2-6594, 1-6643, Ex-6627, 2-6640, 1-6623, Ex-6647, 2-6630, 1-6608, Ex-6611, 2-6650, 1-6641, Ex-6596, 2-6625.

These results only pertain to this job and should not be used in the interpretation of any other job. This report is only complete in its entirety. Refer to the listing below of the pages included in a complete final report.

Sincerely,

A handwritten signature in black ink that reads "Sandra Sobrino".

Sandra Sobrino
Asbestos & Materials Laboratory Manager
SanAir Technologies Laboratory

Final Report Includes:

- Cover Letter
- Analysis Pages
- Disclaimers and Additional Information

Sample conditions:

- 30 samples in Good condition.



SanAir ID Number
23045691
 FINAL REPORT
 8/25/2023 5:37:30 PM

Name: Performance Abatement Services
Address: 13600 NE 10th Ave
 Vancouver, WA 98685
Phone: 360-574-8400

Project Number: 23-07240
P.O. Number:
Project Name: Tony's Building
Collected Date: 8/1/2023
Received Date: 8/18/2023 10:45:00 AM

Analyst: Feldman, Johnathan

Asbestos Air OSHA TWA NIOSH 7400

Sample	Location	Volume (liters)	Fibers	Fields	LOD	Fibers/ sq mm	Fibers/ cc	RSD
16614 23045691-001	Roofing Area Hector Valles	750	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
Ex 6592 23045691-002	Roofing Area Hector Valles	75	<5.5	100	0.036	7.006	<0.036	0.16 TWA: <0.002
2 6595 23045691-003	Roofing Area Hector Valles	600	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
1-6638 23045691-004	Roofing Area Hector Valles	750	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
Ex-6604 23045691-005	Roofing Area Hector Valles	75	<5.5	100	0.036	7.006	<0.036	0.16 TWA: <0.002
2-6646 23045691-006	Roofing Area Hector Valles	600	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
1-6632 23045691-007	Roofing Area Hector Valles	750	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
Ex-6624 23045691-008	Roofing Area Hector Valles	75	<5.5	100	0.036	7.006	<0.036	0.16 TWA: <0.002
2-6635 23045691-009	Roofing Area Hector Valles	600	Overloaded					
1-8616 23045691-010	Roofing Area Hector Valles	750	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
Ex 6606 23045691-011	Roofing Area Hector Valles	75	<5.5	100	0.036	7.006	<0.036	0.16 TWA: <0.002
2 6626 23045691-012	Roofing Area Hector Valles	600	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
1-6618 23045691-013	Roofing Area 8/8/23	750	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
Ex-6649 23045691-014	Roofing Area 8/8/23	75	<5.5	100	0.036	7.006	<0.036	0.16 TWA: <0.002
2-6620 23045691-015	Roofing Area 8/8/23	600	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
1-6593 23045691-016	Chipping Grout 8-2-23	750	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002

Analyst: *Johnathan R Feldman*

Approved Signatory: *Sandra Sobieraj*

Analysis Date: 8/25/2023

Date: 8/25/2023



SanAir ID Number
23045691
 FINAL REPORT
 8/25/2023 5:37:30 PM

Name: Performance Abatement Services
Address: 13600 NE 10th Ave
 Vancouver, WA 98685
Phone: 360-574-8400

Project Number: 23-07240
P.O. Number:
Project Name: Tony's Building
Collected Date: 8/1/2023
Received Date: 8/18/2023 10:45:00 AM

Analyst: Feldman, Johnathan

Asbestos Air OSHA TWA NIOSH 7400

Sample	Location	Volume (liters)	Fibers	Fields	LOD	Fibers/ sq mm	Fibers/ cc	RSD
Ex-6642 23045691-017	Chipping Grout 8-2-23	75	<5.5	100	0.036	7.006	<0.036	0.16 TWA: <0.002
2-6594 23045691-018	Chipping Grout 8-2-23	600	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
1-6643 23045691-019	Chipping Grout 8-3-23	750	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
Ex-6627 23045691-020	Chipping Grout 8-3-23	75	<5.5	100	0.036	7.006	<0.036	0.16 TWA: <0.002
2-6640 23045691-021	Chipping Grout 8-3-23	600	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
1-6623 23045691-022	Chipping Grout 8-8-23	2400	<5.5	100	0.001	7.006	<0.001	0.16 TWA: <0.002
Ex-6647 23045691-023	Chipping Grout 8-8-23	75	<5.5	100	0.036	7.006	<0.036	0.16 TWA: <0.002
2-6630 23045691-024	Chipping Grout 8-8-23	600	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
1-6608 23045691-025	Chipping Grout 8-9-23	750	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
Ex-6611 23045691-026	Chipping Grout 8-9-23	75	<5.5	100	0.036	7.006	<0.036	0.16 TWA: <0.002
2-6650 23045691-027	Chipping Grout 8-9-23	600	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002
1-6641 23045691-028	Chipping Grout 8-10-23	75	<5.5	100	0.036	7.006	<0.036	0.16 TWA: <0.002
Ex-6596 23045691-029	Chipping Grout 8-10-23	75	<5.5	100	0.036	7.006	<0.036	0.16 TWA: <0.002
2-6625 23045691-030	Chipping Grout 8-10-23	600	<5.5	100	0.004	7.006	<0.004	0.16 TWA: <0.002

Analyst: *Johnathan R Feldman*

Approved Signatory: *Sandra Sobrin*

Analysis Date: 8/25/2023

Date: 8/25/2023

Disclaimer for NIOSH 7400 Version 3: June 2019, ASBESTOS and OTHER FIBERS by PCM

This report is the sole property of the client named on the SanAir Technologies Laboratory chain-of-custody (COC). Results in the report are confidential information intended only for the use by the customer listed on the chain of custody. Neither results nor reports will be discussed with or released to any third party without our client's written permission. Final reports cannot be reproduced, except in full, without written authorization from SanAir. The information provided in this report applies only to the samples submitted and is relevant only for the date, time, and exact location of sampling. The accuracy of the results of the analysis is dependent upon the method of sample procurement and information provided by the client on the COC. SanAir assumes no responsibility for the method of sample procurement. SanAir assumes no responsibility for the information provided by the client on the COC such as project number, project name, collection dates, po number, special instructions, samples collected by, sample numbers, sample identifications, sample type, selected analysis type, flow rate, total volume or area, and start stop times that may affect the validity of the results in this report. Evaluation reports are based solely on the sample(s) in the condition in which they were received at the laboratory and on the information provided by the client on the COC. Samples were received in good condition unless otherwise noted on the report. SanAir assumes no responsibility or liability for the manner in which the results are used or interpreted. RSD values (Sr values) are the relative standard deviation. SanAir does make contamination corrections to results based on field blank results, only when field blanks are provided by the client at the responsibility of the client. The identity of blank filters are known to the analyst prior to count completion. Limit of Detection is 7 fibers/mm². Fiber counts that are above 1300 fibers/mm² and fiber counts from samples with greater than 50% of the filter area covered with particulate shall be considered as uncountable or probably biased. Fiber counts that outside the 100-1300 fibers/mm² range shall be considered as having greater than optimal variability and as being probably biased.

SanAir is accredited by AIHA LAP, LLC in the IHLAP program (Laboratory ID LAP-162952). Refer to our accreditation certificate and scope or www.aihaaccreditedlabs.org for an up to date list of the Fields of Testing for which we are accredited.

This report does not constitute nor shall be used by the client to claim product, process, system, or person certification, approval, or endorsement by NVLAP, NELAC, NIST, AIHA LAP, LLC and/or any other U.S. governmental agencies; and may not be accredited by every local, state and federal regulatory agencies.

LELAP LAB ID #05088

State of Maine Department of Environmental Protection, License Number: LA-0084

The Commonwealth of Massachusetts, Certification for Asbestos Analytical Services License: AA000222

New York State Department of Health Laboratory Id Number: 11983

State of Connecticut, Department of Public Health Registration Number: PH-0105

Texas Department of State Health Services, Asbestos Laboratory, License Number: 300440

Virginia Department of Professional and Occupational Regulation Laboratory Number: 3333000323

Vermont Department of Health, Environmental Health, Asbestos Analytical License: AL166318

Washington State Department of Ecology, Environmental Laboratory ID: C989

State of West Virginia, Office of Environmental Health Services, Analytical Laboratory Number: LT000616



1551 Oakbridge Dr. STE B
 Powhatan, VA 23139
 804.897.1177 / 888.895.1177
 Fax 804.897.0070
 sanair.com

Asbestos
 Chain of Custody
 Form 140, Rev 3, 8/28/19

SanAir ID Number

23045691

Company: <u>Performance Abatement Services</u>		Project #: <u>23-07240</u>		Collected by: <u>Francisco T. [unclear]</u>	
Address: <u>13600 NE 10th Ave</u>		Project Name: <u>Tony's Building</u>		Phone #: <u>360-562-3505</u>	
City, St., Zip: <u>Manassas VA 20108</u>		Date Collected: <u>8-01-23</u>		Fax #:	
State of Collection: <u>07</u> Account#: <u>2253</u>		P.O. Number:		Email:	

Bulk		Air		Soil	
ABB	PLM EPA 600/R-93/116	ABA	PCM NIOSH 7400	ABSE	PLM EPA 600/R-93/116 (Qual.)
	Positive Stop	ABA-2	OSHA w/ TWA*	Vermiculite & Soil	
ABEPA	PLM EPA 400 Point Count	ABTEM	TEM AHERA	ABSP	PLM CARB 435 (LOD <1%)
ABBIK	PLM EPA 1000 Point Count	ABATN	TEM NIOSH 7402	ABSP1	PLM CARB 435 (LOD 0.25%)
ABBN	PLM EPA NOB**	ABT2	TEM Level II	ABSP2	PLM CARB 435 (LOD 0.1%)
ABBCH	TEM Chatfield**	Other:		Dust	
ABBTM	TEM EPA NOB**	New York ELAP		ABWA	TEM Wipe ASTM D-6480
ABQ	PLM Qualitative	ABEPA2	NY ELAP 198.1	ABDMV	TEM Microvac ASTM D-5755
** Available on 24-hr. to 5-day TAT		ABENY	NY ELAP 198.6 PLM NOB	Matrix	
Water		ABBNY	NY ELAP 198.4 TEM NOB	Other	
ABHE	EPA 100.2				

Turn Around Times	3 HR (4 HR TEM) <input type="checkbox"/>	6 HR (8HR TEM) <input type="checkbox"/>	12 HR <input type="checkbox"/>	1 Day <input type="checkbox"/>
	<input type="checkbox"/> 2 Days	<input type="checkbox"/> 3 Days	<input type="checkbox"/> 4 Days	<input checked="" type="checkbox"/> 5 Days

Special Instructions

Sample #	Sample Identification/Location	Volume or Area	Sample Date	Flow Rate*	Start - Stop Time*
1-6614	Hector Valle's Roofing area		8-1-23	2.5	7:00 12:00
EX-6592	" "		" "	" "	1:00 1:30
2-6595	" "		" "	" "	1:30 5:30
1-6638	" "		8-2-23	" "	7:00 12:00
EX-6604	" "		" "	" "	1:00 1:30
2-6646	" "		" "	" "	1:30 5:30
1-6632	" "		8-3-23	" "	7:00 12:00
EX-6634	" "		" "	" "	1:00 1:30
2-6635	" "		" "	" "	1:30 5:30
1-6616	" "		8-7-23	" "	7:00 12:00
EX-6606	" "		" "	" "	1:00 1:30
2-6636	" "		" "	" "	1:30 5:30

Relinquished by	Date	Time	Received by	ILM Date	Time
[Signature]		5:30	ILM	8/2/23	10:45 am
				8/18/23	

If no technician is provided, then the primary contact for your account will be selected. Unless scheduled, the turnaround time for all samples received after 3 pm EST will be logged in the next business day. Weekend or holiday work must be scheduled ahead of time and is charged at 150% of the 3hr TAT or a minimum charge of \$150. A courier charge will be applied for same day and one-day turnaround times for offsite work. SanAir covers Standard Overnight FedEx shipping. Shipments billed to SanAir with a faster shipping rate will result in additional charges.

