



CITY OF THE DALLES
Department of Public Works
1215 West 1st Street
The Dalles, Oregon 97058

PRESS RELEASE

DATE: October 30, 2025

TOPIC: Wastewater Treatment Plant Discharge Exceeds *E. coli* Limit

CONTACT: Public Works Department (541) 296-5401

FOR RELEASE: IMMEDIATELY

The City of The Dalles Wastewater Treatment Plant has discharged effluent that exceeds the plant's limit for *E. coli* due to incomplete disinfection. Sample test results read on the morning of October 28, 2025 indicated an *E. coli* exceedance. Several resamples in the following 24 hour period confirmed that the treatment process is not under control. The cause of the exceedance is unknown at this time. Rigorous water quality monitoring is ongoing.

The ultraviolet disinfection process has been ramped up to maximum capacity in an attempt to compensate for partially treated effluent due to the upset. Wastewater treatment staff is working hard to restore the biological balance so that the plant can quickly return to normal operations.

Staff has increased frequency of sampling until *E. coli* counts are back within permit limits. Samples will also be taken at pre-arranged locations in the river to provide data on the effect of the discharge on water quality in the river.

Signs have been placed at locations of public river access on the Oregon shore of the Columbia River, from The Dalles Riverfront Park to West Mayer Park boat launch. The signs say: "Warning - Contaminated Water - No water contact" and give phone numbers to call for information.

For information about Washington shore public river access, contact Klickitat County Health Department at (509) 493-1558.

The Department is in communication with the Oregon Department of Environmental Quality and local health department officials to coordinate response. Questions can be directed to the Public Works Department office at (541) 296-5401.

For updates go to the City website thedadles.org

--end--