

Bethel-Danebo Closed Landfill Progress Report

For January 2017

Actions during this month:

- Regular sampling.
- Blower has run continually without issue since June the 25th 2015.
- The blower vacuum is at 8.2. The soils are saturated with standing water in several locations on the site.

Actions scheduled to be taken within the next two months:

- Continue sampling schedule.
- Scheduled site review meeting with DEQ on February 13th.

Problems experienced during the month:

- Most probes that are ground surface termination were flooded in the probe. Probe 003 was also saturated and caused the pump to turn off due to pressure exceedance.

Readings for January 2017

Device ID	Date/Time	CH4	CO2	O2	Balance
GEM™5000; G5 V1_11_16; LSGAM:6_0_20160627; {68885332369}		%	%	%	%
Probe001	1/26/2017 12:46	0	0.3	20.9	78.8
Probe002	1/26/2017 12:52	4.2	11.2	1.8	82.8
Probe003	1/26/2017 12:56	0	0.1	20.6	79.3
Probe004	1/26/2017 13:00	20.4	19.3	2.1	58.2
BLOWEXAU	1/26/2017 13:04	0.1	0.2	20.8	78.9
Probe005	1/26/2017 13:10	0	1.7	17.8	80.5
Probe006	1/26/2017 13:22	22.1	6	2.6	69.3

Probe007	1/26/2017 13:27	0	0.2	20.7	79.1
Probe008	1/26/2017 13:31	0	0.7	20.3	79
LP08VPL8	1/26/2017 13:37	0	1.1	19.5	79.4
Probe009	1/26/2017 13:41	0	0.4	20.3	79.3
Probe010	1/26/2017 13:47	0	0.2	20.7	79.1

Don Strunk
Supervisor/Technical Specialist
Lane County Waste Management Division