

Bethel-Danebo Closed Landfill Progress Report

For February 2019

Actions during this month:

- Regular sampling.
- Blower has run continually without issue since June the 25th 2015.
- The blower vacuum is at 10.7 Soils are saturated.
- The entire site was still covered with snow.
- Camp Creek Electric repaired digital console and updated alarm reporting software at site.

Actions scheduled to be taken within the next two months:

- Continue sampling schedule.
- Review building plans and methane control for lot 26 development.

Problems experienced during the month:

- A lot of transient campers and trash spread over the vacant portion of the site with the exception of the ODOT parcel.
- The snow made gas sampling difficult this month and delayed access to the site.
- The business lot where probes 7 and 8 are located was locked with no access to these probes.

Readings for February 2019

Device ID	Date/Time	CH4	CO2	O2	Balanc e	%LEL
GEM™5000; G5 V1_14_12; LSGAM:6_0_20160627; {35564558017}		%	%	%	%	%
Probe001	3/4/2019 14:15	0	0.5	19.3	80.2	0
Probe002	3/4/2019 14:18	0	1.5	16.7	81.8	0
Probe003	3/4/2019 14:23	0	0.1	20	79.9	0
Probe004	3/4/2019 14:29	9.5	12.1	6.7	71.7	>>>>

BLOWEXAU	3/4/2019 14:32	0.1	0.2	19.9	79.8	2
Probe005	3/4/2019 14:36	0	1.2	17.4	81.4	0
Probe006	3/4/2019 14:40	1.2	0.5	19.3	79	24
Probe009	3/4/2019 14:45	0	0.5	19.7	79.8	0
Probe009	3/4/2019 14:47	0	0.5	19.7	79.8	0
Probe010	3/4/2019 14:50	0	0.1	20.5	79.4	0

Don Strunk
Supervisor/Engineering Analyst
Lane County Waste Management Division

Device ID	Date/Time	CH4	CO2	O2	Balance
GEM™5000; G5 V1_14_12; LSGAM:6_0_20160627; {35564558017}		%	%	%	%
Probe001	3/4/2019 14:15	0	0.5	19.3	80.2
Probe002	3/4/2019 14:18	0	1.5	16.7	81.8
Probe003	3/4/2019 14:23	0	0.1	20	79.9
Probe004	3/4/2019 14:29	9.5	12.1	6.7	71.7
BLOWEXAU	3/4/2019 14:32	0.1	0.2	19.9	79.8
Probe005	3/4/2019 14:36	0	1.2	17.4	81.4
Probe006	3/4/2019 14:40	1.2	0.5	19.3	79
Probe009	3/4/2019 14:45	0	0.5	19.7	79.8
Probe009	3/4/2019 14:47	0	0.5	19.7	79.8
Probe010	3/4/2019 14:50	0	0.1	20.5	79.4

NO2	CL2	H2	HCN	Inst-Tech	Latitude	Longitude	Altitude	UTC
		LMH					ft	
N/A	N/A	6	N/A	N/A_	N/A	N/A	N/A	N/A
N/A	N/A	7	N/A	N/A_	N/A	N/A	N/A	N/A
N/A	N/A	5	N/A	N/A_	N/A	N/A	N/A	N/A
N/A	N/A	10	N/A	N/A_	N/A	N/A	N/A	N/A
N/A	N/A	8	N/A	N/A_	N/A	N/A	N/A	N/A
N/A	N/A	9	N/A	N/A_	N/A	N/A	N/A	N/A
N/A	N/A	12	N/A	N/A_	N/A	N/A	N/A	N/A
N/A	N/A	5	N/A	N/A_	N/A	N/A	N/A	N/A
N/A	N/A	11	N/A	N/A_	N/A	N/A	N/A	N/A
N/A	N/A	8	N/A	N/A_	N/A	N/A	N/A	N/A

Rel. Press.	Site Chosen	Comments	Answers	Site Answers	REL.PRES SURE2
inches H2O					inches H2O
0	,,,,,,,,	,,,,,,,,	,,	,,,	N/A
-0.02	,,,,,,,,	,,,,,,,,	,,	,,,	N/A
-0.01	,,,,,,,,	,,,,,,,,	,,	,,,	N/A
-0.01	,,,,,,,,	,,,,,,,,	,,	,,,	N/A
-0.02	,,,,,,,,	,,,,,,,,	,,	,,,	N/A
0	,,,,,,,,	,,,,,,,,	,,	,,,	N/A
0.01	,,,,,,,,	,,,,,,,,	,,	,,,	N/A
-0.07	,,,,,,,,	,,,,,,,,	,,	,,,	N/A
0.01	,,,,,,,,	,,,,,,,,	,,	,,,	N/A
0.01	,,,,,,,,	,,,,,,,,	,,	,,,	N/A