



CURRY COUNTY

Mack Arch on the Curry Coast

BUILDING, PLUMBING, MECHANICAL PERMIT APPLICATION AND SEWER CONNECTION FEE

PERMIT NUMBER
CC13P86
Rec 3657

DATE REC'D 4/1/86
 DATE ISSUED 4/1/86

Applicant to complete numbered spaces only.

JOB ADDRESS WEDDERBURN & HWY 101 N.B.		DATE REC'D	
1 LEGAL DESCR.	LOT NO. 600	BLK 36-14-30CB	DATE ISSUED
2 OWNER JOTS RESORT PO BOX J GOLD BEACH		MAIL ADDRESS	PHONE 97444 247-6676
3 CONTRACTOR NEW HOPE PLUMBING & CO		REG NO. 11474	PLUMBER REG NO.
4 ARCHITECT OR DESIGNER		ELECTRICIAN REG NO.	
5 USE OF BUILDING PLUMBING - 40 UNITS MOTEL - PHASE/E			
6 Class of work: <input type="checkbox"/> NEW <input type="checkbox"/> ADDITION <input type="checkbox"/> ALTERATION <input type="checkbox"/> REPAIR <input type="checkbox"/> MOVE <input type="checkbox"/> REMOVE <input type="checkbox"/> OTHER			
7 Describe work: PERFORM ALL PLUMBING PER PLANS & U.P.C.			

Valuation of work: \$

			PLUMBING PERMIT FEES	
Type of Const.	Occupancy Group	Division	No.	Fee
Size of Bldg. (Total) Sq. Ft.	No. of Stories	Max. Occ. Load	DRAINAGE FIXTURES	
Fire Zone	Use Zone	Fire Sprinklers Required <input type="checkbox"/> Yes <input type="checkbox"/> No	\$	
No. of Dwelling Units	OFFSTREET PARKING SPACES: Covered	Uncovered	161 @ 750 WRS	
FEES			STORM DRAIN	
SEWER CONNECT			PLAN CHECK	
PERMIT			325.825213	
PLAN CHECK			STATE SUR TAX	
SIDEWALK			\$ 5213	
DRIVEWAY			PERMIT	
WATER SERVICE			\$	
STATE SUR TAX			TOTAL FEE	
TOTAL			\$ 1681.25	
			TYPE OF FUEL OIL <input type="checkbox"/> NAT. GAS <input type="checkbox"/> LPG <input type="checkbox"/>	
			MECHANICAL PERMIT FEES	
			No.	Fee
			TYPE OF EQUIPMENT	
			STATE SUR TAX	
			\$	
			PERMIT	
			\$	
			TOTAL FEE	
			\$	


I hereby acknowledge that I have read this application and that the above is correct. I agree to comply with all applicable City Ordinances and/or State laws, and my State registration is in full force and effect.

X Peter E. Peters
 Signature of Owner, Contractor or Authorized Agent

WHEN PROPERLY VALIDATED (IN THIS SPACE) THIS IS YOUR PERMIT

APPROVED BUILDING OFFICIAL John Harrell PERMIT VALIDATION CK. M.O. CASH

By: _____



Samuels & Clay
Architects and Planners, A.I.A.
170 South Second, Suite 202
Coos Bay, Oregon 97420
(503) 269-5555

April 1, 1986

Mr. Jim Jaqua
Department of Commerce
Building Codes Division
Plans Review Section
4th Floor Labor & Industries Building
Salem, OR 97310

RE: Jot's Resort Motel Addition
Project #8603
State Plan Review No. 175-86

Dear Mr. Jaqua:

I have reviewed the following items with the Owner and he has decided to modify the plans as follows:


1. The carports located on the first floor will now be used for storage. Please change the designation from "carport" to "storage". It is my understanding that the 2 hour fire separation between the carport area and the first floor living area may now be reduced to 1 hour.
2. The draftstop that is installed above each party wall throughout the Motel Addition is to extend over and through the overhangs on both the north and south sides of the building.
3. The roof ventilation will be taken care of by installing roof vents on the roof. One roof ventilator shall be located near the ridge, (as shown in Section 1/5,) and shall be approximately .9 square feet in area. Two additional vents will be located approximately 5 feet above the gutter on each side of the building and will be approximately .45 square feet in area. All roof vents will be covered with galvanized metal mesh to protect the opening from insects, etc.
4. The cedar shakes installed over 5/8" water resistant type-x gypboard, shall be changed to class "B" fire retardant treated wood shakes installed over a layer of 30 pound asphalt felt (in lieu of approved asbestos felt) lapped 2" on the horizontal and vertical joints. An 18" wide strip of the same felt shall be shingled in between each course of the shakes, in such a manner that no felt is exposed to the weather below the shake butt. The entire roofing

system on the 5/8" plywood roof sheathing:

5. The ceiling on the second floor shall be changed from 5/8" type x gypsum board on 1x4 stripping at 16" o.c. to 5/8" type x gypsum board secured to metal furring channel with type "S" screws at 6" o.c. The metal furring channel shall be installed at 16" o.c. and perpendicular to the trusses and nailed or screwed to each truss.

I hope this answers all of your concerns regarding the Jot's Motel Addition.
If you need any additional information, please call.

Very truly yours,



Lon Samuels, AIA

LS/11/c8603-05

cc: Lou Giottonini

479-3032 -

4-1-86

THIS IS YOUR LICENSE

IF YOUR LICENSE REQUIRES SPECIAL PROVISIONS, THIS SECTION WILL BE COMPLETED AND SHOULD BE CARRIED WITH YOUR LICENSE.

STATE OF OREGON

STATE OF OREGON

BUILDING CODES (PLUMBING)
LIC./REG. AS: NO: 2217JP
JOURNEYMAN PLUMBER

PETERS PETER E
DBA NEW HOPE PLBG AND CONST.
6650 NEW HOPE RD
GRANTS PASS OR 97526

Please Sign

DEPARTMENT OF COMMERCE

07/31/86
EXPIRES

DEPARTMENT OF COMMERCE

THIS IS YOUR LICENSE

IF YOUR LICENSE REQUIRES SPECIAL PROVISIONS, THIS SECTION WILL BE COMPLETED AND SHOULD BE CARRIED WITH YOUR LICENSE.

STATE OF OREGON

STATE OF OREGON

BUILDING CODES (PLUMBING)
LIC./REG. AS: NO: 17-16PB
PLUMBING BUSINESS

NEW HOPE PLUMBING & CONSTRUCTION
6650 NEW HOPE RD
GRANTS PASS OR 97526

Please Sign

DEPARTMENT OF COMMERCE

07/31/86
EXPIRES

DEPARTMENT OF COMMERCE

STATE OF OREGON

DEPARTMENT OF COMMERCE

BUILDERS BOARD

THIS CERTIFIES THAT THE PERSON NAMED HEREON IS
LICENSED/REGISTERED AS PROVIDED BY LAW AS A

BUILDER RESIDENTIAL
COMMERCIAL/INDUSTRIAL

LICENSE
NUMBER: 11474

EXPIRES: 07/02/86

PETERS/PETER EDWARD

NEW HOPE PLUMBING & CONSTRUCTION
6650 NEW HOPE RD
GRANTS PASS OR 97527

SIGNATURE OF LICENSEE/REGISTRANT

Curry County
Building Inspection Request

Date 4/3/86 CC13P86
Name New Hope Plumbing
Location Job Motel

Groundwork
Plumbing OK
to come

James

By _____