



Oregon

Tina Kotek, Governor

Department of Environmental Quality

Agency Headquarters

700 NE Multnomah Street, Suite 600

Portland, OR 97232

(503) 229-5696

FAX (503) 229-6124

TTY 711

December 17, 2025

Amazon Data Services, Inc.
79539 Rippee Rd.
Boardman, OR 97818
Sent electronically only

Shannon Moore,

Amazon Data Services, Inc.'s (ADS) PDX-4 facility was called in to the Cleaner Air Oregon (CAO) program on June 27, 2024. DEQ approved ADS's CAO Emissions Inventory on January 31, 2025, and the combined CAO Modeling Protocol and Risk Assessment Work Plan on July 9, 2025. ADS submitted a CAO Level 3 Risk Assessment (Risk Assessment) on October 31, 2025. DEQ reviewed the Risk Assessment and requested edits on November 25, 2025. ADS submitted the revisions to the Risk Assessment on December 12, 2025. DEQ has completed its review and approves the Risk Assessment submitted on December 12, 2025, with supporting files also submitted on October 31, 2025, for the PDX-4 facility in Boardman, OR (Your DEQ Online [YDO] submittal 62799). This approval is in accordance with [Oregon Administrative Rule \(OAR\) 340-245-0050\(1\)](#).

The resulting Acute Noncancer Hazard Index of 1.4 (rounded to 1), as determined by the Risk Assessment, exceeds the Source Permit Level of 0.5 for existing sources. [\[OAR 340-245-0200\(4\) & OAR 340-245-8010, Table 1\]](#) All other risk values for this facility do not exceed the Source Permit Level. Because the Acute Noncancer Hazard Index exceeds the Source Permit Level, Source Risk Limits will be required in the permit to limit the risk from toxic air contaminant emissions from this facility.

The next step in the CAO process is for ADS to submit a completed [AQ501 CAO Permit Application Form](#) in YDO, along with payment of the Standard ACDP "Level 3 Risk Assessment – not de minimis" fee of **\$11,831**, by no later than thirty (30) days from the date of this letter, or **January 16, 2026**. [\[OAR 340-216-8030 Table 3 & OAR 340-245-0030\(1\)\(h\)\]](#) Note that an additional 4 percent technology fee of **\$473.24** will be applied to this payment in YDO.

If you have any questions regarding this letter, please contact me directly at 971-300-3653 or amy.devita-mcbride@deq.oregon.gov. I look forward to your continued assistance with this process.

Sincerely,

Amy DeVita-McBride

Amy DeVita-McBride
Cleaner Air Oregon Project Engineer

Cc: Jason Bowker, Amazon
Darren Wilton, Amazon
Garrett Koehler, Amazon
Doka Bui, Amazon

25-0008 Amazon Data Services, Inc.

Beth Ryder, Trinity Consultants
Carlos Rubio Regalado, DEQ
Owen Rudloff, DEQ
J.R. Giska, DEQ
File