



# Oregon

Tina Kotek, Governor

Department of Environmental Quality

Headquarters Office

700 NE Multnomah Street, Suite 600

Portland, OR 97232

(503) 229-5263

TTY 711

December 29, 2025

Hindpreet Singh  
Garibaldi Bay, Inc.  
14135 SE Mill Plain Blvd  
Vancouver, WA 98684

RE: UST Compliance Inspection  
Warrenton Mini Mart Texaco  
DEQ UST #7102

Hindpreet Singh:

The Oregon Department of Environmental Quality (DEQ) is conducting underground storage tank (UST) inspections throughout Oregon. The purpose of this letter is to inform you that your facility, located at 58 E Harbor Drive, in Warrenton, has been selected for inspection. A thorough inspection of your facility will be conducted to determine compliance with state and federal UST requirements. **The date you receive this letter is the date that the inspection starts.** If you have work or testing done at this facility after receiving this letter you must have the previous set of records available for evaluation in addition to the most recent records.

**If I do not hear from you, the inspection for this facility is scheduled for February 20, 2026, starting at approximately 9:30 am.** Please note that the inspection will require uninterrupted participation and attendance by you or a knowledgeable assistant. For the inspection you need to provide access to tank sumps, under dispenser areas, cathodic protection rectifiers, and leak monitoring equipment. DEQ will not touch the equipment; if you are unable to assist with equipment access, please have your UST Service Provider there. This inspection may also include review of Stage I Vapor Recovery.

To complete this inspection, you will need to have compliance testing records available on-site on the day of the inspection or sent to me prior to the inspection at [diana.foss@deq.oregon.gov](mailto:diana.foss@deq.oregon.gov).

At a minimum the following records are required to complete this inspection:

- Leak detector testing results for the past three years
- Annual line tightness tests (3) and/or monthly interstitial monitoring records (12)
- Monthly tank leak detection records (12 months)
- Class A, B, and C training documentation
- Financial responsibility mechanism
- Annual tank gauge / release detection equipment certification (3)
- Spill prevention tests
- Overfill Prevention Equipment tests
- Monthly walkthroughs (12)
- Cathodic protection testing (if applicable)
- Tank lining records (if applicable)

As stated previously, DEQ will not touch any equipment and if you are unable to assist with equipment access, please have your UST Service Provider there to remove manway or sump lids. DEQ will need to observe what equipment is in the tank top sumps and under the dispensers. If ball floats are the primary overfill protection device, these will need to be verified during the inspection, please be able to locate and remove the ball floats.

If violations are found at the time of the inspection without prior notification, DEQ is required to initiate enforcement action. For UST violations, enforcement usually begins with a field citation option, which is much like paying a traffic ticket and making corrections.

Some enforcement situations including repeat violations will go through a longer and more formal process including civil penalties.

Thank you for your cooperation. I can be reached at 503-869-0770 or [diana.foss@deq.oregon.gov](mailto:diana.foss@deq.oregon.gov) to answer any questions you may have and assist you in the preparation for your inspection.

Sincerely,

*Diana Foss*

Diana Foss  
Senior Policy Analyst  
UST Compliance Program

**Oregon Department of Environmental Quality - Underground Storage Tank Program**  
**Technical Compliance Inspection - UST Inspection Report**

Inspector: FOSS Date: 2/20/26 Time: \_\_\_\_\_ Facility: 7102

<b>I. Site Information</b>		
Facility Name: <u>Warrenton Mini Mart</u>	Permittee: <u>Hindpract Sing</u>	Contact
Site Address: <u>58 E Harbor Dr</u>	Organization: <u>Gambaldi Bay Inc</u>	Phone
City: <u>Warrenton</u>	Phone: <u>360-450-7143</u>	

<b>II. Tank Information</b>					
DEQ Permit #	<u>HEJG</u>	<u>HEJH</u>	<u>83449-L</u>	<u>83449-K</u>	
Estimated Gallons	<u>10k</u>	<u>10k</u>	<u>12k</u>	<u>8k</u>	
Substance	<u>gas</u>				
Tank Material	<u>CP steel</u>		<u>comp</u>		
Tank Install Date	<u>2/1984</u>	<u>2/1984</u>	<u>2025</u>	<u>2025</u>	
Pipe Material			<u>flex</u>	<u>flex</u>	
Pipe Type	<u>pressure</u>				
Pipe Install Date	<u>?</u>	<u>?</u>	<u>2025</u>	<u>2025</u>	
Overfill Device	<u>alarm</u>				

**Notes and Comments from the UST database:**  Check file before conducting inspection

improve current MCP  
ATG in alarm

If tanks are manifolded, which tanks:

<b>III. Operating Certificate</b>		Compliance <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
<input checked="" type="checkbox"/> Current	<input type="checkbox"/> Accurate <u>NO</u>	<input checked="" type="checkbox"/> Posted for delivery drive to observe <u>only 2 tanks</u>

<b>IV. Operator Training</b>		Compliance <input type="checkbox"/> Yes <input type="checkbox"/> No
Class A/B Operator <input type="checkbox"/> Yes <input type="checkbox"/> No	Name: <u>Hindpract Sing</u>	Date: <u>12/29/12</u>
Class C Operator <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Cardlock	

<b>V. Financial Responsibility</b>		Compliance <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Type of coverage: <u>insurance</u>	Begin Date: <u>8/30/25</u>	End Date: <u>8/31/26</u>
Coverage amount correct: <u>yes</u>	Number of tanks covered:	<u>not signed</u>

Financial responsibility could also be in the form of self insurance, bonds, local government, trust fund, and or guarantee

<b>VI. Walkthrough Requirements</b>		Compliance <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Spill prevention and release detection equipment checked monthly?		<input type="checkbox"/> Yes <input type="checkbox"/> No
Tank top sumps checked annually?		<input type="checkbox"/> Yes <input type="checkbox"/> No

alarms not responded to

VII. Release Detection Compliance  Yes  No

a) Annual Release Detection Operability Testing (Sometimes referred to as Tank Gauge Certification)  
 8/20/25 2 new tank  
 Date of last testing: \_\_\_\_\_ Last three tests available?  Yes  No

b) Piping Release Detection (Check all that apply)

Pressurized Piping  
 Mechanical Leak Detector (MLLD)  Electronic Leak Detector (ELLD) - check for swift check requirement  
 Date of last testing: \_\_\_\_\_ Last three tests available?  Yes  No  
 Number of lines tested: \_\_\_\_\_ Number of LD tested: \_\_\_\_\_  
 Leak detector manufacturer make and model: \_\_\_\_\_  
 Tank gauge manufacturer make and model: \_\_\_\_\_  
 MLLD on turbine manifold?  Yes  No  
 MLLD product appropriate? (Example, diesel Red Jacket FX series on diesel system?)  Yes  No  
 If ELLD and no line testing: Annual 0.1 gph results from tank gauge?  Yes  No

Interstitial Monitoring

[Monthly records must include, date system was checked, observations made, initials of person checking. Electronic records must include power status (on or off), alarm indication status (yes or no) and sensor malfunction notes (yes or no).]  
 Date of last sump testing: \_\_\_\_\_ Last two tests available?  Yes  No  
 Date of last sensor testing: \_\_\_\_\_ Last three tests available?  Yes  No  
 Float sensors installed correctly?  Yes  No  
 Interstitial space opened to sump?  Yes  No  
 Presence of water in sumps?  Yes  No

Safe Suction

Check valve directly below suction pump?  Yes  No

c) Monthly Tank Release Detection (Check all that apply)

Tank Gauge  CSLD  SCALD  Static  
 Are correct tank sizes programmed at tank gauge?  Yes  No  
 Tank diameter/length seem appropriate?  Yes  No  
 Are tanks manifolded?  Yes  No  
 If so, tank gauge testing setup for manifolded tanks?  Yes  No

*If Veeder Root tank gauge leak detection*  
 CSLD set at 99%  
 Thermal coefficient set correctly?  
 (Gasoline 0.00070; Diesel 0.00045)  
*If Incon/Franklin tank gauge leak detection*  
 If SCALD is Vol Qual set to 14% (or 99% confidence)  
 Is API gravity set correctly?  
 (Regular 63.5; Plus 62.8; Super 51.3; Diesel 32.8)  
 For all tank gauges doing static tests  
 (Static tests require tank to be 50% full for a valid test)

Interstitial Monitoring [Monthly records must include, date system was checked, observations made, initials of person checking. Electronic records must include power status (on or off), alarm indication status (yes or no) and sensor malfunction notes (yes or no).]

SIR Ensure pass or fail results within 30-day period. Inconclusive result means release detection requirement not met

Tank release detection records available during inspection *none*

T1:	<input type="checkbox"/> Jan	<input type="checkbox"/> Feb	<input type="checkbox"/> Mar	<input type="checkbox"/> Apr	<input type="checkbox"/> May	<input type="checkbox"/> Jun	<input type="checkbox"/> Jul	<input type="checkbox"/> Aug	<input type="checkbox"/> Sep	<input type="checkbox"/> Oct	<input type="checkbox"/> Nov	<input type="checkbox"/> Dec
T2:	<input type="checkbox"/> Jan	<input type="checkbox"/> Feb	<input type="checkbox"/> Mar	<input type="checkbox"/> Apr	<input type="checkbox"/> May	<input type="checkbox"/> Jun	<input type="checkbox"/> Jul	<input type="checkbox"/> Aug	<input type="checkbox"/> Sep	<input type="checkbox"/> Oct	<input type="checkbox"/> Nov	<input type="checkbox"/> Dec
T3:	<input type="checkbox"/> Jan	<input type="checkbox"/> Feb	<input type="checkbox"/> Mar	<input type="checkbox"/> Apr	<input type="checkbox"/> May	<input type="checkbox"/> Jun	<input type="checkbox"/> Jul	<input type="checkbox"/> Aug	<input type="checkbox"/> Sep	<input type="checkbox"/> Oct	<input type="checkbox"/> Nov	<input type="checkbox"/> Dec
T4:	<input type="checkbox"/> Jan	<input type="checkbox"/> Feb	<input type="checkbox"/> Mar	<input type="checkbox"/> Apr	<input type="checkbox"/> May	<input type="checkbox"/> Jun	<input type="checkbox"/> Jul	<input type="checkbox"/> Aug	<input type="checkbox"/> Sep	<input type="checkbox"/> Oct	<input type="checkbox"/> Nov	<input type="checkbox"/> Dec
T5:	<input type="checkbox"/> Jan	<input type="checkbox"/> Feb	<input type="checkbox"/> Mar	<input type="checkbox"/> Apr	<input type="checkbox"/> May	<input type="checkbox"/> Jun	<input type="checkbox"/> Jul	<input type="checkbox"/> Aug	<input type="checkbox"/> Sep	<input type="checkbox"/> Oct	<input type="checkbox"/> Nov	<input type="checkbox"/> Dec

Inspector: FOSS

Date: 2/20/20

Time:

Facility: 7102

**VIII. Spill Prevention** Compliance  Yes  No

Date(s) of testing: 7/30/25 2 new tanks Number of spill buckets tested? \_\_\_\_\_

Did spill bucket pass most recent testing?  Yes  No If no, was spill bucket replaced/repaired?  Yes  No

During inspection, visual damage to spill bucket?  Yes  No

Hydrostatic testing (test takes one hour to complete)

Vacuum test (test takes 1 minute, ending vacuum must be 26 inches water column or greater)

*clean + diesel tested 1/124/20*

**IX. Overfill Prevention** Compliance  Yes  No

Date(s) of testing: 7/30/25 2 new tanks

Overfill device pass most recent testing?  Yes  No If no, overfill device replaced?  Yes  No

Overfill method that was tested:  Alarm  Flapper  Ball Float

Overfill Alarm

Alarm sounds when tank is 90% full  Yes  No

Driver can see or hear alarm at point of transfer?  Yes  No

Sound alarm from tank gauge during inspection?  Yes  No

Flapper Valve

Testing verified the valve automatically restricts flow at 95%  Yes  No

Visual observation of flapper on day of inspection?  Yes  No

Ball Float

Testing verified the ball float automatically restricts flow at 90%  Yes  No

Visual observation of ball float during inspection?  Yes  No

*clean + diesel 1/124/20*

**X. Corrosion Protection** Compliance  Yes  No

Cathodic  Galvanic  Impressed Current

Steel tank with cathodic?  Yes  No

Steel pipes with cathodic?  Yes  No

Steel flex-lines with cathodic?  Yes  No

Date of cathodic test: \_\_\_\_\_

Last two tests available?  Yes  No

Did last test pass?  Yes  No

If not:

Was failed test reported to DEQ?  Yes  No

Was system repaired?  Yes  No

Date of repair? \_\_\_\_\_

Cathodic retested within 6 mos. of repair?  Yes  No

Date of retesting? \_\_\_\_\_

If impressed current system:

Rectifier Operational?  Yes  No

Rectifier log maintained?  Yes  No

Rectifier been operating continuously  Yes  No

Tank Lining

Date of last test? \_\_\_\_\_

Pressure test conducted after tank lining inspection?  Yes  No


*no tests*

J.S 1996@Yahoo.com

XI. General notes from inspection


Representative onsite: \_\_\_\_\_

email: \_\_\_\_\_



Sensor not in lowest point

Water up to sensor level



Water level in tank is same as alarm

Compliance Determination:  No Violations Observed

Observed violations resulting in enforcement

Inspector Signature: \_\_\_\_\_

Date: \_\_\_\_\_

alarm history cleared

Submitted By: diana.foss\_deq

Submitted Time: February 20, 2026 11:08 AM

Creation Time: February 23, 2026 10:36 AM

### Date

February 20, 2026

### Time

09:20

### UST Facility ID

7,102


### Inspector

Foss

### Type of Inspection

Full Compliance

### Location



Esri, FAO, NOAA, USGS

Powered by Esri

Photograph



photos-20260220-172131.jpg



photos-20260220-172142.jpg



photos-20260220-172323.jpg



photos-20260220-172333.jpg



photos-20260220-172635clr.jpg




photos-20260220-172924.jpg



photos-20260220-172943.jpg



photos-20260220-174136.jpg




photos-20260220-174144.jpg



photos-20260220-174156die.jpg



photos-20260220-174342.jpg



photos-20260220-174546.jpg



photos-20260220-174731.jpg



photos-20260220-174908.jpg



photos-20260220-175242.jpg



photos-20260220-175307.jpg



photos-20260220-175344.jpg




photos-20260220-175530.jpg



photos-20260220-175537.jpg



photos-20260220-175545.jpg



photos-20260220-175551.jpg



photos-20260220-175559.jpg



photos-20260220-175638.jpg



photos-20260220-181209.jpg



photos-20260220-181315.jpg



photos-20260220-181420.jpg



photos-20260220-181532.jpg



photos-20260220-182201.jpg



photos-20260220-182309.jpg



photos-20260220-182510.jpg



photos-20260220-182800.jpg



photos-20260220-183035disp12.jpg



photos-20260220-184022.jpg



photos-20260220-184052.jpg

Company Phone: 480-521-0230

### Spill Bucket Testing Information

Test Method Developed By:  Manufacturer  Industry Standard  Professional Engineer  
 (Check Method/s) Other: (Specify) RP 1200

Test Method/Methods Used:  Hydrostatic  Vacuum  Pressure  
 (Check Method/s)  Manufacturer  Other (Specify)

Test Equipment Used: Manufacture per RP 1200 Liquid / Debris Removed:  Y  N  N/A

Contents:	Clear Turbine Sump	Diesel Turbine Sump	Super Turbine Sump	Unleaded Turbine Sump
Sump	Turbine - New	Turbine - New	Turbine - New	Turbine - New
Manufacturer / Type / Description / Model #	Bravo	Bravo	Bravo	Bravo
Single Wall / Double Wall	Single	Single	Single	Single
Diameter:	38.5	38.5	38.5	38.5
Depth:	20.5	21	21.5	22
Capacity:	-	-	-	-
Visual Inspection: (No Cracks, Tank Riser Cap Installed, Drain Valve Etc.)	Pass	Pass	Pass	Pass
Testing Method Utilized:	Hydrostatic	Hydrostatic	Hydrostatic	Hydrostatic
Test Start Time:	10:17	10:39	11:43	11:59
Initial Reading:	20.5	21	21.5	22
Test End Time:	11:22	11:58	12:59	13:06
Final Reading:	20.5	21	21.5	22
Test Duration:	1	1	1	1
Change in Reading:	0.0"	0.0"	0.0"	0.0"
Pass/Fail Threshold-Criteria:	1/8"	1/8"	1/8"	1/8"
Test Result:	Pass	Pass	Pass	Pass

NOTE: Pass Fail Criteria "Must" pass visual inspection and integrity Testing

Technicians' Signature: \_\_\_\_\_ Date: October 15, 2025

Comments: Total test time (24) hours - removed water on November 3, 2025 - No Loss

photos-20260220-184536.jpg



State of Oregon Department of Environmental Quality  
**UST Monthly Walkthrough Inspection Checklist**

Facility Name	Shell		Facility Address	58E Harbor Dr Warrenton, OR, 97146										
Year:	2026		Facility											
Is tank monitor/automatic tank gauge (ATG) (Veeder Root, Incon, etc.) powered on and in proper operating mode?	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug						
Have you responded to any leak detection alarm appropriately? Provide comments on the back page if there have been any alarms.	✓	✓												
Is the tank monitor / ATG providing a passing printout for 0.2 gph or are you keeping liquid status sensor printouts? Keep at least one per month.	N/A	N/A												
Are spill buckets free of damage for each tank? (No cracks, bulges or holes, no water or debris, etc.)	✓	✓												
Are fill pipes free of obstructions for each tank?	✓	✓												
Is the fill cap secure on the fill pipe for each tank?	✓	✓												
Are UDCs (Underground Detection Containments (UDC) free of damage, water,	✓	✓												

photos-20260220-185006.jpg

Is tank monitor/automatic tank sensor powered on and in proper operating mode?	✓	✓		
Have you responded to any leak detection alarm appropriately? Provide comments on the back page if there have been any alarms.	N/A	N/A		
Is the tank monitor / ATG providing a passing printout for 0.2 gph or are you keeping liquid status sensor printouts? Keep at least one per month.	✓	✓		
Are spill buckets free of damage for each tank? (No cracks, bulges or holes, no water or debris, etc.)	✓	✓		
Are fill pipes free of obstructions for each tank?	✓	✓		
Is the fill cap secure on the fill pipe for each tank?	✓	✓		
Are the under-dispenser containments (UDC) free of damage, water, debris and hazardous substances?	✓	✓		
Initials of person conducting walkthrough inspection:	AS	AS		
Date of walkthrough inspection:	01/07/25	02/16/25		

**Translation or other formats**

español | 한국어 | 繁體中文 | Русский | Tiếng Việt | العربية  
 00-452-4011 | TTY: 711 | [deainfo@deq.oregon.gov](mailto:deainfo@deq.oregon.gov)

photos-20260220-185101.jpg







# Oregon

Tina Kotek, Governor

## Department of Environmental Quality

700 NE Multnomah Street, Suite 600  
Portland, OR 97232  
(503) 229-5263  
FAX (503) 229-6945  
TTY 711

February 23, 2026

Hindpreet Singh  
Garibaldi Bay Inc.  
14135 SE Mill Plain Blvd  
Vancouver, Washington 98684

RE: Pre-enforcement Notice  
WARRENTON MINI MART TEXACO  
DEQ UST Facility ID No. 7102  
2026-PEN-10109

Attention Hindpreet Singh:

The Oregon Department of Environmental Quality (DEQ) believes WARRENTON MINI MART TEXACO has violated Oregon's environmental regulations at the underground storage tank (UST) facility 7102 located at 58 E Harbor Dr, Warrenton, Oregon 97146.

On 02/20/2026, the Department of Environmental Quality (DEQ) conducted an inspection at the above facility. Based upon this investigation, the Department has concluded that Garibaldi Bay Inc. is responsible for the following violations of Oregon environmental law:

### **Violations**

<b>Violation Description</b>	<b>Rule Reference</b>	<b>Corrective Action #</b>
(A4b) Failure to provide documentation of compliance with financial responsibility upon request	340-150-0163 (k)	1
(A5a) Failure to have a trained UST System Operator for an UST facility or to provide emergency response information.	340-150-0200 (1)	2
(A9) Failure to provide facility operating certificate number and tank identification number to a distributor when arranging a delivery.	340-150-0150 (2)	3
(A15) Failure to conduct monthly periodic operation and maintenance walkthrough inspection by 10/01/20 and each month thereafter.	340-150-0315(1)(a)(A)	4
(A16) Failure to conduct annual periodic operation and maintenance walkthrough inspection.	340-150-0315(a)(B)	5
(C1e) Failure to test spill prevention equipment and/or equipment used for interstitial monitoring of piping at least once every 3 years.	340-150-0310(8)(b)	6
(C2c) Failure to inspect overfill equipment at least once every 3 years.	340-150-0310(9)	7
(D2) Failure to continuously protect from corrosion any part of an UST system that routinely contains a regulated substance. (i.e., inoperable due to power off or interrupted such that protection is not continuously provided).	340-150-0325(1)	8
(D6) Failure to inspect impressed current corrosion protection system every 60 days.	340-150-0325(3)	9
(D5a) Failure to conduct the most recent 3-year corrosion protection test.	340-150-0325(2)(b)	10
(G2) Failure to operate or maintain a method or combination of methods for release detection such that the method can detect a release from any portion of the UST system.	340-150-0400(1)(c)	11

<b>Violation Description</b>	<b>Rule Reference</b>	<b>Corrective Action #</b>
(G5) Failure to install, operate, maintain or calibrate RD equipment per manufacturer's instructions, including service checks for operability or running condition (i.e. device has been incorrectly installed, is defective, damaged, or may have been tampered with.)	340-150-0400(1)(c)	12
(H2.9) Failure to perform an annual test of operation of line leak detector or annual test has not been conducted in accordance with manufacturer standards.	340-150-0410(2)(c)	13
(J8.5a) Failure to use interstitial monitoring equipment to monitor UST or suction piping for a release at least every 30 days and/or failure to record results on a monthly basis.	340-150-0465(3)	14
(J8.5b) Failure to use interstitial monitoring equipment to monitor pressurized piping for a release daily and/or failure to record results on a daily basis for each month.	340-150-0465(4)	15
(L1) Failure to report a suspected release.	340-150-0163(1)(f)	16
(L2) Failure to investigate or confirm a suspected release.	340-150-0163(1)(f)	17

You must take the following actions by the date indicated:

### **Corrective Actions**

<b>#</b>	<b>Corrective Action Description</b>	<b>Due Date</b>
1	Submit certificate of insurance signed by the underwriter	03/23/2026
2	Provide training to staff on site	03/23/2026
3	Post correct version of operating certificate with all tanks listed.	03/23/2026
4	Perform walkthrough inspections that actually include UDCs and state of ATG alarm. Record responses to alarms. Submit March walkthrough.	03/23/2026
5	Submit passing annual walkthrough inspection for clear premium and diesel tanks	03/23/2026
6	Submit passing spill bucket tests for clear premium and diesel tanks	03/23/2026
7	Submit passing overfill tests for clear premium and diesel tanks	03/23/2026
8	Submit passing cathodic protection test for clear premium and diesel tanks	03/23/2026
9	No further corrective action	
10	Submit passing cathodic protection test for clear premium and diesel tanks	02/23/2026
11	Submit photos of all tank top sumps and UDCs showing that sumps are clean and dry, and that sensors are position correctly at the lowest part of the sump, standing straight, flush with the sump floor	02/23/2026
12	Submit passing release detection operability test that include all sensors and probes	02/23/2026
13	Submit passing leak detector tests for clear premium and diesel tanks	02/23/2026
14	Submit monthly tank release detection records for all tanks. Continue in the future.	02/23/2026
15	Submit passing piping release detection records for all tanks. Continue into the future	02/23/2026
16	No further corrective action	
17	Investigate presence of fuel in tank top sumps and UDCs. Submit results of investigation and photographs showing that sumps are clean and dry.	03/23/2026

This matter is being referred to the Department's Office of Compliance and Enforcement for formal enforcement action, which may include assessment of civil penalties and/or issuance of a Department order. Your timely and responsive action on these items will be taken into consideration in any civil penalty assessment issued by the Department.

If you believe any of the facts in this Pre-Enforcement Notice are in error, you may provide written information to me at the address shown at the top of this letter. The Department will consider new information you submit in determining the appropriate enforcement actions that will be taken for this violation. Please feel free to contact the UST Duty Officer at [ust.dutyofficer@deq.oregon.gov](mailto:ust.dutyofficer@deq.oregon.gov) or at (503) 229 - 5034 if you have any questions about compliance with DEQ's UST regulations.

Sincerely,

*Diana Foss*

Diana Foss  
Senior Policy Analyst  
Underground Storage Tanks  
Compliance Program