

Earl T... Dec 3...

Oregon Department of Environmental Quality - Underground Storage Tank Program
Technical Compliance Inspection - UST Inspection Report

Inspector: Blake Gilbert Date: 02/12/2025 Time: 8:00am Facility: 6216

I. Site Information

Facility Name: <u>Astro #206</u>	Permittee: <u>Glenn Zirkle</u>	Contact
Site Address: <u>1111 NW 21ST AVE,</u>	Organization: <u>Early Oil, LLC</u>	Phone
City: <u>PORTLAND, OR 97209</u>	Phone: <u>503-243-2929</u>	

II. Tank Information

DEQ Permit #	BHEKK	BHEKA	BHEKB		
Estimated Gallons	12000	6000	6000		
Substance	G	D	BIO D		
Tank Material	FRP	FRP	FRP		
Tank Install Date	02/18/2019	2019	2019		
Pipe Material	F	F	F		
Pipe Type	P	P	P		
Pipe Install Date	02/18/2019	2019	2019		
Overfill Device	?	?	?		

Check file before conducting inspection

Notes and Comments from the UST database:

If tanks are manifolded, which tanks:

Compliance Yes No

III. Operating Certificate

Current Accurate Posted for delivery drive to observe

Compliance Yes No

IV. Operator Training

Class A/B Operator Yes No Name: Mike Zirkle Date: Aug 20 2010

Class C Operator Yes No Cardlock

Compliance Yes No

V. Financial Responsibility

Type of coverage: Yes No

Coverage amount correct: Yes No

Begin Date: 11-24-20 End Date: 11-20-20

Number of tanks covered: 3

Financial responsibility could also be in the form of self insurance, bonds, local government, trust fund, and or guarantee

Compliance Yes No

VI. Walkthrough Requirements

Spill prevention and release detection equipment checked monthly? Yes No

Tank top sumps checked annually? Yes No

VII. Release Detection

Compliance Yes No

a) Annual Release Detection Operability Testing (Sometimes referred to as Tank Gauge Certification)

Date of last testing: 4/7/25 9/15/24 5-5-23
 Last three tests available? Yes No

b) Piping Release Detection (Check all that apply)

Pressurized Piping

Mechanical Leak Detector (MLLD) Electronic Leak Detector (ELLD) - check for swiftcheck requirement

Date of last testing: 4/3/25 Last three tests available? Yes No

Number of lines tested: 3 Number of LD tested: 3

Leak detector manufacturer make and model: 99LD200

Tank gauge manufacturer make and model: Veeder 450

MLLD on turbine manifold? Yes No
 MLLD product appropriate? (Example, diesel Red Jacket FX series on diesel system?) Yes No
 If ELLD and no line testing: Annual 0.1 gph results from tank gauge? Yes No

Interstitial Monitoring

[Monthly records must include, date system was checked, observations made, initials of person checking. Electronic records must include power status (on or off), alarm indication status (yes or no) and sensor malfunction notes (yes or no).]

Date of last sump testing: 4/3/25 Last two tests available? Yes No

Date of last sensor testing: 4/3/25 Last three tests available? Yes No

Float sensors installed correctly? Yes No
 Interstitial space opened to sump? Yes No
 Presence of water in sumps? Yes No

Safe Suction

Check valve directly below suction pump? Yes No

c) Monthly Tank Release Detection (Check all that apply)

Tank Gauge CSLD SCALD Static
 Are correct tank sizes programmed at tank gauge? Yes No
 Tank diameter/length seem appropriate? Yes No
 Are tanks manifolded? Yes No
 If so, tank gauge testing setup for manifolded tanks? Yes No

If Veeder Root tank gauge leak detection

CSLD set at 99%

Thermal coefficient set correctly? (Gasoline 0.00070; Diesel 0.00045)

If Incon/Franklin tank gauge leak detection

If SCALD is Vol Qual set to 14% (or 99% confidence)

Is API gravity set correctly? (Regular 63.5; Plus 62.8; Super 51.3; Diesel 32.8)

For all tank gauges doing static tests (Static tests require tank to be 50% full for a valid test)

Interstitial Monitoring [Monthly records must include, date system was checked, observations made, initials of person checking. Electronic records must include power status (on or off), alarm indication status (yes or no) and sensor malfunction notes (yes or no).] Yes

SIR Ensure pass or fail results within 30-day period. Inconclusive result means release detection requirement not met

2020 ATG print w/...

Tank release detection records available during inspection

T1:	<input checked="" type="checkbox"/> Jan	<input checked="" type="checkbox"/> Feb	<input checked="" type="checkbox"/> Mar	<input checked="" type="checkbox"/> Apr	<input checked="" type="checkbox"/> May	<input checked="" type="checkbox"/> Jun	<input checked="" type="checkbox"/> Jul	<input checked="" type="checkbox"/> Aug	<input checked="" type="checkbox"/> Sep	<input checked="" type="checkbox"/> Oct	<input checked="" type="checkbox"/> Nov	<input checked="" type="checkbox"/> Dec
T2:	<input checked="" type="checkbox"/> Jan	<input checked="" type="checkbox"/> Feb	<input checked="" type="checkbox"/> Mar	<input checked="" type="checkbox"/> Apr	<input checked="" type="checkbox"/> May	<input checked="" type="checkbox"/> Jun	<input checked="" type="checkbox"/> Jul	<input checked="" type="checkbox"/> Aug	<input checked="" type="checkbox"/> Sep	<input checked="" type="checkbox"/> Oct	<input checked="" type="checkbox"/> Nov	<input checked="" type="checkbox"/> Dec
T3:	<input checked="" type="checkbox"/> Jan	<input checked="" type="checkbox"/> Feb	<input checked="" type="checkbox"/> Mar	<input checked="" type="checkbox"/> Apr	<input checked="" type="checkbox"/> May	<input checked="" type="checkbox"/> Jun	<input checked="" type="checkbox"/> Jul	<input checked="" type="checkbox"/> Aug	<input checked="" type="checkbox"/> Sep	<input checked="" type="checkbox"/> Oct	<input checked="" type="checkbox"/> Nov	<input checked="" type="checkbox"/> Dec
T4:	<input type="checkbox"/> Jan	<input type="checkbox"/> Feb	<input type="checkbox"/> Mar	<input type="checkbox"/> Apr	<input type="checkbox"/> May	<input type="checkbox"/> Jun	<input type="checkbox"/> Jul	<input type="checkbox"/> Aug	<input type="checkbox"/> Sep	<input type="checkbox"/> Oct	<input type="checkbox"/> Nov	<input type="checkbox"/> Dec
T5:	<input type="checkbox"/> Jan	<input type="checkbox"/> Feb	<input type="checkbox"/> Mar	<input type="checkbox"/> Apr	<input type="checkbox"/> May	<input type="checkbox"/> Jun	<input type="checkbox"/> Jul	<input type="checkbox"/> Aug	<input type="checkbox"/> Sep	<input type="checkbox"/> Oct	<input type="checkbox"/> Nov	<input type="checkbox"/> Dec

Inspector: Blake Gilbert

Date: 2/19/26

Time: 8:00

Facility: B216

Correct
Mistake

VIII. Spill Prevention

Compliance

Yes No

Date(s) of testing: 4/3/25 6/13/22 Number of spill buckets tested? 3

Did spill bucket pass most recent testing? Yes No If no, was spill bucket replaced/repaired? Yes No

During inspection, visual damage to spill bucket? Yes No

Hydrostatic testing (test takes one hour to complete)

Vacuum test (test takes 1 minute, ending vacuum must be 26 inches water column or greater)

IX. Overfill Prevention

Compliance

Yes No

Date(s) of testing: 4/3/25 6/13/22

Overfill device pass most recent testing? Yes No If no, overfill device replaced? Yes No

Overfill method that was tested: Alarm Flapper Ball Float

Overfill Alarm

Alarm sounds when tank is 90% full Yes No
Driver can see or hear alarm at point of transfer? Yes No
Sound alarm from tank gauge during inspection? Yes No

Flapper Valve

Testing verified the valve automatically restricts flow at 95% Yes No
Visual observation of flapper on day of inspection? Yes No

Ball Float

Testing verified the ball float automatically restricts flow at 90% Yes No
Visual observation of ball float during inspection? Yes No

X. Corrosion Protection

Compliance

Yes No

Cathodic Galvanic Impressed Current

Steel tank with cathodic? Yes No

Steel pipes with cathodic? Yes No

Steel flex-lines with cathodic? Yes No

Date of cathodic test: _____

Last two tests available? Yes No

Did last test pass? Yes No

If not:

Was failed test reported to DEQ? Yes No

Was system repaired? Yes No

Date of repair? _____

Cathodic retested within 6 mos. of repair? Yes No

Date of retesting? _____

If impressed current system:

Rectifier Operational? Yes No

Rectifier log maintained? Yes No

Rectifier been operating continuously Yes No

Tank Lining

Date of last test? _____

Pressure test conducted after tank lining inspection? Yes No

not

N

XI. General notes from inspection

Representative onsite: Mike Z email: _____

(D)

(F)

(F)

(V)

Verified alarm history, set up, audible alarm, stills good
~~class~~ Records onsite all good.

SHOCK

E

(F)

(V)

(P)

(R)

Compliance Determination: No Violations Observed Observed violations resulting in enforcement

Inspector Signature: Blake Gilbert *Blake Gilbert*

Date: 2/19/26

S

V

Other

Alarm

UST Inspection Survey

Submitted by: blakely.gilbert_deq

Submitted time: Feb 19, 2026, 9:00:43 AM

Date

Feb 19, 2026

Time

08:03

UST Facility ID

6,216

Inspector


Gilbert

Type of Inspection

Full Compliance

Location

Lat: 45.530743 Lon: -122.694977



Esri, FAO, NOAA, USGS

Powered by Esri

Photograph



photos-20260219-165810.jpg




photos-20260219-165717.jpg



photos-20260219-164932.jpg




photos-20260219-165413.jpg




photos-20260219-161525.jpg




photos-20260219-164254.jpg



photos-20260219-161507.jpg




photos-20260219-161428.jpg




photos-20260219-164405.jpg




photos-20260219-165159.jpg



photos-20260219-164303.jpg



photos-20260219-164355.jpg



photos-20260219-161519.jpg



photos-20260219-164238.jpg



photos-20260219-161456.jpg



Oregon

Tina Kotek, Governor

Department of Environmental Quality

Northwest Region

700 NE Multnomah Street, Suite 600

Portland, OR 97232

(503) 229-5263

FAX (503) 229-6945

TTY 711

02/23/26

Mike Zirkle
ASTRO #206
1111 NW 21st Ave
PORTLAND, OR 97209

RE: UST Determination Letter
DEQ UST # 6216

Mike,

The Oregon Department of Environmental Quality (DEQ) finalized the underground storage tank (UST) full compliance inspection that was conducted at the facility listed above on February 19, 2026. The purpose of this letter is to inform you of the results of this inspection. Based on the records available and site conditions, the DEQ inspector did not observe any violations with applicable State of Oregon UST rules on this day.

During an inspection, DEQ attempts to conduct a thorough review of the UST system. Nonetheless, you, as the permittee and owner, remain responsible for complying with all applicable UST rules. Therefore, if a violation is observed during a subsequent inspection, the facility will be cited for this violation and may be subject to civil penalties.

The DEQ appreciates your efforts to operate and maintain your UST system in compliance with Oregon environmental law. This facility is subject to future inspections. Please remember to conduct service and maintenance inspections and periodic testing at the required intervals and to implement and/or maintain adequate record keeping. Some general recommendations for maintaining UST compliance are listed below.

- Monitor tanks and piping for leaks and keep twelve months of monthly and or daily records as necessary for your specific systems. **Notify the DEQ any leak test results indicating the possibility of a release (i.e., test failure) within 24 hours as a suspected release (OAR 340-150-0500) and immediately begin investigation under OAR 340-150-0510.**
- Maintain financial responsibility coverage for pollution liability.
- Keep spill prevention devices emptied and clean – particularly just before fuel deliveries.
- Schedule and complete UST system corrosion protection testing on the required 3 year schedule, if necessary.
- Monitor fuel delivery records for signs of overfilling to capacity and make corrections to defective overfill prevention equipment or improper delivery procedures as necessary.

- Be aware of any suspected release condition and keep an alarm log to record any such conditions. Suspected release conditions include failed tank or piping leak tests, fuel or liquid sensor alarms, fuel is found in secondary containments or when liquid of any kind (dry or vacuum systems) is found in a tank interstitial space. Such conditions must be reported to the DEQ within 24 hours and an investigation into the cause must be conducted.
- Contact your service provider for assistance with testing and alarm investigation.
- Contact your service provider and begin an investigation if you suspect fuel loss, equipment is malfunctioning, leak detectors are triggering, or product lines are losing prime.
- Report a confirmed release to the DEQ within 24 hours of confirming product loss into the subsurface in any amount.

Please contact me if you have any questions about this matter at the DEQ Northwest office at 503-360-4408 or blakely.gilbert@deq.oregon.gov.

Blake GILBERT

Blake Gilbert
Natural Resource Specialist
Underground Storage Tank Program



APPENDIX C-7

**AUTOMATIC TANK GAUGE
OPERATION INSPECTION**

PORTLAND 800.452.5019
SEATTLE 800.481.7311
TRI-CITIES 888.450.7867
ANCHORAGE 855.715.7867

Facility Name: WSCO Astro #206		Owner: WSCO Petroleum Corp.	
Address: 1111 NW 21st Avenue		Address: 2929 NW 29th Avenue	
City, State, Zip Code: Portland, OR 97210		City, State, Zip Code: Portland, OR. 97210	
Facility I.D. #:		Phone #:	
Testing Company: Mascott Equipment CO.		Phone #: (800) 452-5019	Date:
This procedure is to determine whether the ATG is operating properly. See PEI/RP1200, Section 8.2 for the inspection procedure. This procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place.			
Tank Number	1	2	3
Product Stored	Unleaded	Super	Diesel
ATG Brand and Model	V-R TLS-450	V-R TLS-450	V-R TLS-450
1. Tank Volume, gallons	11608	6118	6118
2. Tank Diameter, inches	91	91	91
3. After removing the ATG from the tank, has it been inspected and any damaged or missing parts replaced?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Yes <input type="checkbox"/> No
4. Float moves freely on the stem without binding?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Yes <input type="checkbox"/> No
5. Does the fuel float level agree with the value programmed into the console?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Yes <input type="checkbox"/> No
6. Does the water float level agree with the value programmed into the console?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Yes <input type="checkbox"/> No
7. Inch level from bottom of stem when 90% alarm is triggered.	76	76	76
8. Does inch level at which the overfill alarm activates correspond with value programmed in the gauge?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Yes <input type="checkbox"/> No
9. Inch level from the bottom when the water float first triggers an alarm.	2	2	2
10. Does inch level at which the water float alarm activates correspond with value programmed in the gauge?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Yes <input type="checkbox"/> No
If any answers in Lines 3, 4, 5, or 6 are "No," the system has failed the test.			
Test Results	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail <input type="checkbox"/> Pass <input type="checkbox"/> Fail
Comments:			

Tester's Name **D. Reeves** Tester's Signature *D. Reeves*