



Annual Release Detection Operability Testing Form

- In-tank setup and alarm history reports must be attached to testing form.
- Maintain three years of testing records.
- [Instructions on how to use this form.](#)

I. FACILITY INFORMATION – Type or print (in ink) all items.				TEST DATE
Facility ID #:	2158	Facility Name:	UNITED PACIFIC #7470	11/5/25
II. AUTOMATIC TANK GAUGE				<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail
ATG Manufacturer:	Veeder-Root		ATG Model:	TLS-350
Release Detection Method:		Tank Gauge 0.2 gph leak tests: (<input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Static) <input type="checkbox"/> SIR <input type="checkbox"/> Interstitial Monitoring		
Battery Backup Functional?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	ATG software properly programmed? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
ATG alarms functional and audible?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	ATG In-Tank Setup Reports attached to form? <input checked="" type="checkbox"/> Yes		
III. TEST PROCEDURE				
<input type="checkbox"/> PEI/RP 1200	<input checked="" type="checkbox"/> Oregon Testing Procedures (Page 2)	<input type="checkbox"/> Manufacturer Testing Procedures	<input type="checkbox"/> Other Method (Describe)	

IV. PROBE AND TESTING INFORMATION

Tank Number	844	845	846	847	
Product Stored	Gas	Diesel	Diesel	Gas	
Model	Mag	Mag	Mag	Mag	
Is the ATG console clear of alarms?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No			
Disconnect cable from tank probe. Is appropriate alarm triggered?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No			
Tank gauge probes removed and inspected for damage?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No			
Residual buildup on floats has been removed?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No			
Float(s) move freely?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No			
Measured product and water levels match ATG values?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No			
Alarm history report attached?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No			
V. TEST RESULT	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail			

Any "No" answer indicates the test failed. Failed tests must be remedied and retested immediately.

VIII. COMMENTS

The comments section should be used to note additional information discovered or actions taken during testing that affect compliance

IX. TESTER

Person conducting testing: D. Reeves

SOFTWARE REVISION LEVEL
 VERSION 130.01
 SOFTWARE# 346130-100-B
 CREATED - 10.07.23.17.44
 S-MODULE# 330160-002-A
 SYSTEM FEATURES:
 PERIODIC IN-TANK TESTS
 ANNUAL IN-TANK TESTS
 OSLD

SYSTEM SETUP
 NOV 5, 2025 8:22 AM

SYSTEM UNITS
 U.S.
 SYSTEM LANGUAGE
 ENGLISH
 SYSTEM DATE/TIME FORMAT
 MON DD YYYY HH:MM:SS AM
 PO-F 3-147
 49950 MAY 26
 BANKS, OR 97106

SHIFT TIME 1 : DISABLED
 SHIFT TIME 2 : DISABLED
 SHIFT TIME 3 : DISABLED
 SHIFT TIME 4 : DISABLED
 TANK PER TEST NEEDED WRN
 DISABLED
 TANK ANN TEST NEEDED WRN
 DISABLED
 LINE RE-ENABLE METHOD
 PASS LINE TEST
 LINE PER TEST NEEDED WRN
 DISABLED
 LINE ANN TEST NEEDED WRN
 DISABLED
 PRINT TO VOLLMERS
 ENABLED
 TEMP COMPENSATION
 VALUE (DEG F) : 60.0
 STICK HEIGHT OFFSET
 DISABLED
 HILAGE: 90%
 H-PROTOCOL DATA FORMAT
 HEIGHT
 DAYLIGHT SAVING TIME
 DISABLED
 RE-DIRECT LOCAL PRINTOUT
 DISABLED

EURO PROTOCOL PREFIX
 S

SYSTEM SECURITY
 CODE : 000000

TANK CHART SECURITY
 DISABLED

CUSTOM ALARMS
 DISABLED

SERVICE NOTICE
 DISABLED

130 3166 COUNTPY
 CODE:

MASS/DENSITY
 DISABLED

IN-TANK SETUP

T 1: DIESEL MAIN : 1
 PRODUCT CODE : .000470
 THERMAL COEFF : 95.00
 TANK DIAMETER : 1 FT
 TANK PROFILE : 1 FT
 FULL VOL : 4065

FLOAT SIZE: 4.0 IN.

WATER WARNING : 0.8
 HIGH WATER LIMIT: 2.0

MAX OR LABEL VOL: 4065
 OVERFILL LIMIT : 90%
 : 3658

HIGH PRODUCT : 95%
 : 3861

DELIVERY LIMIT : 30%
 : 1219

LOW PRODUCT : 1000
 LEAK ALARM LIMIT: 99
 SUDDEN LOSS LIMIT: 99
 TANK TILT : 2.00
 PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
 T#: 02
 LINE MANIFOLDED TANKS
 T#: NONE

LEAK MIN PERIODIC: 0%
 PERIODIC TEST TYPE
 STANDARD

PERIODIC TEST FAIL
 ALARM DISABLED

GROSS TEST FAIL
 ALARM DISABLED

PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TEST SIPHON BREAK:OFF
 DELIVERY DELAY : 5 MIN
 PUMP THRESHOLD : 10.00%

PORT SETTINGS:

COMM BOARD : 2 (RS-232)
 BAUD RATE : 2400
 PARITY : EVEN
 STOP BIT : 1 STOP
 DATA LENGTH: 7 DATA
 RS-232 SECURITY
 CODE : DISABLED

AUTO TRANSMIT SETTINGS:

AUTO LEAK ALARM LIMIT
 DISABLED
 AUTO HIGH WATER LIMIT
 DISABLED
 AUTO OVERFILL LIMIT
 DISABLED
 AUTO LOW PRODUCT
 DISABLED
 AUTO THEFT LIMIT
 DISABLED
 AUTO DELIVERY START
 DISABLED
 AUTO DELIVERY END
 DISABLED
 AUTO EXTERNAL INPUT ON
 DISABLED
 AUTO EXTERNAL INPUT OFF
 DISABLED
 AUTO SENSOR FUEL ALARM
 DISABLED
 AUTO SENSOR WATER ALARM
 DISABLED
 AUTO SENSOR OUT ALARM
 DISABLED

RS-232 END OF MESSAGE
 DISABLED

T 2:DIESEL
 PRODUCT CODE :
 THERMAL COEFF : .000045
 TANK DIAMETER : 95.00
 TANK PROFILE : 1 PT
 FULL VOL : 4065

FLOAT SIZE: 4.0 IN.

WATER WARNING : 0.8
 HIGH WATER LIMIT: 2.0

MAX OR LABEL VOL.: 4065
 OVERFILL LIMIT : 90%
 HIGH PRODUCT : 3658
 DELIVERY LIMIT : 3861
 : 30%
 : 1219

LOW PRODUCT : 1000
 LEAK ALARM LIMIT: 99
 SUDDEN LOSS LIMIT: 99
 TANK TILT : 6.40
 PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
 T#: 01
 LINE MANIFOLDED TANKS
 T#: NONE

LEAK MIN PERIODIC: 0%
 : 0

LEAK MIN ANNUAL : 0%
 : 0

PERIODIC TEST TYPE
 STANDARD

ANNUAL TEST FAIL
 ALARM DISABLED

PERIODIC TEST FAIL
 ALARM DISABLED

GROSS TEST FAIL
 ALARM DISABLED

ANN TEST AVERAGING: OFF
 PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN
 PUMP THRESHOLD : 10.00%

T 3:UNLEADED
 PRODUCT CODE :
 THERMAL COEFF : .000700
 TANK DIAMETER : 95.50
 TANK PROFILE : 1 PT
 FULL VOL : 10568

FLOAT SIZE: 4.0 IN.

WATER WARNING : 0.8
 HIGH WATER LIMIT: 2.0

MAX OR LABEL VOL.: 10568
 OVERFILL LIMIT : 90%
 HIGH PRODUCT : 9511
 DELIVERY LIMIT : 10039
 : 30%
 : 3170

LOW PRODUCT : 1579
 LEAK ALARM LIMIT: 99
 SUDDEN LOSS LIMIT: 99
 TANK TILT : 2.40
 PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
 T#: NONE
 LINE MANIFOLDED TANKS
 T#: NONE

LEAK MIN PERIODIC: 0%
 : 0

LEAK MIN ANNUAL : 0%
 : 0

PERIODIC TEST TYPE
 STANDARD

ANNUAL TEST FAIL
 ALARM DISABLED

PERIODIC TEST FAIL
 ALARM DISABLED

GROSS TEST FAIL
 ALARM DISABLED

ANN TEST AVERAGING: OFF
 PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN
 PUMP THRESHOLD : 10.00%

T 4:SUPER
 PRODUCT CODE :
 THERMAL COEFF : .000700
 TANK DIAMETER : 76.00
 TANK PROFILE : 1 PT
 FULL VOL : 3366

FLOAT SIZE: 4.0 IN.

WATER WARNING : 0.8
 HIGH WATER LIMIT: 2.0

MAX OR LABEL VOL.: 3866
 OVERFILL LIMIT : 90%
 HIGH PRODUCT : 3479
 DELIVERY LIMIT : 3672
 : 30%
 : 1159

LOW PRODUCT : 1470
 LEAK ALARM LIMIT: 39
 SUDDEN LOSS LIMIT: 99
 TANK TILT : 1.65
 PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
 T#: NONE
 LINE MANIFOLDED TANKS
 T#: NONE

LEAK MIN PERIODIC: 0%
 : 0

LEAK MIN ANNUAL : 0%
 : 0

PERIODIC TEST TYPE
 STANDARD

ANNUAL TEST FAIL
 ALARM DISABLED

PERIODIC TEST FAIL
 ALARM DISABLED

GROSS TEST FAIL
 ALARM DISABLED

ANN TEST AVERAGING: OFF
 PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN
 PUMP THRESHOLD : 10.00%

LEAK TEST METHOD

TEST OSLD : ALL TANK
Pd = 99%
CLIMATE FACTOR:MODERATE

REPORT ONLY:
DISABLED

TEST EARLY STOP:DISABLED
LEAK TEST RELOFT FORMAT
ENHANCED

MAINTY TEST:2 T

TRUCKER STATUS:METSYS

MAY 14:01 5202 5 AM

90166 NO. S/NMBA
90 AMH 09666F
PC-F41-3 J-04

ALARM HISTORY REPORT

IN TANK ALARM

T 1:DIESEL MAIN

HIGH WATER ALARM

NOV 5, 2025 9:49 AM
NOV 7, 2024 11:50 AM
NOV 15, 2023 1:07 PM

OVERFILL ALARM

SEP 12, 2021 9:44 PM

LOW PRODUCT ALARM

JUN 17, 2025 10:28 AM
JUN 17, 2025 10:12 AM
NOV 7, 2024 11:42 AM

INVALID FUEL LEVEL

NOV 7, 2024 12:41 PM
NOV 7, 2024 11:42 AM
AUG 6, 2024 7:37 AM

PROBE OUT

NOV 5, 2025 10:07 AM
NOV 5, 2025 9:44 AM
JUN 23, 2025 11:24 AM

HIGH WATER WARNING

NOV 5, 2025 9:49 AM
JUN 17, 2025 10:20 AM
JUN 16, 2025 9:35 PM

DELIVERY NEEDED

JUN 17, 2025 10:28 AM
JUN 17, 2025 10:12 AM
JUN 1, 2025 10:21 AM

OSLD INCR RATE ALARM

AUG 2, 2024 11:32 PM
MAY 24, 2024 9:24 PM
AUG 30, 2023 10:52 PM

LOW TEMP WARNING

JUN 17, 2025 4:01 AM
JUN 16, 2025 9:20 PM
JUN 16, 2025 4:26 PM

***** END *****

SYSTEM STATUS REPORT

MAINTY TEST:2 T

L 3:SUMP
TRI-STATE (SINGLE FLOAT)
CATEGORY : OTHER SENSORS

L 4:SUMP
TRI-STATE (SINGLE FLOAT)
CATEGORY : OTHER SENSORS

MAY 9:01 5202 5 AM

90166 NO. S/NMBA
90 AMH 09666F
PC-F 3-147

NOV 5, 2025 10:35 AM

L 3:SUMP
OTHER SENSORS
FUEL ALARM

L 4:SUMP
OTHER SENSORS
FUEL ALARM

NOV 5, 2025 10:34 AM

ALARM HISTORY REPORT

IN-TANK ALARM

T 2:DIESEL

HIGH WATER ALARM
 NOV 5. 2025 9:49 AM
 NOV 7. 2024 11:50 AM
 NOV 16. 2023 11:03 PM

LOW PRODUCT ALARM
 NOV 28. 2024 8:21 AM
 NOV 16. 2023 12:58 PM
 NOV 18. 2022 11:08 AM

PROBE OUT
 NOV 5. 2025 10:05 AM
 NOV 5. 2025 9:42 AM
 JUN 17. 2025 9:49 AM

HIGH WATER WARNINGS
 NOV 5. 2025 9:49 AM
 NOV 7. 2024 11:50 AM
 NOV 16. 2023 11:03 PM

DELIVERY NEEDED
 AUG 19. 2025 5:31 AM
 AUG 10. 2025 1:08 PM
 JUN 1. 2025 8:44 AM

PERIODIC TEST FAIL
 MAY 19. 2024 2:47 PM
 APR 29. 2024 1:36 PM
 JUL 7. 2023 5:53 PM

SELD INCR RATE WARN
 AUG 2. 2024 11:32 PM
 JUL 30. 2024 9:13 PM

LOW TEMP WARNINGS
 JUN 17. 2025 9:51 AM
 NOV 7. 2024 12:42 PM
 NOV 18. 2022 11:09 AM

***** END *****

ALARM HISTORY REPORT

IN-TANK ALARM

T 3:UNLEADED

HIGH WATER ALARM
 NOV 5. 2025 9:45 AM
 NOV 7. 2024 11:42 AM
 NOV 16. 2023 11:06 PM

LOW PRODUCT ALARM
 OCT 23. 2025 7:48 PM
 SEP 27. 2025 11:49 AM
 SEP 19. 2025 7:29 PM

HIGH PRODUCT ALARM
 AUG 14. 2020 12:37 PM
 AUG 14. 2020 11:36 AM

INVALID FUEL LEVEL
 SEP 1. 2025 9:21 PM
 AUG 26. 2025 1:58 PM
 AUG 10. 2025 11:22 AM

PROBE OUT
 NOV 5. 2025 10:01 AM
 NOV 5. 2025 9:59 AM
 NOV 5. 2025 9:38 AM

HIGH WATER WARNING
 NOV 5. 2025 9:45 AM
 OCT 27. 2025 8:22 AM
 JUL 17. 2025 9:37 PM

DELIVERY NEEDED
 NOV 3. 2025 10:02 AM
 OCT 30. 2025 9:33 AM
 OCT 22. 2025 8:48 PM

MAX PRODUCT ALARM
 AUG 14. 2020 12:37 PM
 AUG 14. 2020 11:36 AM

LOW TEMP WARNING
 NOV 5. 2025 10:00 AM
 AUG 14. 2020 12:26 PM

***** END *****

ALARM HISTORY REPORT

IN-TANK ALARM

T 4:SUPER

HIGH WATER ALARM
 NOV 5. 2025 9:41 AM
 NOV 7. 2024 12:30 PM
 AUG 17. 2020 9:11 AM

OVERFILL ALARM
 DEC 15. 2023 10:46 AM
 JAN 11. 2023 1:14 AM
 MAR 17. 2022 11:18 AM

LOW PRODUCT ALARM
 NOV 5. 2025 9:35 AM
 SEP 22. 2025 8:12 AM
 AUG 20. 2025 2:59 PM

HIGH PRODUCT ALARM
 NOV 18. 2022 11:16 AM
 AUG 17. 2020 9:02 AM
 AUG 17. 2020 8:59 AM

INVALID FUEL LEVEL
 JAN 30. 2025 10:15 AM
 AUG 19. 2023 1:18 AM
 AUG 13. 2023 9:54 AM

PROBE OUT
 NOV 5. 2025 9:53 AM
 NOV 5. 2025 9:36 AM
 FEB 13. 2025 8:32 AM

HIGH WATER WARNING
 NOV 5. 2025 9:41 AM
 FEB 12. 2025 4:42 PM
 JAN 30. 2025 11:06 AM

DELIVERY NEEDED
 AUG 22. 2025 1:41 PM
 JUL 13. 2025 11:47 AM
 JUN 8. 2025 2:35 PM

MAX PRODUCT ALARM
 NOV 18. 2022 11:16 AM
 AUG 17. 2020 9:02 AM
 AUG 17. 2020 9:01 AM

PERIODIC TEST FAIL
 JUL 20. 2020 9:07 AM

LOW TEMP WARNING
 NOV 5. 2025 9:58 AM
 AUG 17. 2020 8:31 AM
 AUG 17. 2020 6:32 AM

***** END *****

DEQ tank gauge and probe functionality testing procedures

1. Inspect console and verify that there are no active or recurring warnings or alarms.
2. Confirm that both the visual and audible alarms on the tank gauge console function correctly.
3. Verify that the correct set-up parameters for the probes and appropriate tank leak detection is programmed correctly.
4. Test battery backup (if present).
5. Remove tank probe from tank.
6. Disconnect probe, wait for "Probe Out" alarm, reconnect probe and reset tank gauge.
7. Remove build up from probes.
8. Measure the fuel and water contents of the tank and compare with the tank gauge inventory report ensuring that they are the same.
9. Ensure that the probe's fuel and water floats are the correct type for the product stored in the tank.
10. Reposition the floats, measure distance from bottom of the probe, and utilize tank charts to confirm accuracy of the tank gauge.
11. Reinstall probes ensuring that the tank riser cap seals properly and the communication cable seal is tight.
12. If tank gauge is equipped with printer, attach the printed tank gauge in-tank setup and alarm history report demonstrating that probes were tested.

DEQ sensor functionality testing procedures

1. Inspect sensor for damage.
2. Place sensor in at least three inches of testing liquid.
3. Verify sensor alarms at tank gauge or sensor has appropriate alarm response (dispenser or turbine shut down).
4. Clear alarm.
5. Reinstall sensor upon verification of proper operation.
6. If tank gauge is equipped with printer, attach the printed tank gauge in-tank setup and alarm history report demonstrating that sensors were tested.



Annual Release Detection Operability Testing Form

- In-tank setup and alarm history reports must be attached to testing form.
- Maintain three years of testing records.
- [Instructions on how to use this form.](#)

I. FACILITY INFORMATION – Type or print (in ink) all items.				TEST DATE
Facility ID #:	2158	Facility Name:	UNITED PACIFIC #7470	11/5/25
II. AUTOMATIC TANK GAUGE				<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail
ATG Manufacturer:	Veeder-Root		ATG Model:	TLS-350
Release Detection Method:		Tank Gauge 0.2 gph leak tests: (<input checked="" type="checkbox"/> Continuous <input type="checkbox"/> Static) <input type="checkbox"/> SIR <input type="checkbox"/> Interstitial Monitoring		
Battery Backup Functional?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		ATG software properly programmed? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
ATG alarms functional and audible?	<input type="checkbox"/> Yes <input type="checkbox"/> No		ATG In-Tank Setup Reports attached to form? <input checked="" type="checkbox"/> Yes	
III. TEST PROCEDURE				
<input type="checkbox"/> PEI/RP 1200	<input checked="" type="checkbox"/> Oregon Testing Procedures (Page 2)		<input type="checkbox"/> Manufacturer Testing Procedures	<input type="checkbox"/> Other Method (Describe)

IV. PROBE AND TESTING INFORMATION					
Tank Number	844	845	846	847	
Product Stored	Gas	Diesel	Diesel	Gas	
Model	Mag	Mag	Mag	Mag	
Is the ATG console clear of alarms?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No			
Disconnect cable from tank probe. Is appropriate alarm triggered?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No			
Tank gauge probes removed and inspected for damage?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No			
Residual buildup on floats has been removed?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No			
Float(s) move freely?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No			
Measured product and water levels match ATG values?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No			
Alarm history report attached?	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No			
V. TEST RESULT	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail			
Any "No" answer indicates the test failed. Failed tests must be remedied and retested immediately.					
VIII. COMMENTS					
The comments section should be used to note additional information discovered or actions taken during testing that affect compliance					
IX. TESTER					
Person conducting testing:	D. Reeves				

SYSTEM SETUP

NOV 7, 2024 10:29 AM

COMMUNICATIONS SETUP

IN-TANK SETUP

SYSTEM UNITS : U.S.
 SYSTEM LANGUAGE : ENGLISH
 SYSTEM DATE/TIME FORMAT : MON DD YYYY HH:MM:SS XM

PC-F 3-147
 49950 HWY 26
 BANKS, OR 97106

SHIFT TIME 1 : DISABLED
 SHIFT TIME 2 : DISABLED
 SHIFT TIME 3 : DISABLED
 SHIFT TIME 4 : DISABLED

TANK PER TST NEEDED : WARN
 TANK ANN TST NEEDED : WARN
 DISABLED

LINE RE-ENABLE METHOD :
 PASS LINE TEST

LINE PER TST NEEDED : WARN
 LINE ANN TST NEEDED : WARN
 DISABLED

PRINT TO VOLUMES :
 ENABLED

TEMP COMPENSATION :
 VALUE (DEG F) : 60.0
 STICK HEIGHT OFFSET :
 DISABLED
 ULLAGE : 90%

H-PROTOCOL DATA FORMAT :
 HEIGHT :
 DAYLIGHT SAVING TIME :
 DISABLED
 RE-DIRECT LOCAL PRINTOUT :
 DISABLED

EURO PROTOCOL PREFIX :
 S

SYSTEM SECURITY :
 CODE : 000000

TANK CHART SECURITY :
 DISABLED

CUSTOM ALARMS :
 DISABLED

SERVICE NOTICE :
 DISABLED

ISO 3166 COUNTRY :
 CODE :

MASS/DENSITY :
 DISABLED

PORT SETTINGS:

COMM BOARD : 2 (RS-232)
 BAUD RATE : 2400
 PARITY : EVEN
 STOP BIT : 1 STOP
 DATA LENGTH: 7 DATA
 RS-232 SECURITY :
 CODE : DISABLED

AUTO TRANSMIT SETTINGS:

AUTO LEAK ALARM LIMIT :
 DISABLED
 AUTO HIGH WATER LIMIT :
 DISABLED
 AUTO OVERFILL LIMIT :
 DISABLED
 AUTO LOW PRODUCT :
 DISABLED
 AUTO THEFT LIMIT :
 DISABLED
 AUTO DELIVERY START :
 DISABLED
 AUTO DELIVERY END :
 DISABLED
 AUTO EXTERNAL INPUT ON :
 DISABLED
 AUTO EXTERNAL INPUT OFF :
 DISABLED
 AUTO SENSOR FUEL ALARM :
 DISABLED
 AUTO SENSOR WATER ALARM :
 DISABLED
 AUTO SENSOR OUT ALARM :
 DISABLED

RS-232 END OF MESSAGE :
 DISABLED

T 1:DIESEL MAIN : 1
 PRODUCT CODE : .000470
 THERMAL COEFF : 95.00
 TANK DIAMETER : 1 PT
 TANK PROFILE : 4065
 FULL VOL : 4065

FLOAT SIZE : 4.0 IN.
 WATER WARNINGS : 0.8
 HIGH WATER LIMIT : 2.0

MAX OR LABEL VOL : 4065
 OVERFILL LIMIT : 90%
 HIGH PRODUCT : 3658
 DELIVERY LIMIT : 95%
 : 3861
 : 30%
 : 1219

LOW PRODUCT : 1000
 LEAK ALARM LIMIT : 99
 SUDDEN LOSS LIMIT : 99
 TANK TILT : 2.00
 PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS :
 T#: 02
 LINE MANIFOLDED TANKS :
 T#: NONE

LEAK MIN PERIODIC : 0%
 PERIODIC TEST TYPE : 0
 STANDARD

PERIODIC TEST FAIL :
 ALARM DISABLED

GROSS TEST FAIL :
 ALARM DISABLED

PER TEST AVERAGING : OFF
 TANK TEST NOTIFY : OFF

TNK TST SIPHON BREAK:OFF
 DELIVERY DELAY : 5 MIN
 PUMP THRESHOLD : 10.00%

T 2:DIESEL
PRODUCT CODE : 2
THERMAL COEFF : .0000045
TANK DIAMETER : 95.00
TANK PROFILE : 1 PT
FULL VOL : 4065

FLOAT SIZE: 4.0 IN.

WATER WARNING : 0.8
HIGH WATER LIMIT: 2.0
MAX OR LABEL VOL: 4065
OVERFILL LIMIT : 90%
HIGH PRODUCT : 3658
DELIVERY LIMIT : 95%
 : 3861
 : 30%
 : 1219
LOW PRODUCT : 1000
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 6.40
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: 01
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 0%
 : 0
LEAK MIN ANNUAL : 0%
 : 0

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN
PUMP THRESHOLD : 10.00%

T 3:UNLEADED
PRODUCT CODE : 3
THERMAL COEFF : .000700
TANK DIAMETER : 95.50
TANK PROFILE : 1 PT
FULL VOL : 10568

FLOAT SIZE: 4.0 IN.

WATER WARNING : 0.8
HIGH WATER LIMIT: 2.0
MAX OR LABEL VOL: 10568
OVERFILL LIMIT : 90%
HIGH PRODUCT : 9511
DELIVERY LIMIT : 95%
 : 10039
 : 30%
 : 3170
LOW PRODUCT : 1579
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 2.40
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 0%
 : 0
LEAK MIN ANNUAL : 0%
 : 0

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN
PUMP THRESHOLD : 10.00%

T 4:SUPER
PRODUCT CODE : 4
THERMAL COEFF : .000700
TANK DIAMETER : 76.00
TANK PROFILE : 1 PT
FULL VOL : 3866

FLOAT SIZE: 4.0 IN.

WATER WARNING : 0.8
HIGH WATER LIMIT: 2.0
MAX OR LABEL VOL: 3866
OVERFILL LIMIT : 90%
HIGH PRODUCT : 3479
DELIVERY LIMIT : 95%
 : 3672
 : 30%
 : 1159
LOW PRODUCT : 1470
LEAK ALARM LIMIT: 99
SUDDEN LOSS LIMIT: 99
TANK TILT : 1.65
PROBE OFFSET : 0.00

SIPHON MANIFOLDED TANKS
T#: NONE
LINE MANIFOLDED TANKS
T#: NONE

LEAK MIN PERIODIC: 0%
 : 0
LEAK MIN ANNUAL : 0%
 : 0

PERIODIC TEST TYPE
STANDARD

ANNUAL TEST FAIL
ALARM DISABLED

PERIODIC TEST FAIL
ALARM DISABLED

GROSS TEST FAIL
ALARM DISABLED

ANN TEST AVERAGING: OFF
PER TEST AVERAGING: OFF

TANK TEST NOTIFY: OFF

TNK TST SIPHON BREAK:OFF

DELIVERY DELAY : 5 MIN
PUMP THRESHOLD : 10.00%

LEAK TEST METHOD

TEST CSLD : ALL TANK
Pd = 99%
CLIMATE FACTOR: MODERATE

REPORT ONLY:
DISABLED

TST EARLY STOP: DISABLED

LEAK TEST REPORT FORMAT
ENHANCED

LIQUID SENSOR SETUP

L 1: SUMP
TRI-STATE (SINGLE FLOAT)
CATEGORY : OTHER SENSORS

L 2: SUMP
TRI-STATE (SINGLE FLOAT)
CATEGORY : OTHER SENSORS

L 3: SUMP
TRI-STATE (SINGLE FLOAT)
CATEGORY : OTHER SENSORS

L 4: SUMP
TRI-STATE (SINGLE FLOAT)
CATEGORY : OTHER SENSORS

PC-F 3-147
49950 HWY 26
BANKS, OR 97106

NOV 7, 2024 10:15 AM

SYSTEM STATUS REPORT

ALL FUNCTIONS NORMAL

SENSOR ALARM

L 2: SUMP
OTHER SENSORS
FUEL ALARM
NOV 7, 2024 10:16 AM

SENSOR ALARM

L 4: SUMP
OTHER SENSORS
FUEL ALARM
NOV 7, 2024 10:17 AM

SENSOR ALARM

L 3: SUMP
OTHER SENSORS
FUEL ALARM
NOV 7, 2024 10:17 AM

SENSOR ALARM

L 1: SUMP
OTHER SENSORS
FUEL ALARM
NOV 7, 2024 10:17 AM

DEQ tank gauge and probe functionality testing procedures

1. Inspect console and verify that there are no active or recurring warnings or alarms.
2. Confirm that both the visual and audible alarms on the tank gauge console function correctly.
3. Verify that the correct set-up parameters for the probes and appropriate tank leak detection is programmed correctly.
4. Test battery backup (if present).
5. Remove tank probe from tank.
6. Disconnect probe, wait for "Probe Out" alarm, reconnect probe and reset tank gauge.
7. Remove build up from probes.
8. Measure the fuel and water contents of the tank and compare with the tank gauge inventory report ensuring that they are the same.
9. Ensure that the probe's fuel and water floats are the correct type for the product stored in the tank.
10. Reposition the floats, measure distance from bottom of the probe, and utilize tank charts to confirm accuracy of the tank gauge.
11. Reinstall probes ensuring that the tank riser cap seals properly and the communication cable seal is tight.
12. If tank gauge is equipped with printer, attach the printed tank gauge in-tank setup and alarm history report demonstrating that probes were tested.

DEQ sensor functionality testing procedures

1. Inspect sensor for damage.
2. Place sensor in at least three inches of testing liquid.
3. Verify sensor alarms at tank gauge or sensor has appropriate alarm response (dispenser or turbine shut down).
4. Clear alarm.
5. Reinstall sensor upon verification of proper operation.
6. If tank gauge is equipped with printer, attach the printed tank gauge in-tank setup and alarm history report demonstrating that sensors were tested.

This section for DEQ use only



State of Oregon
Department of
Environmental
Quality

Department of Environmental Quality
Underground Storage Tank Program

Field Citation
For UST Violations

DEQ Information		UST Facility Information	
Inspection Date:	02/18/2026	Facility ID#:	2158
Inspector:	Blakely GILBERT	Facility Name:	UNITED PACIFIC #7470
DEQ Office:	700 NE Multnomah St Suite 600 FLR # 14	Facility Address:	49950 NW Sunset Hwy, Banks, Oregon 97106-7611
Phone #:	503-360-4408	County:	Washington

Oregon DEQ inspected the facility listed above and identified the UST violations listed on page 3 of this Field Citation.

Field Citation Issued: In Person By Email Both Date Issued: 02/19/2026

Facility Representative Present During Inspection: Permittee Owner Other

Name of Permittee or Owner: Apro, LLC dba United Pacific

Mailing Address: 4130 Cover St , Long Beach California 90808

Field Citation Penalty – See Page 3 for a detailed listing of each violation. \$ 100

Check payable to: DEQ Financial Services LBX3615; P.O. Box 3615; Portland OR 97208-3615

Or pay online through your YDO account

This Field Citation is issued in accordance with the requirements for the expedited enforcement of Underground Storage Tank (UST) violations, OAR 340-150-0250.

Owner or Permittee should select Option 1 or Option 2 below and return a signed copy of this form to DEQ by the following date: 03/19/2026

DEQ Revenue Section
700 NE Multnomah St. #600
Portland, Oregon 97232

Check one option

- Option 1 - I acknowledge that the listed violation(s) have occurred, and I am remitting the listed field citation penalty.
- Option 2 - I do not want to participate in the expedited enforcement process and understand that my file will be referred to the Department's Office of Compliance and Enforcement for formal enforcement action.

Name: _____ Owner / Permittee

Signature: _____ Date: _____

Important
Read pages 2 and 3 for more information about your options and a detailed listing of violations and compliance requirements.

Field Citation Requirements

The permittee or owner should select Option 1 or Option 2 and return a signed copy of Page 1 of the Field Citation form within thirty (30) days of issuance of the Field Citation. If the permittee or owner fails to sign and send Page 1 of the Field Citation form back or pay the penalty within thirty days, Option 1 expires, the Field Citation will serve as a Pre-Enforcement Notice (PEN) and the permittee and owner will be subject to formal enforcement, including the imposition of civil penalties in accordance with OAR Chapter 340, Division 12.

The permittee or owner must complete the actions required to correct the violations listed on the Field Citation by the date specified to prevent further enforcement action by DEQ.

Option 1:

By checking Option 1, the permittee or owner acknowledges that the violations listed on Page 3 of this Field Citation have occurred and agrees to pay the established penalty.

By submitting payment of the penalty amount, the responding permittee or owner agrees to accept the field citation as a final order of the Environmental Quality Commission (commission) and waives any and all rights and objections to the form, content, manner of service and timeliness of the Field Citation; to a contested case hearing and judicial review of the Field Citation [OAR 340-150-0250(6)]; and to service of a copy of this Final Order (*i.e.*, no other copy will be provided).

Upon the Department's receipt of payment of the penalty amount set forth in the Field Citation, the Field Citation becomes a Final Order of the Commission that:

1. Imposes upon the permittee or owner a civil penalty in the amount listed on Page 1 of this Field Citation; and
2. Requires the permittee or owner to satisfactorily complete the requirements and actions necessary to correct the violations documented by the dates set forth on Page 3 of this Field Citation.

Failure by the permittee or owner to complete the actions set forth on Page 3 of the Field Citation by the specified date violates the Commission Order and subjects the permittee and owner to a formal enforcement action, including the imposition of additional civil penalties.

Option 2:

The permittee or owner may deny that the violations as listed on Page 3 of this Field Citation have occurred or contest the Field Citation process by checking Option 2 and submitting to the Department a signed copy of Page 1 of the Field Citation. In that event, the Field Citation will serve as a Pre-Enforcement Notice (PEN) and the permittee and owner will be subject to formal enforcement for those violations set forth in the Field Citation, including the imposition of civil penalties in accordance with OAR Chapter 340, Division 12. Civil penalties that will be imposed by the formal enforcement process will exceed the Field Citation penalties for the same violation(s).

The Department appreciates your cooperation and efforts to comply with the regulations for underground storage tank systems.

UST FIELD CITATION

DATE ISSUED: 02/19/2026

PROGRAM ENFORCEMENT No.: 2026-FC-10118

FACILITY ID: 2158

Page 3 of 3

Violation #1: *TCR:	(G5) Failure to install, operate, maintain or calibrate RD equipment per manufacturer's instructions, including service checks for operability or running condition (i.e. device has been incorrectly installed, is defective, damaged, or may have been tampered with.)		
Corrective Action:	No corrective actions are required due to passing annual testing in 2024 and 2025.		
Rule Citation: OAR 340-150-0400(1)(c)	Penalty Amount: \$ 100	Correct Violation by: COMPLETE	Date Violation Corrected: 02/18/2026
Violation #2: *TCR:			
Corrective Action:			
Rule Citation: OAR	Penalty Amount: \$	Correct Violation by:	Date Violation Corrected:
Violation #3: *TCR:			
Corrective Action:			
Rule Citation: OAR	Penalty Amount: \$	Correct Violation by:	Date Violation Corrected:
Violation #4: *TCR:			
Corrective Action:			
Rule Citation: OAR	Penalty Amount: \$	Correct Violation by:	Date Violation Corrected:
Violation #5: *TCR:			
Corrective Action:			
Rule Citation: OAR	Penalty Amount: \$	Correct Violation by:	Date Violation Corrected:
Violation #6: *TCR:			
Corrective Action:			
Rule Citation: OAR	Penalty Amount: \$	Correct Violation by:	Date Violation Corrected:
Total Penalty Amount: \$ 100			

YOU MUST CORRECT THE VIOLATIONS AS REQUIRED, ENTER THE DATES CORRECTED, SIGN THE STATEMENT BELOW, AND

RETURN THIS FORM TO THE DEQ INSPECTOR LISTED ON PAGE 1 ON OR BEFORE: 03/19/2026

Retain a copy of this form and all documentation of corrective actions for your records.

I hereby certify that the UST violations noted above have been corrected: _____ / _____
Permittee/Owner Signature *Date*

T 2:DIESEL
PRODUCT CODE : 2
THERMAL COEFF : 000045
TANK DIAMETER : 95.00
TANK PROFILE : 1 PT
FULL VOL : 4065

FLOAT SIZE : 4.0 IN.
WATER WARNING : 0.8
HIGH WATER LIMIT : 2.0

MAX OR LABEL VOL : 4065
OVERFILL LIMIT : 90%
 : 3658
HIGH PRODUCT : 95%
 : 3861
DELIVERY LIMIT : 30%
 : 1219

LOW PRODUCT : 1000
LEAK ALARM LIMIT : 99
SUDDEN LOSS LIMIT : 99
TANK TILT : 6.40
PROBE OFFSET : 0.00

Oregon Department of Environmental Quality - Underground Storage Tank Program
 Technical Compliance Inspection - UST Inspection Report

Inspector: Blake Gilbert Date: 02/11/2026 Time: 1:00 PM Facility: 2158

I. Site Information

Facility Name: UNITED PACIFIC #7470	Permittee: Alan Beaudette	Contact
Site Address: 49950 NW HWY 26,	Organization:	Phone
City: BANKS, OR 97106	Phone: 310-436-3703	

II. Tank Information

DEQ Permit #	ADCCG	ADCCH	ADCCJ	ADCDK
Estimated Gallons	4000	4000	4000	10000
Substance	G	D	D	G
Tank Material	CATHODICAL	PROTECTED	STEEL	
Tank Install Date	03/24/1982	1982	1982	
Pipe Material	SMITH FIBER	CAST	MAKER	
Pipe Type	P	P	P	
Pipe Install Date	1982	1982	1982	
Overfill Device	Flapper	Flapper	Flapper	

Notes and Comments from the UST database: Check file before conducting inspection
PS from Ann RB1

permits@unitedpacific.com - Advanum Brant

If tanks are manifolded, which tanks:

III. Operating Certificate Current Accurate Posted for delivery drive to observe Compliance Yes No

IV. Operator Training Current Accurate Posted for delivery drive to observe Compliance Yes No

Class A/B Operator	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Name: Steve Matthew	Date: 21-12
Class C Operator	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Cardlock MO Leonard	5-12-24 to 5-15-24

V. Financial Responsibility Current Accurate Posted for delivery drive to observe Compliance Yes No

Type of coverage: *Insurance* Begin Date: **7-1-24** End Date: **7-1-29**

Coverage amount correct: Yes No Number of tanks covered: **3** All

VI. Walkthrough Requirements Compliance Yes No

Spill prevention and release detection equipment checked monthly? Yes No

Tank top sumps checked annually? Yes No

VII. Release Detection

Compliance

Yes No

a) Annual Release Detection Operability Testing (Sometimes referred to as Tank Gauge Certification)

Date of last testing: 11/5/25

11/7/24

Last three tests available?

Yes No

b) Piping Release Detection (Check all that apply)

Pressurized Piping

Mechanical Leak Detector (MLLD) Electronic Leak Detector (ELLD) - check for switchover requirement

Date of last testing: 11/5/25

11/7/24

Last three tests available?

Yes No

Number of lines tested: 3

Diesel manifold system

Number of LD tested: 3

Leak detector manufacturer make and model: 99LD 2000 - Super Red Jacket FX-1V

Tank gauge manufacturer make and model: Veeco KAL FLS-350

MLLD on turbine manifold?

Yes No

MLLD product appropriate? (Example, diesel Red Jacket FX series on diesel system?)

Yes No

If ELLD and no line testing: Annual 0.1 gph results from tank gauge?

Yes No

Interstitial Monitoring

[Monthly records must include, date system was checked, observations made, initials of person checking. Electronic records must include power status (on or off), alarm indication status (yes or no) and sensor malfunction notes (yes or no).]

Date of last sumpt testing: _____

Last two tests available?

Yes No

Date of last sensor testing: _____

Last three tests available?

Yes No

Float sensors installed correctly?

Yes No

Interstitial space opened to sumpt?

Yes No

Safe Suction

Check valve directly below suction pump? Yes No

c) Monthly Tank Release Detection (Check all that apply)

Tank Gauge CSLD SCALD Static

Are correct tank sizes programmed at tank gauge?

Yes No

Tank diameter/length seem appropriate?

Yes No

Are tanks manifolded?

Yes No

If so, tank gauge testing setup for manifolded tanks?

Yes No

If Veeder Root tank gauge leak detection
 CSLD set at 99%
 Thermal coefficient set correctly?
(Gasoline 0.00070; Diesel 0.00045)
- T-2 Diesel 0.00045
 If Incon/Franklin tank gauge leak detection
 If SCALD is Vol Qual set to 14% (or 99% confidence)
 Is API gravity get correctly?
(Regular 63.5; Plus 62.8; Super 51.3; Diesel 32.8)
 For all tank gauges doing static tests
(Static tests require tank to be 50% full for a valid test)

Interstitial Monitoring [Monthly records must include, date system was checked, observations made, initials of person checking.

Electronic records must include power status (on or off), alarm indication status (yes or no) and sensor malfunction notes (yes or no).]

SIR

Ensure pass or fail results within 30-day period. Inconclusive result means release detection requirement not met

Tank release detection records available during inspection

T1: <input type="checkbox"/> Jan	<input type="checkbox"/> Feb	<input type="checkbox"/> Mar	<input type="checkbox"/> Apr	<input type="checkbox"/> May	<input type="checkbox"/> Jun	<input type="checkbox"/> Jul	<input type="checkbox"/> Aug	<input type="checkbox"/> Sep	<input type="checkbox"/> Oct	<input type="checkbox"/> Nov	<input type="checkbox"/> Dec
T2: <input type="checkbox"/> Jan	<input type="checkbox"/> Feb	<input type="checkbox"/> Mar	<input type="checkbox"/> Apr	<input type="checkbox"/> May	<input type="checkbox"/> Jun	<input type="checkbox"/> Jul	<input type="checkbox"/> Aug	<input type="checkbox"/> Sep	<input type="checkbox"/> Oct	<input type="checkbox"/> Nov	<input type="checkbox"/> Dec
T3: <input type="checkbox"/> Jan	<input type="checkbox"/> Feb	<input type="checkbox"/> Mar	<input type="checkbox"/> Apr	<input type="checkbox"/> May	<input type="checkbox"/> Jun	<input type="checkbox"/> Jul	<input type="checkbox"/> Aug	<input type="checkbox"/> Sep	<input type="checkbox"/> Oct	<input type="checkbox"/> Nov	<input type="checkbox"/> Dec
T4: <input type="checkbox"/> Jan	<input checked="" type="checkbox"/> Feb	<input type="checkbox"/> Mar	<input type="checkbox"/> Apr	<input type="checkbox"/> May	<input type="checkbox"/> Jun	<input type="checkbox"/> Jul	<input checked="" type="checkbox"/> Aug	<input type="checkbox"/> Sep	<input type="checkbox"/> Oct	<input type="checkbox"/> Nov	<input type="checkbox"/> Dec
T5: <input type="checkbox"/> Jan	<input type="checkbox"/> Feb	<input type="checkbox"/> Mar	<input type="checkbox"/> Apr	<input type="checkbox"/> May	<input type="checkbox"/> Jun	<input type="checkbox"/> Jul	<input type="checkbox"/> Aug	<input type="checkbox"/> Sep	<input type="checkbox"/> Oct	<input type="checkbox"/> Nov	<input type="checkbox"/> Dec

Bobson 12 Mark pink 2025

Inspector: Blake Gilbert Date: 2/18/26 Time: 1pm Facility: 2158

VIII. Spill Prevention Compliance Yes No

Date(s) of testing: 11/7/24 11/18/20 Number of spill buckets tested? 4
Did spill bucket pass most recent testing? Yes No If no, was spill bucket replaced/repared? Yes No
During inspection, visual damage to spill bucket? Yes No

Hydrostatic testing (test takes one hour to complete)
 Vacuum test (test takes 1 minute, ending vacuum must be 26 inches water column or greater)

IX. Overfill Prevention Compliance Yes No

Date(s) of testing: 11/7/24 11/27/24 11/18/20

Overfill device pass most recent testing? Yes No If no, overfill device replaced? Yes No
Overfill method that was tested: Alarm Flapper Ball Float

Overfill Alarm
Alarm sounds when tank is 90% full Yes No
Driver can see or hear alarm at point of transfer? Yes No
Sound alarm from tank gauge during inspection? Yes No

Flapper Valve
Testing verified the valve automatically restricts flow at 95% Yes No
Visual observation of flapper on day of inspection? Yes No

Ball Float
Testing verified the ball float automatically restricts flow at 90% Yes No
Visual observation of ball float during inspection? Yes No

X. Corrosion Protection Compliance Yes No

Cathodic Galvanic Impressed Current
Steel tank with cathodic? Yes No
Steel pipes with cathodic? Yes No
Steel flex-lines with cathodic? Yes No

Date of cathodic test: 11/12/24
Last two tests available? Yes No
Did last test pass? - 11/21/19 - 12/05/21 Yes No

If not:
Was failed test reported to DEQ? Yes No
Was system repaired? Yes No

Date of repair? _____
Cathodic retested within 6 mos. of repair? Yes No

Date of retesting? _____
If impressed current system:
Rectifier Operational? Yes No
Rectifier log maintained? Yes No
Rectifier been operating continuously Yes No

Tank Lining
Date of last test? _____
Pressure test conducted after tank lining inspection? Yes No

XI. General notes from inspection

Representative onsite: _____

email: _____

2023 MYSOFT is LOCATING INVOICE to check tax was done - see back of file
cite GA-5

Compliance Determination: No Violations Observed

Observed violations resulting in enforcement

~ GA-5
cited


Inspector Signature: Blake Gilbert
BL AGM

Date: 2/18/26




SUNSET HWY

United Pacific #7470
49950 NW HWY 210
Banks OR 97106
ID # 2158



Structure S
CSC R



GILBERT Blakely * DEQ

From: UST Duty Officer * DEQ
Sent: Wednesday, February 18, 2026 3:02 PM
To: UST Duty Officer * DEQ
Cc: Adrienne.Breaux@unitedpacific.com; Steven.Mathew@unitedpacific.com
Subject: DEQ UST # 2158 determination letter

Alan Beaudette,

Thank you for having Steven Mathew meet me on site at UST # 2158 on February 18, 2026, to conduct our Full Compliance Inspection at the United Pacific # 7470 located at 49950 NW Sunset Hwy, Banks Or. 97106
There is one violation listed below for missing the annual testing in 2023. No corrective actions are required due to passing tests for 2024 and 2025.

DEQ observed violations, enforcement will be issued per the enforcement guidance. Below are the listed violations.

You will receive the enforcement documentation via a separate email from the UST Duty officer email. The payment can be made via [Your DEQ Online Website](#).

***Please email the UST duty officer with all communications about the violation or when sending over the final testing records and any repair documentation. DO NOT SEND THEM TO ME. Contact the UST Duty Officer at 503-229-5034 or ust.dutyofficer@deq.oregon.gov**

Violations:

1. G-5 Failure to maintain or calibrate Release Detection equipment per manufactures instructions, including testing for operability or running condition annually 340-150-0400(2) class 1 *Due to missing annual testing in 2023.

Corrective Actions:

No corrective actions are required due to passing annual testing in 2024 and 2025.



Blake Gilbert (he/him)
Inspector, Underground Storage Tanks
DEQ Headquarters, Land Quality Division
700 NE Multnomah Street, Suite 600
Portland OR 97232-4100
C 503-360-4408

UST Inspection Survey

Submitted by: blakely.gilbert_deq

Submitted time: Feb 18, 2026, 3:28:35 PM

Date

Feb 18, 2026

Time

10:21

UST Facility ID

2,158

Inspector


Gilbert

Type of Inspection

Full Compliance

Location

Lat: 45.679456 Lon: -123.191196



Esri, FAO, NOAA, USGS

Powered by Esri

Photograph

Site Information
 Facility Name: UNITED PACIFIC #7475
 Site Address: 49850-NW HWY 26
 City: BANKS, OR 97106
 Phone: 310-436-3722
 Permit No: 21-2008 Date: 1-10-24

Site Details

Area	ADCCD	ADCCN	ADCCJ	ADCCK
Volume	4000	4000	4000	10000
Substrate	G	G	G	G
Core Material	CATHODICAL	PROTECTED	STEEL	H
Start Install Date	03/24/1982	1982	1982	
Core Material	SMITH FIBER	CAST	MAKER	
Core Type	P	P	P	
Start Install Date	1982	1982	1982	
Coating	Pt-Nv	Prsh	Pt-Pr	

Notes and Comments from the DOT Division: (Add job before continuing inspection)

permits@unitedpacific.com

Operator Training

Class A/B Operator: Yes No Name: Steve Millward Date: 3-1-24 to 6-30-24
 Class C Operator: Yes No Exempt

Financial Responsibility

Type of coverage: Self Other
 Coverage amount correct: Yes No Number of tanks covered: 3
 Financial responsibility could also be in the form of self insurance, bond, local government, trust fund, and co-guarantee.

Walkthrough Requirements

Spill prevention and release detection equipment checked monthly? Yes No
 Tank top pumps checked annually: Yes No

Page 1 of 4

photos-20260218-182132.jpg



photos-20260218-182458.jpg



photos-20260218-182600.jpg



photos-20260218-182621.jpg



photos-20260218-182627.jpg



photos-20260218-182642.jpg



photos-20260218-182653.jpg



photos-20260218-182730.jpg



photos-20260218-182759.jpg



photos-20260218-182811.jpg



photos-20260218-182828.jpg



photos-20260218-182845.jpg



photos-20260218-182905.jpg




photos-20260218-182941.jpg




photos-20260218-183034.jpg



photos-20260218-183135.jpg




photos-20260218-183211.jpg



photos-20260218-183242.jpg



photos-20260218-183313.jpg



photos-20260218-183329.jpg




photos-20260218-183823.jpg



photos-20260218-183839.jpg



photos-20260218-183901.jpg



photos-20260218-185549.jpg



photos-20260218-185949.jpg

Notes

E

Oregon Department of Environmental Quality Cathodic Protection Test Information Page

UST Owner

UST Facility

NAME: APPRO LLC UNITED PACIFIC	NAME: UNITED PACIFIC #7470 TIME OIL	ID#: 2158
ADDRESS: 4130 COVER ST	ADDRESS: 49950 NW HWY 26	
CITY: LONG BEACH	STATE: CA	CITY: BANKS
		STATE: OR

Cathodic Protection Tester

TESTER'S NAME: GREG PORT	CP TESTER'S LICENSE #: 27044	
COMPANY NAME: MTM SERVICES	EXPIRATION DATE: 5/7/22	
ADDRESS: PO BOX 576	PHONE NUMBER: (509) 322-4525	
CITY: TWISP	STATE: WA	NACE CERTIFICATION #: 69817
Cathodic protection system is: <input type="checkbox"/> Galvanic	<input checked="" type="checkbox"/> Impressed current	Date Last Tested: 11/21/19

Weather Conditions at Time of Testing/Inspection:

Temperature: 50 Soil/Backfill Conditions (check moist dry sand gravel soil Describe soil: SANDY LOAM

Cathodic Protection System Certification

Identify which of the following testing situations is being recorded:

- Test required within 6 months of installation of CP system (installation date was 12/05/21)
- Test required at least every 3 years after installation/test noted above
- Test required within 6 months of any repair activity

The cathodic protection system is effective; testing was performed according to NACE Standard RP-0285, and is providing cathodic protection to all tanks and product lines: Yes No

Signature of Tester *Greg Port* Date 12/05/21

UST SYSTEM INFORMATION

TANK #	YR TANK INSTALLED	CAPACITY	TANK MATERIAL	LINED? Y/N	Date	YR CP INSTALLED	PIPING MATERIAL	YR CP INSTALLED
844	1982	4,000	STEEL	YES 1993		1982	FRP	1987
845	1982	4,000	"	"		1982	"	1987
846	1982	4,000	"	"		1982	"	1987
847	1982	10,000	"	"		1982	"	1987

UST SITE PLAN – On the back draw a diagram showing the important parts of the facility (tanks, lines, manway locations, turbines, vents, rectifier, pump islands, buildings). Indicate reference cell locations where structure-to-soil potential or continuity measurements have been made and label(R-1, R-2, R-3); location of all anodes and wires; location of CP test stations.

Facility Name UNITED PACIFIC #7470 TIME OIL Test Date 12/05/21 Facility # 2158

IMPRESSED CURRENT CP TEST RESULTS REPORT PAGE

RECTIFIER DATA			
RECTIFIER MANUFACTURER: UNIVERSAL	RATED DC OUTPUT: 24	VOLTS ² _____ AMPS	
RECTIFIER MODEL: GSA-ACAI	RECTIFIER SERIAL NUMBER: 861331		
RECTIFIER OUTPUT AS INITIALLY DESIGNED OR LAST RECOMMENDED (if available) 8-13	VOLTS 4-1.5 _____ AMPS		
	DATE	TAP SETTINGS	DC OUTPUT
		Coarse	Fine
			Volts
			AMPS
			HOUR
			METER
			COMMENTS
"As Found"	12/05/21		
			SEE ATTACHED
"As Left"	12/05/21		"

STRUCTURE TO SOIL POTENTIAL MEASUREMENTS						
ID	STRUCTURE	CONTACT POINT	REFERENCE CELL LOCATION	ON	INSTANT	
					OFF	NATIVE
				100mV CHANGE		
844	TANK 4K	FILL NECK	OVER TANK NORTH R1	-1485mV	-1016mV	
"	"	"	MID R2	-1142mV	-954mV	
"	"	"	SOUTH R3	-1818mV	-1241mV	
845	TANK 4K	TURBINE	R4	-1015mV	-862mV	
"	"	"	R5	-1218mV	-947mV	
"	"	"	R6	-2052mV	-1132mV	
			CONTINUED ON GALVANIC PAGE			

CP TEST STATION REQUIREMENTS

Have previous CP system test records been reviewed? Yes No

Has this CP test been performed consistent with previous CP system tests? Yes No

If test procedures have changed since last test please explain:

AMPS ARE ADDED TOGETHER FOR TOTAL CURRENT (5.2A)TURN SELECTOR TO EACH ANODE, ADD UP AMPS THIS SHOULD GET VERY CLOSE.

Have potential measurements been made at all tanks and piping including any buried flex-connectors? Yes No

COMPLETE IF ANY REPAIRS OR MODIFICATIONS TO THE CP SYSTEM ARE MADE OR ARE NECESSARY

Complete if any repairs or modifications to the cathodic protection system are made or are necessary.

Additional anodes for an impressed current system (attach corrosion experts design)

Repairs or replacement of rectifier (explain below)

Anode header cables repaired and/or replaced (explain below)

Impressed current protected tanks/piping not electrically continuous (explain below)

Remarks/Other: _____

Cathodic Solutions Individual Anode Data

Date: 12/5/21

UST ID #:2158

Facility Name: United Pacific #7470


Facility Address: 49950 HWY 26 Banks, OR

Rectifier "As Found" Data										
Anode #	1	2	3	4	5	6	7	8	9	10
Volts Panel Meter	11V	12V	11V	12V	10V	12V				
Volts Multi Meter	10.9V	11.4V	10.9V	11.7V	10.4V	11.7V				
Amps Panel Meter	1.1A	.9A	1.2A	.7A	.9A	.4A				
Shunt Rating 50MV=2.5 A										
Shunt Measurement	21.5MV	18.2MV	23.1MV	12.8MV	17.7MV	8.8MV				
Amps Shunt Reading	1.5A	.91A	1.155A	.64A	.885A	.44A				
Tap Settings Course	LOW	LOW	LOW	LOW	LOW	LOW				
Tap Settings Fine	90%	90%	90%	90%	75%	90%				


Rectifier "As Left" Data										
Anode #	1	2	3	4	5	6	7	8	9	10
Volts Panel Meter	11V	12V	11V	12V	10V	12V				
Volts Multi Meter	10.9V	11.4V	10.9V	11.7V	10.4V	11.7V				
Amps Panel Meter	1.1A	.9A	1.2A	.7A	.9A	.4A				
Shunt Rating 50MV=2.5A										
Shunt Measurement	21.5MV	18.2MV	23.1MV	12.8MV	17.7MV	8.8MV				
Amps Shunt Reading	1.5A	.91A	1.155A	.64A	.885A	.44A				
Tap Settings Course	LOW	LOW	LOW	LOW	LOW	LOW				
Tap Settings Fine	90%	90%	90%	90%	75%	90%				

Sunset HWY

United Pacific #7470
49950 NW HWY 210
Banks OR 97100
ID # 2158



Structure S
csc R



Oregon Department of Environmental Quality

Cathodic Protection Test Information Page

UST Owner

NAME: United Pacific	NAME: Food Mart #7470	ID#: 2158
ADDRESS: 4130 Over Street	ADDRESS: 49950 HWY 26	
CITY: Long Beach	STATE: CA	CITY: Banks
		STATE: OR

UST Facility

Cathodic Protection Tester

TESTER'S NAME: Mark Huston	CP TESTER'S LICENSE #: 24150
COMPANY NAME: MTM Services LLC	EXPIRATION DATE: 7/26
ADDRESS: PO Box 576	PHONE NUMBER: (509) 460-6974
CITY: Twisp	STATE: WA
Cathodic protection system is:	<input type="checkbox"/> Galvanic <input checked="" type="checkbox"/> Impressed current
Weather Conditions at Time of Testing/Inspection: Overcast	NACE CERTIFICATION #: _____ Date Last Tested: _____

Temperature: 55 Soil/Backfill Conditions (check moist dry sand gravel soil Describe soil: Mixed backfill)

Cathodic Protection System Certification

Identify which of the following testing situations is being recorded:

- Test required within 6 months of installation of CP system (installation date was _____)
 Test required at least every 3 years after installation/test noted above
 Test required within 6 months of any repair activity

The cathodic protection system is effective, testing was performed according to NACE Standard RP-0285, and is providing cathodic protection to all tanks and product lines: Yes No

Signature of Tester



Date 11/12/24

UST SYSTEM INFORMATION

TANK #	YR TANK INSTALLED	CAPACITY	TANK MATERIAL	LINED? Y/N	Date	YR CP INSTALLED	PIPING MATERIAL	YR CP INSTALLED
844	1982	4,000	Steel	Y, 1994		2015	FRP	1982
845	1982	4,000	Steel	Y, 1994		2015	FRP	1982
846	1982	4,000	Steel	Y, 1994		2015	FRP	1982
847	1982	10,000	Steel	Y, 1994		2015	FRP	1982

UST SITE PLAN – On the back draw a diagram showing the important parts of the facility (tanks, lines, manway locations, turbines, vents, rectifier, pump islands, buildings). Indicate reference cell locations where structure-to-soil potential or continuity measurements have been made and label(R-1, R-2, R-3); location of all anodes and wires; location of CP test stations.

Facility Name Food Mart #7470

Test Date 11/12/24

Facility # 2158

IMPRESSED CURRENT CP TEST RESULTS REPORT PAGE

RECTIFIER DATA

RECTIFIER MANUFACTURER: <u>Universal</u>		RATED DC OUTPUT: <u>24</u>		VOLTS <u>2</u>		AMPS	
RECTIFIER MODEL: <u>CSA-ACAI</u>		RECTIFIER SERIAL NUMBER: <u>861321</u>					
RECTIFIER OUTPUT AS INITIALLY DESIGNED OR LAST RECOMMENDED (if available)							
	DATE	TAP SETTINGS		DC OUTPUT		VOLTS	
		Coarse	Fine	Volts	AMPS	HOUR	
"As Found"	11/12/24	Low	Variable	See attached	See attached	METER	
"As Left"	11/12/24	Low	Variable	See attached	See attached	COMMENTS	

STRUCTURE TO SOIL POTENTIAL MEASUREMENTS

ID	STRUCTURE	CONTACT POINT	REFERENCE CELL LOCATION	ON	INSTANT OFF	NATIVE	100mV CHANGE
847	Regular tank	Turbine	North end of the tank	-1964 mv	-1329 mv		
847	"	"	Center of the tank	-1127 mv	-879 mv		
847	"	"	South end if the tank	-1307 mv	-949 mv		
844	Super tank	"	West end of the tank	-1656 mv	-1084 mv		
844	"	"	Center of the tank	-1558 mv	-1056 mv		
844	"	"	East end of the tank	-2188 mv	-1110 mv		
845	Diesel siphon tank	"	North end of the tank	-1134 mv	-866 mv		
845	"	"	Center of the tank	-1133 mv	-862 mv		

CP TEST STATION REQUIREMENTS

Have previous CP system test records been reviewed? Yes No Has this CP test been performed consistent with previous CP system tests? Yes No

If test procedures have changed since last test please explain:

Have potential measurements been made at all tanks and piping including any buried flex-connectors? Yes No

COMPLETE IF ANY REPAIRS OR MODIFICATIONS TO THE CP SYSTEM ARE MADE OR ARE NECESSARY

Complete if any repairs or modifications to the cathodic protection system are made or are necessary.

Additional anodes for an impressed current system (attach corrosion experts design)

Repairs or replacement of rectifier (explain below)

Anode header cables repaired and/or replaced (explain below)

Impressed current protected tanks/piping not electrically continuous (explain below)

Remarks/Other: _____

Facility Name Food Mart #7470

Test Date 11/12/24

Facility # 2158

IMPRESSED CURRENT CP TEST RESULTS REPORT PAGE

RECTIFIER DATA

RECTIFIER MANUFACTURER: <u>Universal</u>		RATED DC OUTPUT: <u>24</u>		VOLTS ²		AMPS	
RECTIFIER MODEL: <u>CSA-CM1</u>		RECTIFIER SERIAL NUMBER: <u>861331</u>		VOLTS		AMPS	
RECTIFIER OUTPUT AS INITIALLY DESIGNED OR LAST RECOMMENDED (if available)							
	DATE	TAP SETTINGS		DC OUTPUT	HOUR METER	COMMENTS	
		Coarse	Fine				
"As Found"	11/12/24	Low	Variable	See attached	See attached		
"As Let"	11/12/24	Low	Variable	See attached	See attached		

STRUCTURE TO SOIL POTENTIAL MEASUREMENTS

ID	STRUCTURE	CONTACT POINT	REFERENCE CELL LOCATION	ON	INSTANT OFF	NATIVE	100mV CHANGE
845	Diesel siphon tank	Turbine	South end of the tank	-1964 mv	-1329 mv		
846	Diesel turbine tank	"	North end of the tank	-1127 mv	-879 mv		
846	"	"	Center of the tank	-1307 mv	-949 mv		
846	"	"	South end of the tank	-1656 mv	-1084 mv		
844	Super tank	Rect. neg. lead	Continuity				0.7 mv
845	Diesel siphon tank	"	"				0.1 mv
846	Diesel turbine tank	"	"				0.5 mv
847	Regular tank	"	"				0.6 mv

CP TEST STATION REQUIREMENTS

Have previous CP system test records been reviewed? Yes No Has this CP test been performed consistent with previous CP system tests? Yes No

If test procedures have changed since last test please explain:

Have potential measurements been made at all tanks and piping including any buried flex-connectors? Yes No

COMPLETE IF ANY REPAIRS OR MODIFICATIONS TO THE CP SYSTEM ARE MADE OR ARE NECESSARY

Complete if any repairs or modifications to the cathodic protection system are made or are necessary.

Additional anodes for an impressed current system (attach corrosion experts design)

Repairs or replacement of rectifier (explain below)


Anode header cables repaired and/or replaced (explain below)

Impressed current protected tanks/piping not electrically continuous (explain below)


Remarks/Other:

HWY 26

2
4



Fuel
Island



+ Structure contact
* Reference cell location

Cathodic Solutions Individual Anode Data

Date: 11/12/2024

UST ID #: 4122

Facility Name: Food Mart #7470

Facility Address: 49950 Hwy 26, Banks, OR, 97106

Rectifier "As Found" Data										
Anode #	1	2	3	4	5	6	7	8	9	10
Volts Panel Meter	11	11	10.5	11.5	10	11.5				
Volts Multi Meter	10.74	11.31	10.8	11.62	11.42	11.61				
Amps Panel Meter	1.2	1	1.2	0.75	0.9	0.25				
Shunt Rating	50mv=2.5a									
Shunt Measurement	23.1 mv	19.8 mv	23.6 mv	14.3 mv	17.6 mv	5.9 mv				
Amps Shunt Reading	1.155	0.99	1.18	0.715	0.88	0.295				
Tap Settings Course	Low	Low	Low	Low	Low	Low				
Tap Settings Fine	100%	100%	100%	100%	75%	100%				

Rectifier "As Left" Data										
Anode #	1	2	3	4	5	6	7	8	9	10
Volts Panel Meter	11	11	10.5	11.5	10	11.5				
Volts Multi Meter	10.74	11.31	10.8	11.62	11.42	11.61				
Amps Panel Meter	1.2	1	1.2	0.75	0.9	0.25				
Shunt Rating	50mv=2.5a									
Shunt Measurement	23.1 mv	19.8 mv	23.6 mv	14.3 mv	17.6 mv	5.9 mv				
Amps Shunt Reading	1.155	0.99	1.18	0.715	0.88	0.295				
Tap Settings Course	Low	Low	Low	Low	Low	Low				
Tap Settings Fine	100%	100%	100%	100%	75%	100%				

IMPRESSED CURRENT CP TEST RESULTS REPORT PAGE

**Oregon Department of Environmental Quality
Cathodic Protection Test Information Page**

UST Owner

UST Facility

NAME:	UNITED PACIFIC #7470	ID#: 2158
ADDRESS:	ADDRESS: 49950 HWY 26	
CITY:	STATE: OR	CITY: BANKS
		STATE: OR

Cathodic Protection Tester

TESTER'S NAME: ZACH SATHER	CP TESTER'S LICENSE #: 26475
COMPANY NAME: PACIFIC ENVIRONMENTAL SERVICES	EXPIRATION DATE: 6/2022
ADDRESS: 8585 S R 20	PHONE NUMBER: (800) 222-9219
CITY: PORT TOWNSEND	STATE: WA
	NACE CERTIFICATION #: 25935
Cathodic protection system is: <input type="checkbox"/> Galvanic	<input checked="" type="checkbox"/> Impressed current
Date Last Tested:	
Weather Conditions at Time of Testing/Inspection: CLEAR COOL	
Temperature:	Soil/Backfill Conditions (circle): MOIST SANDY GRAVEL


Cathodic Protection System Certification

Identify which of the following testing situations is being recorded:

- Test required within 6 months of installation of CP system (installation date was)
- ✓ Test required at least every 3 years after installation/test noted above
- Test required within 6 months of any repair activity

The cathodic protection system is effective, testing was performed according to NACE Standards RP-0285-2002 and TM0101-2001, and is providing cathodic protection to all tanks and product lines: **[X] Yes [] No**

Signature of Tester



Date 11/21/2019

UST SYSTEM INFORMATION

TANK #	YR TANK INSTALLED	CAPACITY	TANK MATERIAL	LINED? Y/N	Date	YR CP INSTALLED	PIPING MATERIAL	YR CP INSTALLED
ADCDK	GASOLINE	10000	STEEL	N			FRP	
ADCCG	GASOLINE	4000	STEEL	N			FRP	
ADCCH	DIESEL	4000	STEEL	N			FRP	
ADCCJ	DIESEL	4000	STEEL	N			FRP	

UST SITE PLAN – On the back draw a diagram showing the important parts of the facility (tanks, lines, manway locations, turbines, vents, recifier, pump islands, buildings). Indicate reference cell locations where structure-to-soil potential or continuity measurements have been made and label(R-1, R-2, R-3); location of all anodes and wires; location of CP test stations.

RECTIFIER DATA

RECTIFIER MANUFACTURER: UNIVERSAL		RATED DC OUTPUT: 24 VOLTS 2 AMPS					
RECTIFIER MODEL: CSA/ACAI		RECTIFIER SERIAL NUMBER: 861331					
RECTIFIER OUTPUT AS INITIALLY DESIGNED OR LAST RECOMMENDED: 8-15 VOLTS 0.5-1.5 AMPS							
TRANSFORMER	mv	TAP SETTINGS		DC OUTPUT		HOUR METER	COMMENTS
		Course	Fine	Volts	AMPS		
1	26.4	LO	7/10	11.3	.25	NA	
2	21.2	LO	7/10	11.9	0	NA	
3	26.2	LO	7/10	11.3	.25	NA	
4	18.5	LO	7/10	11.9	.55	NA	
5	21.2	LO	7/10	10.8	.25	NA	
6	49	LO	7/10	11.9	.10	NA	

Continuity Test Data		Reference Cell Location		on	Instant off	100mv polarization	
Structure A/ Contact Point	Structure B/ contact point	mv				NATIVE	change
UST 1	NEG LUG	<10	RC-1	-797	-714	-515	>100
			RC-2	-1144	-884	-468	>100
			RC-3	-1320	-969	-541	>100
UST 2	NEG LUG	<10	RC-4	-808	-725	-509	>100
			RC-5	-741	-688	-511	>100
			RC-6	-818	-714	-472	>100
UST 3	NEG LUG	<10	RC-7	-1291	-993	-601	>100
			RC-8	-1194	-863	-564	>100
			RC-9	-917	-758	-522	>100
UST 4	NEG LUG	<10	RC-10	-916	-783	-519	>100
			RC-11	-870	-738	-504	>100
			RC-12	-929	-789	-516	>100

CP Test Station Requirements

Have previous CP system test records been reviewed? YES Has this CP test been performed consistent with previous CP system tests? YES

If test procedures have changed since last test please explain:

Have potential measurements been made at all tanks and piping including any buried flex-connectors? YES

Complete if any repairs or modifications to the cp system are made or are necessary

Complete if any repairs or modifications to the cathodic protection system are made or are necessary.

Additional anodes for an impressed current system (attach corrosion experts design)


Repairs or replacement of rectifier (explain below)

Anode header cables repaired and/or replaced (explain below)

Impressed current protected tanks/piping not electrically continuous (explain)

Remarks/Other::

UST SITE PLAN – On the back draw a diagram showing the important parts of the facility (tanks, lines, manway locations, turbines, vents, rectifier, pump islands, buildings). Indicate reference cell locations where structure-to-soil potential or continuity measurements have been made and label(R-1, R-2, R-3); location of all anodes and wires; location of CP test stations.



PLANDF.COM 253 255 0487

Training Course Modules Included:

Certificate ID: 47309566

Secondary Containment with II

Release Detection for Piping

Corrosion Protection

Emergency Response

Product Compatibility

Financial Responsibility

Notification and Registration

Release Reporting

Closure Requirements

Passed Final Exam

anta

5910 Rice Creek Parkway

Suite 100

Shoreview, MN 55126

Operator Training

USTs - Tanks and Piping

USTs - Ancillary Equipment

Spill and Overfill

Release Detection Overview

GW and Vapor Monitoring

Manual Tank Gauging

Inventory Reconciliation

Automatic Tank Gauging

Name of Trainer

Garrett

This Certificate of Completion to

Steve Matthew

for

Class A+B Operator Training

API WorkSafe

Date


21-May-12

Location

Presents

anta

SMATTHEW@



Effective date of this Endorsement: 01-Jul-2024

**This Endorsement is attached to and forms a part of Policy Number: D27D63240201
Beazley Excess and Surplus Insurance, Inc. referred to in this endorsement as either the "Insurer"
or the "Underwriters"**

**ENDORSEMENT OF INSURANCE TO
DEMONSTRATE FINANCIAL RESPONSIBILITY FOR STORAGE TANKS
STATE OF OREGON**

This endorsement modifies insurance provided under the following:

BEAZLEY ECLIPSE

In consideration of the premium charged for the Policy, it is hereby understood and agreed that:

Facility Name:

CF United, LLC

Address:

4170 Portland Rd Salem OR 97303
2910 Willamette St Eugene OR 97405
2420 SW Cedar Hills Blvd Beaverton OR 97005
12230 SE Sunnyside Rd Clackamas OR 97015
2281 NE 181st Ave Portland OR 97230
5063 Tualitan Valley Hwy Hillsboro OR 97123
3101 Portland Rd Newburg OR 97132
2020 E Burnside St Portland OR 97214
425 NE Broadway Portland OR 97232
2840 Broadway St NE Salem OR 97303
4592 Portland Rd Salem OR 97305
5095 Commercial St SE Salem OR 97306
5720 E. Main StSpringfield OR 97478
102 Lancaster Drive NE Salem OR 97301
1795 N 5th St Springfield OR 97477
790 Lancaster Drive SE Salem OR 97301
376 SE Main Street Clackamas OR 97023
2101 SE Court Ave. Pendleton OR 97801
1510 NE 42nd Ave. Portland OR 97213
15900 Upper Boones-Ferry Rd. Tigard OR 97223
49950 NW Sunset Hwy Banks OR 97106
10580 SE 82nd Portland OR 97086
5235 Sw Macadam Ave. OR 97239
129 E. Ellendale Ave. Dallas OR 97338
1098 13TH ST SE Salem OR 97302

Policy Number:

D27D63240201

Period of Coverage:

E136900R
052024 ed.

01-Jul-2024 to 01-Jul-2029

Name of Insurer:

Beazley Excess and Surplus Insurance, Inc.

Address of Insurer:

65 Memorial Road, Suite 320, West Hartford, CT 06017

Name of Insured:

CF United, LLC

Address of Insured:

4130 Cover Street, Long Beach, CA 90808

1. This endorsement certifies that the policy to which the endorsement is attached provides liability insurance covering the following storage tanks:

Number of Tanks	Facility Name	Facility Address	Facility ID Number
2	CF United	4170 Portland Rd Salem OR 97303	1297
4	CF United	2910 Williamette St Eugene OR 97405	2212AD
3	CF United	2420 SW Cedar Hills Blvd Beaverton OR 97005	5452
3	CF United	12230 SE Sunnyside Rd Clackamas OR 97015	5454
4	CF United	2281 NE 181st Ave Portland OR 97230	5456
3	CF United	5063 Tualitan Valley Hwy Hillsboro OR 97123	5457
3	CF United	3101 Portland Rd Newburg OR 97132	5458
4	CF United	2020 E Burnside St Portland OR 97214	5459
3	CF United	425 NE Broadway Portland OR 97232	5460
3	CF United	2840 Broadway St NE Salem OR 97303	5463
4	CF United	4592 Portland Rd Salem OR 97305	5465
4	CF United	5095 Commercial St SE Salem OR 97306	5466
5	CF United	5720 E. Main StSpringfield OR 97478	5468
4	CF United	102 Lancaster Drive NE Salem OR 97301	5558
2	CF United	1795 N 5th St Springfield OR 97477	5563
4	CF United	790 Lancaster Drive SE Salem OR 97301	7050
3	CF United	376 SE Main Street Clackamas OR 97023	7110
3	CF United	2101 SE Court Ave. Pendleton OR 97801	7180
4	CF United	1510 NE 42nd Ave. Portland OR 97213	7290

2	CF United	15900 Upper Boones-Ferry Rd. Tigard OR 97223	7450
4	CF United	49950 NW Sunset Hwy Banks OR 97106	7470
3	CF United	10580 SE 82nd Portland OR 97086	7520
3	CF United	5235 Sw Macadam Ave. OR 97239	7740
3	CF United	129 E. Ellendale Ave. Dallas OR 97338	7790
3	CF United	1098 13TH ST SE Salem OR 97302	7820

for taking corrective action and/or compensating third parties for bodily injury and property damage caused by sudden accidental releases or nonsudden accidental releases or accidental releases arising from operating the underground storage tank(s) identified above.

The limits of liability are \$1,000,000 each occurrence and \$2,000,000 annual aggregate, exclusive of legal defense costs, which are subject to a separate limit under the policy. This coverage is provided under D27D63240201. The effective date of said policy is 01-Jul-2024.

2. The insurance afforded with respect to such occurrences is subject to all of the terms and conditions of the policy; provided, however, that any provisions inconsistent with subsections (a) through (e) of this Paragraph 2 are hereby amended to conform with subsections (a) through (e):
 - a. Bankruptcy or insolvency of the insured shall not relieve the Insurer of its obligations under the policy to which this endorsement is attached.
 - b. The Insurer is liable for the payment of amounts within any deductible applicable to the policy to the provider of corrective action or a damaged third-party, with a right of reimbursement by the insured for any such payment made by the Insurer. This provision does not apply with respect to the amount of any deductible for which coverage is demonstrated under another mechanism or combination of mechanisms as specified in subsections 40 CFR 280.95-280.102 and 280.104-280.107.
 - c. Whenever requested by a Director of an implementing agency, the Insurer agrees to furnish to the Director a signed duplicate original of the policy and all endorsements.
 - d. Cancellation or any other termination of the insurance by the Insurer, except for non-payment of premium or misrepresentation by the insured, will be effective only upon written notice and only after the expiration of 60 days after a copy of such written notice is received by the insured. Cancellation for non-payment of premium or misrepresentation by the insured shall be effective only upon written notice and only after expiration of a minimum of 10 days after a copy of such written notice is received by the insured.
 - e. The insurance covers claims otherwise covered by the policy that are reported to the Insurer within six months of the effective date of cancellation or non-renewal of policy except where the new or renewed policy has the same retroactive date or a retroactive date earlier than that of the prior policy, and which arise out of any covered occurrence that commenced after the policy retroactive date, if applicable, and prior to such policy renewal or termination date. Claims reported during such extended reporting period are subject to the terms, conditions, limits, including limits of liability, and exclusions of the policy.


I hereby certify that the wording of this instrument is identical to the wording in 40 CFR 280.97(b)(1) as modified by OAR 340-151-0025(3) and that the Insurer is licensed to transact the business of insurance or eligible to provide insurance as an excess or surplus lines insurer in one or more states.



Signature of authorized representative of Insurer

Vanessa Ortega

Group Head of Operations, Authorized Representative of Beazley Excess and Surplus Insurance, Inc.
65 Memorial Road, Suite 320, West Hartford, CT 06017



Lucas 3--147
45990 MAY 28
BANGOR, OR 97106

Jan 29, 2026 2:17 PM
COLD TEST RESULTS
Jan 29, 2026 2:17 PM

T 11013232L PW1X
FROBE SERIAL MAP 014401
T 21013232L
FROBE SERIAL MAP 002122
0.2 COLD-ING TEST
PERS: Jan 29, 2026 1:48

T 21013232L
FROBE SERIAL MAP 000779
0.2 COLD-ING TEST
PERS: Jan 29, 2026 1:48

T 41013232L
FROBE SERIAL MAP 071197
0.2 COLD-ING TEST
PERS: Jan 29, 2026 1:48


***** END *****

To request materials by a
Service 711, or TTY 877.8

747

Sunset HWY

United Pacific #7470
49950 NW HWY 210
Banks OR 97100
ID # 2158



Structure S
csc R

