



GENERAL NOTES FOR ALL DETAILS ON THIS SHEET:

1. All existing AC or PCC pavement shall be sawcut prior to repaving.
2. Concrete pavement shall be replaced with concrete to a minimum thickness of 8" or to the thickness of removed pavement, whichever is greater.
3. For joining new concrete to existing concrete, see contract plans for sepecific details.
4. Place AC mix minimum thkn. of 6" or the thkn. of the removed pavement, whichever is greater. Compact as specified.

CALC. BOOK NO. N/A

SDR DATE 20-JUL-2020

NOTE: All material and workmanship shall be in accordance with the current City of The Dalles Standard Specifications

CITY OF THE DALLES STANDARD DRAWINGS

STREET CUT

2026

The selection and use of this Standard Drawing, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user and should not be used without consulting a Registered Professional Engineer.

DATE	REVISION DESCRIPTION
4/15/2025	Revised trench edge to pavement edge dimension