



Home of the Tualatin River National Wildlife Refuge

Planning Commission Meeting Packet

FOR

March 24, 2015

Work Session at 6 PM

Planning Commission at 7 PM

**Sherwood City Hall
22560 SW Pine Street
Sherwood, Oregon**



**City of Sherwood
PLANNING COMMISSION**

**Sherwood City Hall
22560 SW Pine Street
Sherwood, OR 97140**

March 24, 2015

6:00 PM Work Session

7:00 PM Planning Commission Meeting

6 PM Work Session Agenda

- 1. Medical Marijuana Dispensary Draft Language**
- 2. Housing Needs Analysis regulatory framework**

7 PM Planning Commission Agenda

- 1. Call to Order/ Roll Call**
- 2. Consent Agenda**
 - a. January 13, 2015 Planning Commission Minutes
 - b. February 24, 2015 Work Session Minutes
 - c. March 10, 2015 Work Session Minutes
- 3. Council Liaison Announcements (Council President Robinson)**
- 4. Staff Announcements (Brad Kilby)**
- 5. Community Comments**
- 6. New business**
 - a. Public Hearing – PA 15-01 Water System Master Plan Update (Brad Kilby)**

The City of Sherwood is updating the City's Water System Plan to address short and long-term community service needs. The proposed amendments provide an inventory of existing assets and conditions, and identifies strategies to ensure that the City can maintain and expand the existing water system to meet future demand.

For information and to view the draft documents go to the City's website at www.sherwoodoregon.gov/publicworks

- 7. Planning Commissioner Announcements**
- 8. Adjourn**



Home of the Tualatin River National Wildlife Refuge

Memorandum

City of Sherwood
22560 SW Pine St.
Sherwood, OR 97140
Tel 503-625-5522
Fax 503-625-5524
www.sherwoodoregon.gov

Mayor
Krisanna Clark
Council President
Sally Robinson

Councilors
Linda Henderson
Dan King
Jennifer Kuiper
Jennifer Harris
Beth Cooke

City Manager
Joe Gall, ICMA-CM

Assistant City Manager
Tom Pessemier, P.E.



2009 Top Ten Selection



2007 18th Best Place to Live

Sherwood

2006

All-America City Finalist

DATE: March 17, 2015
TO: PLANNING COMMISSION
FROM: Michelle Miller, AICP, Senior Planner
SUBJECT: PA 15 -02 Medical Marijuana Dispensaries

Attached please find the Draft Code amendments for Medical Marijuana Dispensaries.

Overall, the proposed changes:

- Add regulations for Medical Marijuana Dispensaries under the “Special Use” chapter within the Sherwood Zoning and Development Code
- Add relevant definitions to Chapter 16.10
- Adds a new category for processing Medical Marijuana Dispensaries under a Type II land use process; and
- Adds Medical Marijuana Dispensaries as a special permitted use with restrictions under the Commercial and Industrial land use categories tables

Under Chapter 16.38 (Special Uses), the proposed language reflects the land use process for permitting dispensaries and identifies location restrictions and other site restrictions for operating a medical marijuana dispensary in the City of Sherwood. The amendments also reinforce the rules established by the Oregon Health Authority under the Oregon Medical Marijuana Program.

Medical Marijuana Dispensaries

Plan Amendment -**DRAFT CODE LANGUAGE**

March 17, 2015

Additions are in BLUE

Add to Section 16.10- DEFINITIONS

MEDICAL MARIJUANA DISPENSARY: A retail facility registered by the Oregon Health Authority that is allowed to receive marijuana, immature marijuana plants or usable marijuana products (such as edible products, ointments, concentrates or tinctures) and to transfer that marijuana, immature plants, or usable project to a person with a valid Oregon Medical Marijuana Program card (a patient or the patient's caregiver).

MOBILE VENDOR: A service establishment operated from a licensed and moveable vehicle that vends or sells food and/or drink or other retail items processed or prepared on-site to walkup customers.

EXISTING Definitions (for reference purposes)

Public Park: A park, playground, swimming pool, reservoir, athletic field, or other recreational facility which is under the control, operation or management of the City or other government agency.

Educational Institution: Any bona-fide place of education or instruction, including customary accessory buildings, uses, and activities, that is administered by a legally-organized school district; church or religious organization; the State of Oregon; or any agency, college, and university operated as an educational institution under charter or license from the State of Oregon. An educational institution is not a commercial trade school as defined by Section 16.10.020.

Add to Land uses tables of Chapter 16.22.10 and 16. XX tables with footnotes to see Special Uses

Chapter 16.22 Commercial Land Use Districts

16.22.020 - Uses

A. The table below identifies the land uses that are permitted outright (P), permitted conditionally (C), and not permitted (N) in the Commercial Districts. The specific land use categories are described and defined in Chapter 16.88 Use Classifications and Interpretations.

B. Uses listed in other sections of this code, but not within this specific table are prohibited.

C. Any use not otherwise listed that can be shown to be consistent or associated with the uses permitted outright or conditionally in the commercial zones or contribute to the achievement of

the objectives of the commercial zones may be permitted outright or conditionally, utilizing the provisions of Chapter 16.88 Use Classifications and Interpretations.

D. Additional limitations for specific uses are identified in the footnotes of this table.

COMMERCIAL USES	OC	NC	RC	GC
COMMERCIAL				
General Retail - sales oriented				
<ul style="list-style-type: none"> General retail trade, not exceeding 10,000 square feet of gross square footage. 	P	P	P	P
<ul style="list-style-type: none"> General retail trade greater than 10,000 square feet of gross square footage 	N	P	P	P
<ul style="list-style-type: none"> Medical Marijuana Dispensary, not exceeding 5,000 square feet of gross square footage 	<u>N</u>	<u>N</u>	<u>P⁹</u>	<u>P⁹</u>

[9. See Special Criteria for Dispensaries under Chapter 16.38.020 .](#)

CHAPTER 16.31 INDUSTRIAL LAND USES

16.31.020 - Uses

A. The table below identifies the land uses that are permitted outright (P), permitted conditionally (C) and not permitted (N) in the industrial zoning districts. The specific land use categories are described and defined in Chapter 16.88

B. Uses listed in other sections of this code, but not within this specific table are prohibited.

C. Any use not otherwise listed that can be shown to be consistent or associated with the uses permitted outright or conditionally in the commercial zones or contribute to the achievement of the objectives of the commercial zones may be permitted outright or conditionally, utilizing the provisions of Chapter 16.88

D. Additional limitations for specific uses are identified in the footnotes of this table.

INDUSTRIAL USES	LI	GI	EI
COMMERCIAL			
<ul style="list-style-type: none"> Commercial Trade Schools, commercial educational services and training facilities 	N	P	P
Entertainment/recreation			
<ul style="list-style-type: none"> Country clubs, sports and racquet clubs and other similar clubs. 	C	C	C
<ul style="list-style-type: none"> Indoor recreation facilities such as arcades, mini-golf, or bounce house facilities^{2,3} 	C	C	C
<ul style="list-style-type: none"> Medical Marijuana Dispensary, not exceeding 5,000 square feet of gross square footage 	<u>P</u>	<u>P</u>	<u>N</u>

[10. See Special Criteria for Dispensaries under Chapter 16.38.020 .](#)

Add Medical Marijuana Dispensary to Category Type II Land Use Procedures for Processing Development Permits.

CHAPTER 16.72 Procedures for Processing Developing Permits

16.72.010 - Generally

A. Classifications

Except for Final Development Plans for Planned Unit Developments, which are reviewed per Section 16.40.030, all quasi-judicial development permit applications and legislative land use actions shall be classified as one of the following:

2. Type II

The following quasi-judicial actions shall be subject to a Type II review process:

a. Land Partitions

- b. Expedited Land Divisions - The Planning Director shall make a decision based on the information presented, and shall issue a development permit if the applicant has complied with all of the relevant requirements of the Zoning and Community Development Code. Conditions may be imposed by the Planning Director if necessary to fulfill the requirements of the adopted Comprehensive Plan, Transportation System Plan or the Zoning and Community Development Code.
- c. "Fast-track" Site Plan review, defined as those site plan applications which propose less than 15,000 square feet of floor area, parking or seating capacity of public, institutional, commercial or industrial use permitted by the underlying zone, or up to a total of 20% increase in floor area, parking or seating capacity for a land use or structure subject to conditional use permit, except as follows: auditoriums, theaters, stadiums, and those applications subject to Section 16.72.010.4, below.
- d. "Design Upgraded" Site Plan review, defined as those site plan applications which propose between 15,001 and 40,000 square feet of floor area, parking or seating capacity and which propose a minimum of eighty percent (80%) of the total possible points of design criteria in the "Commercial Design Review Matrix" found in Section 16.90.020.4.G.4.
- e. Industrial "Design Upgraded" projects, defined as those site plan applications which propose between 15,001 and 60,000 square feet of floor area, parking or seating capacity and which meet all of the criteria in 16.90.020.4.H.1.
- f. Homeowner's association street tree removal and replacement program extension.
- g. Class B Variance
- h. Street Design Modification
- i. Subdivisions between 4—10 lots
- [j. Medical Marijuana Dispensary permit](#)

16.38 SPECIAL USES

16.38.010 GENERAL PROVISIONS

Special uses included in this Section are uses which, due to their effect on surrounding properties, must be developed in accordance with special conditions and standards. These conditions and standards may differ from the development standards established for other uses in the same zoning district. When a dimensional standard for a special use differs from that of the underlying zoning district, the standard for the special use shall apply.

16.38.020 MEDICAL MARIJUANA DISPENSARIES

A. CHARACTERISTICS: Medical marijuana dispensaries are defined in Section § 16.10. For purposes of this Code, medical marijuana dispensaries must be registered by the Oregon Health Authority. A dispensary or facility not registered by the Oregon Health Authority is not permitted in any zone.

B. APPROVAL PROCESS: Where permitted, medical marijuana dispensaries are subject to approval under § 16.72.010A.2a, a Type II land use process.

C. STANDARDS

1. Hours of Operation: Dispensaries shall operate between the hours of 10 am to 6 pm Sunday through Thursday; and 10 am to 8 pm Friday and Saturday. An individual dispensary may set hours within those specified, but may not be open outside those parameters.

2. Security Measures Required

a. Landscaping must be continuously maintained to provide clear lines for sight from public rights of way to all building entrances.

b. Exterior lighting must be provided and continuously maintained.

c. Any security bars installed on doors or windows visible from the public right of way must be installed interior to the door or window, in a manner that they are not visible from the public right of way.

3. Co-location prohibited.

a. A dispensary cannot be located at the same address as a marijuana manufacturing facility, including a grow operation.

b. A dispensary cannot be located at the same address with any facility or business at which medical marijuana is inhaled or consumed by cardholders.

4. Mobile Vendors Prohibited

A dispensary may not operate as a mobile vendors as defined in Chapter 16.10.

5. Drive-through marijuana dispensaries are prohibited

6. Proximity Restrictions

A dispensary must not be located within 1,000 feet of any of the uses listed below. For purposes of this paragraph, the distance specified is measured from the closest points between property lines of the affected properties:

a. Educational Institution: public or private elementary, secondary, or career school that is attended primarily by children under 18 years of age.

b. Other medical marijuana dispensaries.

c. Public Parks and plazas

Consent Agenda

City of Sherwood, Oregon
Planning Commission
January 13, 2015

Planning Commission Members Present: Staff Present:

Chair Jean Simson

Vice Chair Russell Griffin

Commissioner James Copfer

Commissioner Beth Cooke

Commissioner John Clifford

Julia Hajduk, Community Development Director

Bob Galati, Civil Engineer

Brad Kilby, Planning Manager

Michelle Miller, Senior Planner

Kirsten Allen, Planning Dept. Program Coordinator

Planning Commission Members Absent:

Commissioner Lisa Walker

Council Members Present:

Councilor Sally Robinson

Legal Counsel:

Chris Crean

1. Call to Order/Roll Call

Chair Jean Simson called the meeting to order at 7:02 pm.

2. Consent Agenda

Chair Simson suggested the minutes in the Consent Agenda could be approved at once or individually when the following motion was received.

Motion: From Commissioner Beth Cook to accept the Consent Agenda, Seconded by Vice Chair James Copfer.

Chair Simson noted a scrivener error on the December 9, 2014 failing to list Connie Randall as staff.

Commissioner Clifford pointed to two locations where he was labeled as John Clifford instead of Commissioner Clifford in the September 9, 2014 minutes.

Chair Simson asked for vote approving the Consent Agenda with the changes.

All present Planning Commissioners voted in favor (Commissioners Walker was absent).

3. Council Liaison Announcements

Julia Hajduk, Community Development Director introduced Sally Robinson as a former Planning Commissioner and newly sworn in councilor and elected Council President.

Ms. Robinson said she had volunteered to continue meeting with the Planning Commission in the liaison capacity as she enjoyed the work before the Planning Commission.

Ms. Robinson commented on Ms.Hajduk's presentation at the Chamber of Commerce breakfast regarding long range growth in Sherwood and indicated that a City Council work session scheduled for the evening was cancelled due to Council Henderson and Commissioner Griffin's objections.

Commissioner Griffin asked for clarification and said he did not have any involvement in the meeting cancellation. Ms.Hajduk explained that there was a work session scheduled and there were comments raised about proper notice which resulted in rescheduling the meeting.

Commissioner Griffin asked to clear the record and objected to claims that he did something to sabotage the meeting. He explained that he had emailed the city recorder inquiring about an agenda for the work session and received a list of topics for the work session. Commissioner Griffin noted that the list of topics was also on a weekly email from the city manager to staff and board members and that he later received an agenda from the city recorder. Commissioner Griffin stated that he was upset by the accusation and that he was unaware that the meeting had not taken place.

4. Staff Announcements

Brad Kilby, Planning Manager, said there were several announcements.

- Sherwood West Preliminary Concept Plan
 - An informational meeting for Community Advisory Committee applicants on January 26, 2015.
 - There were 43 applicants for 13 open positions. This meeting is open to the public.
 - The first Community Advisory Committee meeting is scheduled for February 5, 2015 at Edy Ridge cafeteria at 6pm.
 - Discussion will include the project objectives, schedule, existing conditions, and how the buildable lands inventory for the housing needs analysis was being conducted.
- Joint Planning Commission and City Council Work Session on February 3, 2015
 - Topics include the Code Update recently recommended by the Planning Commission to City Council and Marijuana regulation. The city must have regulations in place on marijuana before a moratorium ends in May 2015.
- Planning Commission Vacancies
 - Subject to his appointment by the City Council, Mayor Clark and Chair Simson have chosen Dr. Alan Pearson to fill Sally Robinson's seat.
 - Commissioner John Clifford has decided not renew his term as a Planning Commissioner and hopes to serve on the Parks and Recreation Board.
 - Commissioner Cooke has registered to be on the ballot for the open City Council position.
- Tonquin Employment Area (Julia Hajduk) –
 - The City and Washington County received a grant for \$371,446 for large lot industrial site assessments throughout Washington County. The City's focus is an implementation and marketing strategy for the Tonquin Employment Area (TEA) to identify what is preventing the area from developing and what the city can do to assist.
 - The study may identify if there are adjustments that can be made to the development code and what can be done to bring the area and jobs online.
 - The consultants are nearly done with the large lot site assessments and will move to the TEA focus in the next few months. If changes to the code are recommended a public process will take place.

- Tannery Environmental Protection Agency Grant (Julia Hajduk)
 - The City received a \$200,000 grant from the federal government through the Environmental Protection Agency Grant (EPA) to do a site assessment on the orphan properties of the tannery site [on Oregon Street].
 - The properties are owned by Washington County due to foreclosure.
 - The site assessments will identify potential clean-up plans with the intent of helping the city decide about acquiring the property. One of the internal discussions has been to move the public works yard to that location and open the existing location to redevelopment that is more consistent with the Old Town vision.
 - The project is just starting and the City is beginning the contracting negotiation process with a consultant.
- To learn more about land use activities which include applications before the Planning Commission, Hearing Officer, and Staff decisions there is a new email service that will send weekly email with information about those activities on from the website. To sign up for the e-news list go to www.sherwoodoregon.gov/newsletter/subscriptions or find the link on the [Planning Department](#) or the [Planning Commission](#) websites.

Chair Simson indicated that the traffic calming process, as brought to light by Lynnly Way residents, has not been budgeted yet. Staff hopes to have a more formal policy and budgeting in place within the next budget cycle.

5. Community Comments

There were no community comments.

6. New Business

a. Election of new Chair and Vice Chair

Chair Simson indicated that per the Sherwood Zoning and Community Development Code a Planning Commission chair and vice chair should be elected in odd calendar years. She opened the floor for nominations.

Nominations were received, seconded and accepted for Commissioner Simson to continue as chair and for Commissioner Griffin to be vice chair. All present Planning Commissioners voted in favor (Commissioners Walker was absent).

b. Public Hearing – SP 14-03 Lam Research Major Modification

Chair Simson read the public hearing statement and asked for any ex parte contact, bias, or conflicts of interest. Commissioner Cooke and Clifford indicated they had visited the site, Vice Chair Griffin had Googled it, and Chair Simson indicated she drives passed it regularly.

Chair Simson revealed that the Planning Commission was the decision making body, any appeals would go to the City Council, and asked staff for a report.

Senior Planner, Michelle Miller gave a presentation (see record, Exhibit 1) and said the applicant, Lam Research, was proposing to add fifty four parking spaces to an existing industrial site by re-striping the existing driveways around the perimeter of the building. She indicated that the review was a Site Plan

Major Modification, because Lam Research would be adding over one hundred average daily trips to the site; a criterion for a major modification. Ms. Miller explained that major modifications require the same decision maker as in the original decision which was the Planning Commission and the review entailed only the code criteria for the changes that the applicant was proposing; the parking lot and parking lot landscaping.

Ms. Miller showed aerial views of the site which is off of Tualatin Sherwood Road in the northeast portion of the city at 20551 SW Wildrose Place. She communicated that it was part of a development from 1998 and was the former distributions center for Pacific Foods. The site is just less than five acres with an existing 100,400 square feet building. Ms. Miller said the property is zoned General Industrial and surrounded by other General Industrial properties. She disclosed that the site currently has 21 parking spaces, a water quality facility and three large delivery bays.

Ms. Miller described Lam Research as a company in the semiconductor industry that wished to put warehousing and light assembly in the building. Lam Research is based in California with another building in Tualatin. Ms. Miller indicated they would run three shifts of twenty five employees arriving at different times of the day and most of the added traffic was for deliveries occurring during the course of the day. She said the City did not receive any citizen comments on the proposal.

Ms. Miller showed a site plan with the proposed parking which surrounded the perimeter of the building and explained that the applicant would convert the drive ways into one-way drive aisles and most of the recommended conditions of approval were regarding adequate signage, ensuring that the landscape islands were the proper size, and that the tree canopy requirements were met. The conditions were listed in the staff report.

Ms. Miller revealed that comments from Clean Water Services were received; they were satisfied with the existing water quality facility on site and Tualatin Valley Fire and Rescue had made recommendations found in the staff report. She said one of the main issues with the project concerned the Traffic Impact Analysis (TIA) that indicated failed traffic wait times or mobility targets on Wildrose Place at the intersection with Tualatin Sherwood Road. Ms. Miller explained that the mitigation proposed was to install a traffic light at Wildrose Place, but it was too close the traffic lights at Cipole Road and Oregon Street to install a light at Wildrose place. She said another option that was discussed in the transportation study was to restripe Wildrose Place to add a left turn lane on (towards Tualatin). Ms. Miller suggested that Bob Galati, City Engineer, could answer questions, but in weighing that alternative he found that restriping would not meet the mobility targets and it would be problematic for trucks turning, because they would use both lanes anyway. Ms. Miller stated that the mitigation measure would not achieve the desired result and the recommendation was to look at a long term solution instead; there is property to the east that may develop and amend the traffic patterns as the area develops over time. Ms. Miller pointed to a letter from Washington County (see planning record, Exhibit G, SP 14-03) and said the County recommended the Planning Commission consider the restriping because of mobility targets, but that was the County's standard answer.

Ms. Miller indicated that Staff recommended approval of the site plan modification with the conditions of approval identified in the staff report, offered to answer questions from the Planning Commission, and asked the Commission to hold a public hearing.

Commissioner Clifford commented that during high traffic time the left turn signal onto Oregon Street backed up and said it would likely interfere with traffic turning left from Wildrose Place. Bob Galati responded that most of the traffic from the development was towards Tualatin as the site will be used as a storage warehouse and packaging assembly for the Tualatin location. He said most of

their turning movements were in the left hand lane from Wildrose onto Tualatin Sherwood Road and, based on conversation with the traffic engineer and Washington County, congestion at Oregon Street would not be affected as much. Mr. Galati expressed that the concern involved fifty foot long trucks making a right hand turn onto Wildrose Place from Tualatin Sherwood Road and encroaching into the left turn lane should the striping occur. If a car were in that lane waiting to turn left on to Tualatin Sherwood Road the truck would have to wait until there is room; congestion would be towards Cipole Road. He pointed out that the big issue was traffic backing up on Wildrose Place, which is a dead end street coming onto a major road without a signal. Mr. Galati said congestion at Cipole Road and Oregon Street will basically remain the same. He said the long term solution was to mitigate for the future by getting a route through development towards Cipole Road along the back of the property, allowing for a right in/right out at Wildrose Place by diverting traffic to Cipole Road. Mr. Galati recommended not providing the left turn lane on Wildrose Place, because it will be an issue with backing up on Tualatin Sherwood Road for the right turn into the development.

Chair Simson commented that the letter from Washington County calls for the restriping of Wildrose Place, but the restriping was not in the conditions of approval nor was it in agreement with staff's recommendation. She asked if the City could ignore the County, because Wildrose Place was a city road. Discussion followed regarding exiting Wildrose Place onto Tualatin Sherwood Road, with a reminder that shifts would be staggered and most of the truck traffic from Lam Research would be toward Tualatin.

Lance Forney, All County Surveyors & Planners, PO Box 955, Sandy Oregon came forward and said All County Surveyors had been hired by the owner, Brad Picking, to complete the planning, surveying, and on site civil engineering portions of the project and had teamed up with Makenzie for the traffic analysis.

Mr. Forney thanked staff for the conditions of approval and said everything on site was straight forward and would be easy to complete through the final engineering and design process. He stated that changing the use of the existing warehouse would create added average daily trips and the only obstacle faced onsite was fire department access. Mr. Forney indicated they had come up with a plan that the fire chief had agreed upon regarding aisle widths and offered to answer questions.

Chair Simson asked for confirmation that Mr. Forney was in agreement with the conditions of approval, as written by staff and that the fire lane would be around the entire perimeter of the property. Mr. Forney confirmed.

Commissioner Clifford asked if approval from the fire department was before or after the addition of wheel stops which added three feet of parking stall space. Mr. Forney responded that the design was standard, the length of the spaces was taken into consideration, and he did not see any issues. He added that it was up to the client to ensure that the fire lane stayed clear.

Commissioner Clifford asked if All County would take care of the landscape island dimensions. Mr. Forney confirmed and said they were laid out on the site plan to meet code. Commissioner Clifford asked regarding the tree canopies and encroachment of the trees selected. Mr. Forney replied that one of the proposed trees would hinder parking and they were working with a landscape architect to select a tree that would not hinder movement.

Commissioner Cooke complemented the applicant on the design given the constraints of the site and the number of spaces required.

The applicant had twenty eight minutes of rebuttal time remaining.

Chair Simson acknowledge that bringing these jobs into Sherwood would increase the number of average daily trips by three hundred, said there would be three staggered shifts, and said she assumed there would be consideration of shift change time and rush hour traffic times. Mr. Forney responded that Lam Research was familiar with the traffic patterns on Tualatin Sherwood Road and should take that into consideration.

Chair Simson asked if there were any questions for Makenzie and commented that the executive summary was easy to understand. None were received.

Chair Simson asked for any citizen testimony. Seeing none, Chair Simson closed the public comment portion of the hearing and asked if there were any questions for staff.

Commissioner Cooke asked if there were any potential issues if the City decided not to accept the County's recommendation to create a left turn lane on Wildrose Place. Ms. Miller answered that the impacts were not on the County road and the County's comments were a recommendation based on the transportation study.

Motion: From Commissioner James Copfer to approve the application, SP 14-03 Lam Research Major Modification, based on the applicant's testimony, public testimony received, and the analysis, finding and conditions in the Staff Report. Seconded by Commissioner Beth Cooke. All present Planning Commissioners voted in favor (Commissioners Walker was absent).

Chair Simson called for a recess at 7:50 pm and reconvened at 7:55 pm.

c. Public Hearing – PUD 14-01/SUB 14-01, Cedar Brook PUD Final Development Plan

Chair Simson read the public hearing statement and asked for any ex parte contact, bias, or conflicts of interest.

Chair Simson disclosed that she works for a company that distributes building materials for new construction and those customers at some time may sell to DR Horton, but the company does not sell directly to DR Horton. She said she did not think it would affect her ability to make an impartial decision. She asked if anyone in the audience wished to challenge the any Planning Commission member's ability to participate. None were received.

Senior Planner, Michelle Miller gave a presentation (see record, Exhibit 2) and said the issue before the Planning Commission was the approval of the Final Development Plan for the Cedar Brook Planned Unit Development to ensure that it was in compliance with the preliminary approval of the Planned Unit Development (PUD). She gave some project background and said the Planning Commission forwarded a recommendation of approval to Council of the project in June 2014 which they approved in August 2014. Ms. Miller stated that the hearing would determine if the final development plan was in compliance with all of the conditions that were set forth in the original notice of decision and said all of the conditions in that approval were still in effect.

Ms. Miller explained that the final development materials had been submitted by the applicant and the evaluation would include the CCR's, the architectural details found in the architectural pattern book and the proposed elevations. She said the Planning Commission should ensure the housing design fit with the community's standards. Ms. Miller indicated that the applicant's final plat was also included as a reference against the original preliminary approval. She added that the final plat was currently in

review by city staff through a Type I review process which will be forwarded to Washington County for their review and approval.

Ms. Miller showed an aerial view of the site and said it was on the north side of 99W, located next to the Woodhaven Crossing II development (Creekview Crossing) near the roundabout on Meinecke Road. The proposal was for a 65 lot residential development with a mix of single family attached and detached homes. Ms. Miller showed a layout of the site plan and said it would be a combination of two story, two car garage town homes in the interior of the site with single family detached on the outside of the site along Cedar Brook Way. She said Street A where the front loaded single car garage townhomes were located would be named Berkshire Terrace and along Meinecke Parkway were the single garage townhomes.

Ms. Miller stated that parking would be allowed on both sides of Cedar Brook Way and on one side of SW Berkshire Terrace which accounted for 77 parking spaces. Combined with the on-site parking it totaled 261 parking spaces with an average of four parking spaces per dwelling unit.

Ms. Miller displayed illustrations of the single family front loaded garage units and said the applicant submitted an architectural pattern book which described the material the applicant was proposing to use. Sample material boards were available along the wall in the community room that included siding and stonework. She commented that the color palate used in the overall design of the site was called "Northwest" cottage style. The buildings will have at least three different materials, porches will be covered, and there will be three different colors with no repeated colors next to each other. Ms. Miller said the architectural pattern book contained a checklist that would be submitted with each building permit application. She explained that the checklist included setback requirements for each of the different lots; varied setbacks were approved by the Planning Commission in the preliminary approval. The checklist will aid with the plot plan review for each building permit application and ensure that the townhome standards were met.

Chair Simson asked about the front yard setbacks for lots 29-38 showing a 15 feet setback. Ms. Miller reminded the Commission that a text amendment changed the front yard setback in the Medium Density Residential High and High Density Residential zones to a minimum of 14 feet.

Ms. Miller showed a rendering of the rear loaded townhomes and a single family detached unit. She showed the fencing plan with perimeter fencing at the multi-family development, side yard fencing along the Cedar Brook Way properties, and rear fencing along SW Meinecke Parkway. Ms. Miller said the applicant had agreed to break up some of the wooden fencing along SW Meinecke Parkway with masonry pillars to make it a little nicer for the pedestrian view and as part of the visual corridor requirement. She stated that there are easements over all of the pathways for public access.

Ms. Miller explained that the Covenants, Conditions and Restrictions (CCR's) discussed how the property is to be maintained, about the open space areas, as well as the condition requested by the Planning Commission to ensure that garages would be used exclusively for parking. Ms. Miller noted that the CCR's noted that the garage receptacles would need to be kept out of view, so one of the recommended conditions was to account for room in the garages for those types of extra items in the garages.

Ms. Miller showed open space areas, known as tracts E and F in the center of the site. She said the tracts included activity centers and garbage receptacles.

Ms. Miller showed tract K which was proposed to be a fenced in dog park area with landscaping. She said she had questions about the materials that the applicant has proposed and contacted Tualatin Hills Park and Recreation District (THPRD) about the material they use. Ms. Miller discovered that bark mulch is a good material instead of grass because grass can be overused by the dogs, but THPRD indicated that the proposed bark mulch was problematic to the dogs' paws. She asked the Planning Commission to review.

Ms. Miller indicated that staff was recommending approval with conditions; the applicant should provide dimensions of the one and two car garages to show there was adequate space for garbage/recycling receptacles, a Landscape Plan showing the types of trees to ensure the tree canopy requirements were met, open space maintenance and irrigation schedules, continue to receive Final Plat approval and comply with the preliminary Planned Unit Development conditions of approval. Ms. Miller offered to answer questions from the Commission.

Chair Simson asked for clarification on the height of fences along Meinecke Parkway. Ms. Miller replied that the houses along Meinecke Parkway faced the interior alleyway without access on to Meinecke and the fences would be six foot tall. Ms. Miller added that there would also be a visual corridor on Meinecke Parkway and the portion of the fencing in the corridor was allowed. Chair Simson commented that the fencing would create visual breaks using different fencing materials and asked if there would be shrubbery for screening as well. Ms. Miller confirmed and explained that there would be landscaping and street trees.

Commissioner Clifford asked regarding the water quality facility. Ms. Miller commented that there had been some changes to storm water management that took place at the City Council level and referred to the City Engineer. Mr. Galati Galati responded that site development requires management of storm water runoff and the plan presented to the Planning Commission was rough in design and changes were made make it fit better. He said the design changes would account for requirements and constructability; the final plan reflects a more refined design pattern to the storm water facility based on the City's criteria, Clean Water Services' criteria and constructability. Commissioner Clifford asked if the storm water would be treated first in this water quality facility and any overflow would go into the existing water quality facility or if it was designed for a certain area of the project. Mr. Galati responded that the area would be treated for the two year storm flow where everything would go to the water quality facility for the two year level. At a twenty five year storm event the water quality facility would discharge. Mr. Galati said he did not think it discharged to the existing system, but into to the stream corridor, which was allowed and the engineer of record could confirm.

Chair Simson noted the City Council had approved a few minor changes from what the Planning Commission had recommended and asked if there were any other significant changes. Mr. Galati replied that the storm water was the only major change and commented that the changes were refinements made during the process of development to layout the site, design storm water management, and confirm constructability.

Ms. Miller added that besides the addition of the water quality facility, the percentage of open space was reduced near the SW Cedar Brook Way on the east side of the property, but still met the requirement and City Council expressed concern regarding signage for the proposed use of tract K, the Dog Park and the dedication of the pedestrian pathways.

Vice Chair Griffin asked if the dog park would be exclusive use for the residents. Ms. Miller clarified that the dog park would be exclusive, but the pedestrian pathway would be public so people could walk from Meinecke Parkway and Cedar Brook Way to the school or along the trail.

With no other questions from the Commission, Chair Simson called for applicant testimony.

Andy Tiemann, Project Manager for DR Horton came forward and gave a presentation (see record, Exhibit 3). He indicated he read and agreed with the staff report and the conditions of approval and would satisfy those conditions when they go through the remainder of the development with building permits and other plan approvals. Mr. Tiemann showed the proposed site plan, what the three, four, and five-plexes looked like, as well as the single family detached homes.

Mr. Tiemann stated that the architect was making revisions to the plans for the single car garage townhomes to ensure that the garbage receptacles had room in the garage and the detached homes would store garbage receptacles in the side yard. He said the change would be reflected on the plans when building permits were applied for. The garage door would be shifted about a foot for the front loaded townhomes (the proposed elevations showed the garage doors centered).

Commissioner Clifford asked if the receptacles could be removed from the garages while a car was parked inside the garage. Mr. Tiemann responded that the car would have to be outside the garages and indicated that the townhomes had been built in other jurisdictions and homeowners did it on a regular basis. He communicated that the open spaces would be irrigated and maintained by the homeowners association and a detailed maintenance plan would be provided describing the homeowner's responsibilities. Chair Simson asked if the all of the pocket parks in the project would be maintained and owned by the homeowners association. Mr. Tiemann confirmed.

Commissioner Cooke stated that the illustrations were beautiful, but she did not think they were an accurate representation. She said the amount of space illustrated did not show how close the buildings were, they were not representative of the reality and she would like the industry to show a more accurate representation when testifying before planning commissions of how the neighborhoods would impact each other and how the homes are set next to each other. Commissioner Cooke conveyed her struggle after the initial approval, which she voted for, because she felt the Commission was constrained by Metro's guidelines. She commented that it felt like a tight development and she was concerned about the livability it would bring to our community.

Mr. Tiemann responded that the property was zoned High Density Residential and they tried to implement detached homes, but it was a very difficult project to design and it would be a dense community.

Commissioner Copfer commented that this was why the city had codes in place and the applicant had met the code requirements.

Chair Simson stated that the Planning Commission would not revisit the PUD, but look to see if the applicant had met the code. She said in the Townhomes code Section 16.44.010E.4.b it specifically stated that *the roofs of each attached townhome must be distinct from the other through either separation of roof pitches or direction, variation in roof design, or architectural feature. Hipped, gambrel, gabled, or curved roofs are required. Flat roofs are not permitted.*

Chair Simson stated she had looked at the building designs and expressed concern for two buildings not meeting the criteria. She commented that she was not a structural engineer, but what was shown in the pictures with the split roof looked like two homes even though it represented four or five homes. Chair Simson acknowledged that creating five distinct roofs would look busy and she could appreciate the compromise between a roof design that created distinct features and a busy design. She pointed to the three-plex facing SW Berkshire Terrace had no roof distinction and the five-plex at lots

58-62. Chair Simson noted that one of the four-plexes had three distinct roof lines with architectural interest that met the intent of the code.

Mr. Tiemann said roof breaks could be added to the interior units. Discussion followed. Staff was asked to draft a condition of approval.

Commissioner Clifford asked regarding the landscape plan provided and commented that there was a conflict between the renderings and the landscape plan. He said the renderings had a number of plants and the landscape plan had only lawn and he would like to see more ground cover or shrubs at utility box locations, not rock, gravel, or fake plants. Commissioner Clifford suggested there should be something in the CCR's that prohibited things in the yard that would not be cohesive with the rest of the neighborhood. Mr. Tiemann responded that certain materials could be restricted, but the intent was to have grass, ground cover and shrubs in the front yard.

Commissioner Clifford conveyed his understanding that DR Horton would maintain the project site until the last house or townhouse was sold and asked if a management company would oversee maintenance of the development along with the homeowners association. Mr. Tiemann confirmed and indicated that a property management company would be contracted as soon as the open spaces were landscaped and the management company would hire landscapers to maintain the areas during construction. Mr. Tiemann said the management company would be retained until the last home was sold and at that point the board will be turned over to the community.

Commissioner Clifford disclosed that he lived in a community with CCR's and the original purchaser of the home was required to live in the home for a year before it could be rented. He asked if there was anything preventing a person from buying a number of townhomes and rent them. Mr. Tiemann replied that he was not aware of any restrictions, that it was not a typical restriction, and that he did not think DR Horton sold to a high number of investors; their typical buyer was a home buyer, not an investor who would buy a whole block or subdivision. Mr. Tiemann commented that about forty percent of the population rents, so in general there may be forty percent of the development in rentals.

With no other questions for the applicant, chair Simson asked how much time the applicant had for rebuttal. She was told there was approximately 23:30 minutes left prior to questions from the commission. 1:30

Chair Simson asked for public testimony.

Bill Sweet, Sherwood resident came forward and asked for the plat map to be shown on the screen. Mr. Sweet said the trail going passed the dog trail went down a hill, crossed the wetlands and came back and connected to the trail that runs behind the Vineyards subdivision. He asked who would maintain that portion of the trail and said it was right behind his backyard. Mr. Sweet expressed concern because he already had people on the trail late at night smoking, drinking, and going off into the trees. He revealed that he could be out on any summer night at one or two o'clock in the morning as just happened on New Year's. Mr. Sweet asked if the trail would be patrolled.

Mr. Sweet expressed concern regarding the dog park, said it should not be exclusive, and that he owned two Siberian Huskies that should be able to use the dog park. He asked if the trail was going through regardless, because he saw the city there doing some flagging. Chair Simson asked staff to respond.

Ms. Miller replied that this trail was mislabeled and the Cedar Creek Trail was a different project. She said the trail Mr. Sweet was referring to was a local connection to the school and the current local trail. They are public trails owned and maintained by the City. Ms. Miller recommended that he contact the authorities for issues he was having so activity in the area can be monitored. She advised that when there are more trail users there is less crime, because there are more eyes on the trail, similar to a public street. Ms. Miller indicated that the hope was that the trail will be used by people in the neighborhood.

With respect to the dog park, Ms. Miller reported that the Parks and Recreation Board made the decision that the dog park would be owned by the homeowners association because the City did not want to take on the maintenance responsibility. They saw the site as too small for more than just the neighborhood to use. Some of the smaller parks are harder for city staff to maintain.

Commissioner Copfer asked regarding the trail marked as the Cedar Creek Trail. Ms. Miller responded that the trail for this project was a “spur” and the main corridor of the trail followed the Cedar Creek corridor and this wetland was a tributary to the creek. She indicated that people could use this trail and connect along Meinecke Parkway to 99W and connect to the trail or in the future it might be a connection through the Vineyards and cross over to connect with main Cedar Creek Trail. Ms. Miller said at this point it was not part of the federal grant project known as the Cedar Creek Trail.

Chair Simson added that this trail was part of the City’s Transportation System Plan for pedestrian street connectivity. Mr. Sweet asked if the connection was part of the project and if it was in that location so the children could walk to the school.

Chair Simson explained that this local trail was part of the master plan through the Transportation Plan which included transportation for pedestrians, bicycles and vehicles and in this location there was a connection identified. As development occurs it is the responsibility of the developer to provide services deemed appropriate as part of the master plan; roads, trails, bike and pedestrian pathways have to connect. Mr. Sweet pointed out that it was being used even as a dirt trail.

Bob Galati, City Engineer, added that it was being located there because there is an existing access. Mr. Sweet said if the connection was to make it easier for the kids to get to school it would make more sense to put it at the other end where it comes out by a park that has a sidewalk that goes right to the school.

Commissioner Copfer said that there was a connection to Sherwood High School through Meinecke Parkway specifying that the trail does not go through the new development, but alongside it.

Mr. Sweet commented that he was the one that lived in the area and would have to deal with problems. He suggested that he should have paid more attention or someone should have knocked on his door to inform him of the new path. Mr. Sweet asked if the pathway would have lighting. When the answer was no he asked how that would deter crime and people going down there and doing what they do now. He said it would still be a dark hole and the illicit activity would continue.

Commissioner Copfer commented that the walking trails through the Woodhaven subdivision were not lit. Mr. Sweet said he had lived in Sherwood for over twenty years. Sherwood has changed a great deal, and was not very different from Orange County, California. The city was so big and congested.

With no other public comments, Chair Simson asked if the applicant would care to provide rebuttal. The applicant declined.

Chair Simson closed the public hearing and the Commission began deliberation. She asked staff for the condition of approval that was requested.

Ms. Miller asked for clarification on which units the Planning Commission would like the condition to apply to. Commissioner Copfer commented that there should not be more than two units without a roof break. Commissioner Cooke said she was most concerned about the five-plex. Chair Simson said the code called for each roof being distinct, but in looking at the other design elements (gables and glazing on the end) she felt the other criteria had been met. By providing the roof breaks at least every two units in conjunction with the gables and architectural features, they would be in compliance with a distinct roof per unit.

Chair Simson asked for any other discussion points while staff drafted language.

Vice Chair Griffin asked to talk about the dog park. Chair Simson commented that the Commission was not dismissing the citizen's concerns, but that the local trail was part of the master plan. Vice Chair Griffin said he had questions about the proposed materials for the dog park and asked and what materials might be used instead. Commissioner Cooke commented that the dog park in Tualatin used bark chips and users were discovering that bark chips were not good for the dog's paws, but smaller dog parks have a hard time with grass.

Commissioner Copfer added that he understood Mr. Sweet's concerns about the trail in his backyard and said Woodhaven had trails go behind people's backyards. Chair Simson said trails added to livability so people could walk to schools and exercise. Commissioner Copfer said a lot of communities would love to have the trails that Sherwood has.

The following sixth condition of approval was drafted as part of the approval. *Prior to issuance of building permits, submit plans that show that there is at least one roof break at a minimum of every two townhome units.*

With no other discussion, the following motion was received.

Motion: From Vice Chair Russell Griffin to approve the application for Cedar Brook PUD Final Development Plan (PUD 14-01/SUB 14-01), based on the applicant's testimony, public testimony received, and the analysis, finding and existing conditions and new condition now in the Staff Report. Seconded by Commissioner James Copfer.

Commissioner Beth Cooke stated that while she felt the applicant had met the code requirements she had concerns about how the development impacted the livability of the community. She said she recognized that there was a zoning change to the property, she would not vote against it, but could not cast a yes vote and would abstain.

All other present Planning Commissioners voted in favor (Commissioners Walker was absent).

7. Planning Commissioner Announcements

Chair Simson commented that when the Commission moves forward with code amendments and other community wide actions a citizen had suggested having a note in the utility bills. She explained there are sometimes notifications in a big red font on the bill and it would be nice if the Planning Department could use the utility bills as an additional way to say code amendments were coming.

Ms.Hajduk responded that staff had looked into the option and there was a cost associated with it adding flyers to the utility bills, but she would talk to other managers about the feasibility of adding a note on to the bills.

Vice Chair Griffins reported that, Mary Poppins, the first official show in the new cultural center, would be the first two weekends of March, Thursday through Saturday. He said casting took place the week previous and rehearsals had begun. He commented that it would be a great way to open up the brand new center. The auditorium can seat almost four hundred people and the stage is forty feet wider than the one at Stella Olsen Park. Vice Chair Griffin said there would be about seventy five people on stage, singing, at the same time.

8. Adjourn

Chair Simson adjourned the meeting at 8:56 pm.

Submitted by:

Kirsten Allen

Planning Department Program Coordinator

Approval Date: _____

City of Sherwood, Oregon
Planning Commission
Work Session
February 24, 2015

Planning Commissioners Present:

Chair Jean Simson
Commissioner John Clifford
Commissioner Alan Pearson
Commissioner Lisa Walker

Staff Present:

Julia Hajduk, Community Development Director
Rich Sattler, Operations Supervisor of Water
Brad Kilby, Planning Manager
Michelle Miller, Senior Planner
Kirsten Allen, Planning Dept. Program Coordinator

Planning Commission Members Absent:

Vice Chair Russell Griffin
Commissioner James Copfer

Council Members Present:

Council President Sally Robinson

Legal Counsel:

None

1. Call to Order/Roll Call

Chair Jean Simson called the meeting to order at 7:04 pm.

2. Council Liaison Announcements

Council President Sally Robinson stated that the initial meeting for the Sherwood West Preliminary Concept took place on February 5, 2015. She said the project would utilize an online survey tool that might be useful to determine public sentiment about medical marijuana and other projects in Sherwood.

3. Staff Announcements

Brad Kilby, Planning Manager introduced Commissioner Alan Pearson as a new planning commissioner. Commissioner Pearson has called Sherwood his home for a couple of years; he said he hopes to help guide the city as it grows, he was not opposed to development, but opposed to bad development.

Mr. Kilby commented that Commissioner John Clifford would be leaving the Planning Commission to serve on the Parks and Recreation Board which leaves two open Planning Commission seats. Applications will be accepted by the City Recorder's office through March 13, 2015. Commissioner Lisa Walker suggested previous Planning Commission applicants be contacted regarding their interest in serving.

Mr. Kilby disclosed that the new Police Advisory Committee has been invited to participate in the medical and recreational marijuana discussions, but none were present as they have not yet met as a committee.

4. Water System Master Plan Update

The Planning Commission was provided with an electronic copy of the February 2015 Draft Water System Master Plan Update prior to the meeting (see record, Exhibit 1)

Rich Sattler, Operations Supervisor for Water explained that in 2005 when the previous master planning was completed, the City was looking for a source of water. The City now takes water from the Willamette River Water Treatment Plant (WRWTP) in Wilsonville and a number of improvements in the plan have been built. He said a water system plan is used to determine future demand for the next 20 years, identify deficiencies, update the City's Capital Improvement Program (CIP) and evaluate water rates and System Development Charges (SDC).

Mr. Sattler reported that staff was working with the City Finance Department to assess rate costs and SDC's. He introduced consultants, Heidi Springer and Brian Ginter of Murray, Smith & Associates, Inc. (MSA) and said there would be an open house the following evening on February 25, 2015 at the Police Facility to receive citizen input.

Ms. Springer gave a presentation (see record, Exhibit 2). Discussion followed which included current and anticipated demand, capital improvements, potable water, water rates, resilience plan, water storage, current capacity, regional coordination and fund allocation. The Planning Commission asked for more information about how different revenue sources pay for capital improvements and how those projects are prioritized.

5. Medical Marijuana Dispensaries

Michelle Miller, Senior Planner gave a presentation (see record, Exhibit 3), reminded the Commission that the discussion was limited to Medical Marijuana Dispensaries (MMD) as the City was bumping up against the May 1, 2015 deadline to have legislation in place.

Ms. Miller reviewed the state regulations, options for legislation, pros and cons for locating dispensaries in the commercial or industrial zones, process options, and actions from other jurisdictions. Discussion followed.

Staff was directed to provide official recommendations from the police department, a clear definition of education facilities, buffer maps within commercial and industrial zones and discussion points for the Medical Marijuana Public Work Session on March 10, 2015 at 6:30pm.

6. Planning Commissioner Announcements

Chair Simson commented the Sherwood West Preliminary Concept Plan Open House was well attended and recommended viewing the video on the website at www.sherwoodoregon.gov/sherwoodwest.

The next meeting for the Sherwood West Citizen Advisory Committee (CAC) will be on April 2, 2015 at the Police Facility.

7. Adjourn

Chair Simson adjourned the meeting at 9:20pm.

Submitted by:

Kirsten Allen
Planning Department Program Coordinator

Approval Date: _____

Planning Commission Meeting DRAFT Minutes
February 24, 2015
Page 2 of 2

City of Sherwood, Oregon
Planning Commission
Public Work Session Meeting Minutes
March 10, 2015

Planning Commission Members Present:

Chair Jean Simson
Vice Chair Russell Griffin
Commissioner James Copfer
Commissioner Alan Pearson
Commissioner Lisa Walker

Staff Present:

Joseph Gall, City Manager
Julia Hajduk, Community Development Director
Ty Hanlon, Police Captain
Brad Kilby, Planning Manager
Michelle Miller, Senior Planner
Kirsten Allen, Planning Dept. Program Coordinator

Planning Commission Members Absent:

None. Two seats vacant

Legal Counsel:

None

Council Members Present:

Councilor Sally Robinson
Councilor Dan King

Others Present:

Bob Silverforb, Police Advisory Committee member
Sean Garland, Police Advisory Committee member
Chris West, Police Advisory Committee member
Laurie Zwingli, Police Advisory Committee member

Public Work Session

Planning Commission Chair Jean Simson began the work session at 6:30 pm.

Michelle Miller, Senior Planner gave a presentation with an overview of the state Medical Marijuana Dispensary (MMDs) program, (see record, Exhibit 1).

Ms. Miller advised that dispensaries:

- Must be located in Commercial, Industrial, Mixed use or Agricultural zone (there are no agricultural zones within Sherwood)
- Cannot be in same location as a Grow site
- Cannot be 1,000 feet from a school (public or private)
- Cannot be 1,000 feet from another medical marijuana dispensary
- Must be a registered business in Oregon
- Must install a security system
- Cannot be mobile

Members of the community, Planning Commissioners, and Staff split up into four table groups. Groups discussed the state rules regarding Medical Marijuana Dispensaries, existing and additional buffer locations, where Medical Marijuana Dispensaries could be located, hours of operation, and what approval process should be used.

Participants were provided information for the discussion (see record, Exhibit 2 – Public Discussion on Medical Marijuana Dispensaries, Exhibit 3 – Commercial Properties 1000 Foot School Buffer Map,

Exhibit 4 – Industrial Properties 1000 Foot School Buffer Map, Exhibit 5 – Commercial and Industrial Properties 1000 Foot School Buffer Map, Exhibit 6 – Commercial and Industrial Properties 1000 Foot School and Parks Buffer Map, Exhibit 7 – Email from Police Chief Groth regarding Medical Marijuana Dispensaries)

After the roundtable discussion, each Commissioner at the table group gave a summary of the ideas and concerns expressed in the dialogue.

Buffers

A majority of participants were in favor of an additional 1000-foot buffer around City parks and the YMCA. Others were in favor of no park buffers and to maintain buffers established by the State. About a quarter wanted to add residential buffers or to increase the 1000 foot school or park buffers.

Hours of Operation

A third of the participants were in favor of no regulations for hours of operation. The remaining participants wanted restrictions for hours of operation. Two scenarios offered were to be open six days a week during normal business hours or open seven days a week between 7am -10 pm. The latter is the same hours that the Oregon Liquor Control Commission (OLCC) allows.

Process

The approval process for MMDs could include a staff level decision or require a public hearing with a hearings officer, the Planning Commission or City Council. Each subsequent approval process having increased fees and public notice. The participants were in favor of a process that allowed staff level decision with clear criteria that must be met and required notification to property owners within 1000 feet of the proposed location.

Zoning

State law prescribes that MMDs are permitted in Sherwood's Industrial or Commercial Zones. Most of the participants preferred MMDs to be allowed in both Industrial and Commercial zones, with the second option of limiting dispensaries to industrial zoned property only.

3. Adjourn

Chair Simson adjourned the meeting at 8:08 pm.

Submitted by:

Kirsten Allen
Planning Department Program Coordinator

Approval Date: _____

New Business Agenda

Item A

City of Sherwood
Staff Report to the Planning Commission:
File No: PA 15-01 Code Update

March 13, 2015

Proposal: The City is proposing to amend the Table of Contents and Chapter 7 *Community Facilities and Services*, of the Sherwood Comprehensive Plan, Part 2, and to adopt the 2015 City of Sherwood Water Master Plan as a technical appendix to the Comprehensive Plan. The proposed amendments coincide with an update of the City's Water System Master Plan. Although the Water System Plan was updated in 2005, the language within the Comprehensive Plan was never updated to reflect the changes to the system in 2005. The proposed amendments to the text would delete and replace the existing language within the Comprehensive Plan to be aligned with the 2015 Water Master Plan Update. Adoption of the plan as a technical appendix is consistent with the single goal and eight policies that related to community facilities and services.

I. BACKGROUND

- A. Applicant: This is a City initiated text amendment.
- B. Location: The proposed amendment is to the text of the Comprehensive Plan and applies citywide.
- C. Review Type: The proposed text amendments are legislative and require a Type V review, which involves public hearings before the Planning Commission and City Council. Any appeal of the City Council's decision relating to this matter will be considered by the Oregon Land Use Board of Appeals.
- D. Public Notice and Hearing: Notice of the March 24, 2015 Planning Commission hearing on the proposed amendment was published in *The Times* on February 26, 2015 and March 19, 2015. Notice was also posted in five public locations around town on March 4, 2015, and on the City of Sherwood web site on February 18, 2014.

Oregon Department of Land Conservation and Development (DLCD) notice was submitted on February 3, 2015.

- E. Review Criteria:
The required findings for the Plan Amendment are identified in Section 16.80.030 of the SZCDC.
- F. Background:
The City Public Works Department along with the consultant, Murray Smith and Associates, have been working on the plan for the past year, and were charged with ensuring that the plan complies with the Oregon Administrative Rules (OAR) for Public Water Systems, Chapter 333, Division 61.

II. AFFECTED AGENCY, PUBLIC NOTICE, AND PUBLIC COMMENTS

Agencies:

DLCD notice was submitted on February 3, 2015, but has not submitted any comments as of the date of this report..

Public:

The Planning Commission held a Work Session to discuss the Water System Plan Update on February 24, 2015. In addition, a public meeting hosted by Public Works and the Project team was conducted on February 25, 2015. Individual invitations to that meeting were provided to all customers of the Sherwood Water System. Many of the comments raised in the public open house were related to a frustration with the existing water rates.

III. REQUIRED FINDINGS FOR A PLAN TEXT AMENDMENT

The applicable Plan Text Amendment review criteria are 16.80.030.A and C

16.80.030.A - Text Amendment Review

An amendment to the text of the Comprehensive Plan shall be based upon the need for such an amendment as identified by the Council or the Commission. Such an amendment shall be consistent with the intent of the Comprehensive Plan, and with all other provisions of the Plan and Code, and with any applicable State or City statutes and regulations.

With respect to the proposed changes, the Comprehensive Plan would be updated with current language that reflects the Master Plan. Specific changes include:

- Updating the table of contents page
- Updating Objective B.7 to remove old plan dates and make relevant to the current time period
- Update Table VII-1 to reflect the name change of “unified sewerage agency” to “clean water services” and to remove reference to telephone and cable providers (housekeeping)
- Replace entire section under “water service plan”, including the introduction, existing water system conditions, analysis of the existing water system and recommended improvements to the existing water system, with up to date information from the 2015 Master Plan
- Adopt the 2015 Water Master Plan by reference

It should be noted that the Comprehensive Plan was not updated with the 2005 update to the Water System Plan, and that the Comprehensive Plan is in dire need of a complete update. Staff has identified recommended changes to reflect the updated Water Master Plan and some minor housekeeping items but it is recognized that there are other areas within the comprehensive plan that are out of date. Staff is currently working with the Council, the Planning Commission, and the State of Oregon to enter into the periodic review process to update the Sherwood Comprehensive Plan.

The proposal seeks to amend chapter 7 of Volume II of the Comprehensive Plan to reflect the updated Water Master Plan. The Council authorized the Water System Master Plan by both approving a budget that included the update and by authorizing contracts for the update, therefore it can be assumed that the Council identified a need to update the Master Plan.

There is only one stated goal in chapter 7 which is “To insure the provision of quality community services and facilities of a type, level and location which is adequate to support

existing development and which encourages efficient and orderly growth at the least public cost.”

There are 8 objectives under this policy statement:

1. Develop and implement policies and plans to provide the following public facilities and services; public safety fire protection, sanitary facilities, water supply, governmental services, health services, energy and communication services, and recreation facilities.
2. Establish service areas and service area policies so as to provide the appropriate kinds and levels of services and facilities to existing and future urban areas.
3. Coordinate public facility and service plans with established growth management policy as a means to achieve orderly growth.
4. Coordinate public facility and service provision with future land use policy as a means to provide an appropriate mix of residential, industrial and commercial uses.
5. Develop and implement a five-year capital improvements and service plan for City services which prioritizes and schedules major new improvements and services and identifies funding sources.
6. The City will comply with the MSD Regional Solid Waste Plan, and has entered into an intergovernmental agreement with Washington County to comply with the County's Solid Waste and Yard Debris Reduction Plan, 1990.
7. Based on the Sewer, Water and Transportation Plan updates in 1989 and 1990, the City shall prepare a prioritized list of capital improvement projects to those systems and determine funding sources to make the improvements by the end of 1991.
8. It shall be the policy of the City to seek the provision of a wide range of public facilities and services concurrent with urban growth. The City will make an effort to seek funding mechanisms to achieve concurrency.

The updated Master Plan is necessary to the achieving the objectives with the exception of objective 7. The language within this policy has been updated to reflect the 2014 update to the Transportation System Plan, and the 2015 updates to the Sewer and Water Plans.

The need to update the policy language, and in turn the background language of Chapter 7 as it relates to the City's Water System Master Plan is evident in the fact that the current language speaks to plans that were to be adopted in 1989 and 1990. That is over 25 years ago, adding additional evidence that a clear need for the update has been established.

Applicable Regional (Metro) Standards

There are no specific Metro standards that would conflict with the proposed amendments. The Urban Growth Management Functional Plan does not speak specifically to subarea Water System Master planning.

Consistency with Statewide Planning Goals

Because the comprehensive plan policies and strategies are not changing and the comprehensive plan has been acknowledged by the State, there are no known conflicts with these proposed changes. Below is an analysis of how the proposed Water Master Plan update

and Comprehensive Plan amendments are consistent with the applicable statewide planning goals 1, 2 and 11.

Goal 1

The Planning Commission held a public work session, and the project team held a city-wide meeting on the plan. Formal notice was also published in *The Times* two weeks prior to the hearing and again five days prior to the hearing. The hearing has been posted around town in five conspicuous places and on the City's website since March 4, 2015. Public works also maintained a project website for the course of the project.

Goal 2

Goal 2 speaks to comprehensive planning and acknowledges that plans for public facilities are more specific than those included in the comprehensive plan. They are intended to show the size, location, and capacity serving the City, but are not as detailed as construction drawings. The Water System Master Plan is a tool that helps communities to implement their plan.

In Sherwood's case, the plan is being updated to ensure compliance with the requirements outlined by the state as they relate to water system master plans. The requirement to prepare a Water System Master Plan can be found in Oregon Administrative Rules (OAR) Chapter 333, Division 61. The Water System Master Plan itself, is a much more technical document that Public Works staff is charged with preparing and ensuring compliance with these rules. The subject of this review is to ensure that the proposed plan is consistent with the current Comprehensive Plan.

One could argue that because the Comprehensive Plan is out of date, that the policy assumptions are not correct, but we will not know this until we go through a formal goals and policy update with the community as part of a periodic review. There have been many plans updated without thought to the Comprehensive Plan, goals, policies, and community assumptions in the past, and as currently drafted there are no conflicts with the proposed language and the current language as it applies to the single goal and policies that are affected by this change.

Goal 11

Goal 11 of state land use planning relates to Public Facilities and Services. Within this goal, communities are charged with preparing facilities plans that coordinates the type, locations and delivery of public facilities and services in a manner that best supports the existing and proposed land uses. In this case, the plan considers the existing needs of the community as well as those of the Tonquin Employment Area, the Brookman area, and urban reserves associated with both Tonquin and Sherwood West. The numbers assumed for these areas were derived from previously adopted plans and the best available information at the time that they were being prepared.

It should be noted that information is constantly being updated and refined with new information and it is possible that current projects underway or updated plans result in more or less growth than the Water System Master Plan assumes. For these reasons, the Water System Master Plan is a flexible document. If all improvements envisioned in the Water System Master plan are not needed, they will not be constructed and if improvements are needed sooner than envisioned, they will be planned for.

FINDING: As discussed above in the analysis, there is a need for the proposed amendments in order to update the language within the Comprehensive Plan. The proposed amendments are not applicable to Metro's Urban Growth Management Functional Plan. The proposed amendments are consistent with the applicable Comprehensive Plan and applicable City, regional and State regulations and policies.

16.80.030.3 – Transportation Planning Rule Consistency

A. Review of plan and text amendment applications for effect on transportation facilities. Proposals shall be reviewed to determine whether it significantly affects a transportation facility, in accordance with OAR 660-12-0060 (the TPR). Review is required when a development application includes a proposed amendment to the Comprehensive Plan or changes to land use regulations.

FINDING: The proposed amendments do not affect the functional classification of any street and is not triggered by any single development application.

IV. RECOMMENDATION

Based on the above findings of fact, and the conclusion of law based on the applicable criteria, the staff recommends approval of PA 15-01.

- V. EXHIBITS**
- A. PA 15-01 Proposed Code Amendments –track change version
 - B. PA 15-01 Proposed Code Amendments – clean version
 - C. Letter to the Planning Commission from Craig Sheldon dated March 11, 2015
 - D. Draft Water System Master Plan - 2015

Exhibit A

TABLE OF CONTENTS - Part 2 Sherwood Development Plan

	Page
Chapter 1	General Information 1
Chapter 2	The Planning Process 2-1
Figure #1	Sherwood Comprehensive Planning Process 2-5
Figure #2	Periodic Review Process 2-6
Chapter 3	Growth Management 3-1
Table III-1	Population Projections 3-4
Table III-2	Housing Units in UGB 3-4
Table III-3	Employment in UGB 3-4
Table III-4	Buildable Land Inventory 3-10
Chapter 4	Land Use 4-1
Table IV-1	1990 UGB Land Use & Buildable Land Inventory 4-4
Table IV-2	1989 Land Usage 4-5
Table IV-3	Housing Data 4-12
Table IV-4	Planned Residential Land Use & Population 4-16
Table IV-5	Service Economy 4-24
Table IV-6	State Employment Forecasts 4-28
Table IV-7	Sherwood's Major Employers 4-31
Table IV-8	Sherwood Income, Occupation & Employment Data 4-32
Table IV-9	Vacant Industrial Land Inventory 4-33
Map IV-1	Vacant Industrial Land Map 4-34
Table IV-10	Vacant Commercial Land Inventory 4-35
Map IV-2	Vacant Commercial Land Map 4-36
Map IV-3	Plan/Zone Map 4-37
Chapter 5	Environmental Resources 5-1
Table V-1	Open Spaces & Natural Resource Inventory 5-5
Map V-1	Natural Resources & Recreation Plan Map 5-6
Chapter 6	Transportation 6-1
Table VI-1	Trip Generation Rates 6-3
Map VI-1	Transportation Plan Map 6-4
Figure VI-1	Functional Classification 6-5-6
Chapter 7	Community Facilities & Services 7-1
Table VII-1	Service Providers 7-4
Figure VII-1	Existing Sewer System 7-7
Table VII-2	Wastewater Flow Design Criteria 7-8
Figure VII-2	Improvements to Existing Sewer Systems 7-11
Figure VII-3	Major Sewerline Expansion 7-13
Figure VII-4	Existing Water System 7-16
Figure VII-5	Water System Improvements 7-22
Figure VII-6	Water System Expansion 7-24
Figure VII-7	Storm Drainage Plan 7-32

COMMUNITY FACILITIES AND SERVICES

A. GENERAL INTRODUCTION

Community facilities and services in the Sherwood Planning Area are provided by Washington County, the City of Sherwood, special service districts, semi-public agencies and the State and Federal government, (see Table VII-1). Public facilities and services include sewer, water, fire and police protection, libraries, drainage, schools, parks and recreation, solid waste and general governmental administrative services. Semi-public facilities and services are those which are privately owned and operated but which have general public benefit. They include health facilities, energy and communication utilities, and day care.

Although a small community, Sherwood has learned well the importance of adequate community facilities and services to orderly urban growth. Lack of sewer treatment capacity curtailed growth in the City in the 1970's. Planning for public facilities and services in response to growth rather than in advance of growth results in gaps in facilities and services. As population growth and density increase in the Sherwood Planning Area, greater facility and service support will be required. In recognition of this basic fact, the Plan stresses the need for provision of necessary facilities and services in advance of, or in conjunction with, urban development.

The Community Facilities and Services element identifies general policy goals and objectives; service areas and providers, problems, and service plans, and potential funding for key public and semi-public facilities and services. Park and recreation facilities are treated in Chapter 5, Environmental Resources. Transportation facilities are treated in Chapter 6, Transportation. This element was updated in 1989 to comply with OAR 197.712(2)(e).

B. POLICY GOAL AND OBJECTIVES

To insure the provision of quality community services and facilities of a type, level and location which is adequate to support existing development and which encourages efficient and orderly growth at the least public cost.

OBJECTIVES

1. Develop and implement policies and plans to provide the following public facilities and services; public safety fire protection, sanitary facilities, water supply, governmental services, health services, energy and communication services, and

Sherwood Comprehensive Plan, Part 2

- b. Bikeways
 - (1) City of Sherwood
 - (2) Washington County
 - (3) State of Oregon

- c. Public Transit
 - Tri-Met

Sherwood Comprehensive Plan, Part 2

- 4. Public Health and Safety
 - a. Police Protection
 - (1) City of Sherwood
 - (2) Washington County
 - (3) State of Oregon
 - b. Fire Protection
 - Tualatin -Valley Fire and Rescue
 - c. Animal Control
 - Washington County
- 5. Recreation
 - a. Parks and Recreation
 - City of Sherwood
 - b. Library
 - City of Sherwood
- 6. Schools
 - Sherwood School District 88J

Sherwood Comprehensive Plan, Part 2

insert map

July of 1984, at points throughout the Durham Basin.

The July 1979 Sewer Service Plan used values ranging from 500 gallons per acre per day (gpad) to 700 gpad for inflow and infiltration (I&I), depending on land use designation. These values were concurrent with past EPA design standards and were based on the assumption that rehabilitation measures would remove 60 to 90 percent of excessive I&I. According to USA's 1985 Master Plan these abatement techniques proved to be ineffective. USA's review of the Durham treatment facility led to the design rate of 4000 gpad for the existing peak annual occurrence for infiltration and inflow. This value is not anticipated to decrease for the Durham basin and is therefore also used for the future design flowrates.

Two areas of special concern exist inside the current City of Sherwood UGB. Both areas are recent additions to the UGB and have not yet been assigned a land use. Rather than assume zoning designations for the areas they were both excluded from the model. Both areas can be served by gravity and neither will cause deficiencies in the system. Their service routes are discussed below.

The first area is located in the southwest corner of the UGB in the Cedar Creek Basin, between Pacific Highway and Old Highway 99W. This area can be served by line number 1 in area A (Figure VII-2). The northern half of this area may also be served by connecting to the southern most extension of line number 2 in area B. The second area is located east of Pacific Highway and north of Edy Road, in the Rock Creek Basin. The southern portion should be incorporated in line number 3 extending from Rock Creek west along Edy Road (Figure VII-2). The northern half must be served using a direct lateral to the area from the Rock Creek trunk.

RECOMMENDED IMPROVEMENTS TO EXISTING SEWER SYSTEM

The analysis of the existing system shows no size deficiencies in any of the City maintained pipes. City officials have confirmed that there are areas of surcharge in the system due to pipe under sizing. Surcharge due to blockage of the system has occurred but has since been remedied.

Improvements are recommended to the existing sewer systems main trunk lines. These improvements are required due to very slight slips which occur in the northern sections of the Rock Creek and Cedar Creek main trunk lines.

The Rock Creek trunk requires improvements from manhole number 11663, which is located at the confluence of the Rock Creek and Cedar Creek trunk lines, south to a manhole located near the Southern Pacific crossing of Rock Creek. The existing 18-inch diameter pipe has a length of 6,035 feet and an existing slope of 0.0031 feet/feet. The USA master plan recommends that a 15-inch diameter pipe be placed parallel to the existing 18-inch in order to convey future flows based on 20-year ultimate development peak flowrates. Our analysis is based on total ultimate development of the Sherwood UGB and therefore suggests that an 18-inch diameter pipe parallel the existing 18-inch at the existing slope of 0.0031 feet/feet.

Sherwood Comprehensive Plan, Part 2

insert Figure VII-2

Sherwood Comprehensive Plan, Part 2

insert Figure VII-3

~~in currently served areas of the City. Major water lines required as extensions to areas without service are also identified. The cost of all recommended and identified improvements are listed in 1990 dollars.~~

~~The amount of growth that can occur within distinct areas and neighborhoods within the City's Urban Growth Boundary without creating pressure or overall supply problems is also estimated.~~

~~1. The City's existing reservoir capacity of 2.5 million gallons (MG) is adequate to cover the needs of the City until a population of 8,200 is reached.~~

EXISTING WATER SYSTEM CONDITIONS

Pressure Zones

Formatted: Font: Bold

The City's existing distribution system is divided into three major pressure zones. Pressure zone boundaries are defined by ground topography in order to maintain service pressures within an acceptable range for all customers in the zone. The hydraulic grade line (HGL) of a zone is designated by overflow elevations of water storage facilities or outlet settings of pressure reducing valves (PRVs) serving the zone.

The majority of Sherwood customers are served from the 380 Pressure Zone which is supplied by gravity from the City's Sunset Reservoirs. The 535 Pressure Zone, serving the area around the Sunset Reservoirs, is supplied constant pressure by the Sunset Pump Station, and the 455 Pressure Zone serves higher elevation customers on the western edge of the City by gravity from the Kruger Reservoir.

Storage Reservoirs

Formatted: Font: Bold

Sherwood's water system has three reservoirs with a total combined storage capacity of approximately 9.0 million gallons (MG). Two reservoirs, Sunset Nos. 1 and 2, provide 6.0 million gallons (MG) of gravity supply to the 380 Pressure Zone. The other reservoir, Kruger Road, provides 3.0 mg of gravity supply to the 455 Pressure Zone.

Pump Stations

Formatted: Font: Bold

Sherwood's water system includes two booster pump stations, the Sunset Pump Station and the Wyndham Ridge Pump Station.

The Sunset Pump Station is located in Snyder Park adjacent to the Sunset Reservoir complex and has an approximate total capacity of 3,770 gallons per minute (gpm). This station provides constant pressure service and fire flow to the 535 Pressure Zone.

horizon with an additional 1 mgd of capacity required at 20 years and an additional 4 mgd needed at build-out. Existing City groundwater wells provide an effective emergency supply to complement emergency storage in the City's reservoirs.

Pumping and Storage

Formatted: Font: Bold

The City's distribution system has adequate storage and pumping capacity to meet existing service area demands through 2034. Due to significant uncertainty related to long-term growth and system expansion, minor storage and pumping deficiencies at build-out should be re-evaluated with the next Water Master Plan Update or as development warrants. Additional pump stations are recommended to serve proposed high-elevation closed pressure zones in the water service expansion areas: Brookman Annexation and West Urban Reserve.

Distribution Piping

Formatted: Font: Bold

Sherwood's distribution piping is sufficiently looped to provide adequate fire flow capacity to commercial, industrial and residential customers. Few piping improvement projects are needed to meet fire flow criteria. Extensive large diameter mains will be needed to expand the City's water service area to supply the Brookman Annexation, TEA and West Urban Reserve as development occurs.~~Peak Domestic Flows Analysis~~

~~The total peak domestic flow rate for the year 2008 used in this analysis is 3,000 gallons per minute. The domestic flow is the combination of all residential, commercial, and industrial uses other than those for fire protection. Domestic use also accounts for summertime irrigation of lawns and landscaping.~~

~~The total peak domestic flow rate of 3,000 gallons per minute is derived from the detailed data published in the 1979 Water Service Plan and has been increased by approximately 15 percent as a conservative measure for unexpected conditions such as excessive water line leakage, high volume users, etc.~~

~~The 1979 Water Service Plan estimated the water usage by the City's commercial and industrial customers to be 30 percent of the residential use when the City's population reached 7,800 people. This percentage was used in the determination of the peak domestic flow rates in this analysis. The total peak domestic flow rate is based on a maximum peak consumption of 410 gallons per capita per day, and is consistent with the 1979 Water Service Plan.~~

Sherwood Comprehensive Plan, Part 2

The total 3,000 gallons per minute peak domestic flow was proportioned throughout the existing developed areas of the City, based on knowledge of the amounts and types of potential development that can occur in each area. Within each area of the City the proportioned flow was concentrated at "worst case" locations so that deficiencies in the City's water system would be highlighted.

Computer models require calibration to known data to assure that they represent the physical system. Known information on the pumping capacity and characteristics of the City's three wells, including their effect on the groundwater table and the historical operation of the wells and the water storage reservoir, was used to calibrate the factors in the computer model. The computer model accurately matches the operation of the City's wells and water storage reservoir during peak use.

Peak Domestic Flows Results

The existing water system for the City of Sherwood meets the needs of the peak domestic flows in the year 2008. There are no areas requiring improvements to meet these domestic needs. The resulting operating pressures during the peak flows range from 40 to 85 psi (pounds per square inch) throughout the City. The acceptable range for water line pressures is 20 to 100 psi.

Fire Protection Flows Analysis

The flow rate required to provide adequate fire protection varies with the type of building. Single-family residential requires fire flows of only 1,500 gallons per minute, whereas large industrial and commercial structures without fire sprinklers can require fire flows in excess of 4,000 gallons per minutes. Most new construction of larger structures is required to have fire sprinklers for increased fire/life safety. Fire sprinklers reduce the flow requirements for fire protection.

For a City the size of Sherwood, it can only be expected that adequate flows for one major fire at a time can be provided. The low probability of multiple major fires at one time does not warrant the major expense of providing the additional supply sources and the larger diameter pipe lines. Also, because of the expense, it is cost effective to require fire sprinklers in structures that would require excessive amounts of flow for fire protection.

For this analysis, a fire flow of 2,000 gallons per minute is used to determine the adequacy of the water supply and distribution system to provide fire flows at an adequate operating pressure. The fire flow is assumed to be concurrent in time with the peak domestic flows.

Fire Protection Flows Results

The computer model was used to simulate the need for fire flows to every area of the city. In general, the ability to adequately supply fire flows in most areas of the City is good. There are three

Emergency stand-by power would provide an additional margin of safety during periods of total power loss. The booster pump at the water storage reservoir is the only source of pressure for the residents in the E. Division Street and upper S. Pine Street area. During power outages, this area is without adequate water service. Stand-by power is recommended for this booster pump to eliminate this potential problem.

Although the water storage reservoir provides ample volumes of water for emergencies, it is recommended that stand-by power be provided at one of the wells as an added precautionary measure for extended periods of power outage. Since Well No. 3 is the City's largest well, stand-by power is recommended for that well. Completion of a manually-operated interconnect at Cipole Road with the City of Tualatin water system is also recommended as an additional safeguard against a catastrophic interruption in the City of Sherwood's system.

RECOMMENDED IMPROVEMENTS TO EXISTING WATER SYSTEM

Recommended improvements for the City's water system include proposed supply, pump station and water line projects.

Cost Estimating Data

Formatted: Font: Bold

An estimated project cost has been developed for each improvement project recommended. Cost estimates represent opinions of cost only, acknowledging that final costs of individual projects will vary depending on actual labor and material costs, market conditions for construction, regulatory factors, final project scope, project schedule and other factors. The cost estimates presented have an expected accuracy range of -30 percent to +50 percent. As the project is better defined, the accuracy level of the estimates can be narrowed. Estimated project costs include approximate construction costs and an aggregate 45 percent allowance for administrative, engineering and other project related costs.

Capital Improvement Program

Formatted: Font: Bold

A summary of all recommended improvement projects and estimated project costs is presented in Table ES-3 of the 2015 City of Sherwood Water System Master Plan Update. The table provides for project sequencing by showing fiscal year-by-year project priorities for the first five fiscal years, then prioritized projects in 5-year blocks for the 10-year, 20-year and Beyond 20 year timeframes. The total estimated cost of these projects is approximately \$24.6 million through FY 2034. Approximately \$19.9 million of the total estimated cost is for projects needed within the 10-year timeframe and \$5.4 million of these improvements are required in the next 5 years. Improvements are recommended to the existing water system to provide adequate fire protection capability to three areas of the City. Improvements are not necessary for year 2008 population projections. These recommendations are based upon the assumption that water lines are not required to be extended

Sherwood Comprehensive Plan, Part 2

Recommended Improvements to Existing Water System

1. Loop Projects

— Tualatin-Sherwood	3800 LF	\$238,000
— Scholls-Sherwood	2800 LF	\$178,500
— Murdock/Roy	600 LF	\$ 59,500
— Highland Extension	2700 LF	\$178,500
— Tualatin-sherwood Relocate	2130 LF	\$ 74,100

2. Supply Projects

— Well No. 6 (Murdock)	800' deep	\$236,500
— Reservoir Booster Pump	35 hp gen.	\$ 59,500
— Well No. 3 Standby Power	75 hp gen.	\$119,000
— Cipole Road Intertie with City of Tualatin		\$ 23,400 (50%)

3. 4 Inch Waterline Replacements

— Old Town (8")	1600 LF	\$ 76,800
— Ladd Hill (12")	1300 LF	\$ 92,300
— Meinecke/99W (8")	2000 LF	\$ 96,000
— W. Sunset (10")	1500 LF	\$ 88,500

4. 6-Inch Waterline Replacements (all 8")

— Old Town	1600 LF	\$ 76,800
— Lower Lincoln	1000 LF	\$ 48,000
— Lower Roy	1300 LF	\$ 62,400
— Oregon	1300 LF	\$ 62,400
— Upper Washington	1300 LF	\$ 62,400
— Gleneagle	3000 LF	\$144,000
— Upper Roy	900 LF	\$ 43,400

5. Other Waterline Extensions

— 12 Inch	18,500 LF	\$1,313,500
— 10 Inch	32,800 LF	\$1,935,200
— 8 Inch	25,400 LF	\$1,219,200

Beyond these recommended improvements, the City should continue its existing undersized water lines replacement program.

Sherwood Comprehensive Plan, Part 2

| -insert Fig. VII-5

Sherwood Comprehensive Plan, Part 2

| -Insert Fig VII-6

4. The rational method formula was used to estimate runoff to proposed storm sewers. This method has a tendency to overestimate design flows when applied to large basins. Runoff coefficients used in the rational method are predicted on the City's Comprehensive Plan. During final design of storm sewers, actual development within the basin should be reviewed to verify previous assumptions in selection of a runoff coefficient.

5. Cost estimates for proposed storm sewer improvements have been prepared, based on 1980 construction costs and increased in 1990 by 1.25%, and on Engineering News Record (ENR) index of 3264. These estimates are presented in Table 2 of the Appendix.

6. Design of relief culverts in Cedar Creek and Rock Creek may significantly alter hydraulic control sections used by the U.S. Army Corps of Engineers to establish water surface elevations and limits of the flood plain as set forth in Flood Insurance Study, City of Sherwood, Oregon, and provided to the City in preliminary draft, dated December 17, 1980. Design of relief culverts should be coordinated with the U.S. Army Corps of Engineers to insure integrity of their flood insurance study.

Implementation

1. The City will endeavor to establish a source of revenue to finance the cost of storm sewer construction, acquisition of lands along creeks, maintenance of storm sewers and waterways, and administration of the storm plan in accordance with the regional Surface Water Drainage Management Plan.

2. Until user fees are in effect, the City should obtain waivers of remonstrance to future storm drainage improvements projects from all property owners wishing to develop their land, and the City should also require all developers to provide adequate storm sewers to serve their property as well as those properties that would naturally drain to the proposed storm sewer.

SOLID WASTE

Solid waste disposal is a regional concern requiring regional solutions. The City of Sherwood recognizes MSD's responsibility and authority to prepare and implement a solid waste management plan and supports the MSD Solid Waste Facilities Model Siting Ordinance and will participate in these procedures as appropriate. There are no landfills in Sherwood.

The Model Siting Ordinance will be incorporated into this Plan when approved by METRO. In addition, the City conducted extensive hearings on solid waste incineration in 1990 and determined incineration is generally not a form of solid waste disposal environmentally compatible in the community except in limited circumstances. Therefore, solid waste incineration is generally prohibited by this Plan.

ELEMENTARY AGE STUDENTS (K-5)

J. Clyde Hopkins Elementary School has a capacity to house 600 students. Currently, 670 students are enrolled in grades K-5. Three double portable classrooms and one single portable classroom are utilized to address the growing elementary age population.

INTERMEDIATE AGE STUDENTS (6-8)

Approximately 300 students are enrolled in grades 6-8. The Intermediate School building capacity is 400 students. This capacity can be accessed by relocating District office services, which occupy a four classroom wing of the building.

HIGH SCHOOL AGE STUDENTS (9-12)

Sherwood High School has a capacity of 500 students. Approximately 420 students are currently enrolled. No major housing issues exist in this 1971 constructed facility.

SCHOOL FACILITY PLANNING

The School District is preparing to undertake a detailed facility development plan. The most immediate need for the District is to expand housing of elementary age school children (K-5). During the Fall of the 1990-91 school year, the District completed the purchase of a new elementary school site located within the City limits of Sherwood. The District also owns a school site (purchased in 1971) in the proximity of the Tualatin portion of the school district.

The intent of the District is to seek voter approval of a bond measure to address short and long-term housing needs. The measure is planned to be submitted in the Fall of 1991 or the Spring of 1992 in order to construct an additional elementary school.

I. PUBLIC SAFETY

POLICE PROTECTION

The City of Sherwood, Washington County and the State Police co-ordinate police protection within the Planning Area. In 1989 the Sherwood Police Force consisted of five officers. In order to meet future demand it is anticipated that the department will need additional patrolmen proportional to the projected increase in population. The State formula for City police protection is one officer per 500 people. The police force should expand accordingly.

FIRE PROTECTION

The Planning Area is wholly contained within the Tualatin Valley Consolidated Fire and Rescue

K. HEALTH FACILITIES

The local health system is linked to a number of organizations and institutions that can and do affect how it will develop. The latest planning legislation P.L. 93-641 and its recent amendments has placed Health care delivery systems planning are under the auspices of the State Certificate of Need laws and the Federal Health System Agency (HSA) planning regulations. Sherwood is located in the six county Northwest Oregon Health Systems Agency (NOHS) which is charged with reviewing new service proposals, expenditures involving public funds and the development of a health system plan for the area. The first HSA plan was adopted in 1978. State agencies administer HSA regulations. NOHS established subdistricts within the six county service area. Sherwood is located in the south-rural sub-district (see Figure VII-8). The only hospital located in the sub-district is Meridian Park Hospital in Tualatin.

Sherwood is served by various Metropolitan area hospitals depending on local physician affiliations. The City currently has only one doctor with offices in the Planning Area. St. Vincent's Hospital in Beaverton has expressed interest in establishing a satellite clinic in Sherwood.

The City will encourage the decentralization of Metropolitan health care delivery to assure that a broad range of inpatient, outpatient and emergency medical services are available to Sherwood residents. To that end the City will support the location of a St. Vincent's Satellite Center in Sherwood and encourage the appropriate expansion of Meridian Park facilities to meet the growing needs of the Planning Area.

L. SOCIAL FACILITIES AND SERVICES

A broad range of social services will be needed in the Planning Area to serve a growing urban population. Sherwood will continue to depend on metropolitan area services for which the demand does not justify a decentralized center. Multi-purpose social and health services and referral are offered by the Washington County Satellite Center in Tigard. The City will encourage the continued availability of such services.

Sherwood is located in Region 8 of the State Department of Human Resources Service Area and benefits from that agency's services. State services are administered through the County's Washington County office located in Hillsboro. In addition to public social service programs, many private organizations serve the Sherwood area.

Exhibit B

TABLE OF CONTENTS - Part 2 Sherwood Development Plan

	Page
Chapter 1	General Information..... 1
Chapter 2	The Planning Process 2-1
Figure #1	Sherwood Comprehensive Planning Process 2-5
Figure #2	Periodic Review Process..... 2-6
Chapter 3	Growth Management..... 3-1
Table III-1	Population Projections..... 3-4
Table III-2	Housing Units in UGB..... 3-4
Table III-3	Employment in UGB..... 3-4
Table III-4	Buildable Land Inventory..... 3-10
Chapter 4	Land Use 4-1
Table IV-1	1990 UGB Land Use & Buildable Land Inventory 4-4
Table IV-2	1989 Land Usage 4-5
Table IV-3	Housing Data..... 4-12
Table IV-4	Planned Residential Land Use & Population..... 4-16
Table IV-5	Service Economy 4-24
Table IV-6	State Employment Forecasts 4-28
Table IV-7	Sherwood’s Major Employers..... 4-31
Table IV-8	Sherwood Income, Occupation & Employment Data 4-32
Table IV-9	Vacant Industrial Land Inventory 4-33
Map IV-1	Vacant Industrial Land Map..... 4-34
Table IV-10	Vacant Commercial Land Inventory 4-35
Map IV-2	Vacant Commercial Land Map 4-36
Map IV-3	Plan/Zone Map 4-37
Chapter 5	Environmental Resources 5-1
Table V-1	Open Spaces & Natural Resource Inventory..... 5-5
Map V-1	Natural Resources & Recreation Plan Map..... 5-6
Chapter 6	Transportation 6-1
Table VI-1	Trip Generation Rates 6-3
Map VI-1	Transportation Plan Map 6-4
Figure VI-1	Functional Classification..... 6-5-6
Chapter 7	Community Facilities & Services 7-1
Table VII-1	Service Providers 7-4
Figure VII-1	Existing Sewer System..... 7-7
Table VII-2	Wastewater Flow Design Criteria 7-8
Figure VII-2	Improvements to Existing Sewer Systems 7-11
Figure VII-3	Major Sewerline Expansion 7-13
Figure VII-7	Storm Drainage Plan 7-32
Chapter 8	Urban Growth Boundary Additions 8-1
Table VIII-1	Summary of UGB Additions 2002-2004 8-2
Table VIII-2	Concept Plan Summary by Area 8-3

COMMUNITY FACILITIES AND SERVICES

A. GENERAL INTRODUCTION

Community facilities and services in the Sherwood Planning Area are provided by Washington County, the City of Sherwood, special service districts, semi-public agencies and the State and Federal government, (see Table VII-1). Public facilities and services include sewer, water, fire and police protection, libraries, drainage, schools, parks and recreation, solid waste and general governmental administrative services. Semi-public facilities and services are those which are privately owned and operated but which have general public benefit. They include health facilities, energy and communication utilities, and day care.

Although a small community, Sherwood has learned well the importance of adequate community facilities and services to orderly urban growth. Lack of sewer treatment capacity curtailed growth in the City in the 1970's. Planning for public facilities and services in response to growth rather than in advance of growth results in gaps in facilities and services. As population growth and density increase in the Sherwood Planning Area, greater facility and service support will be required. In recognition of this basic fact, the Plan stresses the need for provision of necessary facilities and services in advance of, or in conjunction with, urban development.

The Community Facilities and Services element identifies general policy goals and objectives; service areas and providers, problems, and service plans, and potential funding for key public and semi-public facilities and services. Park and recreation facilities are treated in Chapter 5, Environmental Resources. Transportation facilities are treated in Chapter 6, Transportation. This element was updated in 1989 to comply with OAR 197.712(2)(e).

B. POLICY GOAL AND OBJECTIVES

To insure the provision of quality community services and facilities of a type, level and location which is adequate to support existing development and which encourages efficient and orderly growth at the least public cost.

OBJECTIVES

1. Develop and implement policies and plans to provide the following public facilities and services; public safety fire protection, sanitary facilities, water supply, governmental services, health services, energy and communication services, and

recreation facilities.

2. Establish service areas and service area policies so as to provide the appropriate kinds and levels of services and facilities to existing and future urban areas.
3. Coordinate public facility and service plans with established growth management policy as a means to achieve orderly growth.
4. Coordinate public facility and service provision with future land use policy as a means to provide an appropriate mix of residential, industrial and commercial uses.
5. Develop and implement a five-year capital improvements and service plan for City services which prioritizes and schedules major new improvements and services and identifies funding sources.
6. The City will comply with the MSD Regional Solid Waste Plan, and has entered into an intergovernmental agreement with Washington County to comply with the County's Solid Waste and Yard Debris Reduction Plan, 1990.
7. Based on Sewer, Water, Stormwater, and Transportation Plan updates, the City shall prepare a prioritized list of capital improvement projects to those systems and determine funding sources to realize the improvements envisioned in those plans.
8. It shall be the policy of the City to seek the provision of a wide range of public facilities and services concurrent with urban growth. The City will make an effort to seek funding mechanisms to achieve concurrency.

C. PUBLIC AND SEMI-PUBLIC UTILITIES

Public utilities including water, sanitary sewer, drainage, and solid waste, as well as semi-public utilities including power, gas and telephone services are of most immediate importance in the support of new urban development. Water, sewer collection, and drainage facilities are the major services for which the City of Sherwood has responsibility. Service plans for these key services are contained in this section. The other utilities referred to above are the principal responsibilities of those agencies listed in Table VII-1. These agencies have been contacted for the purpose of coordinating their service planning and provision with the level and timing of service provision required to properly accommodate growth anticipated by the Plan.

**TABLE VII-1
FACILITY AND SERVICE PROVIDERS
IN THE SHERWOOD PLANNING AREA**

1. Public Utilities
 - a. Public Water Supply
City of Sherwood
 - b. Sanitary Sewer System
 - (1) Clean Water Services
 - (2) City of Sherwood
 - c. Storm Drainage System
 - (1) City of Sherwood
 - (2) Washington County
 - (3) State of Oregon
2. Private/Semi-Public Utilities
 - a. Natural Gas
Northwest Natural Gas Co.
 - b. Electric Power
Portland General Electric
 - c. Solid Waste: Pride Disposal Co.
3. Transportation
 - a. Paved Streets, Traffic Control, Sidewalks, Curbs,
Gutters, Street Lights
 - (1) City of Sherwood
 - (2) Washington County
 - (3) State of Oregon
 - b. Bikeways
 - (1) City of Sherwood
 - (2) Washington County
 - (3) State of Oregon

- c. Public Transit
 - Tri-Met

- 4. Public Health and Safety
 - a. Police Protection
 - (1) City of Sherwood
 - (2) Washington County
 - (3) State of Oregon

 - b. Fire Protection
 - Tualatin Valley Fire and Rescue

 - c. Animal Control
 - Washington County

- 5. Recreation
 - a. Parks and Recreation
 - City of Sherwood

 - b. Library
 - City of Sherwood

- 6. Schools
 - Sherwood School District 88J

D. SEWER SERVICE PLAN

INTRODUCTION

The Sewer Service Plan of the Comprehensive Plan was updated in 1990 and is included as an appendix to the Plan, and is incorporated into this chapter. The following describes the existing sewer system, recommended improvements to the existing system, recommended expansion of the sewer system and estimated costs.

EXISTING SEWER SYSTEM

The City of Sherwood's existing sewer system is as shown on Figure VII-1. The system is located in USA's Durham South Basin which consists of two sub-basins are centered around Cedar Creek and Rock Creek, respectively, and will be referred to as the Cedar Creek basin and the Rock Creek basin throughout the remainder of this section.

The Rock Creek Basin system currently serves a residential area bounded by Lincoln Street to the west, West Sunset Boulevard to the south, Oregon Street to the north and the UGB to the east. Rock Creek Basin also contains approximately 71.2 acres of land, north of Oregon Street, which is currently zoned and developed for industrial use. The remaining northern portion of the Basin is essentially undeveloped and zoned primarily for industrial use. Flow is by gravity from south to north, eventually connecting to USA's Rock Creek trunk. This trunk then follows Rock Creek until it connects with the Upper Tualatin Interceptor which transports sewage to the Durham treatment plant.

The Cedar Creek Basin system serves the majority of Sherwood. Drainage is again from south to north and the main trunk of the system follows Cedar Creek from Sunset Boulevard under Pacific Highway continuing north until it connects with the Upper Tualatin Interceptor. From this point sewage is transported to the Durham Treatment plant.

insert map

ANALYSIS OF EXISTING SEWER SYSTEM

The population for the City of Sherwood in the year 2008 is estimated to be 7,000 people. The 1979 Sewer Service Plan estimated a population of 10,600 people in the year 2008, and a full-development population within the Sherwood Urban Growth Boundary (UGB) of 18,900 people.

In order to accentuate any deficiencies in the existing sanitary sewer system, peak flowrates were generated based on full development or saturation of the Sherwood UGB. This analysis was used for the following reasons. Maximum design flows for sanitary sewers are far less than peak storm sewer flows. Very often sanitary sewer pipes are sized at a minimum 8-inch diameter for maintenance purposes; consequently the majority of these pipes are flowing at a minimum of their capacity. A full-development demand analysis was the most conservative and efficient way of analyzing the system for all deficiencies.

Wastewater flow criteria for the analysis was taken from USA's 1985 Master Sewer Plan Update and is based on land use designation as listed below:

**TABLE VII-2
 WASTEWATER FLOW DESIGN CRITERIA
 DESIGN UNIT FLOW RATE**

<u>LAND USE DESIGNATION</u>	<u>EXISTING</u>	<u>FUTURE</u>
RESIDENTIAL	75 gpcd	75 gpcd
COMMERCIAL	1000 gpad	1000 gpad
INDUSTRIAL	3000 gpad	3000 gpad
INSTITUTIONAL	500 gpad	500 gpad
PEAK ANNUAL	4000 gpad	4000 gpad

The City of Sherwood Zoning Map was used to determine the amount of acreage of each land use designation. This acreage was then applied to tributary basins contributing to their respective sewers and multiplied by the appropriate land use design unit flowrate in order to generate the total design flowrate. An average of residential densities per tributary basin was used to account for the five different residential zoning densities shown on the current City Zoning Map.

The domestic sewage flow allowance for the 1979 Sewer Plan followed the 1969 USA Master Plan value of 90 gallons per capita per day (gpcd). The updated, June 1985 USA Master Plan, has reduced this value to 75 gpcd.

In order to account for periods of maximum use, flowrates are multiplied by factors which result in peak flowrates. The 1979 Sewer Service Plan used peak factors of 3.0 for lateral sewers and 2.7 for trunk sewer lines. The 1985 USA Master Plan Update requires peak factors ranging from 1.5 to 2.0. These lower values are based on actual dry-weather flow monitoring, performed in June and

July of 1984, at points throughout the Durham Basin.

The July 1979 Sewer Service Plan used values ranging from 500 gallons per acre per day (gpad) to 700 gpad for inflow and infiltration (I&I), depending on land use designation. These values were concurrent with past EPA design standards and were based on the assumption that rehabilitation measures would remove 60 to 90 percent of excessive I&I. According to USA's 1985 Master Plan these abatement techniques proved to be ineffective. USA's review of the Durham treatment facility led to the design rate of 4000 gpad for the existing peak annual occurrence for infiltration and inflow. This value is not anticipated to decrease for the Durham basin and is therefore also used for the future design flowrates.

Two areas of special concern exist inside the current City of Sherwood UGB. Both areas are recent additions to the UGB and have not yet been assigned a land use. Rather than assume zoning designations for the areas they were both excluded from the model. Both areas can be served by gravity and neither will cause deficiencies in the system. Their service routes are discussed below.

The first area is located in the southwest corner of the UGB in the Cedar Creek Basin, between Pacific Highway and Old Highway 99W. This area can be served by line number 1 in area A (Figure VII-2). The northern half of this area may also be served by connecting to the southern most extension of line number 2 in area B. The second area is located east of Pacific Highway and north of Edy Road, in the Rock Creek Basin. The southern portion should be incorporated in line number 3 extending from Rock Creek west along Edy Road (Figure VII-2). The northern half must be served using a direct lateral to the area from the Rock Creek trunk.

RECOMMENDED IMPROVEMENTS TO EXISTING SEWER SYSTEM

The analysis of the existing system shows no size deficiencies in any of the City maintained pipes. City officials have confirmed that there are areas of surcharge in the system due to pipe under sizing. Surcharge due to blockage of the system has occurred but has since been remedied.

Improvements are recommended to the existing sewer systems main trunk lines. These improvements are required due to very slight slips which occur in the northern sections of the Rock Creek and Cedar Creek main trunk lines.

The Rock Creek trunk requires improvements from manhole number 11663, which is located at the confluence of the Rock Creek and Cedar Creek trunk lines, south to a manhole located near the Southern Pacific crossing of Rock Creek. The existing 18-inch diameter pipe has a length of 6,035 feet and an existing slope of 0.0031 feet/foot. The USA master plan recommends that a 15-inch diameter pipe be placed parallel to the existing 18-inch in order to convey future flows based on 20-year ultimate development peak flowrates. Our analysis is based on total ultimate development of the Sherwood UGB and therefore suggests that an 18-inch diameter pipe parallel the existing 18-inch at the existing slope of 0.0031 feet/foot.

The Cedar Creek Trunk presents similar slope problems along the northern trunk. USA's Master Plan breaks these into three sections but this report will combine them for simplicity. The section of sewer begins at manhole 11663, which is located at the confluence of the Rock Creek and Cedar Creek trunks, and continues south to manhole number 11752 which is 200 feet south of Edy Road and slightly west of the UGB. (see Fig.1) The entire 12,640 feet of this line is outside of the UGB, and has a slope averaging between 0.0016 feet/foot and 0.0025 feet/foot. Depending on existing slopes a parallel system will be required ranging from 18 to 30-inches in diameter.

insert Figure VII-2

RECOMMENDED SEWER SYSTEM EXPANSION

The City of Sherwood's Urban Growth Boundary includes significant areas that are currently not served by the existing sanitary sewer system. All of these areas are part of either the Rock Creek Basin system or the Cedar Creek Basin system and can be easily served by extending laterals off the respective trunk lines of each basin. These new laterals have no special priority except to serve those who require sewer service. The locations of the recommended sewers are shown on Figure VII-3.

All new sewer lines should have a minimum diameter of 8-inches for ease of serviceability. These new laterals were designed by setting the slope of the sewer pipe invert, equal to the slope of the existing ground along the sewer line path. Individual pipe slopes may be required to be less than natural ground slopes in order to serve isolated areas of low ground elevation.

The sewer expansions are listed below under the basin in which they occur. The costs are listed by pipe diameter and are in 1990 dollars. These costs are typically paid for by the land developments that create the need for the extensions. The costs include design and construction. Land acquisition may be required but those costs are not included in the estimates below.

1.	Sewer Trunk Lines		
	Cedar Creek Parallel (15"-30")	12,640LF	\$991,000
	Rock Creek Parallel (18")	6,750 LF	\$378,000
2.	Rock Creek Basin Lines (All 8")		
	Tonquin	1400 LF	\$ 47,000
	Highland/12th	3000 LF	\$100,800
	Tualatin-Sherwood	2300 LF	\$ 77,300
	Onion Flats W.	5000 LF	\$168,000
	Onion Flats E.	2900 LF	\$ 97,500
3.	Cedar Creek Basin Lines (8" except as noted)		
	Steeplechase S. (10")	4100 LF	\$160,700
	Steeplechase N. (12")	650 LF	\$ 29,100
	Steeplechase N. (10")	4100 LF	\$161,000
	E. Sunset	1300 LF	\$ 43,700
	W. Sunset	3500 LF	\$117,600
	Scholls-Sherwood W.	1200 LF	\$ 40,300
	Scholls-Sherwood E.	3100 LF	\$104,200
	BPA#	3500 LF	\$117,600

insert Figure VII-3

WATER SERVICE PLAN

INTRODUCTION

The City draws the majority of its water supply from the Willamette River Water Treatment Plant (WRWTP) in the City of Wilsonville, approximately 6 miles southeast of Sherwood. The City owns 5 million gallons per day (MGD) of production capacity in the existing WRWTP facilities. Sherwood also maintains four groundwater wells within the city limits for back-up supply. Prior to 2011, the City also purchased water from the Portland Water Bureau (PWB) through the City of Tualatin's water system and maintains an emergency connection and transmission piping associated with this supply source.

The City's future water service area is comprised of five different planning areas:

1. Sherwood city limits
2. Tonquin Employment Area (TEA)
3. Brookman Annexation Area
4. West Urban Reserve
5. Tonquin Urban Reserve

Each of these areas has their own land use characteristics, approximate development timelines and existing planning information. Estimates of future growth and related water demand are developed using the best available information for each area including Sherwood buildable lands geographic information system (GIS) data, population growth projections, development area concept plans and current water demand data.

Water demand growth is projected at 10 years, 20 years and at saturation development. Estimated water demands at saturation development are used to size recommended transmission and distribution improvements. .

EXISTING WATER SYSTEM CONDITIONS

Pressure Zones

The City's existing distribution system is divided into three major pressure zones. Pressure zone boundaries are defined by ground topography in order to maintain service pressures within an acceptable range for all customers in the zone. The hydraulic grade line (HGL) of a zone is designated by overflow elevations of water storage facilities or outlet settings of pressure reducing valves (PRVs) serving the zone.

The majority of Sherwood customers are served from the 380 Pressure Zone which is supplied by gravity from the City's Sunset Reservoirs. The 535 Pressure Zone, serving the area around the

Sunset Reservoirs, is supplied constant pressure by the Sunset Pump Station, and the 455 Pressure Zone serves higher elevation customers on the western edge of the City by gravity from the Kruger Reservoir.

Storage Reservoirs

Sherwood's water system has three reservoirs with a total combined storage capacity of approximately 9.0 million gallons (MG). Two reservoirs, Sunset Nos. 1 and 2, provide 6.0 million gallons (MG) of gravity supply to the 380 Pressure Zone. The other reservoir, Kruger Road, provides 3.0 mg of gravity supply to the 455 Pressure Zone.

Pump Stations

Sherwood's water system includes two booster pump stations, the Sunset Pump Station and the Wyndham Ridge Pump Station.

The Sunset Pump Station is located in Snyder Park adjacent to the Sunset Reservoir complex and has an approximate total capacity of 3,770 gallons per minute (gpm). This station provides constant pressure service and fire flow to the 535 Pressure Zone.

The Wyndham Ridge Pump Station is located on SW Handley Street west of Highway 99W. Two 40-hp pumps supply a total capacity of approximately 1,200 gpm from 380 Zone distribution piping to the Kruger Road Reservoir.

Distribution System

The City's distribution system is composed of various pipe materials in sizes up to 24 inches in diameter. The total length of piping in the service area is approximately 77.4 miles. Pipe materials include cast iron, ductile iron, PVC and copper. The majority of the piping in the system is ductile iron.

ANALYSIS OF EXISTING WATER SYSTEM

Water Supply

Sherwood's supply from the WRWTP is sufficient to meet MDD through the 10-year planning horizon with an additional 1 mgd of capacity required at 20 years and an additional 4 mgd needed at build-out. Existing City groundwater wells provide an effective emergency supply to complement emergency storage in the City's reservoirs.

Pumping and Storage

The City's distribution system has adequate storage and pumping capacity to meet existing service area demands through 2034. Due to significant uncertainty related to long-term growth and system expansion, minor storage and pumping deficiencies at build-out should be re-evaluated with the next Water Master Plan Update or as development warrants. Additional pump stations are recommended to serve proposed high-elevation closed pressure zones in the water service expansion areas: Brookman Annexation and West Urban Reserve.

Distribution Piping

Sherwood's distribution piping is sufficiently looped to provide adequate fire flow capacity to commercial, industrial and residential customers. Few piping improvement projects are needed to meet fire flow criteria. Extensive large diameter mains will be needed to expand the City's water service area to supply the Brookman Annexation, TEA and West Urban Reserve as development occurs.

RECOMMENDED IMPROVEMENTS TO EXISTING WATER SYSTEM

Recommended improvements for the City's water system include proposed supply, pump station and water line projects.

Cost Estimating Data

An estimated project cost has been developed for each improvement project recommended. Cost estimates represent opinions of cost only, acknowledging that final costs of individual projects will vary depending on actual labor and material costs, market conditions for construction, regulatory factors, final project scope, project schedule and other factors. The cost estimates presented have an expected accuracy range of -30 percent to +50 percent. As the project is better defined, the accuracy level of the estimates can be narrowed. Estimated project costs include approximate construction costs and an aggregate 45 percent allowance for administrative, engineering and other project related costs.

Capital Improvement Program

A summary of all recommended improvement projects and estimated project costs is presented in Table ES-3 of the 2015 City of Sherwood Water System Master Plan Update. The table provides for project sequencing by showing fiscal year-by-year project priorities for the first five fiscal years, then prioritized projects in 5-year blocks for the 10-year, 20-year and Beyond 20 year timeframes. The total estimated cost of these projects is approximately \$24.6 million through FY 2034. Approximately \$19.9 million of the total estimated cost is for projects needed within the 10-year timeframe and \$5.4 million of these improvements are required in the next 5 years.

F. DRAINAGE PLAN

INTRODUCTION

The Sherwood Planning Area is located within the Willamette River-Tualatin River Basin as identified in the Portland-Vancouver Metropolitan Area Water Resources Study (PMAWRS). The Cedar Creek and Rock Creek sub-basins channel surface runoff to the Tualatin River just north of the Planning Area. Within these sub-basins there exists considerable variation in slope. A highland area known as Washington Hill has some erosion and sedimentation potential. High groundwater and poorly drained soils in portions of the northern half of the Planning Area will require measures to regulate excavation and site drainage.

In March 1989, DEQ issued draft rules for storm water quality control to all jurisdictions in the Tualatin River sub-basin. The City of Sherwood is required to comply with the rules and participate in the development of a Surface Water Drainage Management Plan for the region. When the Plan is completed and adopted this section will be amended accordingly.

Objectives

1. Comply with DEQ Storm water quality control rules until completion of a Drainage Management Plan.
2. Cooperate with United Sewerage Agency, Washington County, and DEQ in the preparation of a Drainage Management Plan.

Findings

1. A storm drainage plan for the City's urban growth area has been developed and is illustrated on Figure VII-7. Major storm sewers are recommended for construction in accordance with the Plan; minor storm sewers are not shown on the proposed storm drainage plan. This Plan will be updated upon completion of the regional Drainage Plan.
2. Cedar Creek, Rock Creek, and Chicken Creek shall continue to be the City's primary conveyance systems for storm runoff.
3. Existing flood areas have been identified and are analyzed and described in Section VII Background Data and Analysis. It is anticipated, all but one of the problem areas will be eliminated by implementation of the Plan. An area of flooding at N.W. 12th Street and Highway 99W remains to be resolved by construction of a minor storm sewer, which is not shown on the Plan.
4. The rational method formula was used to estimate runoff to proposed storm sewers. This method has a tendency to overestimate design flows when applied to large basins. Runoff

coefficients used in the rational method are predicted on the City's Comprehensive Plan. During final design of storm sewers, actual development within the basin should be reviewed to verify previous assumptions in selection of a runoff coefficient.

5. Cost estimates for proposed storm sewer improvements have been prepared, based on 1980 construction costs and increased in 1990 by 1.25%, and on Engineering News Record (ENR) index of 3264. These estimates are presented in Table 2 of the Appendix.

6. Design of relief culverts in Cedar Creek and Rock Creek may significantly alter hydraulic control sections used by the U.S. Army Corps of Engineers to establish water surface elevations and limits of the flood plain as set forth in Flood Insurance Study, City of Sherwood, Oregon, and provided to the City in preliminary draft, dated December 17, 1980. Design of relief culverts should be coordinated with the U.S. Army Corps of Engineers to insure integrity of their flood insurance study.

Implementation

1. The City will endeavor to establish a source of revenue to finance the cost of storm sewer construction, acquisition of lands along creeks, maintenance of storm sewers and waterways, and administration of the storm plan in accordance with the regional Surface Water Drainage Management Plan.

2. Until user fees are in effect, the City should obtain waivers of remonstrance to future storm drainage improvements projects from all property owners wishing to develop their land, and the City should also require all developers to provide adequate storm sewers to serve their property as well as those properties that would naturally drain to the proposed storm sewer.

SOLID WASTE

Solid waste disposal is a regional concern requiring regional solutions. The City of Sherwood recognizes MSD's responsibility and authority to prepare and implement a solid waste management plan and supports the MSD Solid Waste Facilities Model Siting Ordinance and will participate in these procedures as appropriate. There are no landfills in Sherwood.

The Model Siting Ordinance will be incorporated into this Plan when approved by METRO. In addition, the City conducted extensive hearings on solid waste incineration in 1990 and determined incineration is generally not a form of solid waste disposal environmentally compatible in the community except in limited circumstances. Therefore, solid waste incineration is generally prohibited by this Plan.

Electrical Power

The Sherwood Planning Area is well served by major power facilities. Portland General Electric Co. (PGE) runs and operates a major regional sub-station in the northern portion of the Planning Area and has a network of major transmission lines which cross the Planning Area. Minor sub-station siting and construction, if needed in response to development, will be coordinated with PGE.

Natural Gas

The Sherwood Planning Area is served by Northwest Natural Gas Co. (NNG) lines. The existing system consists of a 6" high pressure line extended to the Planning Area via Tualatin-Sherwood Road, So. Sherwood Blvd. and Wilsonville Road. The distribution system is adequate to serve immediate development. NNG reports that the 6" main will be adequate to serve growth projected by the Plan with new lateral line extensions and attention to proper "looping" of existing lines.

Telephone

General Telephone services the Sherwood Planning Area. Planned improvements should have the capability of handling projected growth demands in the Area.

H. SCHOOLS

INTRODUCTION

The Sherwood Planning Area is wholly contained within Sherwood School District 88J. Although the City of Sherwood is the only currently urbanized area within the district, district boundaries include approximately 44 square miles and parts of Washington, Clackamas, and Yamhill Counties. The District is currently predominately rural but, by the year 2000, the Sherwood Planning Area will contribute most of the total student enrollment.

FUTURE ENROLLMENT/FACILITY NEEDS

The School District completed a School Enrollment Study (Metro Service District Analysis) in the Fall of 1990. Revisions were made in the Spring of 1991. The study data suggests that school enrollments will be increasing sharply in the coming years. The growth assumption is supported by record-setting residential building permit issuance during 1990. Major arterial road improvements between I-5 and 99W will also cause further growth and development.

ELEMENTARY AGE STUDENTS (K-5)

J. Clyde Hopkins Elementary School has a capacity to house 600 students. Currently, 670 students

are enrolled in grades K-5. Three double portable classrooms and one single portable classroom are utilized to address the growing elementary age population.

INTERMEDIATE AGE STUDENTS (6-8)

Approximately 300 students are enrolled in grades 6-8. The Intermediate School building capacity is 400 students. This capacity can be accessed by relocating District office services, which occupy a four classroom wing of the building.

HIGH SCHOOL AGE STUDENTS (9-12)

Sherwood High School has a capacity of 500 students. Approximately 420 students are currently enrolled. No major housing issues exist in this 1971 constructed facility.

SCHOOL FACILITY PLANNING

The School District is preparing to undertake a detailed facility development plan. The most immediate need for the District is to expand housing of elementary age school children (K-5). During the Fall of the 1990-91 school year, the District completed the purchase of a new elementary school site located within the City limits of Sherwood. The District also owns a school site (purchased in 1971) in the proximity of the Tualatin portion of the school district.

The intent of the District is to seek voter approval of a bond measure to address short and long-term housing needs. The measure is planned to be submitted in the Fall of 1991 or the Spring of 1992 in order to construct an additional elementary school.

I. PUBLIC SAFETY

POLICE PROTECTION

The City of Sherwood, Washington County and the State Police co-ordinate police protection within the Planning Area. In 1989 the Sherwood Police Force consisted of five officers. In order to meet future demand it is anticipated that the department will need additional patrolmen proportional to the projected increase in population. The State formula for City police protection is one officer per 500 people. The police force should expand accordingly.

FIRE PROTECTION

The Planning Area is wholly contained within the Tualatin Valley Consolidated Fire and Rescue District. One engine house is located within the City. The District feels that present physical facilities will be adequate to serve the projected year 2000 growth in the area with some increase in manpower and equipment. The District currently employs a 5-year capital improvement planning

process which is updated annually. The City will co-ordinate its planning with the district to assure the adequacy of fire protection capability in the Planning Area.

J. GENERAL GOVERNMENTAL SERVICES

As a general purpose governmental unit, the City of Sherwood intends to fulfill its responsibilities in the principal areas of general administration, planning, public works, and library services. With expected growth in Sherwood, additional manpower and facilities will be required.

1. Manpower Needs

In 1989 there are currently seventeen (17) City staff in general governmental services. A review of cities which have reached Sherwood's projected five and twenty year growth levels indicate that new staffing will be needed proportional to population increases in most departments. Using this assumption a full-time staff of 15-20 persons will be required by 1985 and a staff of 20-40 will be needed by the year 2000. Most critical immediate needs are in the area of clerical staff to support existing departmental work loads.

2. Space Needs

The City offices, water department, police department, planning department and public works, are currently housed in a remodeled turn-of-the-century house. Although the structure is significant historically and should be saved, it may not meet the long term functional or space needs of a City Hall.

In 1982 the Senior and Community Center was built and provides meeting space for the City Council and Planning Commissions.

K. HEALTH FACILITIES

The local health system is linked to a number of organizations and institutions that can and do affect how it will develop. The latest planning legislation P.L. 93-641 and its recent amendments has placed Health care delivery systems planning are under the auspices of the State Certificate of Need laws and the Federal Health System Agency (HSA) planning regulations. Sherwood is located in the six county Northwest Oregon Health Systems Agency (NOHS) which is charged with reviewing new service proposals, expenditures involving public funds and the development of a health system plan for the area. The first HSA plan was adopted in 1978. State agencies administer HSA regulations. NOHS established subdistricts within the six county service area. Sherwood is located in the south-rural sub-district (see Figure VII-8). The only hospital located in the sub-district is Meridian Park Hospital in Tualatin.

Sherwood is served by various Metropolitan area hospitals depending on local physician affiliations. The City currently has only one doctor with offices in the Planning Area. St. Vincent's Hospital in Beaverton has expressed interest in establishing a satellite clinic in Sherwood.

The City will encourage the decentralization of Metropolitan health care delivery to assure that a broad range of inpatient, outpatient and emergency medical services are available to Sherwood residents. To that end the City will support the location of a St. Vincent's Satellite Center in Sherwood and encourage the appropriate expansion of Meridian Park facilities to meet the growing needs of the Planning Area.

L. SOCIAL FACILITIES AND SERVICES

A broad range of social services will be needed in the Planning Area to serve a growing urban population. Sherwood will continue to depend on metropolitan area services for which the demand does not justify a decentralized center. Multi-purpose social and health services and referral are offered by the Washington County Satellite Center in Tigard. The City will encourage the continued availability of such services.

Sherwood is located in Region 8 of the State Department of Human Resources Service Area and benefits from that agency's services. State services are administered through the County's Washington County office located in Hillsboro. In addition to public social service programs, many private organizations serve the Sherwood area.

The City is particularly interested in locating a multi-purpose social and health service referral agency in Sherwood so that residents of Sherwood would be able to get timely information on the available services. The City also supports the development of a Comprehensive Social and health services delivery plan for the Planning Area to identify gaps in needed services and develop an ongoing strategy for their provision. Of particular concern are day care and senior citizens services.

Day Care

A growing need exists for day care. State standards for the establishment of day care centers are supplemented by City standards. Currently day care has been carried on by churches and small home operations. The City recognizes and supports the proper siting and housing of day care services.

Senior Citizens Services

With an increasing proportion of the Planning Areas population reaching the age of 60, Sherwood will require additional specialized services and facilities for senior citizens. The City was awarded a grant from HUD for a Senior Citizen Community Center was completed in 1982. Community Center functions will be carried out under the authority of the City. It is the intent of the City that the Center be the focus for the Community activities requiring meeting and multi-purpose areas with particular emphasis on Senior Citizens programs and activities.

Exhibit C



City of Sherwood
15527 SW Willamette St
Sherwood, OR 97140
Tel 503-625-5722
Fax 503-625-0679
www.sherwoodoregon.gov

March 11, 2015

Mayor
Krisanna Clark

Mr. Brad Kilby and
City of Sherwood Planning Commission
22560 SW Pine Street
Sherwood, OR 97140

Council President
Sally Robinson

Councillors
Linda Henderson
Dan King
Jennifer Harris
Jennifer Kuiper
Beth Cooke

Re: Sherwood Water System Master Plan Update (WSMPU)

Brad and Members of the Planning Commission:

City Manager
Joseph Gail, ICMA-CM

Assistant City Manager
Tom Pessemier, P.E.

The following questions are paraphrased from discussion at the Sherwood Planning Commission work session regarding the Water System Master Plan Update. The answers given herein are intended to provide clarification for the commissioners in advance of a Planning Commission Public Hearing anticipated on March 24, 2015.

Questions

1. *What is a Water System Master Plan Update and what is the process for water master planning in Sherwood?*



2009 Top Ten Selection



2007 18th Best Place to Live

The City of Sherwood (City) is required to maintain a current water system master plan as a drinking water provider in the State of Oregon with more than 300 customers. The City's water master plan must comply with Oregon Administrative Rule (OAR) 333-061-0060(5). This OAR stipulates certain elements that must be part of the plan, including, an evaluation of the water system for at least a 20 year period and an estimate of projected growth in the water system during that time.



The completed plan must be reviewed and approved by the Oregon Health Authority's Drinking Water Services for compliance with the OAR. Prior plan adoption by the governing body of the water system, such as a city council, is not expressly required by the OAR for State approval. However, most if not all water providers, including the City of Sherwood, will seek water master plan adoption by their governing body before submitting the plan to the Oregon Health Authority.

Funding for the capital improvement program (CIP) recommended in the Sherwood Water System Master Plan Update (WSMPU) is being assessed through a water rate and system development charge (SDC) analysis independent of the Master Plan Update document. This rate and SDC analysis will be presented to the budget committee, City Council for review, public hearing, and adoption, in coordination with the Water System Master Plan Update, consistent with Sherwood policies.

2. *What is being approved if the Water System Master Plan Update is recommended for adoption by the Planning Commission?*

The Water System Master Plan Update will serve as an amendment to the Public Facilities Chapter of the Sherwood Comprehensive Plan (Part 2). Any addendum to Sherwood's comprehensive plan must be reviewed and approved by the Oregon State Department of Land Conservation and Development (DLCD) and recommended by Sherwood's Planning Commission for adoption by the City Council.

Water rates, SDCs and water utility funding are independent of the Water System Master Plan Update document and will be presented to the budget committee, City Council for review, public hearing and adoption consistent with Sherwood policies.

3. *Why are we planning for so much growth?*

Public water system master plans are required to evaluate water system needs for a minimum of 20 years. The Sherwood WSMPU considers 4 growth areas; the existing city limits, Tonquin Employment Area (TEA), Brookman Annexation Area and Sherwood West Urban Reserve. The Sherwood city limits, TEA and Brookman fall within the existing Metro Urban Growth Boundary (UGB) which is drawn to accommodate anticipated Portland metro area growth within 20 years. Thus, any of these areas may be expected to experience growth within 20 years.

Sherwood West was identified by City Planning staff as the next likely area to develop after TEA and Brookman. Although this area remains outside of the Metro UGB, it is prudent for the City to consider the long range water system needs to serve potential customers in Sherwood West. With a basic water infrastructure plan in place for Sherwood West, the City can ensure that appropriately-sized water facilities are built when and if development occurs.

Any project in the water system CIP designated 100% for growth would only be constructed if development occurred in the area served by that project. Projects in the CIP may be re-prioritized or delayed based on

where or if growth is occurring in the Sherwood water system but additional projects would not be added to the CIP without updating the Water System Master Plan. Review and re-prioritization of projects will occur annually as part of the budgeting process, in addition to longer-range prioritization of projects by the Engineering and Public Works Departments.

4. *What is the total CIP cost to existing Sherwood water customers?*

Of the \$36.2 million total estimated cost for recommended capital improvement projects, only \$2.2 million is anticipated to be paid by existing customers through saturation development. The remaining projects in the CIP are for water system expansion to serve growth, as development occurs. These improvements will be funded through the collection of System Development Charges (SDCs).

Note:

A typo was identified in the CIP summary table presented in the Draft Water System Master Plan Update. Water main projects M-3, 4 & 5 which replace existing 8-inch mains in order to provide adequate fire flow for future development in Brookman Annexation should be 100% allocated to growth. An updated CIP summary table showing this 100% allocation is attached. The attached table replaces Table ES-3 on page 7 of the draft Executive Summary and Table 5-3 on page 13 of Section 5.

A second version of the CIP summary table showing the total estimated CIP cost to existing customers is also attached with the M-3, 4 & 5 allocation correction. The uncorrected table was displayed as a poster at the WSMPU public open house February 25, 2015, and a specific question related to this typo was asked by a Sherwood citizen during the open house.

Sincerely,



Craig Sheldon
Public Works Director

**Table ES-3
CIP Summary**

DRAFT

Project Category	Project ID	Project Description	CIP Schedule and Project Cost Summary								% Allocated to Growth
			FY1 (2016)	FY2 (2017)	FY3 (2018)	FY4 (2019)	FY5 (2020)	10-Year (2024)	20-Year (2034)	Beyond 20 years	
Supply	S-1	Existing WRWTP upgrades to achieve max 15 mgd capacity				\$ 250,000	\$ 250,000	\$ 500,000			21%
	S-2	WRWTP purchase 5 mgd intake capacity			\$ 100,000	\$ 150,000	\$ 150,000	\$ 1,600,000			100%
	S-3	WRWTP treatment expansion - Sherwood 5 mgd share			\$ 440,000	\$ 550,000	\$ 550,000	\$ 6,160,000			100%
	S-4	Install hydrants at Wells 3 and 5	\$ 25,000								0%
	S-5	Abandon Well 4 and transfer water rights	\$ 25,000								0%
		Subtotal	\$ 50,000	\$ -	\$ 540,000	\$ 950,000	\$ 950,000	\$ 8,260,000	\$ -	\$ -	
Pump Station	P-1	Proposed 1,600 gpm Ladd Hill Pump Station to serve future 400 Brookman Zone customers							\$ 477,000		100%
	P-2	Proposed 2,400 gpm Kruger Pump Station to serve future 630 Zone customers								\$ 2,547,000	100%
	P-3	Proposed 1,600 gpm Edy Road Pump Station to serve future 475 Zone customers								\$ 1,505,000	100%
		Subtotal	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 477,000	\$ 4,052,000	
Water Main	M-1	Fire flow capacity - Sherwood Senior Center		\$ 36,000							0%
	M-2	Fire flow capacity - Norton Ave			\$ 92,000						0%
	M-60	Fire flow capacity - June Court				\$ 43,000					0%
	M-7	Expansion to TEA - Loop with existing Oregon Street mains		\$ 68,000							100%
	M-8				\$ 204,000						100%
	M-9				\$ 239,000						100%
	M-29				\$ 154,000						100%
	M-30					\$ 264,000					100%
	M-31					\$ 438,000					100%
	M-32						\$ 267,000				100%
	M-33						\$ 162,000				100%
	M-34					\$ 178,000				100%	
	M-3, 4 & 5	10-Year (2024) - upgrade existing mains						\$ 300,000			100%
	M-6, 10 to 19B, 35 to 37, 40 to 42	10-Year (2024)						\$ 5,275,000			100%
	M-20 to 28, 43 to 45	20-Year (2034)							\$ 3,295,000		100%
M-38, 39, 46 to 59	Beyond 20 years								\$ 7,183,000	100%	
	Routine Pipe Replacement Program	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 250,000	\$ 500,000	\$50K annually	57%	
	Subtotal	\$ 50,000	\$ 154,000	\$ 739,000	\$ 795,000	\$ 657,000	\$ 5,825,000	\$ 3,795,000	\$ 7,183,000		
PRV	V-1	SW Sherwood PRV			\$ 150,000						100%
	V-2	Handley PRV					\$ 150,000				100%
	V-3	Haide PRV							\$ 150,000		100%
	V-4	195th PRV							\$ 150,000		100%
	Subtotal	\$ -	\$ -	\$ 150,000	\$ -	\$ -	\$ 150,000	\$ -	\$ 300,000		
Other	Upgrade SCADA System		\$ 75,000								35%
	Subtotal	\$ -	\$ 75,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	
Planning		Update Water Master Plan						\$ 150,000	\$ 150,000		35%
		Update Water Management and Conservation Plan			\$ 150,000				\$ 150,000		35%
		Update Vulnerability Assessment						\$ 60,000	\$ 60,000		35%
		Resiliency Plan	\$ 150,000						\$ 150,000		35%
	Subtotal	\$ 150,000	\$ -	\$ 150,000	\$ -	\$ -	\$ 210,000	\$ 510,000	\$ -		
Capital Improvement Program (CIP) Total			\$ 250,000	\$ 229,000	\$ 1,579,000	\$ 1,745,000	\$ 1,607,000	\$ 14,445,000	\$ 4,782,000	\$ 11,535,000	\$ 36,172,000

Annual Average CIP Cost		
\$1,082,000	\$1,985,500	\$1,231,850
over 5 years	over 10 years	over 20 years

Water System Master Plan Update
Proposed Capital Improvement Program (CIP) Summary

DRAFT

Project Category	Project ID	Project Description	CIP Schedule and Project Cost Summary							% Allocated to Future Growth	
			FY1 (2016)	FY2 (2017)	FY3 (2018)	FY4 (2019)	FY5 (2020)	10-Year (2024)	20-Year (2034)		Beyond 20 years
Supply	S-1	Existing WRWTP upgrades to achieve max 15 mgd capacity				\$ 250,000	\$ 250,000	\$ 500,000			21%
	S-2	WRWTP purchase 5 mgd intake capacity			\$ 100,000	\$ 150,000	\$ 150,000	\$ 1,600,000			100%
	S-3	WRWTP treatment expansion - Sherwood 5 mgd share			\$ 440,000	\$ 550,000	\$ 550,000	\$ 6,160,000			100%
	S-4	Install hydrants at Wells 3 and 5	\$ 25,000								0%
	S-5	Abandon Well 4 and transfer water rights	\$ 25,000								0%
		Subtotal	\$ 50,000	\$ -	\$ 540,000	\$ 950,000	\$ 950,000	\$ 8,260,000	\$ -	\$ -	
Pump Station	P-1	Proposed 1,600 gpm Ladd Hill Pump Station to serve future 400 Brookman Zone customers							\$ 477,000		100%
	P-2	Proposed 2,400 gpm Kruger Pump Station to serve future 630 Zone customers								\$ 2,547,000	100%
	P-3	Proposed 1,600 gpm Edy Road Pump Station to serve future 475 Zone customers								\$ 1,505,000	100%
		Subtotal	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 477,000	\$ 4,052,000	
Water Main	M-1	Fire flow capacity - Sherwood Senior Center		\$ 36,000							0%
	M-2	Fire flow capacity - Norton Ave			\$ 92,000						0%
	M-60	Fire flow capacity - June Court				\$ 43,000					0%
	M-7	Expansion to Brookman - Loop from prop SW		\$ 68,000							100%
	M-8	Sherwood PRV to Hwy 99			\$ 204,000						100%
	M-9				\$ 239,000						100%
	M-29				\$ 154,000						100%
	M-30					\$ 264,000					100%
	M-31	Expansion to TEA - Loop with existing Oregon Street mains				\$ 438,000					100%
	M-32						\$ 267,000				100%
	M-33						\$ 162,000				100%
	M-34						\$ 178,000				100%
	M-3, 4 & 5	10-Year (2024) - upgrade existing mains						\$ 300,000			100%
	M-6, 10 to 19B, 35 to 37, 40 to 42	10-Year (2024)						\$ 5,275,000			100%
M-20 to 28, 43 to 45	20-Year (2034)							\$ 3,295,000		100%	
M-38, 39, 46 to 59	Beyond 20 years								\$ 7,183,000	100%	
	Routine Pipe Replacement Program	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 250,000	\$ 500,000	\$50K annually	57%	
	Subtotal	\$ 50,000	\$ 154,000	\$ 739,000	\$ 795,000	\$ 657,000	\$ 5,825,000	\$ 3,795,000	\$ 7,183,000		
PRV	V-1	SW Sherwood PRV			\$ 150,000						100%
	V-2	Handley PRV					\$ 150,000				100%
	V-3	Haide PRV							\$ 150,000		100%
	V-4	195th PRV							\$ 150,000		100%
	Subtotal	\$ -	\$ -	\$ 150,000	\$ -	\$ -	\$ 150,000	\$ -	\$ 300,000		
Other		Upgrade SCADA System		\$ 75,000							35%
	Subtotal	\$ -	\$ 75,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
Planning		Update Water Master Plan					\$ 150,000	\$ 150,000			35%
		Update Water Management and Conservation Plan			\$ 150,000				\$ 150,000		35%
		Update Vulnerability Assessment					\$ 60,000	\$ 60,000			35%
		Resiliency Plan	\$ 150,000						\$ 150,000		35%
	Subtotal	\$ 150,000	\$ -	\$ 150,000	\$ -	\$ -	\$ 210,000	\$ 510,000	\$ -		
Capital Improvement Program (CIP) Total			\$ 250,000	\$ 229,000	\$ 1,579,000	\$ 1,745,000	\$ 1,607,000	\$ 14,445,000	\$ 4,782,000	\$ 11,535,000	

Overall CIP Total	\$ 36,172,000
Total Allocated to Future Growth	\$ 34,020,000
Total Allocated to Current Customers	\$ 2,152,000

Exhibit D

DRAFT Water System Master Plan – 2015

To view the draft document, click on the City's website link below. The draft can be found under the supporting documents at the bottom of the page.

<http://www.sherwoodoregon.gov/publicworks/page/water-system-master-plan-update>

A hard copy of the document is available for viewing at City Hall.



CITY OF SHERWOOD WATER SYSTEM MASTER PLAN UPDATE

DRAFT

FEBRUARY 2015

WATER SYSTEM MASTER PLAN UPDATE

FOR

CITY OF SHERWOOD

FEBRUARY 2015

DRAFT

**MURRAY, SMITH & ASSOCIATES, INC.
121 SW Salmon, Suite 900
Portland, OR 97204
503.225.9010**

TABLE OF CONTENTS

	Page
EXECUTIVE SUMMARY	
Introduction	ES-1
Study Area.....	ES-1
Planning Period	ES-1
Water System Background.....	ES-1
Supply Facilities	ES-1
Pressure Zones	ES-2
Storage Reservoirs.....	ES-2
Pump Stations	ES-2
Distribution System	ES-2
Water Demand Projections.....	ES-3
Current Water Demand.....	ES-3
Future Water Demand Projections.....	ES-3
Planning and Analysis Criteria.....	ES-4
Water System Analysis.....	ES-4
Water Supply	ES-4
Pumping and Storage.....	ES-4
Distribution Piping.....	ES-4
Recommendations and Capital Improvement Program.....	ES-4
Cost Estimating Data	ES-5
Capital Improvement Program.....	ES-5

1. INTRODUCTION AND EXISTING WATER SYSTEM

Introduction	1-1
Study Area.....	1-1
Water System Background.....	1-3
Supply Facility	1-3
Willamette River Water Treatment Plant	1-3
Groundwater Wells.....	1-4
Tualatin Emergency Intertie	1-5
Pressure Zones.....	1-5
Storage Reservoirs.....	1-6
Sunset Reservoirs.....	1-6
Kruger Road Reservoir	1-7
Pump Stations.....	1-7
Sunset Pump Station	1-7
Wyndham Ridge Pump Station.....	1-8
Distribution System.....	1-8
SCADA System.....	1-10

Summary 1-10

2. LAND USE AND WATER REQUIREMENTS

Service Area 2-1
Planning Period 2-1
Current Water Demand 2-1
 Water Demand by Pressure Zone 2-2
 Water Consumption by Customer Class 2-3
 Water Demand per Residential Unit 2-4
Future Water Demand Projections 2-5
 Approach 2-5
 Sherwood City Limits 2-5
 Tonquin Employment Area (TEA) 2-6
 Brookman Annexation Area 2-7
 West Urban Reserve 2-8
 Tonquin Urban Reserve 2-8
Equivalent Residential Units (ERUs) 2-9

3. PLANNING AND ANALYSIS CRITERIA

Performance Criteria 3-1
 Water Supply 3-1
 Service Pressure 3-1
 Main Size 3-2
 Storage Capacity 3-3
 Pump Stations 3-4
 Required Fire Flow 3-5
Summary 3-6

4. WATER SYSTEM ANALYSIS

Water Supply Analysis 4-1
 WRWTP Capacity 4-1
 Emergency Supply 4-2
 Potential Future Supply to Tualatin 4-4
Pressure Zone Analysis 4-4
 Future 535 Zone Reservoir 4-4
 Future Service Area Expansion 4-5
Storage Capacity Analysis 4-6
 Operational Storage 4-7
 Emergency Storage 4-7
 Storage Analysis Findings 4-8
Pump Station Analysis 4-9
 Closed Zones 4-9

Open Zones (Supplied by Gravity Storage)..... 4-9
Back-Up Power..... 4-9
Pump Station Analysis Findings..... 4-9
Distribution System Analysis 4-11
 Modeled Demands 4-11
 Fire Flow Analysis..... 4-11
 Peak Hour Demand Analysis 4-11
Summary 4-12

5. RECOMMENDATIONS AND CAPITAL IMPROVEMENT PROGRAM (CIP)

Cost Estimating Data..... 5-1
Water System Capital Improvement Program..... 5-1
 CIP Cost Allocation to Growth..... 5-2
Water Supply Projects 5-2
 WRWTP..... 5-2
 City Wells 5-3
Pump Station Projects 5-4
 P-1 Ladd Hill Pump Station..... 5-4
 P-2 Kruger Pump Station..... 5-4
 P-3 Edy Road Pump Station 5-4
Distribution Main Improvement Projects..... 5-5
 Projects for Fire Flow 5-5
 Projects for Future System Expansion..... 5-5
 Routine Pipe Replacement Program..... 5-6
PRV Projects 5-7
SCADA System Upgrade..... 5-7
Planning Projects..... 5-7
Summary 5-8

FIGURES

1-1 Sherwood Water System Master Plan Update 1-2
1-2 Water System Schematic 1-10
2-1 Water Service Area and Proposed Pressure Zones 2-10
2-2 Current Annual Water Consumption by Customer Class 2-3
5-1 Proposed Water System Schematic 5-14

TABLES

ES-1 Current Water Demand Summary ES-3
ES-2 Future Water Demand Summary ES-4
ES-3 CIP Summary..... ES-7
1-1 WRWTP-Sherwood Transmission Main 1-4
1-2 Groundwater Well Summary 1-5

1-3	Reservoir Summary	1-6
1-4	Pump Station Summary	1-7
1-5	Distribution System Pipe Summary	1-9
2-1	Current Water Demand Summary	2-2
2-2	Current Water Demand by Pressure Zone	2-3
2-3	ADD per Residential Unit.....	2-4
2-4	TEA Projected Growth and Future Water Demand.....	2-6
2-5	Brookman Projected Growth and Future Water Demand.....	2-7
2-6	West Urban Reserve Projected Growth and Future Water Demand.....	2-8
2-7	Future Water Demand Summary	2-11
2-8	Demand Summary by Pressure Zone.....	2-12
3-1	Recommended Service Pressure Criteria.....	3-2
3-2	Required Fire Flow Summary.....	3-6
3-3	Water System Performance Criteria	3-7
4-1	WRWTP Supply Capacity Analysis	4-2
4-2	Well Capacity Summary	4-3
4-3	Emergency Supply from City Wells	4-3
4-4	Storage Analysis	4-8
4-5	Pump Station Analysis.....	4-10
5-1	Unit Cost for Water Main Projects	5-5
5-2	Water Main Projects	5-9
5-3	CIP Summary.....	5-13

APPENDICES

Appendix A: Plate 1 Water System Map

EXECUTIVE SUMMARY

Introduction

The purpose of this Water System Master Plan Update is to perform an analysis of the City of Sherwood's (City's) water system and:

- Document water system upgrades, including significant changes in water supply completed since the 2005 Master Plan
- Estimate future water requirements including potential water system expansion areas
- Identify deficiencies and recommend water facility improvements that correct deficiencies and provide for growth
- Update the City's capital improvement program (CIP)
- Evaluate the City's existing water rates and system development charges (SDCs)

This plan complies with water system master planning requirements established under Oregon Administrative Rules (OAR) for Public Water Systems, Chapter 333, Division 61.

Study Area

The study area of this planning effort includes the current city limits, the Tonquin Employment Area (TEA), Brookman Annexation area, the West Urban Reserve and a portion of the Tonquin Urban Reserve, which generally includes all area within the City's existing Urban Growth Boundary (UGB).

Planning Period

The planning period for this Water Master Plan Update is 20 years, through the year 2034. Some planning and facility sizing efforts within this plan will use estimates of water demands at saturation development. Saturation development occurs when all the vacant, developable land within the planning area has been developed to the maximum zoning density with some practical allowance for in-fill of existing developed properties.

Water System Background

The City owns and operates a public water system that supplies potable water to all residents, businesses and public institutions within the city limits.

Supply Facilities

The City draws the majority of its water supply from the Willamette River Water Treatment Plant (WRWTP) in the City of Wilsonville, approximately 6 miles southeast of Sherwood. The City owns 5 mgd of production capacity in the existing WRWTP facilities. Sherwood also maintains four groundwater wells within the city limits for back-up supply. Prior to

2011, the City also purchased water from the Portland Water Bureau (PWB) through the City of Tualatin's water system and maintains an emergency connection and transmission piping associated with this supply source.

Pressure Zones

The City's existing distribution system is divided into three major pressure zones. Pressure zone boundaries are defined by ground topography in order to maintain service pressures within an acceptable range for all customers in the zone. The hydraulic grade line (HGL) of a zone is designated by overflow elevations of water storage facilities or outlet settings of pressure reducing valves (PRVs) serving the zone.

The majority of Sherwood customers are served from the 380 Pressure Zone which is supplied by gravity from the City's Sunset Reservoirs. The 535 Pressure Zone, serving the area around the Sunset Reservoirs, is supplied constant pressure by the Sunset Pump Station, and the 455 Pressure Zone serves higher elevation customers on the western edge of the City by gravity from the Kruger Reservoir.

Storage Reservoirs

Sherwood's water system has three reservoirs with a total combined storage capacity of approximately 9.0 million gallons (MG). Two reservoirs, Sunset Nos. 1 and 2, provide 6.0 million gallons (mg) of gravity supply to the 380 Pressure Zone. The other reservoir, Kruger Road, provides 3.0 mg of gravity supply to the 455 Pressure Zone.

Pump Stations

Sherwood's water system includes two booster pump stations, the Sunset Pump Station and the Wyndham Ridge Pump Station.

The Sunset Pump Station is located in Snyder Park adjacent to the Sunset Reservoir complex and has an approximate total capacity of 3,770 gallons per minute (gpm). This station provides constant pressure service and fire flow to the 535 Pressure Zone.

The Wyndham Ridge Pump Station is located on SW Handley Street west of Highway 99W. Two 40-hp pumps supply a total capacity of approximately 1,200 gpm from 380 Zone distribution piping to the Kruger Road Reservoir.

Distribution System

The City's distribution system is composed of various pipe materials in sizes up to 24 inches in diameter. The total length of piping in the service area is approximately 77.4 miles. Pipe materials include cast iron, ductile iron, PVC and copper. The majority of the piping in the system is ductile iron.

Water Demand Projections

Water demand refers to all water required by the system including residential, commercial, industrial and institutional uses. Demands are described using two water use metrics, average daily demand (ADD) and maximum day demand (MDD), in gallons per unit of time such as gallons per day (gpd) or million gallons per day (mgd).

Current Water Demand

For the purposes of this Plan, water production data is used to calculate total water demand in order to account for unmetered water uses. Table ES-1 summarizes the City's current system-wide water demand based on water production data.

**Table ES-1
Current Water Demand Summary**

Year	ADD (mgd)	MDD (mgd)	Ratio MDD:ADD
2012	1.85	3.85	2.1
2013	1.87	3.83	2.0
Average	1.86	3.84	2.1

Future Water Demand Projections

The City's future water service area is comprised of five different planning areas:

1. Sherwood city limits
2. Tonquin Employment Area (TEA)
3. Brookman Annexation Area
4. West Urban Reserve
5. Tonquin Urban Reserve

Each of these areas has their own land use characteristics, approximate development timelines and existing planning information. Estimates of future growth and related water demand are developed using the best available information for each area including Sherwood buildable lands geographic information system (GIS) data, population growth projections, development area concept plans and current water demand data.

Water demand growth is projected at 10 years, 20 years and at saturation development. Estimated water demands at saturation development are used to size recommended transmission and distribution improvements. Future MDD is projected from estimated future ADD based on the current average ratio of MDD:ADD, also referred to as a peaking factor.

Future demand projections by planning area and pressure zone are summarized in Tables ES-2.

**Table ES-2
Future Water Demand Summary**

Pressure Zone	Current			10-Year (2024)			20-Year (2034)			Saturation Development		
	ERUs	ADD (mgd)	MDD (mgd)	ERUs	ADD (mgd)	MDD (mgd)	ERUs	ADD (mgd)	MDD (mgd)	ERUs	ADD (mgd)	MDD (mgd)
<i>City Limits</i>	8,779	1.87	3.93	9,536	2.03	4.26	9,536	2.03	4.26	9,536	2.03	4.26
380	6,857	1.47	3.09	7,447	1.59	3.34	7,447	1.59	3.34	7,447	1.59	3.34
400	149	0.03	0.06	162	0.03	0.06	162	0.03	0.06	162	0.03	0.06
455	816	0.17	0.36	887	0.19	0.40	887	0.19	0.40	887	0.19	0.40
535	957	0.20	0.42	1,039	0.22	0.46	1,039	0.22	0.46	1,039	0.22	0.46
<i>Tonquin Employment Area (TEA)</i>				238	0.05	0.11	484	0.11	0.23	744	0.16	0.34
380	-	-	-	238	0.05	0.11	484	0.11	0.23	744	0.16	0.34
<i>Brookman Annexation</i>				752	0.16	0.34	1,330	0.28	0.59	1,330	0.28	0.59
380	-	-	-	752	0.16	0.34	1,275	0.27	0.57	1,275	0.27	0.57
400 Brookman	-	-	-	-	-	-	55	0.01	0.02	55	0.01	0.02
<i>West Urban Reserve</i>				235	0.05	0.11	2,066	0.43	0.90	7,974	1.70	3.57
380	-	-	-	235	0.05	0.11	1,138	0.24	0.50	4,391	0.94	1.97
455	-	-	-	-	-	-	432	0.09	0.19	1,670	0.36	0.76
475 West	-	-	-	-	-	-	52	0.01	0.02	202	0.04	0.08
630 West	-	-	-	-	-	-	444	0.09	0.19	1,711	0.36	0.76
<i>Tonquin Urban Reserve</i>										591	0.13	0.27
380	-	-	-	-	-	-	-	-	-	591	0.13	0.27
GRAND TOTAL	8,779	1.9	3.9	10,761	2.3	4.8	13,416	2.9	6.0	20,175	4.3	9.0

Planning and Analysis Criteria

Criteria are established for evaluating water supply, distribution system piping, service pressures, storage and pumping capacity and fire flow availability. These criteria are used in conjunction with the water demand forecasts to complete the water system analysis.

The water distribution system should be capable of operating within certain performance limits under varying customer demand and operational conditions. The recommendations of this plan are based on performance criteria developed through a review of State requirements, American Water Works Association (AWWA) acceptable practice guidelines, *Ten States Standards* and the *Washington Water System Design Manual*.

Water System Analysis

Water Supply

Sherwood's supply from the WRWTP is sufficient to meet MDD through the 10-year planning horizon with an additional 1 mgd of capacity required at 20 years and an additional 4 mgd needed at build-out. Existing City groundwater wells provide an effective emergency supply to complement emergency storage in the City's reservoirs.

Pumping and Storage

The City's distribution system has adequate storage and pumping capacity to meet existing service area demands through 2034. Due to significant uncertainty related to long-term growth and system expansion, minor storage and pumping deficiencies at build-out should be re-evaluated with the next Water Master Plan Update or as development warrants. Additional pump stations are recommended to serve proposed high-elevation closed pressure zones in the water service expansion areas: Brookman Annexation and West Urban Reserve.

Distribution Piping

Sherwood's distribution piping is sufficiently looped to provide adequate fire flow capacity to commercial, industrial and residential customers. Few piping improvement projects are needed to meet fire flow criteria. Extensive large diameter mains will be needed to expand the City's water service area to supply the Brookman Annexation, TEA and West Urban Reserve as development occurs.

Recommendations and Capital Improvement Program

Recommended improvements for the City's water system are based on the analysis and findings presented above. These improvements include proposed supply, pump station and water line projects.

Cost Estimating Data

An estimated project cost has been developed for each improvement project recommended. Cost estimates represent opinions of cost only, acknowledging that final costs of individual projects will vary depending on actual labor and material costs, market conditions for construction, regulatory factors, final project scope, project schedule and other factors. The cost estimates presented here have an expected accuracy range of -30 percent to +50 percent. As the project is better defined, the accuracy level of the estimates can be narrowed. Estimated project costs include approximate construction costs and an aggregate 45 percent allowance for administrative, engineering and other project related costs.

Capital Improvement Program

A summary of all recommended improvement projects and estimated project costs is presented in Table ES-3. This CIP table provides for project sequencing by showing fiscal year-by-year project priorities for the first five fiscal years, then prioritized projects in 5-year blocks for the 10-year, 20-year and Beyond 20 year timeframes. The total estimated cost of these projects is approximately \$24.6 million through FY 2034. Approximately \$19.9 million of the total estimated cost is for projects needed within the 10-year timeframe and \$5.4 million of these improvements are required in the next 5 years.

**Table ES-3
CIP Summary**

DRAFT

Project Category	Project ID	Project Description	CIP Schedule and Project Cost Summary							% Allocated to Growth	
			FY1 (2016)	FY2 (2017)	FY3 (2018)	FY4 (2019)	FY5 (2020)	10-Year (2024)	20-Year (2034)		Beyond 20 years
Supply	S-1	Existing WRWTP upgrades to achieve max 15 mgd capacity				\$ 250,000	\$ 250,000	\$ 500,000			20%
	S-2	WRWTP purchase 5 mgd intake capacity			\$ 100,000	\$ 150,000	\$ 150,000	\$ 1,600,000			100%
	S-3	WRWTP treatment expansion - Sherwood 5 mgd share			\$ 440,000	\$ 550,000	\$ 550,000	\$ 6,160,000			100%
	S-4	Install hydrants at Wells 3 and 5	\$ 25,000								0%
	S-5	Abandon Well 4 and transfer water rights	\$ 25,000								0%
		Subtotal	\$ 50,000	\$ -	\$ 540,000	\$ 950,000	\$ 950,000	\$ 8,260,000	\$ -	\$ -	
Pump Station	P-1	Proposed 1,600 gpm Ladd Hill Pump Station to serve future 400 Brookman Zone customers							\$ 477,000		100%
	P-2	Proposed 2,400 gpm Kruger Pump Station to serve future 630 Zone customers								\$ 2,547,000	100%
	P-3	Proposed 1,600 gpm Edy Road Pump Station to serve future 475 Zone customers								\$ 1,505,000	100%
		Subtotal	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 477,000	\$ 4,052,000	
Water Main	M-1	Fire flow capacity -Sherwood Senior Center		\$ 36,000							0%
	M-2	Fire flow capacity - Norton Ave			\$ 92,000						0%
	M-60	Fire flow capacity - June Court				\$ 43,000					0%
	M-7	Expansion to Brookman -		\$ 68,000							100%
	M-8	Loop from prop SW			\$ 204,000						100%
	M-9	Sherwood PRV to Hwy 99			\$ 239,000						100%
	M-29	Expansion to TEA - Loop with existing Oregon Street mains			\$ 154,000						100%
	M-30				\$ 264,000						100%
	M-31				\$ 438,000						100%
	M-32					\$ 267,000					100%
	M-33					\$ 162,000					100%
	M-34					\$ 178,000					100%
	M-3, 4 & 5	10-Year (2024) - upgrade existing mains						\$ 300,000			56%
	M-6, 10 to 19B, 35 to 37, 40 to 42	10-Year (2024)						\$ 5,275,000			100%
M-20 to 28, 43 to 45	20-Year (2034)							\$ 3,295,000		100%	
M-38, 39, 46 to 59	Beyond 20 years								\$ 7,183,000	100%	
	Routine Pipe Replacement Program	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 250,000	\$ 500,000	\$50K annually	57%	
	Subtotal	\$ 50,000	\$ 154,000	\$ 739,000	\$ 795,000	\$ 657,000	\$ 5,825,000	\$ 3,795,000	\$ 7,183,000		
PRV	V-1	SW Sherwood PRV			\$ 150,000						100%
	V-2	Handley PRV						\$ 150,000			100%
	V-3	Haide PRV							\$ 150,000		100%
	V-4	195th PRV							\$ 150,000		100%
		Subtotal	\$ -	\$ -	\$ 150,000	\$ -	\$ -	\$ 150,000	\$ -	\$ 300,000	
Other		Upgrade SCADA System		\$ 75,000							35%
		Subtotal	\$ -	\$ 75,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	
Planning		Update Water Master Plan						\$ 150,000	\$ 150,000		35%
		Update Water Management and Conservation Plan			\$ 150,000				\$ 150,000		35%
		Update Vulnerability Assessment						\$ 60,000	\$ 60,000		35%
		Resiliency Plan	\$ 150,000						\$ 150,000		35%
		Subtotal	\$ 150,000	\$ -	\$ 150,000	\$ -	\$ -	\$ 210,000	\$ 510,000	\$ -	
Capital Improvement Program (CIP) Total			\$ 250,000	\$ 229,000	\$ 1,579,000	\$ 1,745,000	\$ 1,607,000	\$ 14,445,000	\$ 4,782,000	\$ 11,535,000	\$ 36,172,000

Annual Average CIP Cost		
\$1,082,000	\$1,985,500	\$1,231,850
over 5 years	over 10 years	over 20 years

DRAFT

SECTION 1 INTRODUCTION AND EXISTING WATER SYSTEM

Introduction

The purpose of this Water System Master Plan Update is to perform an analysis of the City of Sherwood's (City's) water system and:


- Document water system upgrades, including significant changes in water supply completed since the 2005 Master Plan
- Estimate future water requirements including potential water system expansion areas
- Identify deficiencies and recommend water facility improvements that correct deficiencies and provide for growth
- Update the City's capital improvement program (CIP)
- Evaluate the City's existing water rates and system development charges (SDCs)

In order to identify system deficiencies, existing water infrastructure inventoried in this section will be assessed based on estimated existing and future water needs developed in Section 2 and water system performance criteria described in Section 3. The results of this analysis are presented in Section 4. Section 5 identifies improvement projects to mitigate existing and projected future deficiencies and provide for system expansion including a prioritized CIP. Section 6 presents the water system financial analysis including an assessment of the City's current water rates and SDCs. The planning and analysis efforts presented in this Master Plan Update are intended to provide the City with the information needed to inform long-term water infrastructure decisions.

This plan complies with water system master planning requirements established under Oregon Administrative Rules (OAR) for Public Water Systems, Chapter 333, Division 61.

Study Area


The City's current water service area includes all areas within the current city limits. The study area of this planning effort includes the current city limits, the Tonquin Employment Area (TEA), Brookman Annexation area, the West Urban Reserve and a portion of the Tonquin Urban Reserve. The TEA and Brookman Annexation are within the City's existing Urban Growth Boundary (UGB). Some development in the West and Tonquin Urban Reserves is considered in the future water system analysis in order to provide for anticipated long-term growth. Future jurisdiction of the Tonquin Urban Reserve area is divided between the City of Sherwood and the City of Tualatin with Sherwood serving customers west of SW 124th Avenue. The study area is illustrated in Figure 1-1.



G:\PDX_P\GIS\131508\GIS\MXD\13-1508_FIGURE 1-1.mxd 1/22/2015 1:58:56 PM DKH



Sherwood Water System Master Plan Update



**Figure 1-1
Study Area**

Water System Background

The City owns and operates a public water system that supplies potable water to all residents, businesses and public institutions within the city limits. This section describes the water service area and inventories the City's water system facilities including existing supply sources, pressure zones, finished-water storage reservoirs, pump stations and distribution system piping.

Plate 1 in Appendix A illustrates the City's water system service area limits, water system facilities and distribution system piping. The water system schematic in Figure 1-2 at the end of this section shows the existing configuration of water system facilities and pressure zones.

Supply Facilities

The City draws the majority of its water supply from the Willamette River Water Treatment Plant (WRWTP) in the City of Wilsonville, approximately 6 miles southeast of Sherwood. Sherwood maintains four wells within the city limits for back-up supply. Prior to 2011, the City also purchased water from the Portland Water Bureau (PWB) through the City of Tualatin's water system.

Willamette River Water Treatment Plant

The Willamette River Water Treatment Plant (WRWTP) in the City of Wilsonville began operating in 2002 using conventional filtration to treat up to 15 million gallons per day (mgd) of Willamette River water for municipal consumption. The facility was developed and funded by Wilsonville and the Tualatin Valley Water District (TVWD). In December 2006, Sherwood purchased 5 mgd of the WRWTP's capacity from TVWD. The plant is currently operated and maintained under contract by Veolia Water, a private contractor.

WRWTP Transmission to Sherwood

Water is supplied from the WRWTP to Sherwood's Sunset Reservoirs through approximately 6.3 miles of 63-inch and 48-inch diameter welded steel pipe. Some segments of the transmission main currently serve both Sherwood and Wilsonville customers with pipe oversizing to accommodate future WTP expansion. Intergovernmental agreements (IGAs) between Sherwood, Wilsonville and TVWD define the capacity in each shared pipe segment that is available to each water provider. Transmission main segment descriptions, lengths, sizes and capacities are summarized in Table 1-1.

**Table 1-1
WRWTP-Sherwood Transmission Main**

Pipe Segment	From	To	Length (LF)	Dia (in)	Capacity	
					IGA Total (mgd)	Sherwood Share
1	Willamette River WTP	Kinsman Road at Wilsonville Road	4,300	63	70	5 mgd
2	Kinsman Road at Wilsonville Road	Kinsman Road at Barber Road	2,537	48	40	1/2
3A	Kinsman Road at Barber Road	180 feet north of Segment 2	180	48	40	1/2
3B	Segment 3A	Boeckman Road at Kinsman Road	2,400	48	40	1/2
4	Boeckman Road at Kinsman Road	Tooze Road at 110th Avenue	4,185	48	30	2/3
5A	Tooze Road at 110th Avenue	400 feet west of Tooze Road & Grahams Ferry Road	1,461	48	30	2/3
5B	Segment 5A	Revenue Meter Vault (Tooze Road)	198	48	40	1/2
6 thru 9	Revenue Meter Vault (Tooze Road)	Sherwood Sunset Reservoirs	18,000	48		All

Groundwater Wells

Sherwood operates four groundwater wells for back-up supply within the City's water service area. Well Nos. 3, 4, 5 and 6 have a combined production capacity of approximately 3.3 mgd. Liquid sodium hypochlorite is added at each well for disinfection.

Although the wells are currently used for back-up supply only, they are exercised regularly and supplied approximately 6 percent of the City's annual demand in 2013 while Segment 3B of the WRWTP transmission main was completed. City wells are summarized in Table 1-2.

**Table 1-2
Groundwater Well Summary**

Well No.	Location	Pump Type	Hp	Year Constructed	Production Capacity (gpm)	Approx. Depth (feet)	Casing Dia. (inches)
3	Intersection of Pine and Willamette Street	Vertical Line Shaft Turbine	75	1946	890	319	12
4	17191 Smith Road	Vertical Line Shaft Turbine	60	1969	250	458	14
5	16491 Sunset Boulevard	Vertical Line Shaft Turbine	150	1984	600	800	16
6	1830 Roy Street	Vertical Line Shaft Turbine	75	1997	550 ¹	889	16
Total Production Capacity (gpm):					2,290		
(mgd):					3.3		

¹ Production capacity is limited to 550 gpm by available water rights.

Tualatin Emergency Intertie

Sherwood maintains an emergency connection with the City of Tualatin through an approximately 4-mile long, 24-inch diameter Sherwood-owned transmission main. This transmission main begins at the Tualatin Community Park where the Tualatin-Portland supply main connects to the City of Tualatin's distribution system. A pressure reducing valve (PRV) at this connection reduces the hydraulic grade to approximately 385 feet of head for the City of Sherwood.

Prior to 2011 when Sherwood began drawing water from the WRWTP, Sherwood purchased water from the Portland Water Bureau, under an agreement with the City of Tualatin and TVWD, through this 24-inch main. Currently, the City receives a small amount of supply from Tualatin through this main under normal operating conditions to maintain water quality in the main for use in a water emergency.

Pressure Zones

The City's existing distribution system is divided into three major pressure zones. Pressure zone boundaries are defined by ground topography in order to maintain service pressures within an acceptable range for all customers in the zone. The hydraulic grade line (HGL) of a zone is designated by overflow elevations of water storage facilities, discharge pressure of pump stations, or outlet settings of pressure reducing valves (PRVs) serving the zone. Existing pressure zone HGLs, approximate service elevation ranges and related facilities are summarized in Table 1-3. Water system facilities serving each pressure zone are illustrated on Figure 1-2 at the end of this section.

The majority of Sherwood customers are served from the 380 Pressure Zone which is supplied by gravity from the City’s Sunset Reservoirs. The 380 Zone can also be served by gravity from the WRWTP, the City’s groundwater wells and the Tualatin emergency supply connection. The 535 Pressure Zone, serving the area around the Sunset Reservoirs, is supplied constant pressure by the Sunset Pump Station. The Murdock sub-zone, with an HGL of 400 feet, is served through a PRV from the 535 Zone. The 455 Pressure Zone serves higher elevation customers on the western edge of the City. This zone is served by gravity from the Kruger Reservoir which is filled by pumping out of the 380 Zone at the Wyndham Ridge Pump Station.

Storage Reservoirs

Sherwood’s water system has three reservoirs with a total combined storage capacity of approximately 9.0 million gallons (MG). Table 1-3 presents a summary of the City’s existing storage reservoirs.

**Table 1-3
Reservoir Summary**

Reservoir	Location	Capacity (MG)	Overflow Elevation (ft)	Pressure Zone Served
Sunset No. 1	Snyder Park	2.0	380	380
Sunset No. 2	Snyder Park	4.0	383.5	380
Kruger Road	SW Kruger Road west of Highway 99W	3.0	455	455

Sunset Reservoirs

Sherwood’s Sunset Reservoirs provide gravity service to the City’s largest pressure zone, 380. Both Reservoirs are located at the north end of Snyder Park near the intersection of SW Division and Pine Streets. The 2.0 MG Sunset Reservoir No. 1 is a 105-foot diameter circular, partially buried, cast in place, prestressed concrete reservoir constructed in 1972. Reservoir No. 1 was seismically upgraded in 2005 with more extensive seismic structural improvements, drainage improvements and re-coating completed in 2012. The 4.0 MG Sunset Reservoir No. 2 was constructed in 2009 adjacent to Sunset Reservoir No. 1. Sunset No. 2 is a 155-foot diameter circular, partially buried, cast in place, prestressed concrete reservoir.

Both reservoirs are supplied from the WRWTP through the Sherwood transmission main which terminates at the reservoir site. The reservoirs provide suction supply to the Sunset Pump Station which provides constant pressure service to the 535 Zone. Site piping at

Snyder Park is configured such that either or both reservoirs may be taken out of service for maintenance.

Kruger Road Reservoir

The 3.0 MG Kruger Road Reservoir was constructed in 2002 and is located approximately one-half mile west of Highway 99W, outside of the UGB on the west side of Sherwood. Kruger Road Reservoir is a 130-foot diameter circular, partially buried, cast in place, prestressed concrete reservoir. The reservoir is supplied water from the Wyndham Ridge Pump Station and serves the 455 Pressure Zone by gravity.

Pump Stations

Sherwood’s water system includes two booster pump stations, the Sunset Pump Station and the Wyndham Ridge Pump Station. Table 1-4 summarizes the City’s existing pump stations.

**Table 1-4
Pump Station Summary**

Pump Station	Pump No.	Horsepower (Hp)	Capacity (gpm)	Serves
Sunset	1	7.5	120	Constant Pressure to 535 Zone and Murdock Sub-Zone
	2	20	325	
	3	20	325	
	4	100	1500	
	5	100	1500	
Wyndham Ridge	1	40	600	Kruger Road Reservoir and 455 Zone
	2	40	600	
	3	10	N/A ¹	
	4	10	N/A ¹	

¹ Pumps are not used to supply the Kruger Road Reservoir under normal operating conditions.

Sunset Pump Station

The Sunset Pump Station is located in Snyder Park adjacent to the Sunset Reservoir complex and houses five vertical turbine pumps with an approximate total capacity of 3,770 gallons per minute (gpm). This station provides constant pressure service and fire flow to the 535 Pressure Zone and the PRV controlled Murdock sub-zone. Site piping at Snyder Park is configured such that suction supply to the station can be provided from either the Sunset Reservoirs or the 380 Zone distribution piping. Sunset Pump Station is equipped with variable frequency drives (VFDs) to meet instantaneous demands and improve operating

efficiency. Back-up power and redundant high capacity pumps capable of supplying adequate fire flow provide resilient operation for this continuously operating station.

Wyndham Ridge Pump Station

The Wyndham Ridge Pump Station is located on SW Handley Street west of Highway 99W and houses four close-coupled, end suction centrifugal pumps. Two 40-hp pumps supply water from 380 Zone distribution piping to the Kruger Road Reservoir. Each of these pumps has a capacity of approximately 600 gpm. Prior to the completion of the Kruger Road Reservoir in 2002, the Wyndham Ridge Pump Station provided constant pressure service to the 455 Zone at a lower HGL using a 5-hp and two 10-hp pumps. The required pumping head to deliver water to the Kruger Road Reservoir and the 455 Pressure Zone exceeds the operating range of these original pumps which are not currently used. The 5-hp pump was removed and the piping and valving reconfigured to allow supply from the 455 Zone to the 380 Zone.

In the event that the Kruger Road Reservoir is taken out of service, the pump station is capable of providing constant pressure service to the 455 Zone. The two 40-hp pumps are equipped with VFDs which will operate to maintain pressure and meet demands in the zone. The pump station is equipped with a 125 kilowatt generator for emergency back-up power.

Distribution System

The City's distribution system is composed of various pipe materials in sizes up to 24 inches in diameter. The total length of piping in the service area is approximately 77.4 miles. Pipe materials include cast iron, ductile iron, PVC and copper. The majority of the piping in the system is ductile iron. Table 1-5 presents a summary of pipe lengths by diameter.

**Table 1-5
Distribution System Pipe Summary**

Pipe Diameter	Approximate Length (miles)
4-inch or Less	0.7
6-inch	5.0
8-inch	37.2
10-inch	6.9
12-inch	14.0
14-inch	0.9
16-inch	1.8
18-inch	0.8
24-inch	4.3
Total Length	77.4

SCADA System

Sherwood’s supervisory control and data acquisition (SCADA) system monitors all storage reservoirs, pump stations and wells within the City’s water distribution system and provides for manual or automatic control of certain facilities and operations. The SCADA system also collects and stores system status and performance data.


All facilities are equipped with remote telemetry units (RTUs) that monitor reservoir water surface elevations, pump station on/off status and pump station flow rates. In addition, some sites are equipped with intrusion, overflow warning and fire alarms which alert staff to unauthorized access, flooding or fire.

All signals from the RTUs are collected and transmitted to the local operations center and to a Human-Machine Interface (HMI) located at the Public Works complex which enables City staff to view the status of the water system. The system is also capable of automatically dialing City officials 24 hours a day in the event that one of the alarms is triggered at any of the sites. Many of the City’s telemetry system facilities have recently been upgraded.

Summary

This section presents a summary of the City of Sherwood’s existing water system, including the transmission and supply system, emergency interties, pressure zones, storage and pumping facilities and distribution system piping.

G:\PDX_Projects\13\1508\CAD\13-1508-405-OR-FIG 1-2.dwg FIG 1-2 1/23/15 13:05



LEGEND

	EXISTING
PUMP DISCHARGE WATER MAIN	---
WATER MAIN	—
RESERVOIR (CAPACITY IN MG, OVERFLOW ELEVATION IN FEET)	1.0 MG OE=410'
GROUNDWATER WELL (PRODUCTION CAPACITY IN GPM)	
PRESSURE REDUCING VALVE	
PUMP STATION	
MASTER METER	
WATER TREATMENT PLANT	
DISTRIBUTION SYSTEM EMERGENCY INTERTIES

ABBREVIATIONS

GPM	GALLONS PER MINUTE
HGL	HYDRAULIC GRADE LINE
MG	MILLION GALLONS
MGD	MILLION GALLONS PER DAY
OE	OVERFLOW ELEVATION
PRV	PRESSURE REDUCING VALVE

FIGURE 1-2

Water System Master Plan Update
WATER SYSTEM SCHEMATIC

FEBRUARY 2015

13-1508

DRAFT

SECTION 2

LAND USE AND WATER REQUIREMENTS

This section presents existing and projected future water demands for the City of Sherwood's (City's) water service area. Demand forecasts are developed from current land use, buildable lands data and historical water consumption and production records.

Service Area

The existing water service area is the entire area within the existing city limits. The City's future water system planning area includes the current city limits, the Tonquin Employment Area (TEA), Brookman Annexation Area, West Urban Reserve and a portion of the Tonquin Urban Reserve. The TEA and Brookman Annexation Area are within the City's existing Urban Growth Boundary (UGB). Some development in the West and Tonquin Urban Reserves is considered in the future water system analysis in order to provide for anticipated long term growth. Future jurisdiction of the Tonquin Urban Reserve area is divided between the City of Sherwood and the City of Tualatin with Sherwood serving customers west of SW 124th Avenue.

Future water service expansion areas are divided between existing and proposed future pressure zones based on ground elevations and a service pressure range of 40 to 80 pounds per square inch (psi). Sherwood's existing and future service areas and pressure zones are illustrated on Figure 2-1 at the end of this section.

Planning Period

The planning period for this Water Master Plan Update is 20 years, through the year 2034. Some planning and facility sizing efforts within this plan will use estimates of water demands at saturation development. Saturation development occurs when all the vacant, developable land within the planning area has been developed to the maximum zoning density with some practical allowance for in-fill of existing developed properties. Typically, if substantial water system improvements are required beyond the 20-year planning period in order to accommodate water demands at saturation development, staging is recommended for facilities where incremental expansion is feasible and practical. Unless otherwise noted, recommended improvements identified in this plan are sized for saturation development.

Current Water Demand

Water demand refers to all water required by the system including residential, commercial, industrial and institutional uses. Demands are described using two water use metrics, average daily demand (ADD) and maximum day demand (MDD), in gallons per unit of time such as gallons per day (gpd) or million gallons per day (mgd). ADD is the total annual water volume used in the system divided by 365 days per year. MDD is the largest 24-hour

water volume for a given year. In western Oregon, MDD usually occurs each year between July 1st and September 30th. This timeframe is referred to as the peak season.

Water demand can be calculated using either water consumption or water production data. Water consumption data is taken from the City’s customer billing records which do not include unmetered water use such as system flushing and water loss. Water production is the total of all water entering the Sherwood water system including water purchased from the Willamette River Water Treatment Plant (WRWTP), water wheeled through Tualatin from the Portland Water Bureau and water produced at the City’s wells.

For the purposes of this Plan, water production data is used to calculate total water demand in order to account for unmetered water uses. Customer consumption and billing records are used to distribute demands throughout the Sherwood water system hydraulic model discussed in Section 4 and to estimate water demand distribution among the City’s pressure zones. The historical ratio of MDD:ADD is used to estimate future maximum day demands. Table 2-1 summarizes the City’s current system-wide water demand based on water production data.

**Table 2-1
Current Water Demand Summary**

Year	ADD (mgd)	MDD (mgd)	Ratio MDD:ADD
2012	1.85	3.85	2.1
2013	1.87	3.83	2.0
Average	1.86	3.84	2.1

Water Demand by Pressure Zone

As described in Section 1, water systems are divided into pressure zones in order to provide adequate service pressure to customers at different elevations. Each pressure zone is served by specific facilities, such as, reservoirs or pump stations and related piping which supply pressure to customers. In order to assess the sufficiency of these facilities, it is necessary to estimate demand in each pressure zone. Current water demand based on water production data, as shown in Table 2-1 is distributed between the City’s pressure zones based on metered water consumption from utility billing records. Current water demand by pressure zone is summarized in Table 2-2.

**Table 2-2
Current Water Demand by Pressure Zone**


Pressure Zone	ADD (mgd)	MDD (mgd)
380	1.45	2.97
400	0.04	0.07
455	0.18	0.38
535	0.19	0.42
Total	1.86	3.84

Water Consumption by Customer Class

Current water consumption by service type or customer class from the City’s billing records is used to correlate water demand to land use type for future demand projections. The City’s water utility billing records maintain five service types, Residential, MultiFamily, Commercial, Irrigation and Fireline. Fireline meters are used only in an emergency and are not included in this consumption analysis.

Sherwood’s irrigation consumption serves both residential and non-residential properties. It is important to include irrigation use in estimates of future water consumption for properties that are not yet developed. In order to estimate the water need for each customer class including irrigation use, the current annual irrigation demand is distributed to the other three customer classes, Residential, MultiFamily and Commercial, proportional to their share of total annual metered consumption. Current water consumption by customer class is based on a 2-year average of City water billing data from 2012 and 2013. Current water consumption by customer class, including irrigation use, is illustrated in Figure 2-2.

**Figure 2-2
Current Annual Water Consumption by Customer Class**



Commercial Water Demand per Acre

Commercial demand per acre is used to estimate long term future water demands in areas without detailed planning information, such as, the Tonquin and West Urban Reserves and for infill development within the city limits. Current average daily commercial water demand per acre is estimated by associating commercial water consumption to developed commercial and light industrial acreage within the city limits and TEA. Developed commercial acreage is estimated using the City's buildable lands geographic information systems (GIS) data general zoning categories. Estimated commercial average daily water demand is 437 gpd per acre.

Water Demand per Residential Unit

Growth projections developed for the City through previous planning efforts identify the number of future residential units (RUs) anticipated within an area to be developed. In order to forecast future water demands using these estimated future RUs, an average daily water demand (ADD) per RU is established from current water billing data.

ADD per residential unit is calculated as the total annual consumption by single-family residential customers divided by the total number of single-family residential service connections. As previously discussed, the City has a significant number of irrigation meters. Consumption from irrigation meters is distributed to all other customer classes proportional to their annual water use as illustrated in Figure 2-2. Current ADD per RU including irrigation use is approximately 213 gallons per day (gpd/RU) as summarized in Table 2-3. For the purposes of this analysis, ADD per residential unit is anticipated to remain constant in the future.

**Table 2-3
ADD per Residential Unit**

Annual Water Consumption (gallons)	Residential	370,287,850
	Residential Portion (72.6%) of Irrigation Consumption	43,465,166
	Residential Total	413,753,016
Residential Consumption ADD		1,133,570
No. of Residential Services		5,322
ADD per RU (gpd/RU)		213

Future Water Demand Projections

Approach

The City's future water service area, illustrated on Figure 2-1, is comprised of five different planning areas:

1. Sherwood city limits
2. Tonquin Employment Area (TEA)
3. Brookman Annexation Area
4. West Urban Reserve
5. Tonquin Urban Reserve

Each of these areas has their own land use characteristics, approximate development timelines and existing planning information. Estimates of future growth and related water demand are developed using the best available information for each area including Sherwood buildable lands geographic information system (GIS) data, population growth projections, development area concept plans and current water demand data. The buildable lands GIS includes a calculated number of new units for each residentially zoned property and a net acreage for each non-residential property. Each of these values take into account the property's current zoning and development restrictions such as floodplain overlays.

Water demand growth is projected at 10 years, 20 years and at saturation development. Estimated water demands at saturation development are used to size recommended transmission and distribution improvements. Future MDD is projected from estimated future ADD based on the current average ratio of MDD:ADD, also referred to as a peaking factor. From current water demand data shown in Table 2-1, the MDD:ADD peaking factor for the Sherwood system is approximately 2.1.

Forecasted demands are allocated to existing and proposed future pressure zones based on the ground elevations in water service expansion areas and a service pressure range of 40 to 80 pounds per square inch (psi). Existing and proposed pressure zone boundaries for the study area are illustrated on Figure 2-1 and Plate 1 in Appendix A. Future demand projections by pressure zone are summarized in Tables 2-7 and 2-8 at the end of this section.

Sherwood City Limits

Residential services account for the majority of water demand in the City of Sherwood, thus, an estimated annual average population growth rate is used as an indicator of growth in water demand within the current city limits. The regional government Metro projects saturation development will occur within the existing Sherwood city limits in the next 10 years. According to annual population estimates developed for all Oregon cities by the Portland State University Population Research Center (PRC), recent population growth within the Sherwood city limits has occurred at an average rate of less than 0.3 percent annually.

Based on proposed subdivisions and planned unit developments (PUDs) approved by the City in 2012 and 2013, it is assumed that residential growth within the city limits will be slightly accelerated for the next 3 to 5 years as these housing developments are completed. For this analysis, future population growth within the city limits is estimated based on an annual average growth rate of approximately 1.25 percent through 2019 and 0.15 percent after 2019 to saturation development in approximately 2024.

Tonquin Employment Area (TEA)

Growth in the TEA is estimated based on the September 2010 *Tonquin Employment Area Preferred Concept Plan Report* Table IV-1: TEA 20-Year Employment Forecast. This table develops estimates of job density per acre for four sub-areas within the TEA. For the Water Master Plan analysis, it is assumed the TEA will begin developing in sub-areas A and B1 within 5 years and in sub-areas B2 and B3 within 10 years. Development in the TEA is assumed to follow a linear growth pattern based on 20-year development percentages established in Table IV-1 of the *TEA Concept Plan*. For example, the 96.8 acres of light industrial buildable land in sub-area A is anticipated to be 70 percent developed in 20 years. Using a linear growth pattern, light industrial land in sub-area A will be 35 percent developed in 10 years and approximately 17 percent developed within 5 years. Total jobs within the TEA at saturation development (buildout) are also established in Table IV-1.

Future water demand projections in the TEA are based on water use per employee of 45 gallons per day (gpd) for mixed use commercial, office and light industrial development as presented in the *TEA Concept Plan*. This water demand estimate assumes there will be no process water uses in future TEA developments. Growth projections and future water demand estimates for the TEA are summarized in Table 2-4.

**Table 2-4
TEA Projected Growth and Future Water Demand**

Growth Projection	TEA Sub Area	Total Developed Acres	Total Jobs	ADD (mgd)
5-Year (2019)	A, B1	31.0	490	0.03
10-Year (2024)	All	74.9	1,160	0.05
20-Year (2034)	All	147.0	2,290	0.11
Saturation Development	All	235.2	3,520	0.16

Brookman Annexation Area

Growth projections in the Brookman Annexation Area are developed based on the 2009 *Brookman Addition Concept Plan Final Report* and the City's buildable lands GIS data. The concept plan identifies areas for residential, commercial, office and light industrial development within the Brookman Annexation Area. Table 1 Land Use Metrics from the *Brookman Concept Plan* presents an estimated density and total number of jobs within the Brookman Annexation Area at saturation development. The City's buildable lands GIS data for the Brookman area includes an estimated number of residential units at saturation development. Due to the small amount of developable residential land within the existing city limits and the exclusively non-residential, primarily industrial development anticipated within the TEA, it is assumed that the Brookman Annexation Area will reach saturation development within the 20-year planning horizon.

It is assumed that the Brookman Annexation Area will begin developing in five years with an initial 80 households and 300 jobs. The initial number of households is based on existing housing unit counts in the area from the 2010 Census and two new residential developments of 30 to 40 homes. Approximately eight acres of non-residential development would yield 300 jobs based on the density of 35.83 jobs/acre presented in the *Brookman Concept Plan* Table 1. Growth projections at 10 years are based on a linear growth pattern from initial development at five years to saturation at 20 years.

Average daily water demands for future residential development are estimated based an ADD/RU of 213 gpd/RU. Commercial, office and light industrial average daily water demands within the Brookman Annexation Area are based on an average water use per employee of 45 gpd consistent with the *TEA Concept Plan* for these same land uses. All Brookman Annexation Area growth through 2024 is assumed to occur only in the 380 Pressure Zone. Growth projections and future water demand estimates for the Brookman Annexation Area are summarized in Table 2-5.

**Table 2-5
Brookman Projected Growth and Future Water Demand**

Growth Projection	Non-Residential Developed Acres	Total Jobs	Residential Units	ADD (mgd)
5-Year (2019)	8.4	300	80	0.04
10-Year (2024)	18.6	665	596	0.16
20-Year (2034)	28.7	1,029	1,112	0.28
Saturation Development	28.7	1,029	1,112	0.28

West Urban Reserve

For the purposes of this analysis, future land use within the West Urban Reserve is assumed to mirror the proportion of land use types among developed properties within the current city limits. The proposed 630 West Zone within the West Urban Reserve, as shown on Figure 2-1, is not anticipated to have any industrial development. Percentages of future land use by type have been adjusted to exclude industrial development in this area. 20 percent of land within the West Urban Reserve is assumed to be dedicated to right-of-way, parks and open space with no future water demand.

Due to the small amount of developable residential land within the existing city limits, the exclusively non-residential development anticipated within the TEA, and the assumed build-out of the Brookman Annexation Area, it is assumed that the West Urban Reserve will be approximately one-quarter developed within the 20-year planning horizon. It is assumed that the West Urban Reserve will begin developing in 10 years with an initial 20 acres of non-residential development and 100 residential units. Long term residential development in the West Urban Reserve is anticipated to occur at approximately 10 units per acre based on discussion with City planning staff.

Future water demand in the West Urban Reserve is based on 213 gpd/RU and 437 gpd/acre for non-residential land as developed previously in this section. The West Urban Reserve will be served from the existing 380 and 455 Pressure Zones and proposed 475 West and 630 West Pressure Zones. Initial growth in the West Urban Reserve is assumed to occur only in the 380 Pressure Zone north of SW Handley Street. Growth projections and future water demand estimates for the West Urban Reserve are summarized in Table 2-6.

**Table 2-6
West Urban Reserve Projected Growth and Future Water Demand**

Growth Projection	Total Residential Units	Developed Non-Residential Acres	ADD (mgd)
10-Year (2024)	150	20	0.05
20-Year (2034)	1,849	93.8	0.44
Saturation Development	7,395	281.5	1.70


Tonquin Urban Reserve

The Tonquin Urban Reserve is not anticipated to begin development until the end of the 20-year planning horizon. Future land use within the Tonquin Urban Reserve is anticipated to be entirely industrial and commercial, based on conversations with City planning staff. Future water demands are forecast based on 437 gpd/acre as previously presented. The Tonquin Urban Reserve will be served from the existing 380 Pressure Zone.

Equivalent Residential Units (ERUs)

Sherwood's water system serves single-family residential customers as well as commercial customers and multifamily housing developments. Single-family residential water services generally have a consistent daily and seasonal pattern of water use or demand. Water demands for multifamily residences, commercial and industrial users may vary from service to service depending on the number of multifamily units per service or the type of commercial enterprise. In order to establish a common measure of water demand growth for all service types, the water needs of non-residential and multi-family residential customers are represented by comparing their water use volume to the average single-family residential unit. The number of single-family residential units that could be served by the water demand of these other types of customers is referred to as a number of "equivalent residential units" (ERUs).


ERUs differ from actual metered service connections in that they relate all water services to an equivalent number of representative single-family residential services based on typical annual consumption. ERUs calculated here are specific to estimating future water demand and are not the same as dwelling units used in housing studies or comprehensive planning to forecast future population. Demand per ERU in the Sherwood system is 213 gpd/ERU. ERUs are used in the water system financial analysis to distribute anticipated project costs between existing customers and water system growth.



G:\PDX_P\Projects\131508\GIS\MXD\13-1508_FIGURE 2-1.mxd 1/22/2015 2:00:00 PM DKH



Sherwood Water System Master Plan Update



**Figure 2-1
Existing and Future
Pressure Zones**

**Table 2-7
Future Water Demand Summary**

Pressure Zone	Current			10-Year (2024)			20-Year (2034)			Saturation Development		
	ERUs	ADD (mgd)	MDD (mgd)	ERUs	ADD (mgd)	MDD (mgd)	ERUs	ADD (mgd)	MDD (mgd)	ERUs	ADD (mgd)	MDD (mgd)
City Limits	8,779	1.87	3.93	9,536	2.03	4.26	9,536	2.03	4.26	9,536	2.03	4.26
380	6,857	1.47	3.09	7,447	1.59	3.34	7,447	1.59	3.34	7,447	1.59	3.34
400	149	0.03	0.06	162	0.03	0.06	162	0.03	0.06	162	0.03	0.06
455	816	0.17	0.36	887	0.19	0.40	887	0.19	0.40	887	0.19	0.40
535	957	0.20	0.42	1,039	0.22	0.46	1,039	0.22	0.46	1,039	0.22	0.46
Tonquin Employment Area (TEA)				238	0.05	0.11	484	0.11	0.23	744	0.16	0.34
380	-	-	-	238	0.05	0.11	484	0.11	0.23	744	0.16	0.34
Brookman Annexation				752	0.16	0.34	1,330	0.28	0.59	1,330	0.28	0.59
380	-	-	-	752	0.16	0.34	1,275	0.27	0.57	1,275	0.27	0.57
400 Brookman	-	-	-	-	-	-	55	0.01	0.02	55	0.01	0.02
West Urban Reserve				235	0.05	0.11	2,066	0.43	0.90	7,974	1.70	3.57
380	-	-	-	235	0.05	0.11	1,138	0.24	0.50	4,391	0.94	1.97
455	-	-	-	-	-	-	432	0.09	0.19	1,670	0.36	0.76
475 West	-	-	-	-	-	-	52	0.01	0.02	202	0.04	0.08
630 West	-	-	-	-	-	-	444	0.09	0.19	1,711	0.36	0.76
Tonquin Urban Reserve										591	0.13	0.27
380	-	-	-	-	-	-	-	-	-	591	0.13	0.27
GRAND TOTAL	8,779	1.9	3.9	10,761	2.3	4.8	13,416	2.9	6.0	20,175	4.3	9.0

**Table 2-8
Future Water Demand Summary by Pressure Zone**

Pressure Zone	10-Year (2024)			20-Year (2034)			Saturation Development		
	ERUs	ADD (mgd)	MDD (mgd)	ERUs	ADD (mgd)	MDD (mgd)	ERUs	ADD (mgd)	MDD (mgd)
380	8,672	1.85	3.90	10,344	2.21	4.64	14,448	3.09	6.49
400	162	0.03	0.06	162	0.03	0.06	162	0.03	0.06
455	887	0.19	0.40	1,319	0.28	0.59	2,557	0.55	1.16
475 West	-	-	-	52	0.01	0.02	202	0.04	0.08
535	1,039	0.22	0.46	1,039	0.22	0.46	1,039	0.22	0.46
400 Brookman	-	-	-	55	0.01	0.02	55	0.01	0.02
630 West	-	-	-	444	0.09	0.19	1,711	0.36	0.76

DRAFT

SECTION 3

PLANNING AND ANALYSIS CRITERIA

This section documents the performance criteria used for water system analysis presented in Section 4 of this Water System Master Plan. Criteria are established for evaluating water supply, distribution system piping, service pressures, storage and pumping capacity and fire flow availability. These criteria are used in conjunction with the water demand forecasts presented in Section 2 to complete the water system analysis.

Performance Criteria

The water distribution system should be capable of operating within certain performance limits under varying customer demand and operational conditions. The recommendations of this plan are based on the performance criteria summarized in Table 3-3. These criteria have been developed through a review of State requirements, American Water Works Association (AWWA) acceptable practice guidelines, *Ten States Standards* and the *Washington Water System Design Manual*.

Water Supply

As described in Section 1, the City of Sherwood (City) draws the majority of its water supply from the Willamette River Water Treatment Plant (WRWTP) in Wilsonville. Supplemental water supply can be provided from Sherwood Well Nos. 3, 4, 5 and 6. The City also has an emergency connection to the Portland Water Bureau's Washington County Supply Line through the City of Tualatin.

Based on current water system operations, the City should plan for adequate supply capacity to provide maximum day demand (MDD) from the WRWTP alone. As discussed later in this section, storage capacity in the City reservoirs and supplemental supply from City wells should provide adequate water in the event of a WRWTP supply or transmission emergency lasting less than 48 hours under average demand conditions.

Service Pressure

Water distribution systems are separated by ground elevation into pressure zones in order to provide service pressures within an acceptable range to all customers. Typically, water from a reservoir will serve customers by gravity within a specified range of ground elevations so as to maintain acceptable minimum and maximum water pressures at each individual service connection. When it is not feasible or practical to have a separate reservoir for each pressure zone, pump stations or pressure reducing valves (PRVs) are used to serve customers in different pressure zones from a single reservoir.

The maximum service pressure limit is 80 pounds per square inch (psi) as required by the *Oregon Plumbing Specialty Code*. The desired service pressure range under normal operating conditions is 40 to 70 psi. Conformance to this pressure range may not always be

possible or practical due to topographical relief, existing system configurations and economic considerations. Where mainline pressures exceed 100 psi, services must be equipped with individual PRVs to maintain their static pressures at no more than 80 psi. During a fire flow event or emergency, the minimum service pressure is 20 psi as required by Oregon Health Authority, Drinking Water Program (OHA) regulations. Recommended service pressure criteria are summarized in Table 3-1.

Distribution System Evaluation

The distribution system should also be capable of providing the required fire flow to a given location while, at the same time, supplying MDD and maintaining a minimum residual service pressure at any meter in the system of 20 psi as required by OHA regulations. The system should meet this criterion with all equalization storage depleted, booster pump stations operating at firm capacity and flow velocity in the distribution system of less than 10 feet per second (fps).

The distribution system should be capable of supplying peak hourly demands (PHD) while maintaining service pressures within approximately 85 percent of service pressures under average day demand (ADD) conditions but not less than the minimum 40 psi service pressure as shown in Table 3-1. The system should meet this criterion with booster pump stations operating at firm capacity and flow velocity in the distribution system of less than 10 fps.

**Table 3-1
Recommended Service Pressure Criteria**

Service Pressure Criterion	Pressure (psi)
Normal Range under ADD conditions	40-70
Maximum	80
Minimum under MDD conditions + Fire Flow	20
Minimum under PHD conditions	85% of normal, not less than 40 psi

Main Size

Typically, new water distribution mains should be at least 8 inches in diameter in order to supply minimum fire flows. According to the 2010 *Sherwood Engineering Design Manual*, a minimum 6-inch diameter main is required except 4-inch diameter mains are acceptable on runs less than 300 feet, if no fire hydrant connection is required, there are no more than 8 services on the main and future extension of the main is not anticipated. A 4-inch or 6-inch diameter main may be sufficient under these specific conditions; however, it is recommended that proposed or new water mains be at least 8 inches in diameter to supply adequate fire flows.

Storage Capacity

Sherwood water storage reservoirs should provide capacity for four purposes: operational storage, equalization storage, fire storage, and standby or emergency storage. A brief discussion of each storage element, as defined in the *Washington Water System Design Manual*, is provided below.

Adequate storage capacity must be provided for each pressure zone. Storage volume for pressure zones served through PRVs or by constant pressure pump stations is provided in the upstream pressure zone supplying the PRV or pump station. For instance, Sherwood's Sunset Reservoirs serve customers in the 380 Zone and provide suction supply to the constant pressure 535-Zone Sunset Pump Station which in turn supplies the 400 Zone through the Murdock PRV. Thus, the Sunset Reservoirs must have adequate storage volume to meet the storage criteria for the 380, 535 and 400 Zones.

Operational Storage

Operational storage is the volume of water dedicated to supplying customers while the pumps used to fill the reservoir are "off". Operational storage in the 455 Zone is defined by Kruger Reservoir level set points which signal the Wyndham Ridge pumps to turn on and off. The set points are discussed further in Section 4.

The 380 Zone reservoirs are continuously supplied from the WRWTP making operational storage irrelevant under normal operating conditions. For this analysis, required operational storage for the 380 Zone is assumed to be zero.

Equalization Storage

Equalization storage is required to meet water system demands in excess of delivery capacity from the water supply source to reservoirs serving each pressure zone. Equalization storage volume should be sufficient to supply demand fluctuations throughout the day resulting from typical customer water use patterns and is generally considered as the difference between PHD and MDD on a 24-hour basis.

For pressure zones with a continuously available supply like the 380 Zone's supply from the WRWTP, equalization storage of approximately 25 percent of MDD is sufficient for analysis and planning purposes.

In the 455 Zone, supply to the Kruger Reservoir is provided from only one source, the Wyndham Ridge Pump Station. For pressure zones with a single source of supply to the reservoir, equalization storage is calculated as PHD minus the source capacity operating for 150 minutes.

Fire Storage

Water stored for fire suppression is typically provided to meet the single most severe fire flow demand within each pressure zone. Required fire flow rates and durations based on the 2014 *Oregon Fire Code* (OFC) are discussed later in this section and summarized in Table 3-2. The recommended fire storage volume is determined by multiplying the fire flow rate by the duration of that flow.

Emergency (Standby) Storage

Emergency storage is provided to supply water from storage during emergencies such as pipeline failures, equipment failures, power outages or natural disasters. The amount of emergency storage provided can be highly variable depending upon an assessment of risk and the desired degree of system reliability.

According to standby storage guidelines from the *Washington Water System Design Manual*, water systems with multiple sources, like Sherwood's 380 Zone, should have sufficient storage to supply ADD for 48 hours with the largest source, the WRWTP, out of service. Standby storage for the 380 pressure zone is calculated as two times ADD minus the maximum operational capacity of the City wells operating for 24 hours but not less than 200 gallons per ERU. Standby storage for zones with a single source, like Sherwood's 455 Zone, is calculated as 2 times ADD but not less than 200 gallons per ERU.

Pump Stations

Capacity and Number of Pumps

Pumping capacity requirements vary depending on the water demand, volume of available storage and the number of pumping facilities serving a particular pressure zone. When pumping to storage reservoirs, also referred to as an "open zone", a firm pumping capacity equal to the pressure zone's MDD is recommended. Firm pumping capacity is defined as a station's pumping capacity with the largest pump out of service. A minimum of three pumps at each pump station are recommended for redundancy.

Constant Pressure Pump Stations

Although it is desirable to serve water system customers by gravity from storage, constructing and maintaining a reservoir for a small group of customers may be prohibitively expensive and lead to water quality issues associated with slow reservoir turnover. Constant pressure pump stations supply a pressure zone without the benefit of storage, also referred to as a closed zone. These stations are only recommended for residential developments with a small number of services, preferably in an area that will not be looped back into adjacent pressure zones in the future. Constant pressure stations are commonly used to serve customers at the highest elevations in a water service area where only an elevated reservoir would be capable of providing the necessary head to achieve adequate service pressures by gravity.

Pump stations supplying constant pressure service to closed zones should have firm pumping capacity to meet PHD while simultaneously supplying the largest fire flow demand in the zone.

Backup Power

It is recommended that pump stations supplying gravity storage reservoirs include manual transfer switches and connections for a portable back-up generator. The emergency storage volume in each reservoir will provide short term water service reliability in case of a power outage at the pump station. Back-up power generators with automatic transfer switches are recommended for all constant pressure pump stations serving closed zones without the benefit of gravity storage.

Required Fire Flow

While the water distribution system provides water for domestic uses, it is also expected to provide water for fire suppression. The amount of water required for fire suppression purposes is associated with the local building size and type or land use of a specific location within the distribution system. Fire flow requirements are typically much greater in magnitude than the MDD in any local area. Adequate hydraulic capacity must be provided for these potentially large fire flow demands. Emergency response in the City of Sherwood is provided by Tualatin Valley Fire and Rescue (TVFR). TVFR establishes fire flow requirements for each building within the City. General TVFR fire flow guidelines are described in the TVFR *Fire Code Applications Guideline* consistent with the 2014 OFC. Fire flow requirements by land use type based on these guidelines are summarized in Table 3-2.

Single-Family and Duplex Residential

The OFC and TVFR guidelines specify a minimum fire flow of 1,000 gpm for single-family and two-family dwellings with a square footage less than 3,600 square feet. For residential structures larger than 3,600 square feet, the minimum fire flow requirement is 1,500 gpm. Among currently developed single-family residential properties in the City, approximately 2 percent of homes are 3,600 square feet and larger, based on information available from the regional government Metro. For the purposes of this Plan, residential fire flow capacity will be tested in the water system hydraulic model with a minimum requirement of 1,500 gpm to accommodate the range of potential future residential development in the City.

Medium Density Residential, Office and Neighborhood Commercial

Existing medium density residential development, such as, the Cherry Woods Condominiums have an average building size of approximately 6,900 square feet with four dwellings per building. For the purposes of this Plan, it is assumed that future medium density residential development would involve buildings of similar size. Based on the 2014 OFC requirements adopted by TVFR, a required fire flow of 2,500 gpm is recommended for

medium density residential properties. Properties zoned for neighborhood commercial or office development are anticipated to require similar flows for fire suppression.

High Density Residential, Commercial, Industrial and Institutional

A 3,000 gpm fire flow is recommended for high density residential, commercial and industrial development in Sherwood consistent with TVFR maximum fire flow guidelines. This maximum fire flow requirement is also appropriate for institutional and public facilities, such as, schools or community centers. Fire flow requirements by land use type are summarized in Table 3-2.

**Table 3-2
Required Fire Flow Summary**

Land Use Type	Applicable Zoning	Required Fire Flow (gpm)	Required Duration (hours)
Single-Family and Duplex Residential	VLDR, LDR	1,500	2
Medium Density Residential, Office and Neighborhood Commercial	MDRL, MDRH, NC, OC	2,500	2
High Density Residential, Commercial, Industrial and Institutional	HDR, RC, GC, EI, LI, GI, IP	3,000	3

Summary

Table 3-3 provides a summary listing of the criteria presented in this Section.

**Table 3-3
Water System Performance Criteria**

Water System Facility	Evaluation Criterion	Value	Design Standard/Guideline
Water Supply	Supply Capacity	MDD ²	Ten States Standards and Washington Water System Design Manual
Service Pressure	Normal Range (ADD ¹ Conditions)	40-70 psi	AWWA M32
	Maximum	80 psi	AWWA M32, Oregon Plumbing Specialty Code, Section 608.2
	Minimum, during MDD ² with Fire Flow	20 psi	AWWA M32, OAR 333-061
	Minimum, during PHD ³	85% of normal, not less than 40 psi	MSA recommended, AWWA M32
Distribution Piping	Velocity during PHD ³ or Fire Flow	Not to exceed 10 fps	AWWA M32
	Minimum Pipe Diameter	8-inch recommended for fire flow, current City standard is 6-inch, except 4-inch for short mains without fire service	MSA recommended, Sherwood Engineering Design Manual
Storage	Total Storage Capacity	Sum of operational, equalization, fire suppression and emergency (standby) storage volumes	Washington Water System Design Manual
	Operational Storage	Kruger Res level set point for 455 Zone, none in 380 or closed ⁵ zones	
	Equalization Storage	25% of MDD ²	
	Fire Storage	Required fire flow x flow duration	
	Emergency (Standby) Storage	2 x [ADD ¹ – (all but largest supply to the zone x 24 hours)], not less than 200 gallons per ERU	
Pump Stations	Minimum No. of Pumps at Firm Capacity	2	Ten States Standards
	Open Zone Capacity ⁴	MDD ²	Washington Water System Design Manual
	Closed Zone Capacity ⁵	PHD ³ + Fire Flow	Washington Water System Design Manual
	Backup Power	At least two independent sources	Ten States Standards
Required Fire Flow and Duration	Single Family and Duplex Residential	1,500 gpm for 2 hours	2014 Oregon Fire Code, Tualatin Valley Fire & Rescue Fire Code Applications Guide
	Medium Density Residential, Office and Neighborhood Commercial	2,500 gpm for 2 hours	
	High Density Residential, Commercial, Industrial and Institutional	3,000 gpm for 3 hours	

¹ ADD: Average daily demand, defined as the average volume of water delivered to the system during a 24-hour period = total annual demand/365 days per year.

² MDD: Maximum day demand, defined as the maximum volume of water delivered to the system during any single day.

³ PHD: Peak hour demand, defined as the maximum volume of water delivered to the system during any single hour of the maximum demand day.

⁴ Open zone is defined as a pressure zone supplied by gravity from a storage reservoir.

⁵ Closed zone is defined as a pressure zone supplied constant pressure from a booster pump station without the benefit of storage.

DRAFT

SECTION 4

WATER SYSTEM ANALYSIS

This section presents an analysis of the City of Sherwood's (City's) water distribution system based on criteria outlined in Section 3. The water demand forecasts summarized in Section 2 are used in conjunction with analysis criteria to assess water system characteristics including supply capacity, service pressures, storage and pumping capacity and emergency fire flow availability. This section provides the basis for recommended distribution system improvements presented in Section 5.

Water Supply Analysis

In 2011 Sherwood transitioned their primary water source from the City's groundwater wells to the Willamette River Water Treatment Plant (WRWTP). The City is also able to draw Portland Water Bureau (PWB) supply through a 4-mile long, 24-inch diameter City-owned transmission main from the City of Tualatin's system. An agreement with Tualatin Valley Water District (TVWD) and the City of Tualatin allows Sherwood to purchase up to 3 million gallons per day (mgd) of TVWD's excess capacity in PWB's Washington County Supply Line (WCSL) system and wheel it through the City of Tualatin's transmission to the Tualatin Supply Connection. These agreements expire in 2015.

The City continues to maintain Wells 3, 4, 5 and 6 and the Tualatin Supply Connection. Currently, the City takes a small amount of PWB supply through the Tualatin Supply Connection to maintain drinking water quality in the pipeline for use in a water emergency.

WRWTP Capacity

It is recommended that Sherwood develop adequate source capacity to supply maximum day demand (MDD) from the WRWTP alone. Sherwood's 5 million gallons per day (mgd) share of the WRWTP's existing 15 mgd capacity is adequate to meet forecasted MDD, including projected service area expansion, through the 10-year (2024) planning horizon. It is recommended that the City purchase additional intake capacity and pursue WRWTP expansion within the 20-year planning horizon through existing cooperative agreements with TVWD and the City of Wilsonville. Based on projected MDD and service area expansion presented in Section 2, Sherwood will require a total capacity of approximately 9 mgd from the WRWTP at build out. Future expansion of the WRWTP capacity will likely be through construction of a parallel 15 mgd treatment train. Based on the strong potential for continued growth in Sherwood and anticipated long-term water system expansion into urban reserve areas it is recommended that the City pursue an additional 5 mgd of capacity from the WRWTP. The WRWTP capacity analysis is summarized in Table 4-1.

**Table 4-1
WRWTP Supply Capacity Analysis**

Timeframe	Capacity (mgd)		
	Recommended Supply Capacity (MDD)	Sherwood's Existing WRWTP Share	Surplus / (Deficit)
Current	3.9	5.0	1.1
10-Year (2024)	4.8	5.0	0.2
20-Year (2034)	6.0	5.0	(1.0)
Build-Out	9.0	5.0	(4.0)

Emergency Supply

In the event of a WRWTP supply or transmission emergency, it is recommended that the City’s groundwater wells and storage reservoirs be used to provide adequate emergency water supply to meet average day demands (ADD) for 48 hours.

City Wells

Wells 3, 5 and 6 have an existing combined operational capacity of approximately 1,790 gallons per minute (gpm) (2.6 mgd). Well 5 production capacity is limited to approximately 350 gpm due to foaming in the well caused by air entrainment at higher pumping rates. All of Sherwood’s wells are currently inactive. The City does not have a regular schedule for exercising the wells and monthly water quality samples are not currently required. In order to ensure that wells are available as an on-demand emergency source, water operations staff will begin exercising the wells and performing regular water quality testing. To accomplish this, the City must have a means of isolating the well discharge from the distribution system. There is an existing fire hydrant and isolation valve at Well 6 which allows the City to pump Well 6 to atmosphere. It is recommended that a new hydrant and isolation valve be installed at Wells 3 and 5 for this purpose.

The City has expressed interest in abandoning the low-producing Well 4 which would reduce well maintenance costs and potentially allow water rights to be transferred to other City wells which may have additional production capacity. Sherwood could attain additional value by allowing development of the Well 4 property after the well is abandoned. The well site is located in an established residential area along Smith Avenue and, as presented in Section 2, the City has limited developable land available within the existing city limits. For the purposes of this analysis, Well 4 capacity is not considered as an emergency source. Existing well capacities are summarized in Table 4-2.

**Table 4-2
Well Capacity Summary**

Well	Water Rights Capacity (gpm)	Production Capacity (gpm)
3	900	890
5	673	350
6	550	550
Total	2,123	1,790

It is not recommended that the City develop additional groundwater wells to meet the emergency supply goal of ADD for 48 hours. This emergency capacity should be provided from emergency storage in the City’s reservoirs and from the existing wells. Emergency supply goals and well capacity are summarized in Table 4-3.

**Table 4-3
Emergency Supply from City Wells**

Timeframe	Emergency Supply Goal: 2 * ADD (mgd)	City Well Production Capacity (mgd)	Deficit to be Supplied from Emergency Storage (mgd)¹
Current	3.8	2.6	(1.2)
10-Year (2024)	4.6	2.6	(2.0)
20-Year (2034)	5.8	2.6	(3.2)
Build-Out	8.6	2.6	(6.0)

¹ See Table 4-4 Storage Analysis

Tualatin Supply Connection

Under the City’s supply agreement with TVWD and Tualatin, excess capacity from the PWB wheeled through the WCSL system is interruptible, meaning capacity is only available to Sherwood under certain contractual conditions where surplus supply is available from PWB. Because of this contingent capacity the Tualatin Supply Connection is a less reliable on-demand emergency source than the City’s wells. It is not recommended that the City maintain the Tualatin Supply Connection solely as an on-demand emergency source. However, the 24-inch diameter main is a vital link to long-term regional supply and Sherwood may benefit from maintaining a portion of the 24-inch diameter supply line capacity for emergency supply. The remaining capacity could be sold to Tualatin as part of a future WRWTP supply agreement or to provide large diameter looping within Tualatin’s distribution system.

Potential Future Supply to Tualatin

The City of Tualatin, which currently receives all of its source water from the WCSL system, is in the process of evaluating their long-term source options and needs. If Tualatin opts to pursue source water from the WRWTP, they may negotiate purchase of plant capacity or wholesale water from Sherwood. The Sherwood-owned 24-inch diameter transmission main would be a key facility to allow supply of WRWTP water through Sherwood to Tualatin's distribution system. It is recommended that Sherwood does not abandon the Tualatin Supply Connection to allow for future supply of WRWTP water to Tualatin. However, the City of Tualatin's current supply agreement with PWB does not expire until 2026 so Tualatin may not make a final decision regarding their long-term water source for several years. It is recommended that Sherwood discontinue taking water through the Tualatin Supply Connection and close valves to isolate the transmission main. The transmission main would need to be disinfected before bringing it back on-line to serve the City of Tualatin if a long-term WRWTP supply agreement is established between the two cities in the future.

The 24-inch diameter Tualatin supply main may also be useful to the City of Tualatin as part of their distribution system regardless of Tualatin's long-term source decisions. Sherwood staff have engaged with Tualatin to determine the potential for mutual benefit of selling or transferring portions of the main.

Pressure Zone Analysis

Sherwood's four existing pressure zones provide adequate service pressures between 40 and 80 pounds per square inch (psi) to all water system customers. The existing 380 and 455 Pressure Zones are open zones, served by gravity from storage facilities. The 535 Zone serves the southeast corner of the City by constant pressure from the Sunset Pump Station. Zones served by constant pressure are also referred to as closed zones. Customers in the 400 Zone are supplied from the 535 Zone through the Murdock pressure reducing valve (PRV). The City's existing and proposed future pressure zones are illustrated on Figure 2-1.

Future 535 Zone Reservoir

The 535 and 400 Zones have approximately 810 existing services. For pressure zones of this size, it is preferable to supply customers by gravity from a storage reservoir rather than through a constant pressure pump station. Supplying customers from storage reduces the risk of a water outage due to mechanical or electrical failure at the pump station and reduces maintenance and power costs associated with pumping.

The City's 2005 Master Plan recommended construction of a storage reservoir to serve the 535 Zone by gravity. However, the nearest site which would meet the elevation requirements for a ground level reservoir is almost a mile south of existing 535 Zone distribution mains along Ladd Hill Road. With the approximately mile-long waterline required to fill the proposed reservoir and the relatively low customer demands in this residential zone, it is likely that water quality issues would develop in the waterline and

reservoir due to minimal water circulation and slow reservoir turnover. Due to potential water quality issues associated with a 535 Zone reservoir and the high cost of constructing a transmission main to serve the proposed reservoir, it is recommended that the 535 Zone continue to be served as a closed zone from the Sunset Pump Station.

Future Service Area Expansion

Brookman Annexation and TEA

As the City's water service area expands to include the Brookman Annexation and Tonquin Employment Area (TEA), it is anticipated that the majority of customers in these areas will be served from the 380 Zone by extending existing distribution mains. A small area along Ladd Hill Road in the southeast corner of the Brookman Annexation is too high in elevation to receive adequate service pressure from the 380 Zone. For master planning purposes, this area is referred to as the 400 Brookman Zone.

400 Brookman Zone

As development occurs, it is recommended that the City evaluate the benefits and risks of serving the 400 Brookman Zone through one of the following methods:

1. A PRV which reduces pressure from existing 535-Zone mains on Highpoint Drive east of Ladd Hill Road
2. A booster pump station which provides constant pressure to the zone and draws suction supply from existing 12-inch diameter 380-Zone distribution mains on Ladd Hill Road at Brookman Road

Although option 1, the PRV from the 535 Zone, seems to be the simplest solution there are additional factors which should be considered. Existing 535-Zone distribution mains on Highpoint Drive dead-end approximately 375 feet west of Ladd Hill Road. In order to provide service to the proposed 400 Brookman Zone, the existing 535-Zone mains would need to be extended or existing 380-Zone mains which already extend west to Ladd Hill Road along Highpoint Drive would need to be re-configured to be part of the 535-Zone.

Extending 535-Zone mains west to Ladd Hill Road may add substantial cost to the PRV solution. In addition, the existing Highpoint Drive right-of-way (R-O-W) does not connect with the Ladd Hill Road R-O-W. Thus, any new 535-Zone mains would need to be constructed within an existing 15-foot wide City of Sherwood easement parallel to existing 8-inch diameter 380-Zone mains. Existing 380-Zone mains provide service to 32 existing homes between 225 and 300-foot elevation along Bowmen Lane and Highpoint Drive. Re-configuring these mains to be part of the 535-Zone would cause significant pressure increases for these existing 32 customers and would likely require individual PRVs at each service. Both of these considerations may increase the project cost of option 1 significantly.

A constant pressure pump station, as described in option 2, requires more maintenance and has a higher operating cost than a PRV. However, capital costs for constructing the pump station may be comparable to option 1 because distribution mains upstream of the proposed pump station would not need to be constructed new or re-configured as described above for the PRV.

For the purposes of this Master Plan, an estimated cost for the booster pump station described in option 2 is included in the CIP presented in Section 5.

West Urban Reserve

Initial anticipated growth in the West Urban Reserve will be served by extending existing 380- and 455-Zone distribution mains. Future customers along the ridge north and south of the existing Kruger Reservoir will be served by constant pressure from the proposed Kruger Pump Station at the existing reservoir site. This proposed closed zone is referred to as the 630 West Zone. Some future customers in the West Urban Reserve at the interface between the 630 West and 455 Zones may need to be served through a PRV-controlled sub-zone or through individual PRVs on each service in order to maintain required service pressures. This area is referred to as the 630 West PRV Zone.

A small area on the western edge of the West Urban Reserve along Edy Road near Eastview Road is too high in elevation to receive adequate service pressure from the adjacent 380 Zone. This area will be served as part of the closed 475 West Zone by constant pressure from the proposed Edy Road Pump Station.

Storage Capacity Analysis

Existing storage reservoirs serve customers in the 380 and 455 Pressure Zones by gravity. All of the City's other existing and proposed pressure zones are supplied either through constant pressure pump stations or PRVs. There must be adequate reservoir volume to meet customer demands in the zone served directly from the reservoir, as well as any smaller zones served through constant pressure pumping or PRVs from the zones with storage. For instance, Sherwood's Sunset Reservoirs serve customers in the 380 Zone and provide suction supply to the constant pressure 535-Zone Sunset Pump Station which in turn supplies the 400 Zone through the Murdock PRV. Thus, the Sunset Reservoirs must have adequate storage volume to meet the storage criteria for the 380, 535 and 400 Zones.

Ideally, the 535 Zone, which supplies a relatively large geographic area, would have dedicated gravity storage. As previously described, due to the City's topography, sites with adequate elevation for a future 535-Zone reservoir are too far away from existing 535 Zone customers to be practical or cost effective.

Storage facilities are provided for four purposes: operational storage, equalization storage, fire storage and emergency or standby storage. As presented in Section 3, the total storage required is the sum of these four elements. Storage volumes are calculated according to the following criteria:

- *Operational Storage*
 - 455 Zone - volume of average Kruger Reservoir level drop between “off” and “on” operation of Wyndham Ridge Pump Station
 - 380 Zone and closed zones - none
- *Equalization Storage* - 25 percent of maximum day demand (MDD)
- *Fire Storage* - largest fire flow demand for each pressure zone multiplied by the duration of that flow
- *Emergency Storage* - 2 times average day demand (ADD) minus the approximate volume of water supplied in 24 hours by all but the largest capacity supply to the zone

Operational Storage

Operational storage is the volume of water dedicated to supplying customers while the pumps used to fill the reservoir are “off”. In the 455 Zone, operational storage is managed by City water staff using Kruger Reservoir level set points. These set points signal the Wyndham Ridge pumps to turn on and refill the reservoir when the water level drops to the specified point. Reservoir level set points are adjusted seasonally to mitigate potential water quality issues associated with slow reservoir turnover during periods of low water demand in the fall and winter. For the purpose of this analysis, operational storage in the 455 Zone will be estimated based on a year-round average drop in the Kruger Reservoir level of six feet, approximately 0.6 million gallons (MG).

The 380 Zone’s Sunset Reservoirs are continuously supplied from the WRWTP making operational storage irrelevant under normal operating conditions. For this analysis, required operational storage for all zones served by the Sunset Reservoirs is assumed to be zero.

Emergency Storage

The 380 Zone is supplied by both the WRWTP and the City’s wells. The WRWTP is the largest supply to the 380 Zone. Thus, emergency storage for the 380 Zone is calculated as 2 times ADD minus the volume of water supplied by City Wells 3, 5 and 6 pumping for 24 hours. The only supply to the 455 Zone is the Wyndham Ridge Pump Station. Although the pump station contains multiple pumps there are emergency situations, such as a break in the suction supply line to the pump station, which would take the entire station out of service.

Thus, for the purpose of calculating required emergency storage volume in the 455 Zone, it is assumed that the entire pump station is out of service.

Storage Analysis Findings

Both the Kruger and Sunset Reservoirs have adequate capacity to meet storage criteria through the 20-year planning horizon. An approximately 0.3 MG storage deficit in 455 Zone at build-out may be mitigated by modifying the Kruger Reservoir average water level drop from 6 feet to 3 feet to reduce the operational storage need. No significant operational challenges are anticipated with this change as increased future demands will reduce the need for this operational strategy to maintain water quality. Under existing conditions the Kruger Reservoir water level is set lower to allow the City to store water at Kruger that has been delivered from the WRWTP but is not immediately needed in the 380 Zone and to mitigate potential water quality issues associated with slow reservoir turnover at Kruger. Increasing water demands due to future growth in both the 380 and 455 Zone will lessen the need to drop the Kruger Reservoir to this lower existing set point.

Despite a 0.61 MG storage deficit at build-out, additional storage is not recommended for the 380 Zone due to the uncertainty of long-term future development over a large area to be served from this zone. Storage capacity in the 380 Zone should be re-evaluated with the next Master Plan update to determine if additional capacity will be needed and to identify the optimal sites for additional storage, if needed. The storage analysis is summarized in Table 4-4.

**Table 4-4
Storage Analysis**

Storage Component (MG)	Sunset Reservoirs			Kruger Reservoir		
	380, 535, 400, Future 400 Brookman & Future 475 West Pressure Zones			455 & Future 630 West Pressure Zones		
	Existing	2034	Build-Out	Existing	2034	Build-Out
Operational	-	-	-	0.60	0.60	0.60
Equalization	0.87	1.30	1.78	-	0.05	0.25
Fire Suppression	0.63	0.63	0.63	0.63	0.63	0.63
Emergency	1.58	2.38	4.20	0.36	0.74	1.82
TOTAL Required	3.07	4.31	6.61	1.59	2.01	3.30
Existing Storage	6.00	6.00	6.00	3.00	3.00	3.00
Surplus/(Deficit)	2.93	1.69	(0.61)	1.41	0.99	(0.30)

Pump Station Analysis

Closed Zones

The existing Sunset Pump Station and proposed Ladd Hill, Kruger and Edy Road Pump Stations supply constant pressure to customers in existing and future pressure zones without water storage facilities, also referred to as closed zones. Pump stations serving these closed zones are the only means of supplying domestic water demands and fire flow to the zone. Pump stations serving closed zones should have sufficient firm capacity to supply PHD and the highest required fire flow in the primary zone and any PRV-controlled sub-zones. Firm capacity is defined as the nominal pump station capacity with the largest pump out of service.

Open Zones (Supplied by Gravity Storage)

The Wyndham Ridge Pump Station supplies the Kruger Reservoir which serves customers in the 455 Zone by gravity. Pressure zones with the benefit of gravity storage are also referred to as open zones. Operational and fire storage provided by open zone reservoirs such as the Kruger Reservoir make it unnecessary to plan for fire flow or peak hour capacity from pump stations assuming adequate storage is available. Open zone pump stations such as the Wyndham Ridge Pump Station must have sufficient firm capacity to meet the MDD for all customers in the zone and any higher level zones supplied from the primary zone.

Back-Up Power

At least two independent power sources are recommended for the City's pump stations. Back-up power is particularly critical for facilities that serve closed zones through constant pressure pumping. It is recommended that pump stations supplying gravity storage reservoirs include, at a minimum, manual transfer switches and connections for a portable back-up generator. The emergency storage volume in each reservoir will provide short term water service reliability in case of a power outage at the pump station. On-site standby power generators with automatic transfer switches are recommended for all constant pressure pump stations serving closed zones without the benefit of gravity storage. Both of Sherwood's existing pump stations have on-site, diesel powered, backup generators with automatic transfer switches.

Pump Station Analysis Findings

Table 4-5 summarizes the City's existing and future pumping requirements. Existing pump stations have adequate firm capacity to supply customer demands through the 20-year planning period. There is a small firm capacity deficit in the 455 Zone at build-out which may be addressed by replacing one of the existing Wyndham Ridge pumps as development warrants.

Due to the uncertainty of long-term future development, it is recommended that 455 Zone pumping capacity needs beyond 2034 be re-evaluated with the next Master Plan Update. Additional constant pressure pump stations are recommended to supply future proposed pressure zones as development warrants.

**Table 4-5
Pump Station Analysis**

Pressure Zone	Pumping Criteria	Existing Pump Stations		Firm Pumping Capacity (gpm)					
				Existing		2034		Build-out	
		Name	Firm Capacity (gpm)	Required	Surplus / (Deficit)	Required	Surplus / (Deficit)	Required	Surplus / (Deficit)
535 & 400	PHD + FF	Sunset	2,270	2,078	-	2,114	-	2,114	-
455	MDD	Wyndham Ridge	600	264	-	410	-	806	206
Future 400 Brookman	PHD + FF					1,524	1,524	1,524	1,524
Future 630 West	PHD + FF					1,724	1,724	2,397	2,397
Future 475 West	PHD + FF					1,524	1,524	1,594	1,594

Distribution System Analysis

A steady-state hydraulic network analysis model was used to evaluate the performance of the City's existing distribution system and identify proposed piping improvements based on performance criteria described in Section 3. The purpose of the model is to determine pressure and flow relationships throughout the distribution system for average and peak water demands under existing and projected future conditions. Modeled pipes are shown as "links" between "nodes" which represent pipeline junctions or pipe size changes. Diameter, length and head loss coefficients are specified for each pipe and an approximate ground elevation is specified for each node.

The hydraulic model was developed prior to the Water System Master Plan using the InfoWater modeling software platform and geographic information system (GIS) base mapping. Building on the facilities identified in the prior model and updated facility and operations data provided by the City, analysis scenarios were created to evaluate existing and projected 20-year demand conditions.

Modeled Demands

Existing and projected future demands are summarized in Table 2-7. Within the existing city limits, demands are assigned to the model based on customer billing records and meter locations provided by the City. Future demands in water service expansion areas such as the Brookman Annexation, TEA and West Urban Reserve are assigned uniformly over each proposed pressure zone area shown in Figure 2-1.

Fire Flow Analysis

Fire flow scenarios test the distribution system's ability to provide required fire flows at a given location while simultaneously supplying MDD and maintaining a minimum residual service pressure of 20 psi at all services. Required fire flows are assigned based on the zoning surrounding each node as summarized in Table 3-2.

Since the 2005 Master Plan, the City has invested in large diameter loops through developing commercial areas and small projects to provide additional looping for fire flow in residential areas. As a result, very few fire flow deficiencies were identified under existing and projected future MDD conditions.

Peak Hour Demand Analysis

Distribution system pressures were evaluated under peak hour demand conditions to confirm identified piping improvements. Peak hour demands (PHD) were estimated as 1.7 times the maximum day demand. No additional deficiencies were identified under these conditions.

Summary

Section 4 presents an analysis of Sherwood's water supply capacity and distribution system performance. Criteria outlined in Section 3 and water demand forecasts summarized in Section 2 are used to assess water system characteristics including service pressures, storage and pumping capacity and emergency fire flow availability. Proposed facilities to mitigate deficiencies are discussed in Section 5 and illustrated on Plate 1 Water System Map in Appendix A.

Sherwood's supply from the WRWTP is sufficient to meet MDD through the 10-year planning horizon with an additional 1 mgd of capacity required at 20 years and an additional 4 mgd needed at build-out. Existing City groundwater wells provide an effective emergency supply to complement emergency storage in the City's reservoirs.

The City's distribution system has adequate storage and pumping capacity to meet existing service area demands through 2034. Due to significant uncertainty related to long-term growth and system expansion, minor storage and pumping deficiencies at build-out should be re-evaluated with the next Water Master Plan Update or as development warrants. Additional pump stations are recommended to serve proposed high-elevation closed pressure zones in the water service expansion areas Brookman Annexation and West Urban Reserve.

Sherwood's distribution piping is sufficiently looped to provide adequate fire flow capacity to commercial, industrial and residential customers. Few piping improvement projects are needed to meet fire flow criteria. Extensive large diameter mains will be needed to expand the City's water service area to supply the Brookman Annexation, TEA and West Urban Reserve as development occurs.

DRAFT

SECTION 5

RECOMMENDATIONS AND CAPITAL IMPROVEMENT PROGRAM (CIP)

This section presents recommended improvements for the City of Sherwood's (City's) water system based on the analysis and findings presented in Section 4. These improvements include proposed supply, pump station and water line projects. The capital improvement program (CIP) presented in Table 5-3 later in this section summarizes recommended improvements and provides an approximate schedule for project completion. Proposed distribution system improvements are illustrated on Plate 1 Water System Map in Appendix A and on Figure 5-1, Proposed Water System Schematic at the end of this section.

Cost Estimating Data

An estimated project cost has been developed for each improvement project recommended in this section. Cost estimates represent opinions of cost only, acknowledging that final costs of individual projects will vary depending on actual labor and material costs, market conditions for construction, regulatory factors, final project scope, project schedule and other factors. The Association for the Advancement of Cost Engineering International (AACE) classifies cost estimates depending on project definition, end usage and other factors. The cost estimates presented here are considered Class 4 with an end use being a study or feasibility evaluation and an expected accuracy range of -30 percent to +50 percent. As the project is better defined, the accuracy level of the estimates can be narrowed.

Estimated project costs are based upon recent experience with construction costs for similar work in Oregon and southwest Washington and assume improvements will be accomplished by private contractors. Estimated project costs include approximate construction costs and an aggregate 45 percent allowance for administrative, engineering and other project related costs. Estimates do not include the cost of property acquisition. Since construction costs change periodically, an indexing method to adjust present estimates in the future is useful. The Engineering News-Record (ENR) Construction Cost Index (CCI) is a commonly used index for this purpose. For purposes of future cost estimate updating; the current ENR CCI for Seattle, Washington is 10162 (August 2014).

Water System Capital Improvement Program

A summary of all recommended improvement projects and estimated project costs is presented in Table 5-3. This CIP table provides for project sequencing by showing fiscal year-by-year project priorities for the first five fiscal years, then prioritized projects in 5-year blocks for the 10-year, 20-year and Beyond 20 year timeframes.

The City's fiscal year begins July 1st and ends June 30th. Fiscal years are designated by the year in which they end. For example, fiscal year (FY) 2016 includes the period from July 1, 2015 through June 30, 2016. The 10-year project timeframe includes projects recommended for completion between 6 and 10 years (FY 2021 through FY 2024). The 20-year timeframe

includes projects recommended for completion between 11 and 20 years (FY 2025 through FY 2034).

CIP Cost Allocation to Growth

Water system improvement projects are recommended to mitigate existing system deficiencies and to provide capacity to accommodate growth and service area expansion. Projects that benefit future water system customers by providing capacity for growth may be funded through system development charges (SDCs). SDCs are sources of funding generated through development and water system growth and are typically used by utilities to support capital funding needs. SDCs are determined as part of a financial evaluation and are based in part on a utility's current CIP. To facilitate the Financial Analysis presented in Section 6, a percentage of the cost of each project which benefits future water system growth is allocated in the CIP table. Percentages allocated to growth are described later in this section for each type of recommended facility and summarized in the CIP Table 5-3.

Water Supply Projects

WRWTP

S-1 Existing Plant Upgrades

The City currently owns 5 million gallons per day (mgd) of the WRWTP's current 15 mgd capacity. As part of previous WRWTP studies, Sherwood and Wilsonville have determined that two improvement projects related to surge mitigation and disinfectant contact time (CT) are needed at the plant in order to deliver the current 15 mgd capacity. Sherwood's share of these improvements is approximately \$500,000 for each project. The surge mitigation project needs to be completed in order to achieve 12 mgd plant capacity. Estimated costs for this project are included in the CIP distributed over fiscal years 2019 and 2020. CT improvements are needed to achieve 15 mgd plant capacity. The CT project is included in the CIP in the 10-year timeframe. Costs for both projects are allocated 80 percent to existing customers based on Sherwood's existing maximum day demand (MDD) of 4 mgd of the total 5 mgd Sherwood capacity from the WRWTP. The remaining 20 percent of project cost is allocated to system growth.

S-2 and S-3 Plant Expansion

To meet long-term supply needs, it is recommended that the City pursue purchase of 5 mgd of additional capacity in the WRWTP's oversized intake facilities (S-2). The estimated \$2 million purchase cost for an additional 5 mgd of intake capacity is based on individual treatment plant component costs from the City's 2006 contract with TVWD for the purchase of an initial 5 mgd of capacity at the WRWTP.

It is further recommended that Sherwood pursue expansion of the WRWTP treatment facilities (S-3) to secure a total capacity of 10 mgd from the plant. The cost of plant

expansion is estimated based on the 2005 WRWTP Master Plan which identified improvements required to expand plant capacity by 50 mgd at an estimated 2005 cost of approximately \$900,000 per mgd without contingency. Project cost for Sherwood's proposed 5 mgd share of plant expansion is estimated at \$7.7 million including a 45 percent allowance for administration, engineering and contingency adjusted to 2014 dollars using the ENR CCI for Seattle described previously. An update of the 2005 WRWTP Master Plan is currently being completed and will include an update and refinement of these cost estimates. It is recommended that the City update plant expansion costs in the Sherwood CIP when that study is complete.

It is recommended that the City pursue both projects within the 20-year planning horizon in order to mitigate an estimated 1 mgd supply deficit in 2034. Based on the City's discussions with their WRWTP partner City of Wilsonville, expansion of treatment facilities will need to be completed within the 10-year timeframe in order to meet Wilsonville's forecasted demands. It is anticipated that design and engineering of the WRWTP expansion will begin within fiscal year 2018 with the majority of construction occurring within the 10-year timeframe. 20 percent of estimated costs for treatment plant expansion and future intake capacity purchase are distributed over the 2018, 2019 and 2020 fiscal years with the remaining 80 percent assigned to the 10-year timeframe. Project costs for this supply expansion are allocated 100 percent to growth.

City Wells

S-4 Hydrants at Wells 3 and 5

In order to maintain the City's groundwater wells as an on-demand emergency source, the City must have a means of isolating well water from the distribution system for exercising the well pumps and taking water quality samples. There is an existing fire hydrant and isolation valve at Well 6 which allows the City to pump Well 6 to atmosphere. It is recommended that a new hydrant and isolation valve be installed at Wells 3 and 5 for this purpose within fiscal year 2016. Emergency capacity from all of the City's wells is only sufficient to benefit existing customers, thus the estimated cost of this project is allocated entirely to existing customers.

S-5 Well 4 Abandonment and Water Rights Transfer

It is recommended that the City abandon the low-producing Well 4. Well 4 water rights may be eligible for transfer to one of Sherwood's other existing wells. Approximately \$25,000 is allocated in the CIP to abandon Well 4 and apply for a water rights transfer to other City wells. For the purposes of this analysis it is assumed that the City's total well capacity for emergency supply will be from Wells 3, 5 and 6 not including any capacity from Well 4 or water rights transferred from Well 4. The Well 4 project is recommended for completion in fiscal year 2016. Emergency capacity from all of the City's wells is only sufficient to benefit existing customers, thus the estimated cost of this project is allocated entirely to existing customers.

Pump Station Projects

Sherwood's existing pumping facilities are adequate to meet customer demands in the 455 and 535 Pressure Zones through the 20-year planning horizon. Due to significant uncertainty regarding the nature of future development in the West Urban Reserve, a deficiency in the 455 Zone at build-out is recommended to be re-evaluated with the next Master Plan update or as development warrants. No pump station projects are currently recommended to mitigate this 455 Zone deficiency. Additional pumping facilities are recommended to serve proposed future constant pressure (closed) zones outside of the City's existing service area.

Estimated project costs for proposed pump stations are allocated 100 percent to growth as all of the proposed stations are intended to serve future development outside of the existing Sherwood water service area.

P-1 Ladd Hill Pump Station

The 1,600 gpm Ladd Hill Pump Station is proposed to serve future customers along Ladd Hill Road in the proposed 400 Brookman Zone. The proposed pump station, illustrated on Plate 1 in Appendix A, will boost water from existing 380 Zone distribution mains on Ladd Hill Road at Brookman Road to provide customers with constant pressure service at an hydraulic grade line (HGL) of approximately 400 feet. The pump station is proposed for construction within the 20-year timeframe.

P-2 Kruger Pump Station

The 2,400 gpm Kruger Pump Station is proposed to serve future high-elevation customers west of Kruger Reservoir in the proposed 630 West Zone. The proposed pump station, located on the same site as the existing Kruger Reservoir, will boost water from the reservoir to provide customers with constant pressure service at an HGL of approximately 630 feet. The pump station is proposed for construction beyond 20 years as development warrants.

P-3 Edy Road Pump Station

The 1,600 gpm Edy Road Pump Station is proposed to serve future high-elevation customers along Edy Road near the western boundary of the West Urban Reserve in the proposed 475 West Zone. The proposed pump station, illustrated on Plate 1 in Appendix A, will boost water from proposed 380 Zone distribution mains (M-54 and -55) on Edy Road west of Chicken Creek to provide customers with constant pressure domestic and fire flow service at an HGL of approximately 475 feet. The pump station is proposed for construction beyond 20 years as development warrants.

During the pump station pre-design process, it is recommended that the City evaluate providing fire flow to future 475 West Zone customers from the nearby 380 Zone proposed distribution mains. Providing fire flow from the 380 Zone would allow a significant

reduction in the proposed Edy Road Pump Station capacity thereby reducing construction and long-term maintenance costs for this station.

Distribution Main Improvement Projects

Table 5-2 presents prioritized water distribution main project recommendations for fire flow capacity and system expansion including estimated project costs and cost allocations to future growth. All recommended water main projects are illustrated on Plate 1 in Appendix A. Water main project costs are estimated based on unit costs by diameter shown in Table 5-1.

**Table 5-1
Unit Cost for Water Main Projects**

Pipe Diameter	Cost per Linear Foot
6-inch	\$160
8-inch	\$180
10-inch	\$210
12-inch	\$250

Assumptions:

1. Ductile iron pipe with an allowance for fittings, valves and services
2. Surface restoration is assumed to be asphalt paving
3. No rock excavation
4. No dewatering
5. No property or easement acquisitions
6. No specialty construction included

Projects for Fire Flow

As presented in Section 4, analysis using the City’s water system hydraulic model revealed that minimal piping improvements are needed to provide sufficient fire flow capacity within the existing water service area under existing and projected future demand conditions. Some water main projects identified in the 2005 Sherwood Water System Master Plan were eliminated from the CIP based on the 2014 analysis. This was primarily due to the availability of more refined data in 2014 and completion of major piping improvement projects since 2005. Water main projects recommended for fire flow capacity serve only existing developed areas, thus estimated project costs are allocated 100 percent to existing customers.

Projects for Future System Expansion

Large diameter distribution main loops are needed to serve the currently undeveloped Brookman Annexation, TEA and West Urban Reserve. Proposed water main projects to serve future development in Brookman and TEA are adapted from their respective concept

plans and prioritized according to the projected development timelines provided in the concept plans. Proposed water main projects to serve potential growth in the West Urban Reserve are aligned with existing roadways where possible and highest priority is given to areas with adjacent existing development which will be served from the existing 380 and 455 Pressure Zones.

Cost Allocation to Growth for System Expansion Projects

Estimated costs for projects which are recommended to replace existing pipes in order to serve system expansion areas are allocated to growth based on the ratio of existing and proposed future replacement pipe diameter. The flow area of the existing pipe size is considered to be serving existing system demands and benefiting existing customers. Any capacity beyond the existing pipe size is allocated to growth based on flow area. This cost allocation applies to recommended water main replacement projects M-3, M-4 and M-5.

Costs for all other water main projects recommended to facilitate water system expansion to the Brookman Annexation, TEA and West Urban Reserve are 100 percent allocated to growth.

Routine Pipe Replacement Program

In addition to distribution main projects to address capacity deficiencies, the City should plan for replacement of pipes based on a 100-year life cycle. It is recommended that routine pipe replacement be prioritized as follows:

1. Known pipe capacity and condition issues
2. Pipe material – based on City record of pipe material and era of manufacture
 - Highest priorities are galvanized pipe and post-1950 cast iron
3. Pipe age – coordinate replacement of pipes 50 years or older with other City utilities and transportation (City, County or State) projects

Sherwood has experienced substantial growth and city boundary expansion over the last few decades, as a result much of the City's water system is less than 30 years old. Based on a 100-year replacement cycle, none of this infrastructure would need to be replaced for 70 years, well beyond the planning horizon of this Master Plan Update. However, it is recommended that the City allocate funds for a long term pipe replacement program.

Based on the lengths and diameters of the City's oldest existing pipe, those mains within the 1960 city limit boundary, and input from City staff it is recommended that Sherwood allocate approximately \$50,000 annually for routine pipe replacement. Estimated costs for the pipe replacement program are allocated to future growth based on the ratio of existing to projected build-out demands.

PRV Projects

Two new pressure reducing valves are recommended, as development warrants, to provide an emergency connection between the existing 455 Zone distribution mains and future 380 Zone mains on Elwert Road at Handley Street and on Old Highway 99W at the Brookman Annexation boundary. Two additional PRVs are recommended, as development warrants, to provide an emergency connection between the future 630 West Pressure Zone and 455 Zone future expansion in the West Urban Reserve. Project costs for all four PRVs are allocated 100 percent to growth.

SCADA System Upgrade

A Supervisory Control and Data Acquisition (SCADA) system is a computer and communication system which provides critical real-time information and data recording to inform both immediate and long-term water system operations decisions. The SCADA system monitors water facility performance with measures, such as, system pressure, reservoir water level and pump on/off status as well as entry alarms for security at drinking water reservoirs and pump stations. Based on experience with similar water providers in the region, equipment becomes more difficult to maintain and repair 10 to 15 years after installation as SCADA technology advances leading to increasing maintenance effort and cost. The City's current SCADA system is over 10 years old. It is recommended that the City upgrade their existing SCADA system in fiscal year 2017. Estimated costs for the proposed upgrade are allocated to future growth based on the ratio of existing to 20-year projected demands. It is assumed that the SCADA system would likely need to be upgraded again at the end of the 20-year planning horizon.

Planning Projects

It is recommended that the City update this Water System Master Plan within the next 6 to 10 years and again at 20 years. An update may be needed sooner if there are significant changes to the City's water service area, supply or distribution system which are not currently anticipated.

To comply with Oregon Water Resources Department (OWRD) requirements for groundwater permit holders Sherwood is required to complete an update of their Water Management and Conservation Plan (WMCP) every 10 years. The next update of the City's WMCP is expected to begin in fiscal year 2018.

The City intends to update the existing Water System Vulnerability Assessment within the next 10 years to identify any additional security measures or operations procedures which may be needed to protect water facilities. It is assumed that this assessment update will be repeated at 20 years.

Sherwood staff have identified the need for a local water system resilience plan to achieve the seismic response and recovery goals for Willamette Valley water utilities presented in the

Oregon Resilience Plan. It is recommended that the City begin developing this plan in the next year.

Estimated costs for future water system planning projects are allocated to future growth based on the ratio of existing to 20-year projected demands.

Summary

This section presented recommendations for improvement and expansion projects in the City's supply system, pump stations and distribution mains. As presented in Table 5-3, the total estimated cost of these projects is approximately \$24.6 million through FY 2034. Approximately \$19.9 million of the total estimated cost is for projects needed within the 10-year timeframe and \$5.4 million of these improvements are required in the next 5 years.

DRAFT

**Table 5-2
Water Main Projects**

DRAFT

CIP ID	Project Description	Project Purpose	Diameter (in)	Total Project Length (ft)	Timeframe	Estimated Project Cost	% Allocated to Growth
M-1	Upgrade 6-inch fire line to Sherwood Senior Center (21907 Sherwood Boulevard) from Sherwood Boulevard	Commercial Fire Flow	8	196	FY2 (2017)	\$ 36,000	0%
M-2	Upgrade 6-inch main along Norton Street from Willamette Street south to fire hydrant at Forest Avenue	Residential Fire Flow	8	507	FY3 (2018)	\$ 92,000	0%
M-3	Upgrade 8-inch main along Sanders Terrace from Inkster Drive to Maidenfern Lane	Fire flow to Brookman Expansion	12	487	10-Year (2024)	\$ 122,000	56%
M-4	Upgrade 8-inch main along Maidenfern Lane from Sanders Terrace to Middleton Road, open NCV at 18191 Maidenfern to transfer services from 455 to 380 Zone		12	381	10-Year (2024)	\$ 96,000	56%
M-5	Upgrade 8-inch main along Middleton Road from Maidenfern Lane to city limits, close valve at Middleton & Maidenfern to transfer services from 455 to 380 Zone		12	325	10-Year (2024)	\$ 82,000	56%
M-6	Install new main along Middleton Road from city limits south to 24312 Middleton Road	Brookman Expansion - 380 Zone	12	884	10-Year (2024)	\$ 221,000	100%
M-7	Install new main along Old Hwy 99W from existing dead end south of Crooked River Lane to proposed Southwest Sherwood PRV (V-1)		12	268	FY3 (2018)	\$ 68,000	100%
M-8	Install new main along Old Hwy 99W from proposed Southwest Sherwood PRV (V-1) across Goose Creek		12	813	FY4 (2019)	\$ 204,000	100%
M-9	Install new main along proposed Goose Creek arterial from Old Hwy 99W northwest to Hwy 99W		8	1,325	FY4 (2019)	\$ 239,000	100%
M-10	Install new main along proposed Goose Creek arterial from Old Hwy 99W southeast to Brookman Road		12	1,246	10-Year (2024)	\$ 312,000	100%
M-11	Install new main along Middleton Road from Brookman Road north to 24312 Middleton Road		12	517	10-Year (2024)	\$ 130,000	100%
M-12	Install new main along Brookman Road from Middleton Road east to 16655 Brookman Road		12	1,223	10-Year (2024)	\$ 306,000	100%
M-13			12	1,233	10-Year (2024)	\$ 309,000	100%
M-14			12	2,414	10-Year (2024)	\$ 604,000	100%
M-15			Install new main from 16655 Brookman Road northeast to 24100 Ladd Hill Road	12	1,382	10-Year (2024)	\$ 346,000
M-16	Install new main along Ladd Hill Road from 24100 Ladd Hill Road north to Brookman Road	12	255	10-Year (2024)	\$ 64,000	100%	

**Table 5-2
Water Main Projects**

DRAFT

CIP ID	Project Description	Project Purpose	Diameter (in)	Total Project Length (ft)	Timeframe	Estimated Project Cost	% Allocated to Growth	
M-17	Install new main along proposed roadway running north-south at 17433 Brookman Road	Brookman Expansion - 380 Zone	12	1,726	10-Year (2024)	\$ 432,000	100%	
M-18	Install new main from proposed roadway through 17433 Brookman Road, across Cedar Creek to Redfern Drive		12	1,537	10-Year (2024)	\$ 385,000	100%	
M-19A	Install new main from Redfern Drive east to Brookman Road	Brookman Expansion - 380 Zone	8	565	10-Year (2024)	\$ 102,000	100%	
M-19B	Install new main along Brookman Road to Ladd Hill Road		8	995	10-Year (2024)	\$ 180,000	100%	
M-20	Install new main along Old Hwy 99W from proposed Goose Creek arterial southwest to Brookman Road		8	878	20-Year (2034)	\$ 159,000	100%	
M-21	Install new main along Brookman Road from Old Hwy 99W west to Hwy 99W		8	627	20-Year (2034)	\$ 113,000	100%	
M-22	Install new main along Hwy 99W from Brookman Road north to proposed Goose Creek arterial		8	1,678	20-Year (2034)	\$ 303,000	100%	
M-23	Install new mains along proposed roadways for system looping in the Brookman Annexation area		8	860	20-Year (2034)	\$ 155,000	100%	
M-24			8	2,254	20-Year (2034)	\$ 406,000	100%	
M-25			8	412	20-Year (2034)	\$ 75,000	100%	
M-26	Install new mains along Ladd Hill Road from proposed Ladd Hill Pump Station (P-1) south of Brookman Road		Brookman Expansion - 400 Zone	12	288	20-Year (2034)	\$ 73,000	100%
M-27				12	498	20-Year (2034)	\$ 125,000	100%
M-28	Extend proposed Ladd Hill main (M-27) south to southern boundary of Brookman Annexation	12		453	20-Year (2034)	\$ 114,000	100%	
M-29	Extend Cipole Road main south from Tualatin Sherwood Road to proposed TEA water main backbone	TEA Expansion - 380 Zone	10	731	FY3 (2018)	\$ 154,000	100%	
M-30	Install new mains to form TEA water main backbone running northeast to southwest across TEA parallel to Oregon Street		10	1,256	FY4 (2019)	\$ 264,000	100%	
M-31			12	1,750	FY4 (2019)	\$ 438,000	100%	
M-32			Install new main across 21600 Oregon Street property to TEA water main backbone	10	1,267	FY5 (2020)	\$ 267,000	100%
M-33	Extend proposed Cipole Road main (M-29) southeast to proposed 124th Avenue roadway extension south of Tualatin Sherwood Road		10	768	FY5 (2020)	\$ 162,000	100%	

**Table 5-2
Water Main Projects**

DRAFT

CIP ID	Project Description	Project Purpose	Diameter (in)	Total Project Length (ft)	Timeframe	Estimated Project Cost	% Allocated to Growth
M-34	Install new main along proposed 124th Avenue roadway extension south of Tualatin Sherwood Road contiuing south to proposed collector road running west to east across TEA	TEA Expansion 380 Zone	10	843	FY5 (2020)	\$ 178,000	100%
M-35	Install new main from intersection of Dahlke Lane & Oregon Street southeast to TEA water main backbone		10	1,530	10-Year (2024)	\$ 322,000	100%
M-36	Install new main from TEA water main backbone east to 124th Avenue roadway extension at proposed collector road		12	1,695	10-Year (2024)	\$ 424,000	100%
M-37	Extend proposed TEA water main backbone (M-31) south to serve TEA concept plan area B(2)		12	1,161	10-Year (2024)	\$ 291,000	100%
M-38	Install new main parallel to the south side of the Bonneville Power Easement from Oregon Street to the TEA water main backbone at Dahlke Lane	TEA Expansion 380 Zone	12	1,347	Beyond 20 years	\$ 337,000	100%
M-39	Install new main from Tualatin Sherwood Road west of Cipole Road south to TEA water main backbone		10	942	Beyond 20 years	\$ 198,000	100%
M-40	Extend Edy Road 12-inch 380 Zone main west to Elwert Road	West Expansion 380 Zone	12	870	10-Year (2024)	\$ 218,000	100%
M-41	Install new main along Elwert Road from Edy Road south to 21615 Elwert Road		12	1,323	10-Year (2024)	\$ 331,000	100%
M-42	Install new main along Elwert Road from 21615 Elwert Road to connect with existing 455 Zone piping through proposed Handley PRV (V-2)		12	1,191	10-Year (2024)	\$ 298,000	100%
M-43	Extend existing 12-inch 455 Zone main along Hwy 99W from the intersection of Hwy 99W & Kruger Road southwest across Goose Creek to 23975 Hwy 99W	West Expansion 455 Zone	12	2,908	20-Year (2034)	\$ 727,000	100%
M-44	Install new main from 23975 Hwy 99W west to proposed 195th PRV (V-4)		12	1,533	20-Year (2034)	\$ 384,000	100%
M-45	Install new main from existing 18-inch 455 Zone Kruger Road main south to connect with 455 distribution extension (M-44) near proposed 195th PRV (V-4)		12	2,642	20-Year (2034)	\$ 661,000	100%
M-46	Extend existing 10-inch 380 Zone main along Roy Rogers Road north across Chicken Creek bridge to Scholls Sherwood Road	West Expansion 380 Zone	12	3,168	Beyond 20 years	\$ 792,000	100%
M-47	Install new main along Scholls Sherwood Road from Roy Rogers Road west to Elwert Road		12	3,088	Beyond 20 years	\$ 773,000	100%

**Table 5-2
Water Main Projects**

DRAFT

CIP ID	Project Description	Project Purpose	Diameter (in)	Total Project Length (ft)	Timeframe	Estimated Project Cost	% Allocated to Growth
M-48A	Install new main along Elwert Road from Scholls Sherwood Road south to Conzelmann Road	West Expansion 380 Zone	12	2,640	Beyond 20 years	\$ 660,000	100%
M-48B	Install new main along Elwert Road from Conzelmann Road south across Chicken Creek to Edy Road		12	2,640	Beyond 20 years	\$ 661,000	100%
M-49	Install new main along Haide Road from Elwert Road west to proposed Haide PRV (V-3)	West Expansion 455 Zone	12	2,658	Beyond 20 years	\$ 665,000	100%
M-50	Install new main from existing 18-inch 455 Zone Kruger Road main north to connect with Haide Road 455 distribution extension (M-49)		12	1,998	Beyond 20 years	\$ 500,000	100%
M-51	Install new main along Kruger Road from proposed Kruger Pump Station (P-2) west to serve future West Urban Reserve customers in proposed 630 Zone	West Expansion 630 Zone	12	750	Beyond 20 years	\$ 188,000	100%
M-52	Install new mains from proposed Kruger Road 630 Zone main (M-51) north to loop with proposed 455 Zone mains on Haide Road through proposed Haide PRV (V-3)		12	1,615	Beyond 20 years	\$ 404,000	100%
M-53			12	1,230	Beyond 20 years	\$ 308,000	100%
M-54	Extend proposed 380 Zone main along Edy Road from Elwert Road west across Chicken Creek to proposed Edy Road Pump Station (P-3)	West Expansion 380 Zone	12	1,978	Beyond 20 years	\$ 495,000	100%
M-55			12	970	Beyond 20 years	\$ 243,000	100%
M-56	Install new mains from proposed Kruger Road 630 Zone main (M-51) south to loop with proposed 455 Zone mains through proposed 195th PRV (V-4)	West Expansion 630 Zone	12	1,387	Beyond 20 years	\$ 347,000	100%
M-57			12	1,434	Beyond 20 years	\$ 359,000	100%
M-58			12	559	Beyond 20 years	\$ 140,000	100%
M-59	Install new main along Edy Road west of proposed Edy Road Pump Station (P-3) to serve future West Urban Reserve customers in proposed 455Booster Zone	West Expansion 475 Zone	12	452	Beyond 20 years	\$ 113,000	100%
M-60	Upgrade existing 2-inch main on June Court from Cochran Avenue to existing dead end, add fire hydrant at end of cul-de-sac	Residential Fire Flow	6	263	FY4 (2019)	\$ 43,000	100%
Total Cost						\$ 18,198,000	


**Table 5-3
CIP Summary**

DRAFT

Project Category	Project ID	Project Description	CIP Schedule and Project Cost Summary							% Allocated to Growth	
			FY1 (2016)	FY2 (2017)	FY3 (2018)	FY4 (2019)	FY5 (2020)	10-Year (2024)	20-Year (2034)		Beyond 20 years
Supply	S-1	Existing WRWTP upgrades to achieve max 15 mgd capacity				\$ 250,000	\$ 250,000	\$ 500,000			20%
	S-2	WRWTP purchase 5 mgd intake capacity			\$ 100,000	\$ 150,000	\$ 150,000	\$ 1,600,000			100%
	S-3	WRWTP treatment expansion - Sherwood 5 mgd share			\$ 440,000	\$ 550,000	\$ 550,000	\$ 6,160,000			100%
	S-4	Install hydrants at Wells 3 and 5	\$ 25,000								0%
	S-5	Abandon Well 4 and transfer water rights	\$ 25,000								0%
		Subtotal	\$ 50,000	\$ -	\$ 540,000	\$ 950,000	\$ 950,000	\$ 8,260,000	\$ -	\$ -	
Pump Station	P-1	Proposed 1,600 gpm Ladd Hill Pump Station to serve future 400 Brookman Zone customers							\$ 477,000		100%
	P-2	Proposed 2,400 gpm Kruger Pump Station to serve future 630 Zone customers								\$ 2,547,000	100%
	P-3	Proposed 1,600 gpm Edy Road Pump Station to serve future 475 Zone customers								\$ 1,505,000	100%
		Subtotal	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ 477,000	\$ 4,052,000	
Water Main	M-1	Fire flow capacity -Sherwood Senior Center		\$ 36,000							0%
	M-2	Fire flow capacity - Norton Ave			\$ 92,000						0%
	M-60	Fire flow capacity - June Court				\$ 43,000					0%
	M-7	Expansion to Brookman -		\$ 68,000							100%
	M-8	Loop from prop SW			\$ 204,000						100%
	M-9	Sherwood PRV to Hwy 99			\$ 239,000						100%
	M-29				\$ 154,000						100%
	M-30				\$ 264,000						100%
	M-31	Expansion to TEA - Loop with existing Oregon Street mains			\$ 438,000						100%
	M-32					\$ 267,000					100%
	M-33					\$ 162,000					100%
	M-34					\$ 178,000					100%
	M-3, 4 & 5	10-Year (2024) - upgrade existing mains						\$ 300,000			56%
	M-6, 10 to 19B, 35 to 37, 40 to 42	10-Year (2024)						\$ 5,275,000			100%
M-20 to 28, 43 to 45	20-Year (2034)							\$ 3,295,000		100%	
M-38, 39, 46 to 59	Beyond 20 years								\$ 7,183,000	100%	
	Routine Pipe Replacement Program	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 250,000	\$ 500,000	\$50K annually	57%	
	Subtotal	\$ 50,000	\$ 154,000	\$ 739,000	\$ 795,000	\$ 657,000	\$ 5,825,000	\$ 3,795,000	\$ 7,183,000		
PRV	V-1	SW Sherwood PRV			\$ 150,000						100%
	V-2	Handley PRV						\$ 150,000			100%
	V-3	Haide PRV								\$ 150,000	100%
	V-4	195th PRV								\$ 150,000	100%
	Subtotal	\$ -	\$ -	\$ 150,000	\$ -	\$ -	\$ 150,000	\$ -	\$ 300,000		
Other		Upgrade SCADA System		\$ 75,000							35%
	Subtotal	\$ -	\$ 75,000	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -		
Planning		Update Water Master Plan						\$ 150,000	\$ 150,000		35%
		Update Water Management and Conservation Plan			\$ 150,000				\$ 150,000		35%
		Update Vulnerability Assessment						\$ 60,000	\$ 60,000		35%
		Resiliency Plan	\$ 150,000						\$ 150,000		35%
	Subtotal	\$ 150,000	\$ -	\$ 150,000	\$ -	\$ -	\$ 210,000	\$ 510,000	\$ -		
Capital Improvement Program (CIP) Total			\$ 250,000	\$ 229,000	\$ 1,579,000	\$ 1,745,000	\$ 1,607,000	\$ 14,445,000	\$ 4,782,000	\$ 11,535,000	\$ 36,172,000

Annual Average CIP Cost		
\$1,082,000	\$1,985,500	\$1,231,850
over 5 years	over 10 years	over 20 years

G:\PDX_Projects\13\1508\CAD\13-1508-405-OR-FIG 5-1 1/23/15 13:07



LEGEND

	EXISTING
PUMP DISCHARGE WATER MAIN	---
WATER MAIN	—
RESERVOIR (CAPACITY IN MG, OVERFLOW ELEVATION IN FEET)	
GROUNDWATER WELL (PRODUCTION CAPACITY IN GPM)	
PRESSURE REDUCING VALVE	
PUMP STATION	
MASTER METER	
WATER TREATMENT PLANT	
DISTRIBUTION SYSTEM EMERGENCY INTERTIES

ABBREVIATIONS

GPM	GALLONS PER MINUTE
HGL	HYDRAULIC GRADE LINE
MG	MILLION GALLONS
MGD	MILLION GALLONS PER DAY
OE	OVERFLOW ELEVATION
PRV	PRESSURE REDUCING VALVE

NOTES:

1. FACILITIES SHOWN IN RED ARE PROPOSED.

FIGURE 5-1


Water System Master Plan Update

PROPOSED WATER SYSTEM SCHEMATIC

FEBRUARY 2015

13-1508

DRAFT



Legend

- Existing Reservoir
- Existing Well
- Pump Station**
 - Existing
 - Proposed
- Pressure Reducing Valve**
 - Existing
 - Proposed
- Water Main**
 - Existing
 - Proposed
 - Existing Transmission
- Railroad
- Stream
- City Limits
- Urban Growth Boundary (UGB)

This map is intended for informational purposes only. The City of Sherwood makes no representations, express or implied, as to the accuracy, completeness and timeliness of the information displayed. This map is not suitable for legal, engineering, or surveying purposes. Notification of any errors is appreciated.

Source Data:
 Basemapping - Metro/RLIS Nov. 2014
 Water System - MSA and City of Sherwood Dec. 2014



DRAFT



MSA

MURRAY, SMITH & ASSOCIATES, INC.
ENGINEERS|PLANNERS

Sherwood Planning Commission Meeting

Date: March 24, 2015

Meeting Packet

Approved Minutes

Date Approved: April 14, 2015

Request to Speak Forms

Documents submitted at meeting:



Work Session

1. MMD Presentation -Exh 1

2. Eco Northwest HNA Summary -Exh 2

Regular Session

6a. PA-15-01 Revised Exh A -Exh A



March 24, '15 PC
Date Gov. Body

1 1
Agenda Item Exhibit #

Public Work Session Discussion

Table Discussion Comments

- Split opinion, no consensus but good discussion
- Liked the addition of a parks buffer
- Keep the same hours as OLCC liquor store
- Staff-level decision with adequate notice
- Concern about cash business operation
- Consider what Tualatin did -3000' buffer

Public Work Session Discussion



Restrict Location through Zoning?	Vote
Industrial Only	9
Commercial Only	1
No Restriction on Zoning allow Commercial and Industrial (State Regulations)	17

Public Work Session Discussion

Should there be additional Buffers where Dispensaries could not be located?	Vote
1000 feet from a Park	13
Increase School Buffer	6
Residential Buffer	9
No Additional Buffers	11

Public Work Session Discussion

Who should be the decision- making authority for the land use process for approving Medical Marijuana Dispensaries?	Vote
Staff level with notice (Type II)	25
Hearing Officer	1
Planning Commission	0




Statewide Medical Marijuana Dispensary Land Use-Related Regulations

- * Dispensary must be located in **Commercial, Industrial Mixed Use or Agricultural zone**
- * **Cannot be in same location as a Grow site**
- * **Cannot be within 1,000 feet from a school-public or private**
- * **Cannot be within 1,000 feet from another medical marijuana facility or dispensary**
- * **Must be a Registered Business in Oregon**
- * **Must install a Security System**
- Cannot be Mobile**

SCHOOL ZONE BUFFER


1000 Foot School Buffers with Industrial and Commercial Zones



PROPOSED CODE AMENDMENTS

- * Add Definitions to Chapter 16.10
- * Add Medical Marijuana to the Use Categories in Commercial and Industrial
- * Add Medical Marijuana Dispensary to Type II process
- * Add Criteria for Medical Marijuana Dispensary in Special Use category
 - * Hours
 - * Add Buffers
 - * Security Measures

MEDICAL MARIJUANA DISPENSARIES



**MEDICAL MARIJUANA REGULATION
TIMELINE FOR LAND USE REGULATIONS**

**PLANNING COMMISSION HEARING:
APRIL 14, 2015**

**PLANNING COMMISSION MAKES
RECOMMENDATION TO CITY COUNCIL**

**CITY COUNCIL HEARING
TENATIVE DATE: **May 5, 2015****

EXECUTIVE SUMMARY: SHERWOOD HOUSING NEEDS ANALYSIS

This is an executive summary of the findings of the Sherwood Housing Needs Analysis for the 2015 to 2035 period. The housing needs analysis provides Sherwood with a factual basis to support future planning efforts related to housing, including Pre-Concept Planning for Sherwood West, and prepares to update and revise the City’s Comprehensive Plan policies

The housing needs analysis is intended to comply with requirements of statewide planning policies that govern planning for housing and residential development, Goal 10, OAR 660-007, and Metro’s Functional Growth Management Plan. The City’s primary obligations from Goal 10 are to (1) designate land in a way that 50% of new housing could be either multifamily or single-family attached housing (e.g., townhouses); (2) achieve an average density of six dwelling units per net acre; and (3) provide enough land to accommodate forecasted housing needs for the next 20 years. Sherwood is able to meet these requirements and can accommodate most of the new housing forecast, as described in this summary.

How has Sherwood’s Population Changed in Recent Years?

The basis for the housing needs analysis is an understanding of the demographic characteristics of Sherwood’s residents.¹

Sherwood’s population grew relatively fast in recent years. Sherwood’s population increased from 3,000 people in 1990 to nearly 18,600 people in 2013, averaging 8% annual growth. Sherwood’s fastest period of growth was during the 1990s, consistent with statewide trends. Since 2000, Sherwood grew by 6,600 people, at an average rate of nearly 3.5% per year. For comparison, Washington County grew at 2.5% annually between 1990-2013 and the Portland Region grew at 1.6% per year.

Sherwood’s population is aging. People aged 45 years and older were the fastest growing age group in Sherwood between 2000 and 2010, consistent with state and national trends. By 2035, people 60 years and older will account for 24% of the population in Washington County (up from 18% in 2015) and 25% in the Portland Region (up from 19% in 2015). It is reasonable to assume that the share of people 60 years and older will grow relatively quickly in Sherwood as well.

Sherwood is attracting younger people and more households with children. In 2010, the median age in Sherwood was 34.3 years old, compared to Washington County’s median age of 35.3 years and the State median of 38.4. Sherwood has a larger share of households with children (47% of households), compared with Washington County (33%) or the Portland Region (29%). The Millennial generation—people born roughly between 1980 to 2000—are

¹ The majority of data quoted in this analysis is from the U.S. Census American Community survey, with population data from the Population Research Center at Portland State University and development data from the City’s Building Permit database.

the largest age group in Oregon and will account for the majority of household growth in Sherwood over the next 20 years.

Sherwood's population is becoming more ethnically diverse. About 6% of Sherwood's population is Latino, an increase from 4.7% in 2000. In comparison to Washington County and the Portland Region, Sherwood is less ethnically diverse. In the 2009-2013 period, 16% of Washington County residents, and 12% Portland Region residents, were Latino.

What Factors May Affect Future Growth in Sherwood?

The ongoing changes in Sherwood's population will result in changes in the types of housing needed in Sherwood in the future.

The aging of the population will result in increased demand for smaller single-family housing, multifamily housing, and housing for seniors. People over 65 years old will make a variety of housing choices, including: remaining in their homes as long as they are able, downsizing to smaller single-family homes (detached and attached) or multifamily units, or moving into group housing (such as assisted living facilities or nursing homes) as they continue to age.

The growth of younger and diversified households will result in increased demand for a wider variety of affordable housing appropriate for families with children, such as small single-family housing, townhouses, duplexes, and multifamily housing. If Sherwood continues to attract young residents, then it will continue to have demand for housing for families, especially housing affordable to younger families with moderate incomes. Growth in this population will result in growth in demand for both ownership and rental opportunities, with an emphasis on housing that is comparatively affordable.²

Changes in commuting patterns could affect future growth in Sherwood. Sherwood is part of a complex, interconnected regional economy. Demand for housing by workers at businesses in Sherwood may change with significant fluctuations in fuel and commuting costs, as well as substantial decreases in the capacity of highways to accommodate commuting.

Sherwood households have relatively high income, which affects the type of housing that is affordable. Income is a key determinant of housing choice. Sherwood's median household income (\$78,400) was more than 20% higher than Washington County's median household income (\$64,200). In addition, Sherwood had a smaller share of population below the federal poverty line (7.6%) than the averages of Washington County (11.4%) and the Portland Region (13.9%).

² The housing needs analysis assumes that housing is affordable if housing costs are less than 30% of a household's gross income. For a household earning \$6,500 (the median household income in Sherwood), monthly housing costs of less than \$1,960 are considered affordable.

What Are the Characteristics of Sherwood's Housing Market?

The existing housing stock in Sherwood, homeownership patterns, and existing housing costs will shape changes in Sherwood's housing market in the future.

Sherwood's housing stock is predominantly single-family detached. About 75% of Sherwood's housing stock is single-family detached, 8% is single-family attached (such as townhomes), and 18% is multifamily (such as duplexes or apartments). Sixty-nine percent of new housing permitted in Sherwood between 2000 and 2014 was single-family detached housing.

Almost three quarters of Sherwood's residents own their homes. Homeownership rates in Sherwood are above Washington County (54%), the Portland Region (60%), and Oregon (62%) averages.

Homeownership costs increased in Sherwood, consistent with national trends. Median sales prices for homes in Sherwood increased by about 30% between 2004 and 2014, from about \$245,000 to \$316,500. The median home value in Sherwood is 3.8 times the median household income, up from 2.9 times the median household income in 2000.

Housing sales prices are higher in Sherwood than the regional averages. As of January 2015, median sales price in Sherwood was \$316,500, which is higher than the Washington County (\$281,700), the Portland MSA (\$269,900), and Oregon (\$237,300) median sales prices. Median sales prices were higher in Sherwood than in other Portland westside communities such as Tigard, Tualatin, and Beaverton, but lower than Wilsonville or West Linn.

Rental costs are higher overall in Sherwood than the regional averages. The median rent in Sherwood was \$1,064, compared to Washington County's average of \$852. On a per-square-foot basis, Sherwood/Tigard/Tualatin's rents (\$1.13 per square foot) were lower than the Portland Metro area's average of \$1.22 per square foot.

More than one-third of Sherwood's households have housing affordability problems. Thirty-eight percent of Sherwood's households were cost-burdened (i.e., paid more than 30% of their income on rent or homeownership costs). Renters were more likely to be cost-burdened (40% of renters were cost-burdened), compared to homeowners (35% were cost-burdened) in Sherwood. These levels of cost burden are consistent with regional averages. In Washington County in the 2009-2013 period, 38% of households were cost burdened, compared to 41% in the Portland Region.

Future housing affordability will depend on the relationship between income and housing price. The key question is whether housing prices will continue to outpace income growth. Answering this question is difficult because of the complexity of the factors that affect both income growth and housing prices. It is clear, however, that Sherwood will need a wider variety of housing, especially housing affordable to low- and moderate-income households.

How Much Housing Growth is Forecast, and Can that Growth be Accommodated within Sherwood?

The housing needs analysis in this report is based on Metro's coordinated forecast of household growth in Sherwood. The forecast includes growth in both areas within the city limits, as well as areas currently outside the city limits that the City expects to annex for residential uses (most notably the Brookman area).

Sherwood is forecast to add 1,156 new households between 2015 and 2035. Of these, 606 new households are inside the existing city limits; 550 new households are outside the current city limits in the Brookman Area.

Sherwood's land base can accommodate the entire forecast for growth. Vacant and partially vacant land in the Sherwood Planning Area has capacity to accommodate 1,281 new dwelling units. Compared to demand, Sherwood has a small surplus of residential land.

Sherwood will need to annex the Brookman Area to accommodate the forecast for growth. If Sherwood does not annex the Brookman Area, the city's options for accommodating future growth will be limited to growing within the existing city limits or to growing in a different area, such as Sherwood West. The availability of other areas to accommodate growth, including Sherwood West, will depend on changes to the Metro urban growth boundary and these changes typically take years to make.

What if Sherwood Grows Faster?

The forecast for growth in Sherwood is considerably below historical growth rates. Metro's forecast for new housing in Sherwood shows that households will grow at less than 1% per year. In comparison, Sherwood's population grew at 3.4% per year between 2000 and 2013 and 8% per year between 1990 and 2013. If Sherwood grows faster than the forecast during the 2015 to 2035 period, then Sherwood will not have sufficient land to accommodate growth.

At faster growth rates, Sherwood's land base has enough capacity for several years of growth. At growth rates between 2% to 4% of growth annually, land inside the Sherwood city limits can accommodate two to five years of growth. With capacity in the Brookman Area, Sherwood can accommodate four to ten years of growth at these growth rates.

Additional housing growth in Sherwood depends the availability of development-ready land. The amount of growth likely to happen in Sherwood is largely dependent on when the Brookman Area is annexed, when the Sherwood West area is brought into the city and annexed, and when urban services (such as roads, water, and sanitary sewer) are developed in each area.

What are the Implications for Sherwood's Housing Policies?

To provide adequate land supply, Sherwood voters will need to approve/annex the Brookman area. If voters continue to reject the Brookman annexation, Sherwood as a community will either be unable to accommodate expected growth or will need to identify an alternative (more politically acceptable) area for growth. Sherwood West is just one of these possibilities. Another alternative would be to develop the existing vacant lands at higher densities than what they are zoned.

Sherwood will need Sherwood West to accommodate future growth beyond the existing city limits and Brookman area. The growth rate of Metro's forecast for household growth (0.7% average annual growth) is considerably lower than the City's historical population growth rate over the last two decades (8% average annual growth). Metro's forecast only includes growth that can be accommodated within the Sherwood city limits and Brookman. Given the limited supply of buildable land within Sherwood, it is likely that the City's residential growth will slow until Sherwood West is made development-ready.

Sherwood has a relatively limited supply of land for moderate- and higher-density multifamily housing. The limited supply of land in these zones is a barrier to development of townhouses and multifamily housing, which are needed to meet housing demand resulting from growth of people over 65, young families, and moderate-income households.

The results of the Housing Needs Analysis highlight questions for the update of the City's Comprehensive Plan and the Pre-Concept Planning of Sherwood West.

- Providing housing opportunities for first time home buyers and community elders (who prefer to age in place or downsize their housing) will require a wider range of housing types. Examples of these housing types include: single family homes on smaller lots, clustered housing, cottages or townhomes, duplexes, tri-plexes, four-plexes, garden apartments, or mid-rise apartments. Where should Sherwood consider providing a wider range of housing types? What types of housing should Sherwood plan for?
- Changes in demographics and income for Sherwood and regional residents will require accommodating a wider range of housing types. How many of Sherwood's needed units should the city plan to accommodate within the city limits? How much of Sherwood's needed units should be accommodated in the Brookman Area and in Sherwood West?
- What design features and greenspaces would be important to consider for new housing?
- What other design standards would be needed to "keep Sherwood Sherwood"?

Revised Exhibit A

COMMUNITY FACILITIES AND SERVICES

A. GENERAL INTRODUCTION

Community facilities and services in the Sherwood Planning Area are provided by Washington County, the City of Sherwood, special service districts, semi-public agencies and the State and Federal government, (see Table VII-1). Public facilities and services include sewer, water, fire and police protection, libraries, drainage, schools, parks and recreation, solid waste and general governmental administrative services. Semi-public facilities and services are those which are privately owned and operated but which have general public benefit. They include health facilities, energy and communication utilities, and day care.

Although a small community, Sherwood has learned well the importance of adequate community facilities and services to orderly urban growth. Lack of sewer treatment capacity curtailed growth in the City in the 1970's. Planning for public facilities and services in response to growth rather than in advance of growth results in gaps in facilities and services. As population growth and density increase in the Sherwood Planning Area, greater facility and service support will be required. In recognition of this basic fact, the Plan stresses the need for provision of necessary facilities and services in advance of, or in conjunction with, urban development.

The Community Facilities and Services element identifies general policy goals and objectives; service areas and providers, problems, and service plans, and potential funding for key public and semi-public facilities and services. Park and recreation facilities are treated in Chapter 5, Environmental Resources. Transportation facilities are treated in Chapter 6, Transportation. This element was updated in 1989 to comply with OAR 197.712(2)(e).

B. POLICY GOAL AND OBJECTIVES

To insure the provision of quality community services and facilities of a type, level and location which is adequate to support existing development and which encourages efficient and orderly growth at the least public cost.

OBJECTIVES

1. Develop and implement policies and plans to provide the following public facilities and services; public safety fire protection, sanitary facilities, water supply, governmental services, health services, energy and communication services, and

03-24-15
Date

PC
Gov. Body

6a
Agenda Item

A
Exhibit #

recreation facilities.

2. Establish service areas and service area policies so as to provide the appropriate kinds and levels of services and facilities to existing and future urban areas.
3. Coordinate public facility and service plans with established growth management policy as a means to achieve orderly growth.
4. Coordinate public facility and service provision with future land use policy as a means to provide an appropriate mix of residential, industrial and commercial uses.
5. Develop and implement a five-year capital improvements and service plan for City services which prioritizes and schedules major new improvements and services and identifies funding sources.
6. The City will comply with the MSD Regional Solid Waste Plan, and has entered into an intergovernmental agreement with Washington County to comply with the County's Solid Waste and Yard Debris Reduction Plan, 1990.
7. Based on ~~the~~ Sewer, Water, Stormwater, and Transportation Plan updates in 1989 and 1990, the City shall prepare a prioritized list of capital improvement projects to those systems and determine funding sources to ~~make-realize~~ the improvements by ~~the end of 1991~~ envisioned in those plans.
8. It shall be the policy of the City to seek the provision of a wide range of public facilities and services concurrent with urban growth. The City will make an effort to seek funding mechanisms to achieve concurrency.

C. PUBLIC AND SEMI-PUBLIC UTILITIES

Public utilities including water, sanitary sewer, drainage, and solid waste, as well as semi-public utilities including power, gas and telephone services are of most immediate importance in the support of new urban development. Water, sewer collection, and drainage facilities are the major services for which the City of Sherwood has responsibility. Service plans for these key services are contained in this section. The other utilities referred to above are the principal responsibilities of those agencies listed in Table VII-1. These agencies have been contacted for the purpose of coordinating their service planning and provision with the level and timing of service provision required to properly accommodate growth anticipated by the Plan.

**TABLE VII-1
FACILITY AND SERVICE PROVIDERS
IN THE SHERWOOD PLANNING AREA**

1. Public Utilities

a. Public Water Supply
City of Sherwood

b. Sanitary Sewer System
(1) ~~Unified Sewerage Agency~~ Clean Water Services
(2) City of Sherwood

c. Storm Drainage System
(1) City of Sherwood
(2) Washington County
(3) State of Oregon

2. Private/Semi-Public Utilities

a. Natural Gas
Northwest Natural Gas Co.

b. Electric Power
Portland General Electric

~~e. Telephone
General Telephone and Electric Co.~~

~~d. Cable Television: Columbia Cable~~

~~ec. Solid Waste: Pride Disposal Co.~~

3. Transportation

a. Paved Streets, Traffic Control, Sidewalks, Curbs,
Gutters, Street Lights
(1) City of Sherwood
(2) Washington County
(3) State of Oregon

b. Bikeways

- (1) City of Sherwood
- (2) Washington County
- (3) State of Oregon

c. Public Transit

Tri-Met

4. Public Health and Safety

a. Police Protection

- (1) City of Sherwood
- (2) Washington County
- (3) State of Oregon

b. Fire Protection

Tualatin - Valley Fire and Rescue

c. Animal Control

Washington County

5. Recreation

a. Parks and Recreation

City of Sherwood

b. Library

City of Sherwood

6. Schools

Sherwood School District 88J

D. SEWER SERVICE PLAN

INTRODUCTION

The Sewer Service Plan of the Comprehensive Plan was updated in 1990 and is included as an appendix to the Plan, and is incorporated into this chapter. The following describes the existing sewer system, recommended improvements to the existing system, recommended expansion of the sewer system and estimated costs.

EXISTING SEWER SYSTEM

The City of Sherwood's existing sewer system is as shown on Figure VII-1. The system is located in USA's Durham South Basin which consists of two sub-basins are centered around Cedar Creek and Rock Creek, respectively, and will be referred to as the Cedar Creek basin and the Rock Creek basin throughout the remainder of this section.

The Rock Creek Basin system currently serves a residential area bounded by Lincoln Street to the west, West Sunset Boulevard to the south, Oregon Street to the north and the UGB to the east. Rock Creek Basin also contains approximately 71.2 acres of land, north of Oregon Street, which is currently zoned and developed for industrial use. The remaining northern portion of the Basin is essentially undeveloped and zoned primarily for industrial use. Flow is by gravity from south to north, eventually connecting to USA's Rock Creek trunk. This trunk then follows Rock Creek until it connects with the Upper Tualatin Interceptor which transports sewage to the Durham treatment plant.

The Cedar Creek Basin system serves the majority of Sherwood. Drainage is again from south to north and the main trunk of the system follows Cedar Creek from Sunset Boulevard under Pacific Highway continuing north until it connects with the Upper Tualatin Interceptor. From this point sewage is transported to the Durham Treatment plant.

insert map

ANALYSIS OF EXISTING SEWER SYSTEM

The population for the City of Sherwood in the year 2008 is estimated to be 7,000 people. The 1979 Sewer Service Plan estimated a population of 10,600 people in the year 2008, and a full-development population within the Sherwood Urban Growth Boundary (UGB) of 18,900 people.

In order to accentuate any deficiencies in the existing sanitary sewer system, peak flowrates were generated based on full development or saturation of the Sherwood UGB. This analysis was used for the following reasons. Maximum design flows for sanitary sewers are far less than peak storm sewer flows. Very often sanitary sewer pipes are sized at a minimum 8-inch diameter for maintenance purposes; consequently the majority of these pipes are flowing at a minimum of their capacity. A full-development demand analysis was the most conservative and efficient way of analyzing the system for all deficiencies.

Wastewater flow criteria for the analysis was taken from USA's 1985 Master Sewer Plan Update and is based on land use designation as listed below:

**TABLE VII-2
WASTEWATER FLOW DESIGN CRITERIA
DESIGN UNIT FLOW RATE**

<u>LAND USE DESIGNATION</u>	<u>EXISTING</u>	<u>FUTURE</u>
RESIDENTIAL	75 gpcd	75 gpcd
COMMERCIAL	1000 gpad	1000 gpad
INDUSTRIAL	3000 gpad	3000 gpad
INSTITUTIONAL	500 gpad	500 gpad
PEAK ANNUAL	4000 gpad	4000 gpad

The City of Sherwood Zoning Map was used to determine the amount of acreage of each land use designation. This acreage was then applied to tributary basins contributing to their respective sewers and multiplied by the appropriate land use design unit flowrate in order to generate the total design flowrate. An average of residential densities per tributary basin was used to account for the five different residential zoning densities shown on the current City Zoning Map.

The domestic sewage flow allowance for the 1979 Sewer Plan followed the 1969 USA Master Plan value of 90 gallons per capita per day (gpcd). The updated, June 1985 USA Master Plan, has reduced this value to 75 gpcd.

In order to account for periods of maximum use, flowrates are multiplied by factors which result in peak flowrates. The 1979 Sewer Service Plan used peak factors of 3.0 for lateral sewers and 2.7 for trunk sewer lines. The 1985 USA Master Plan Update requires peak factors ranging from 1.5 to 2.0. These lower values are based on actual dry-weather flow monitoring, performed in June and

July of 1984, at points throughout the Durham Basin.

The July 1979 Sewer Service Plan used values ranging from 500 gallons per acre per day (gpad) to 700 gpad for inflow and infiltration (I&I), depending on land use designation. These values were concurrent with past EPA design standards and were based on the assumption that rehabilitation measures would remove 60 to 90 percent of excessive I&I. According to USA's 1985 Master Plan these abatement techniques proved to be ineffective. USA's review of the Durham treatment facility led to the design rate of 4000 gpad for the existing peak annual occurrence for infiltration and inflow. This value is not anticipated to decrease for the Durham basin and is therefore also used for the future design flowrates.

Two areas of special concern exist inside the current City of Sherwood UGB. Both areas are recent additions to the UGB and have not yet been assigned a land use. Rather than assume zoning designations for the areas they were both excluded from the model. Both areas can be served by gravity and neither will cause deficiencies in the system. Their service routes are discussed below.

The first area is located in the southwest corner of the UGB in the Cedar Creek Basin, between Pacific Highway and Old Highway 99W. This area can be served by line number 1 in area A (Figure VII-2). The northern half of this area may also be served by connecting to the southern most extension of line number 2 in area B. The second area is located east of Pacific Highway and north of Edy Road, in the Rock Creek Basin. The southern portion should be incorporated in line number 3 extending from Rock Creek west along Edy Road (Figure VII-2). The northern half must be served using a direct lateral to the area from the Rock Creek trunk.

RECOMMENDED IMPROVEMENTS TO EXISTING SEWER SYSTEM

The analysis of the existing system shows no size deficiencies in any of the City maintained pipes. City officials have confirmed that there are areas of surcharge in the system due to pipe under sizing. Surcharge due to blockage of the system has occurred but has since been remedied.

Improvements are recommended to the existing sewer systems main trunk lines. These improvements are required due to very slight slips which occur in the northern sections of the Rock Creek and Cedar Creek main trunk lines.

The Rock Creek trunk requires improvements from manhole number 11663, which is located at the confluence of the Rock Creek and Cedar Creek trunk lines, south to a manhole located near the Southern Pacific crossing of Rock Creek. The existing 18-inch diameter pipe has a length of 6,035 feet and an existing slope of 0.0031 feet/feet. The USA master plan recommends that a 15-inch diameter pipe be placed parallel to the existing 18-inch in order to convey future flows based on 20-year ultimate development peak flowrates. Our analysis is based on total ultimate development of the Sherwood UGB and therefore suggests that an 18-inch diameter pipe parallel the existing 18-inch at the existing slope of 0.0031 feet/feet.

The Cedar Creek Trunk presents similar slope problems along the northern trunk. USA's Master Plan breaks these into three sections but this report will combine them for simplicity. The section of sewer begins at manhole 11663, which is located at the confluence of the Rock Creek and Cedar Creek trunks, and continues south to manhole number 11752 which is 200 feet south of Edy Road and slightly west of the UGB. (see Fig.1) The entire 12,640 feet of this line is outside of the UGB, and has a slope averaging between 0.0016 feet/feet and 0.0025 feet/feet. Depending on existing slopes a parallel system will be required ranging from 18 to 30-inches in diameter.

insert Figure VII-2

RECOMMENDED SEWER SYSTEM EXPANSION

The City of Sherwood's Urban Growth Boundary includes significant areas that are currently not served by the existing sanitary sewer system. All of these areas are part of either the Rock Creek Basin system or the Cedar Creek Basin system and can be easily served by extending laterals off the respective trunk lines of each basin. These new laterals have no special priority except to serve those who require sewer service. The locations of the recommended sewers are shown on Figure VII-3.

All new sewer lines should have a minimum diameter of 8-inches for ease of serviceability. These new laterals were designed by setting the slope of the sewer pipe invert, equal to the slope of the existing ground along the sewer line path. Individual pipe slopes may be required to be less than natural ground slopes in order to serve isolated areas of low ground elevation.

The sewer expansions are listed below under the basin in which they occur. The costs are listed by pipe diameter and are in 1990 dollars. These costs are typically paid for by the land developments that create the need for the extensions. The costs include design and construction. Land acquisition may be required but those costs are not included in the estimates below.

1.	Sewer Trunk Lines		
	Cedar Creek Parallel (15"-30")	12,640LF	\$991,000
	Rock Creek Parallel (18")	6,750 LF	\$378,000
2.	Rock Creek Basin Lines (All 8")		
	Tonquin	1400 LF	\$ 47,000
	Highland/12th	3000 LF	\$100,800
	Tualatin-Sherwood	2300 LF	\$ 77,300
	Onion Flats W.	5000 LF	\$168,000
	Onion Flats E.	2900 LF	\$ 97,500
3.	Cedar Creek Basin Lines (8" except as noted)		
	Steeplechase S. (10")	4100 LF	\$160,700
	Steeplechase N. (12")	650 LF	\$ 29,100
	Steeplechase N. (10")	4100 LF	\$161,000
	E. Sunset	1300 LF	\$ 43,700
	W. Sunset	3500 LF	\$117,600
	Scholls-Sherwood W.	1200 LF	\$ 40,300
	Scholls-Sherwood E.	3100 LF	\$104,200
	BPA#	3500 LF	\$117,600

insert Figure VII-3

WATER SERVICE PLAN

INTRODUCTION

The City draws the majority of its water supply from the Willamette River Water Treatment Plant (WRWTP) in the City of Wilsonville, approximately 6 miles southeast of Sherwood. The City owns 5 million gallons per day (MGD) of production capacity in the existing WRWTP facilities. Sherwood also maintains four groundwater wells within the city limits for back-up supply. Prior to 2011, the City also purchased water from the Portland Water Bureau (PWB) through the City of Tualatin's water system and maintains an emergency connection and transmission piping associated with this supply source.

~~This is a 1988 update to the Water Service Plan element of the Sherwood Comprehensive Plan dated July, 1979.~~

The City's future water service area is comprised of five different planning areas:

1. Sherwood city limits
2. Tonquin Employment Area (TEA)
3. Brookman Annexation Area
4. West Urban Reserve
5. Tonquin Urban Reserve

Each of these areas has their own land use characteristics, approximate development timelines and existing planning information. Estimates of future growth and related water demand are developed using the best available information for each area including Sherwood buildable lands geographic information system (GIS) data, population growth projections, development area concept plans and current water demand data.

Water demand growth is projected at 10 years, 20 years and at saturation development. Estimated water demands at saturation development are used to size recommended transmission and distribution improvements. .The population projections used in this analysis are for the year 2008. The following is fully described in the City of Sherwood "Water Service Plan Update," May 1988.

~~The year 2008 population projections are significantly lower today than were anticipated in the original Water Service Plan. This population projection difference, upgrades to the City's water system, and the growth that has actually occurred since 1979, warrant an update to the 1979 Water Service Plan.~~

~~In this update, the City's existing major water distribution lines were analyzed for their ability to deliver peak domestic and fire flows with adequate pressure to all developed areas of the City. The amount of water needed supply to meet future growth is also reviewed.~~

~~Specific improvements are recommended to the existing water system to meet the year 2008 needs~~

~~in currently served areas of the City. Major water lines required as extensions to areas without service are also identified. The cost of all recommended and identified improvements are listed in 1990 dollars.~~

~~The amount of growth that can occur within distinct areas and neighborhoods within the City's Urban Growth Boundary without creating pressure or overall supply problems is also estimated.~~

~~1. The City's existing reservoir capacity of 2.5 million gallons (MG) is adequate to cover the needs of the City until a population of 8,200 is reached.~~

EXISTING WATER SYSTEM CONDITIONS

Pressure Zones

Formatted: Font: Bold

The City's existing distribution system is divided into three major pressure zones. Pressure zone boundaries are defined by ground topography in order to maintain service pressures within an acceptable range for all customers in the zone. The hydraulic grade line (HGL) of a zone is designated by overflow elevations of water storage facilities or outlet settings of pressure reducing valves (PRVs) serving the zone.

The majority of Sherwood customers are served from the 380 Pressure Zone which is supplied by gravity from the City's Sunset Reservoirs. The 535 Pressure Zone, serving the area around the Sunset Reservoirs, is supplied constant pressure by the Sunset Pump Station, and the 455 Pressure Zone serves higher elevation customers on the western edge of the City by gravity from the Kruger Reservoir.

Storage Reservoirs

Formatted: Font: Bold

Sherwood's water system has three reservoirs with a total combined storage capacity of approximately 9.0 million gallons (MG). Two reservoirs, Sunset Nos. 1 and 2, provide 6.0 million gallons (MG) of gravity supply to the 380 Pressure Zone. The other reservoir, Kruger Road, provides 3.0 mg of gravity supply to the 455 Pressure Zone.

Pump Stations

Formatted: Font: Bold

Sherwood's water system includes two booster pump stations, the Sunset Pump Station and the Wyndham Ridge Pump Station.

The Sunset Pump Station is located in Snyder Park adjacent to the Sunset Reservoir complex and has an approximate total capacity of 3,770 gallons per minute (gpm). This station provides constant pressure service and fire flow to the 535 Pressure Zone.

The Wyndham Ridge Pump Station is located on SW Handley Street west of Highway 99W. Two 40-hp pumps supply a total capacity of approximately 1,200 gpm from 380 Zone distribution piping to the Kruger Road Reservoir.

Distribution System

Formatted: Font: Bold

~~The City's distribution system is composed of various pipe materials in sizes up to 24 inches in diameter. The total length of piping in the service area is approximately 77.4 miles. Pipe materials include cast iron, ductile iron, PVC and copper. The majority of the piping in the system is ductile iron. The City of Sherwood's existing water system is as shown on Figure VII 4. The source of all of the City's water is from three wells. A single 2.0 million-gallon reservoir is the sole source of storage and controls operating pressures throughout the City. The major pipelines that distribute the flows to the users range in size from 16-inch diameter to 6-inch diameter. Many smaller diameter lines are not analyzed because they are not relied upon for the distribution of large amounts of flow to general areas of the City. It is, however, recommended that the City continue its recent active policy of upgrading these smaller lines through the processes of annexation, development, and direct City cost sharing.~~

~~The three wells are located at the intersection of S.E. Pine and E. Willamette streets in Old Town, near Pacific Highway by S.W. Meinecke Road, and on W. Sunset Boulevard near St. Charles Way. The storage reservoir is located on high elevation ground in the southeastern portion of the City on E. Division Street. The distribution system is characterized by looped water lines in Old Town and nearby established residential areas. The water lines in the vicinity of Edy Road extend as unlooped single lines for long distances.~~

~~One small residential area bounded by E. Division Street on the north and S. Pine Street on the west in the vicinity of the water storage reservoir is in a separate pressure zone from the remainder of the City. This area is too high in elevation to rely on gravity to provide required pressures. A booster pump station adjacent to the reservoir provides the needed pressure.~~

~~Data on all the physical aspects of the water system was provided by the City of Sherwood staff. The physical system was modeled using the Pressure Pipe Network Analysis water distribution computer model.~~

~~Data on population projections were also provided by City staff. Design flow considerations were based on the information provided in the City of Sherwood's 1979 Water Service Plan.~~

ANALYSIS OF EXISTING WATER SYSTEM

Water Supply

Formatted: Font: Bold

Sherwood's supply from the WRWTP is sufficient to meet MDD through the 10-year planning

horizon with an additional 1 mgd of capacity required at 20 years and an additional 4 mgd needed at build-out. Existing City groundwater wells provide an effective emergency supply to complement emergency storage in the City's reservoirs.

Pumping and Storage

Formatted: Font: Bold

The City's distribution system has adequate storage and pumping capacity to meet existing service area demands through 2034. Due to significant uncertainty related to long-term growth and system expansion, minor storage and pumping deficiencies at build-out should be re-evaluated with the next Water Master Plan Update or as development warrants. Additional pump stations are recommended to serve proposed high-elevation closed pressure zones in the water service expansion areas: Brookman Annexation and West Urban Reserve.

Distribution Piping

Formatted: Font: Bold

Sherwood's distribution piping is sufficiently looped to provide adequate fire flow capacity to commercial, industrial and residential customers. Few piping improvement projects are needed to meet fire flow criteria. Extensive large diameter mains will be needed to expand the City's water service area to supply the Brookman Annexation, TEA and West Urban Reserve as development occurs.~~Peak Domestic Flows Analysis-~~

~~The total peak domestic flow rate for the year 2008 used in this analysis is 3,000 gallons per minute. The domestic flow is the combination of all residential, commercial, and industrial uses other than those for fire protection. Domestic use also accounts for summertime irrigation of lawns and landscaping.~~

~~The total peak domestic flow rate of 3,000 gallons per minute is derived from the detailed data published in the 1979 Water Service Plan and has been increased by approximately 15 percent as a conservative measure for unexpected conditions such as excessive water line leakage, high volume users, etc.~~

~~The 1979 Water Service Plan estimated the water usage by the City's commercial and industrial customers to be 30 percent of the residential use when the City's population reached 7,800 people. This percentage was used in the determination of the peak domestic flow rates in this analysis. The total peak domestic flow rate is based on a maximum peak consumption of 410 gallons per capita per day, and is consistent with the 1979 Water Service Plan.~~

-insert Figure VII-4

~~The total 3,000 gallons per minute peak domestic flow was proportioned throughout the existing developed areas of the City, based on knowledge of the amounts and types of potential development that can occur in each area. Within each area of the City the proportioned flow was concentrated at "worst case" locations so that deficiencies in the City's water system would be highlighted.~~

~~Computer models require calibration to known data to assure that they represent the physical system. Known information on the pumping capacity and characteristics of the City's three wells, including their effect on the groundwater table and the historical operation of the wells and the water storage reservoir, was used to calibrate the factors in the computer model. The computer model accurately matches the operation of the City's wells and water storage reservoir during peak use.~~

~~Peak Domestic Flows Results~~

~~The existing water system for the City of Sherwood meets the needs of the peak domestic flows in the year 2008. There are no areas requiring improvements to meet these domestic needs. The resulting operating pressures during the peak flows range from 40 to 85 psi (pounds per square inch) throughout the City. The acceptable range for water line pressures is 20 to 100 psi.~~

~~Fire Protection Flows Analysis~~

~~The flow rate required to provide adequate fire protection varies with the type of building. Single family residential requires fire flows of only 1,500 gallons per minute, whereas large industrial and commercial structures without fire sprinklers can require fire flows in excess of 4,000 gallons per minutes. Most new construction of larger structures is required to have fire sprinklers for increased fire/life safety. Fire sprinklers reduce the flow requirements for fire protection.~~

~~For a City the size of Sherwood, it can only be expected that adequate flows for one major fire at a time can be provided. The low probability of multiple major fires at one time does not warrant the major expense of providing the additional supply sources and the larger diameter pipe lines. Also, because of the expense, it is cost effective to require fire sprinklers in structures that would require excessive amounts of flow for fire protection.~~

~~For this analysis, a fire flow of 2,000 gallons per minute is used to determine the adequacy of the water supply and distribution system to provide fire flows at an adequate operating pressure. The fire flow is assumed to be concurrent in time with the peak domestic flows.~~

~~Fire Protection Flows Results~~

~~The computer model was used to simulate the need for fire flows to every area of the city. In general, the ability to adequately supply fire flows in most areas of the City is good. There are three~~

areas where the flows could not be delivered at desired pressures. They are as follows:—

- 1. Edy Road Area near Tualatin/Sherwood Road.—
- 2. Scholls-Sherwood Road area north of Highway 99W.—
- 3. Area at the southern end of E. Roy Street.—

The water lines in these three deficient areas are unlooped single lines. Additional lines were added to the computer model to assess the impact of connecting these lines to other existing water lines to form loops. Modeling results show that this improvement to the existing system is sufficient to adequately provide fire flows at adequate operating pressures. Fire flows in excess of 2,000 gallons per minute can be provided to all other areas of the City. Some areas can deliver fire flows in excess of 4,000 gallons per minute.—

Water Supply Capacity Analysis

Three wells are the sole source of water for the City. Combined, they provide nearly 2,000 gallons per minute of flow. The pressures they provide are nearly identical to the gravity pressure provided by the water storage reservoir. The pressure supply system is therefore well balanced. The three well pumps and booster pump, at the reservoir, all rely on electrical power only. There is no emergency stand-by power.—

The normal operation of the reservoir and the wells is for the reservoir to supply all the needed water until the reservoir is 225,000 gallons short of being full. At this point, the wells are used to supplement supply to the users and refill the tank. Normally only one well is operating at a time unless the demand is greater than can be provided by the one well. This is a very efficient system and provides a high margin of safety during emergencies as normal operation never allows the reservoir to be less than 89 percent full. This high margin of safety is very unusual for communities the size of Sherwood. Many cities must pump constantly for all their water use while having little or no storage for emergencies. This excellent supply system would be considered a luxury to most small cities.—

In the event of a fire, the reservoir can supply adequate fire protection flows even if all the pumps in the wells are inoperative. The reservoir alone can provide 5,000 gallons per minute of flow for 6.6 hours and 7,000 gallons per minute of flow for 4.7 hours. Five thousand gallons per minute is equal to the year 2008 peak domestic flows and a simultaneous 2,000 gallon per minute fire flow.—

Water Supply Capacity Results

The water supply sources and the pressures they provide are well balanced and more than adequate to meet the demand needs through the year 2008. New sources of water are not necessary to provide additional quantities.—

~~Emergency stand-by power would provide an additional margin of safety during periods of total power loss. The booster pump at the water storage reservoir is the only source of pressure for the residents in the E. Division Street and upper S. Pine Street area. During power outages, this area is without adequate water service. Stand-by power is recommended for this booster pump to eliminate this potential problem.~~

~~Although the water storage reservoir provides ample volumes of water for emergencies, it is recommended that stand-by power be provided at one of the wells as an added precautionary measure for extended periods of power outage. Since Well No. 3 is the City's largest well, stand-by power is recommended for that well. Completion of a manually operated interconnect at Cipole Road with the City of Tualatin water system is also recommended as an additional safeguard against a catastrophic interruption in the City of Sherwood's system.~~

RECOMMENDED IMPROVEMENTS TO EXISTING WATER SYSTEM

Recommended improvements for the City's water system include proposed supply, pump station and water line projects.

Cost Estimating Data

Formatted: Font: Bold

An estimated project cost has been developed for each improvement project recommended. Cost estimates represent opinions of cost only, acknowledging that final costs of individual projects will vary depending on actual labor and material costs, market conditions for construction, regulatory factors, final project scope, project schedule and other factors. The cost estimates presented have an expected accuracy range of -30 percent to +50 percent. As the project is better defined, the accuracy level of the estimates can be narrowed. Estimated project costs include approximate construction costs and an aggregate 45 percent allowance for administrative, engineering and other project related costs.

Capital Improvement Program

Formatted: Font: Bold

A summary of all recommended improvement projects and estimated project costs is presented in Table ES-3 of the 2015 City of Sherwood Water System Master Plan Update. The table provides for project sequencing by showing fiscal year-by-year project priorities for the first five fiscal years, then prioritized projects in 5-year blocks for the 10-year, 20-year and Beyond 20 year timeframes. The total estimated cost of these projects is approximately \$24.6 million through FY 2034. Approximately \$19.9 million of the total estimated cost is for projects needed within the 10-year timeframe and \$5.4 million of these improvements are required in the next 5 years.~~Improvements are recommended to the existing water system to provide adequate fire protection capability to three areas of the City. Improvements are not necessary for year 2008 population projections. These recommendations are based upon the assumption that water lines are not required to be extended~~

~~into areas currently not needing services.~~

~~The recommended improvements are shown on Figure VII-5 and are listed below. Improvements numbered 1, 2, and 3 are deemed to be of greater priority. The projects can be constructed in almost any order however. The only exception is that the Edy Road Loop Completion should precede the Edy Road to Oregon Street Loop Completion in order to provide the greatest benefit to the users along Edy Road. The costs are in 1990 dollars and include design and construction. Land acquisition may be required but those costs are not included in the estimates below.~~

Recommended Improvements to Existing Water System

1. Loop Projects

— Tualatin-Sherwood	3800 LF	\$238,000
— Scholls-Sherwood	2800 LF	\$178,500
— Murdock/Roy	600 LF	\$ 59,500
— Highland Extension	2700 LF	\$178,500
— Tualatin-sherwood Relocate	2130 LF	\$ 74,100

2. Supply Projects

— Well No. 6 (Murdock)	800' deep	\$236,500
— Reservoir Booster Pump	35 hp gen.	\$ 59,500
— Well No. 3 Standby Power	75 hp gen.	\$119,000
— Cipole Road Intertie with City of Tualatin		\$ 23,400 (50%)

3. 4 Inch Waterline Replacements

— Old Town (8")	1600 LF	\$ 76,800
— Ladd Hill (12")	1300 LF	\$ 92,300
— Meinecke/99W (8")	2000 LF	\$ 96,000
— W. Sunset (10")	1500 LF	\$ 88,500

4. 6-Inch Waterline Replacements (all 8")

— Old Town	1600 LF	\$ 76,800
— Lower Lincoln	1000 LF	\$ 48,000
— Lower Roy	1300 LF	\$ 62,400
— Oregon	1300 LF	\$ 62,400
— Upper Washington	1300 LF	\$ 62,400
— Gleneagle	3000 LF	\$144,000
— Upper Roy	900 LF	\$ 43,400

5. Other Waterline Extensions

— 12 Inch	18,500 LF	\$1,313,500
— 10 Inch	32,800 LF	\$1,935,200
— 8 Inch	25,400 LF	\$1,219,200

Beyond these recommended improvements, the City should continue its existing undersized water lines replacement program.

RECOMMENDED WATER SYSTEM EXPANSION

The City of Sherwood's Urban Growth Boundary includes significant areas that are currently not served by the existing water system. Major water lines are required for expansion of the existing water system into these areas as they develop, and are as shown on Figure VII-5. These line extensions have no special priority except to serve those who require the water service. The locations of the recommended waterlines on Figure VII-6 are schematic only and generally should be conformed to an updated City Transportation Plan for maximum economy and efficiency.

The critical element for expanding the water system in segments is to not construct unlooped single lines for long distances. The maximum length will vary depending on the diameter of the water line and the elevation of the site being served. It would be ideal if unlooped line extensions did not extend so far as to not be able to provide 2,000 gallons per minute of flow with an available end operating pressure of 20 psi. It is recommended that the minimum City of Sherwood standard for water line size be eight inches in diameter for all public lines.

| ~~insert Fig. VII-5~~

~~As noted on Figure VII-5, the existing booster pump near the water storage reservoir may need modification as the service area of that pressure zone is expanded. Also noted is another area (#1) at the western edge of the Urban Growth Boundary just north of Pacific Highway and along Elwert Road that will require a booster pump and its own pressure zone water lines. This is a high elevation area where the 1979 Water Service Plan identified the location for a future water storage reservoir.~~

~~The 1979 Water Service Plan recommended water line loop expansions outside the Sherwood Urban Growth Boundary. These have been re-routed in this update to be completed within the Urban Growth Boundary. The number of major loops have been reduced from the 1979 Water Service Plan and the area each loop serves increased to provide a more cost-efficient future water system.~~

~~The costs of these smaller pressure zone expansion improvements are difficult to estimate. These costs are relatively small compared to the \$4.5 million cost to expand the water system in all the other areas. For the purposes of this report, a cost of \$500,000 is used, making the entire total system expansion cost \$5,000,000.~~

| -Insert Fig VII-6

F. DRAINAGE PLAN

INTRODUCTION

The Sherwood Planning Area is located within the Willamette River-Tualatin River Basin as identified in the Portland-Vancouver Metropolitan Area Water Resources Study (PMAWRS). The Cedar Creek and Rock Creek sub-basins channel surface runoff to the Tualatin River just north of the Planning Area. Within these sub-basins there exists considerable variation in slope. A highland area known as Washington Hill has some erosion and sedimentation potential. High groundwater and poorly drained soils in portions of the northern half of the Planning Area will require measures to regulate excavation and site drainage.

In March 1989, DEQ issued draft rules for storm water quality control to all jurisdictions in the Tualatin River sub-basin. The City of Sherwood is required to comply with the rules and participate in the development of a Surface Water Drainage Management Plan for the region. When the Plan is completed and adopted this section will be amended accordingly.

Objectives

1. Comply with DEQ Storm water quality control rules until completion of a Drainage Management Plan.
2. Cooperate with United Sewerage Agency, Washington County, and DEQ in the preparation of a Drainage Management Plan.

Findings

1. A storm drainage plan for the City's urban growth area has been developed and is illustrated on Figure VII-7. Major storm sewers are recommended for construction in accordance with the Plan; minor storm sewers are not shown on the proposed storm drainage plan. This Plan will be updated upon completion of the regional Drainage Plan.
2. Cedar Creek, Rock Creek, and Chicken Creek shall continue to be the City's primary conveyance systems for storm runoff.
3. Existing flood areas have been identified and are analyzed and described in Section VII Background Data and Analysis. It is anticipated, all but one of the problem areas will be eliminated by implementation of the Plan. An area of flooding at N.W. 12th Street and Highway 99W remains to be resolved by construction of a minor storm sewer, which is not shown on the Plan.

4. The rational method formula was used to estimate runoff to proposed storm sewers. This method has a tendency to overestimate design flows when applied to large basins. Runoff coefficients used in the rational method are predicted on the City's Comprehensive Plan. During final design of storm sewers, actual development within the basin should be reviewed to verify previous assumptions in selection of a runoff coefficient.

5. Cost estimates for proposed storm sewer improvements have been prepared, based on 1980 construction costs and increased in 1990 by 1.25%, and on Engineering News Record (ENR) index of 3264. These estimates are presented in Table 2 of the Appendix.

6. Design of relief culverts in Cedar Creek and Rock Creek may significantly alter hydraulic control sections used by the U.S. Army Corps of Engineers to establish water surface elevations and limits of the flood plain as set forth in Flood Insurance Study, City of Sherwood, Oregon, and provided to the City in preliminary draft, dated December 17, 1980. Design of relief culverts should be coordinated with the U.S. Army Corps of Engineers to insure integrity of their flood insurance study.

Implementation

1. The City will endeavor to establish a source of revenue to finance the cost of storm sewer construction, acquisition of lands along creeks, maintenance of storm sewers and waterways, and administration of the storm plan in accordance with the regional Surface Water Drainage Management Plan.

2. Until user fees are in effect, the City should obtain waivers of remonstrance to future storm drainage improvements projects from all property owners wishing to develop their land, and the City should also require all developers to provide adequate storm sewers to serve their property as well as those properties that would naturally drain to the proposed storm sewer.

SOLID WASTE

Solid waste disposal is a regional concern requiring regional solutions. The City of Sherwood recognizes MSD's responsibility and authority to prepare and implement a solid waste management plan and supports the MSD Solid Waste Facilities Model Siting Ordinance and will participate in these procedures as appropriate. There are no landfills in Sherwood.

The Model Siting Ordinance will be incorporated into this Plan when approved by METRO. In addition, the City conducted extensive hearings on solid waste incineration in 1990 and determined incineration is generally not a form of solid waste disposal environmentally compatible in the community except in limited circumstances. Therefore, solid waste incineration is generally prohibited by this Plan.

Electrical Power

The Sherwood Planning Area is well served by major power facilities. Portland General Electric Co. (PGE) runs and operates a major regional sub-station in the northern portion of the Planning Area and has a network of major transmission lines which cross the Planning Area. Minor sub-station siting and construction, if needed in response to development, will be coordinated with PGE.

Natural Gas

The Sherwood Planning Area is served by Northwest Natural Gas Co. (NNG) lines. The existing system consists of a 6" high pressure line extended to the Planning Area via Tualatin-Sherwood Road, So. Sherwood Blvd. and Wilsonville Road. The distribution system is adequate to serve immediate development. NNG reports that the 6" main will be adequate to serve growth projected by the Plan with new lateral line extensions and attention to proper "looping" of existing lines.

Telephone

General Telephone services the Sherwood Planning Area. Planned improvements should have the capability of handling projected growth demands in the Area.

H. SCHOOLS

INTRODUCTION

The Sherwood Planning Area is wholly contained within Sherwood School District 88J. Although the City of Sherwood is the only currently urbanized area within the district, district boundaries include approximately 44 square miles and parts of Washington, Clackamas, and Yamhill Counties. The District is currently predominately rural but, by the year 2000, the Sherwood Planning Area will contribute most of the total student enrollment.

FUTURE ENROLLMENT/FACILITY NEEDS

The School District completed a School Enrollment Study (Metro Service District Analysis) in the Fall of 1990. Revisions were made in the Spring of 1991. The study data suggests that school enrollments will be increasing sharply in the coming years. The growth assumption is supported by record-setting residential building permit issuance during 1990. Major arterial road improvements between I-5 and 99W will also cause further growth and development.

ELEMENTARY AGE STUDENTS (K-5)

J. Clyde Hopkins Elementary School has a capacity to house 600 students. Currently, 670 students are enrolled in grades K-5. Three double portable classrooms and one single portable classroom are utilized to address the growing elementary age population.

INTERMEDIATE AGE STUDENTS (6-8)

Approximately 300 students are enrolled in grades 6-8. The Intermediate School building capacity is 400 students. This capacity can be accessed by relocating District office services, which occupy a four classroom wing of the building.

HIGH SCHOOL AGE STUDENTS (9-12)

Sherwood High School has a capacity of 500 students. Approximately 420 students are currently enrolled. No major housing issues exist in this 1971 constructed facility.

SCHOOL FACILITY PLANNING

The School District is preparing to undertake a detailed facility development plan. The most immediate need for the District is to expand housing of elementary age school children (K-5). During the Fall of the 1990-91 school year, the District completed the purchase of a new elementary school site located within the City limits of Sherwood. The District also owns a school site (purchased in 1971) in the proximity of the Tualatin portion of the school district.

The intent of the District is to seek voter approval of a bond measure to address short and long-term housing needs. The measure is planned to be submitted in the Fall of 1991 or the Spring of 1992 in order to construct an additional elementary school.

I. PUBLIC SAFETY

POLICE PROTECTION

The City of Sherwood, Washington County and the State Police co-ordinate police protection within the Planning Area. In 1989 the Sherwood Police Force consisted of five officers. In order to meet future demand it is anticipated that the department will need additional patrolmen proportional to the projected increase in population. The State formula for City police protection is one officer per 500 people. The police force should expand accordingly.

FIRE PROTECTION

The Planning Area is wholly contained within the Tualatin Valley Consolidated Fire and Rescue

District. One engine house is located within the City. The District feels that present physical facilities will be adequate to serve the projected year 2000 growth in the area with some increase in manpower and equipment. The District currently employs a 5-year capital improvement planning process which is updated annually. The City will co-ordinate its planning with the district to assure the adequacy of fire protection capability in the Planning Area.

J. GENERAL GOVERNMENTAL SERVICES

As a general purpose governmental unit, the City of Sherwood intends to fulfill its responsibilities in the principal areas of general administration, planning, public works, and library services. With expected growth in Sherwood, additional manpower and facilities will be required.

1. Manpower Needs

In 1989 there are currently seventeen (17) City staff in general governmental services. A review of cities which have reached Sherwood's projected five and twenty year growth levels indicate that new staffing will be needed proportional to population increases in most departments. Using this assumption a full-time staff of 15-20 persons will be required by 1985 and a staff of 20-40 will be needed by the year 2000. Most critical immediate needs are in the area of clerical staff to support existing departmental work loads.

2. Space Needs

The City offices, water department, police department, planning department and public works, are currently housed in a remodeled turn-of-the-century house. Although the structure is significant historically and should be saved, it may not meet the long term functional or space needs of a City Hall.

In 1982 the Senior and Community Center was built and provides meeting space for the City Council and Planning Commissions.

K. HEALTH FACILITIES

The local health system is linked to a number of organizations and institutions that can and do affect how it will develop. The latest planning legislation P.L. 93-641 and its recent amendments has placed Health care delivery systems planning are under the auspices of the State Certificate of Need laws and the Federal Health System Agency (HSA) planning regulations. Sherwood is located in the six county Northwest Oregon Health Systems Agency (NOHS) which is charged with reviewing new service proposals, expenditures involving public funds and the development of a health system plan for the area. The first HSA plan was adopted in 1978. State agencies administer HSA regulations. NOHS established subdistricts within the six county service area. Sherwood is located in the south-rural sub-district (see Figure VII-8). The only hospital located in the sub-district is Meridian Park Hospital in Tualatin.

Sherwood is served by various Metropolitan area hospitals depending on local physician affiliations. The City currently has only one doctor with offices in the Planning Area. St. Vincent's Hospital in Beaverton has expressed interest in establishing a satellite clinic in Sherwood.

The City will encourage the decentralization of Metropolitan health care delivery to assure that a broad range of inpatient, outpatient and emergency medical services are available to Sherwood residents. To that end the City will support the location of a St. Vincent's Satellite Center in Sherwood and encourage the appropriate expansion of Meridian Park facilities to meet the growing needs of the Planning Area.

L. SOCIAL FACILITIES AND SERVICES

A broad range of social services will be needed in the Planning Area to serve a growing urban population. Sherwood will continue to depend on metropolitan area services for which the demand does not justify a decentralized center. Multi-purpose social and health services and referral are offered by the Washington County Satellite Center in Tigard. The City will encourage the continued availability of such services.

Sherwood is located in Region 8 of the State Department of Human Resources Service Area and benefits from that agency's services. State services are administered through the County's Washington County office located in Hillsboro. In addition to public social service programs, many private organizations serve the Sherwood area.

The City is particularly interested in locating a multi-purpose social and health service referral agency in Sherwood so that residents of Sherwood would be able to get timely information on the available services. The City also supports the development of a Comprehensive Social and health services delivery plan for the Planning Area to identify gaps in needed services and develop an ongoing strategy for their provision. Of particular concern are day care and senior citizens services.

Day Care

A growing need exists for day care. State standards for the establishment of day care centers are supplemented by City standards. Currently day care has been carried on by churches and small home operations. The City recognizes and supports the proper siting and housing of day care services.

Senior Citizens Services

With an increasing proportion of the Planning Areas population reaching the age of 60, Sherwood will require additional specialized services and facilities for senior citizens. The City was awarded a grant from HUD for a Senior Citizen Community Center was completed in 1982. Community Center functions will be carried out under the authority of the City. It is the intent of the City that the Center be the focus for the Community activities requiring meeting and multi-purpose areas with particular emphasis on Senior Citizens programs and activities.

APPROVED MINUTES

City of Sherwood, Oregon
Planning Commission
March 24, 2015

Work Session

Planning Commission Members Present: Staff Present:

Chair Jean Simson

Brad Kilby, Planning Manager

Vice Chair Russell Griffin

Michelle Miller, Senior Planner (work session only)

Commissioner Pearson

Connie Randall, Associate Planner (work session only)

Commissioner James Copfer (regular mtg only) Kirsten Allen, Planning Dept. Program Coordinator

Planning Commission Members Absent:

Commissioner Lisa Walker

Council Members Present:

Council President Sally Robinson

Legal Counsel:

Chris Crean (regular meeting only)

Note: Two Planning Commission seats are vacant.

Chair Jean Simson called the meeting to order at 6:00 pm.

1. Medical Marijuana Dispensary Draft Language

Michelle Miller gave a presentation with a review of the Public Work Session held on March 10, 2015, the online survey results and the draft language for Medical Marijuana Dispensary (MMD) legislation (see record, Exhibit 1). Discussion followed. Staff was directed to amend the location of the verbiage in the Industrial Zone code section of the Sherwood Municipal Code and to add City Council's directive not to ban MMD's outright to any future presentations to the public.

2. Housing Needs Analysis regulatory framework

Kirstin Green, with Cogan, Owens, Green the City's consulting firm for the Sherwood West Preliminary Concept Plan reviewed the *Executive Summary: Sherwood Housing Needs Analysis* prepared by ECONorthwest (see record, Exhibit 2). She said the document provided was the "light" version at five pages as housing needs analyses are very detailed and generally over one hundred pages. The draft Housing Needs Analysis is available on line under the About the Project tab at www.sherwoodoregon.gov/sherwoodwest. The Sherwood West Preliminary Concept Plan Community Advisory Committee will discuss the Housing Needs Analysis on April 2nd. Discussion followed.

Chair Simson adjourned the work session at 6:59 pm to convene to a regular Planning Commission meeting.

Regular Meeting

1. Call to Order/Roll Call

Chair Jean Simson called the meeting to order at 7:04 pm.

2. Consent Agenda

Chair Simson asked for a motion and the following was received.

Motion: From Commissioner Alan Pearson to approve the Consent Agenda, Seconded by Vice Chair Russell Griffin. All present Planning Commissioners voted in favor (Commissioner Walker was absent).

3. Council Liaison Announcements

Council President Sally Robinson said the Council would review the Medical Marijuana Dispensaries code language expected to be forwarded by the Planning Commission and announced the Sherwood West Preliminary Concept Plan Community Advisory Committee meeting on April 2, 2015 at 6:30 pm at the Sherwood Police Department.

4. Staff Announcements

Brad Kilby, Planning Manager, announced the Police Advisory Board meeting on April 2, 2015 at 7pm at City Hall would be discussing the Medical Marijuana Dispensaries draft language. He stated that resolutions for two new Planning Commission members would be before the City Council on April 7th; Christopher Flores and Michael Meyer. The new commissioners will be seated before the April 14, 2015 Planning Commission hearing for the medical marijuana legislation.

Mr. Kilby informed of a neighborhood meeting April 20th at City Hall in the mezzanine for the Woodhaven Park improvements, which will include parking and some more formal play areas. He reminded audience members of an opportunity to sign up for weekly notifications related to Planning updates available on the website at <http://www.sherwoodoregon.gov/subscribe>.

Mr. Kilby advised that a new Planning Commission liaison will be needed for the Cedar Creek Trail Local Trail Advisory Committee after the departure of John Clifford from the Planning Commission. The Cedar Creek Trail procurement process at the Oregon Department of Transportation is near completion.

5. Community Comments

There were no community comments.

6. New Business

a. Public Hearing – PA 15-01 Water System Master Plan Update

Chair Simson read the public hearing statement and turned the time over to the Planning Department for a staff report.

Brad Kilby, Planning Manager, informed that the proposed plan amendment incorporated the 2015 Water System Master Plan by reference into the Comprehensive Plan and said Sherwood's Comprehensive Plan had not been updated since 1991. He indicated that the City wanted to take the opportunity to update the Comprehensive Plan with this iteration of the Water System Plan update.

Mr. Kilby pointed to Chapter 7 in Volume 2 of the Comprehensive Plan about [Community Facilities and Services] indicating that the City would update:

- The Table of Contents page,
- Objective B.7, by removing plan dates and make relevant to the current,
- Table VII-1, to reflect the name change from the Unified Sewerage Agency to Clean Water Services, and
- Remove references to telephone and cable providers.

He stated that the entire section under the Water Service Plan including the Introduction, Existing Water System Conditions, Analysis of the Existing System and Recommended Improvements to the Existing System would be replaced and the 2015 Water Master Plan would be adopted by reference.

Mr. Kilby described two specific criteria in the Development Code, chapter three of the Comprehensive Plan, that require

a.) An established need for the changes being proposed is consistent with state, local, and regional laws relating to water systems.

Mr. Kilby believed council established a need by initiating the consultant contract and going through the process of updating the Water System Master Plan; and

b.) Amendments are consistent with the Transportation Planning Rule (TPR).

In updating the Water Service portion of the Chapter 7, the proposed amendments have no effect or bearing on the functional classification of any streets in the transportation system. This criterion was deemed not applicable.

Mr. Kilby explained that Exhibit A, in the packet, was the tracked changes version which included the proposed amendments. He said items shown in red strikethrough are proposed to be deleted (everything in the original 1991 comprehensive plan relating to the water system) and replaced in essence with the Executive Summary from the 2015 Water System Master Plan.

Mr. Kilby indicated that other portions of Comprehensive Plan, Chapter 7 still had references to the Unified Sewerage Agency and other outdated items and the hope was to update the Sewer Master Plan and Waste Water Master Plan, thus updating those portions of Chapter 7 at that time.

Mr. Kilby said Exhibit B was the clean version of the proposed language. He explained that there were questions raised by the Commission at the work session on February 24, 2015 and Exhibit C was a

letter from Craig Sheldon, Public Works Director, addressing concerns raised by the Commission. Exhibit D was the Draft 2015 Water System Master Plan.

Mr. Kilby indicated the Planning Commission would make a recommendation to the City Council, that staff believed findings had been made demonstrating a need to make the changes within the Comprehensive Plan and recommended a Planning Commission recommendation to City Council for approval of the proposed changes to the Comprehensive Plan. He asked for questions from the Commission.

Chair Simson commented that the City was adopting the Water System Plan by reference, but was limited by the existing format of the current Comprehensive Plan because it was really old. She asked for language at the end of the introduction paragraph shown on page 62 of the packet. Brad proposed the following be added *“the Water System Master Plan, that provides the supporting documentation to this section, is available as Appendix A to Volume 2 of the Sherwood Comprehensive Plan”*. There are no current appendixes to the Comprehensive Plan. Chair Simson ensured that other members of Commission had no objections to the added language. None were received.

Chair Simson asked about the policy statement and the eight objectives in the current comprehensive plan on page 50-51 of the packet proposing a change to B.7 which had to do with water, sewer and the Transportation System Plan. Mr. Kilby confirmed, and said it was because it referenced the Water Master Plan updates by year specifically, which were removed.

With no other questions for staff, Chair Simson asked for applicant testimony.

Craig Sheldon, City of Sherwood Public Works Director and Heidi Springer, Murray, Smith and Associates (MSA) came forward. Mr. Sheldon offered to answer any questions the Commission had and reminded that the Commission had viewed a presentation at the work session on February 24, 2015. He said he attempted to respond to concerns raised at the work session through his letter (Exhibit C). Mr. Sheldon stated 9800 letters were sent to account holders (5700) and property owners outside of the city limits because the master plan works out to the year 2034 and the City wanted property owners near the city to be involved too. He provided notes from the open house held on February 25, 2015 (see planning record, Exhibit E). The Commission took time to read the letter.

Chair Simson asked for public testimony.

Anthony Bevel, Sherwood resident came forward and asked about water use in case of a drought, commenting that the mountain looked pretty grim. He asked if the City of Sherwood had plans in place regarding conservation and getting the word out to have citizens conserve water.

With no other comments, Chair Simson asked the applicant to respond.

Craig Sheldon answered that the City is a member of the Regional Water Providers Consortium and conservation measures are in line with the consortium as well as neighboring jurisdictions in the region. He said notice was given through the utility bill as well as conservation notices in the Archer at times throughout the year. Mr. Sheldon indicated that the City was required to put notices about

conservation in the paper April/May, because of the Willamette River fish flow. The City is required to measure the river every day during that time of year and a staff person does so every morning. He explained if the Willamette River hits a certain level we have to go into conservation measures, but commented that the chances of it happening were very slim because of the water rights obtained by Tualatin Valley Water District (TVWD) in the mid-2000's as well as our water management/conservation measures from 2009. Mr. Sheldon said more can always be done on water conservation and there were kits at the Utility Billing office at the Public Works building that property owners can have for free. Kits include leak detection, shower heads, and rain gauges from the Regional Water Providers Consortium.

Chair Simson asked for questions from the Commission regarding the plan amendment and the Water System Master Plan.

Chair Simson expressed concern about fund allocations. She said citizens pay a lot; people living in the Utah desert pay less than in Sherwood. Chair Simson asked what in the Master Plan was going to make the Commission feel that it was not voting in more increases for the citizens of Sherwood.

Mr. Sheldon replied that the City was set up today to have water for years to come without any problem and a number of agencies around Sherwood cannot say that. He said there were agencies building millions of dollars' worth of projects that would not get their end result and they will come looking for water at some point, maybe twenty years from now. Mr. Sheldon said one of the things that has been done is the oversizing of pipes from Wilsonville to Sherwood. He assured the Commission that a lot of work has been done in the last five years.

Mr. Sheldon clarified that when Tualatin Valley Water District (TVWD) ran the water system in Sherwood they did what the City asked them to do, which was not a lot, but a bare bones program and never really moved ahead. He explained that most of the projects designated as rate payers' projects in this master plan were maintenance projects related to upsizing pipes; there are 2" and 4" galvanized pipes that are old and most of the \$50,000 is for the older part of town. Mr. Sheldon commented that System Development Charges (SDCs) pay for growth and some development will need oversizing for different flows in certain areas. He said the Master Plan was a plan that anticipated growth to happen. Mr. Sheldon added that as the person responsible for the water system he was excited, because Sherwood has done some great things over the years.

Mr. Sheldon acknowledged Sherwood's higher rates and said TVWD's current rate from Portland would increase 17% this year, Hillsboro just raised their rates 8% in October, and Tigard's water rates were close to or higher than Sherwood. He said he sees a number of agencies building projects with a 2026 deadline, where Sherwood has built a system, receiving good prices on steel to build the system. He explained the biggest thing would be at the treatment plant; when the Water Treatment Master Plan is done and the shared costs on how the agency moves forward with its partners. Mr. Sheldon indicated that he could not say that water rates would go down. He commented that a lot of people don't understand that 80-90% of the costs involved with water are fixed. He recounted that Sherwood pays \$1.5 million just to get water and it would not matter if the water was from Wilsonville or Portland; that is strictly production costs. He added that pumping costs to the wells takes electricity

and PGE came out with a 6% rate increase this year. Mr. Sheldon said the City does not like to raise rates, but it starts to add up and rates have to be increased. He explained that City Council did not want to raise the rates and wanted to see how it went, so there were several years that rates were not increased. Mr. Sheldon said he would hate to give the Planning Commission misinformation, but out of all of the water systems around here, Sherwood, has done the right thing going to the Willamette, cost wise. And it will pay off in the long run.

Chair Simson commented that the 2015 Water Master Plan allocated a total of \$2.1 million to current customers. In a vacuum it is hard to relate what that means. She asked to compare that amount with what was allocated in the 2005 Water Master Plan. She expressed her thoughts that oversizing the pipe from Wilsonville to Sherwood was a smart move since the City did not want to build six miles of pipe twice, because it was not big enough the first time. Her understanding was the pipe was built to accommodate 50,000 people and even if the Sherwood West area was fully built, the City would have a big enough pipe to get the water to us from Wilsonville.

Mr. Sheldon responded that there were other factors to the oversizing. If future partners come online the City does not want our main transmission line that brings our water source to be shut down in order to bring those partners online. He explained the cost of upsizing of the pipe was a small amount when a ten foot deep ditch was already in the ground and with that cost comes the valving, the air vacuums, and everything else on the transmission line. Mr. Sheldon commented that oversizing the pipe was not for short term or future partners, but for the long term; 20 years from now.

Chair Simson asked if the emergency water access through Tualatin would be retained, as the contracts were expiring. She said it was discussed at the work session that if the water supply from Wilsonville was shut off the City would only have two days of water supply in our storage tanks, but as homeowners we are advised to have three days of emergency water. She questioned if the City was acting responsibly by only having little bit of storage and how long would it take to bring Tualatin online.

Mr. Sheldon responded that the plan called for the line to be shut down; but to remain as an emergency backup, after testing, chlorination, and flushing of the system. He explained that something could be online within two or three days. The City would have to flush the line and pass it through back tees in order for the water to enter the system.

Chair Simson asked for the fund allocation from customers in the 2005 Water Master Plan. Brian Ginter, from MSA responded that \$2.8 million in non-growth related projects was budgeted for the first ten years of the Capital Improvement Projects list from 2006-2015. The next ten years was similar with a total \$15 million in capital improvement projects in the 2005 Water System Master Plan which did not include the source improvements from Wilsonville to Sherwood that have been built. Mr. Ginter pointed out that when the plan was updated in 2005, a new source was not considered; it was just a distribution master plan.

Chair Simson commented that based on the capital improvements in the budget, rates should remain the same or go down taking nothing else into consideration. Mr. Sheldon commented that the biggest

cost was operational which would continue to go up. He informed the Commission that the City has made some operational changes through installation of AMI meters (smart meters) that should pay off in the next two years and staff is already seeing some of the savings from an operational side. He said one of the bare minimums in the 2005 Plan was for \$25,000 to be reserved for replacements and the 2015 Plan called for \$50,000 in replacement costs, because no money has been put into water infrastructure in the old part of town. The last larger project we did was upsizing a 6" water main on Upper Roy street to an 8" water main four or five years ago.

Chair Simson asked about the Supervisory Control and Data Acquisition System (SCADA). Mr. Sheldon explained that the SCADA telemetry system was how the City ran the water system after hours and collected data during the day from wells and pumps. He said staff can go online from home and run the water system after hours.

Vice Chair Griffin asked how long the city's investment with the city of Wilsonville was. Mr. Sheldon said he believed Tigard, Tualatin, TVWD, and Sherwood purchased water rights and stated Sherwood had guaranteed access to water through the Wilsonville plant from the Willamette River at least through 2043 or 2050 which could be renewed at that time.

Vice Chair Griffin inquired about other larger municipalities west of Sherwood who might find themselves in a pinch for water and asked if Sherwood could get pushed aside or that the amount we draw would be imposed upon by a larger customer coming to Wilsonville.

Mr. Sheldon replied that this subject was a topic of discussion at a regional level. He explained that there were plans for an additional treatment plant and all the water rights are expected to be used up around the year 2070. He stated that through an agreement with the Willamette River Water Coalition the City has up to twenty million gallons of water right and he did not see where Sherwood would get pushed out. Mr. Sheldon commented that there were bigger players at the table, a benefit to Sherwood, and that operationally, having those players build a second treatment plant could change some of the dynamics of how Sherwood draws water and how the treatment plant operates; current staff at the treatment plant can run both of plants and production water around 2026 should go down.

Vice Chair Griffin asked when the treatment plant master plan expected to be available. Mr. Sheldon responded that it would be the end of 2016.

Chair Simson commented on the Capital Improvements Program Summary, saying that of the \$36 million budgeted, \$34 million is expected to be paid by development as it occurs. She detailed that the way it had been explained to her was that a capital improvement project list allows the city to better forecast the SDC charges and provides a reasonability measurement for when a developer comes in and what they are paying for. Then development pays for the cost of growth. So even though huge amounts of projects are listed, the City is not using citizen's money until someone comes in to develop and then the developer pays through their SDC fees. She concluded that if the City has done the job right, existing customers do not have to pay for the cost of growth.

Note: developers also directly construct infrastructure needed to serve development.

Mr. Sheldon confirmed and commented on the lack of red lines in the 2015 Water System Master Plan that were prevalent in the 2005 plan. He said the City has spent money to get better data, in our water flushing program, in order to provide results to MSA for this update; in a water system you have to spend money to do some of this. He added that the City's goal with this update was to craft a plan that was more maintenance related now that the City has a long term source. Chair Simson received verification that the red lines from the 2005 Master plan were from water lines that needed to be fixed, replaced or maintained.

Vice Chair Griffin asked if Mr. Sheldon thought there was an Achilles' heel in the Water System. Mr. Sheldon answered that many other agencies wished they had what Sherwood's has; they have old pipes that cannot be funded. Sherwood has some things that need done, but overall is doing well.

Commissioner Copfer asked if there were any conversations about adding additional storage. Mr. Sheldon said there was not as they feel there was enough storage. Mr. Sheldon expounded that there was a plan for another reservoir at a future date. One was planned to partner with Wilsonville, but that did not work out. Instead the City built the reservoir at Snyder Park. He added that spending the money to build the second Snyder Park reservoir took a lot of the red the red lines off the master plan and the 535 Reservoir that will need to be built has been pushed out even farther.

Mr. Sheldon commented that if he had anything he was concerned about with this system it would be that there was no upper elevation reservoir serving the other side of Sunset Blvd and the area was getting fed strictly out of the new pump station. If the area was being fed out of an old pump station he would be worried because the City would be relying on a 1970 pump station in the summer months because water from the single existing reservoir could not pump down. He said he was less worried then he used to be.

Commissioner Copfer asked if Sherwood was part of the Wilsonville reservoir to be built on Tooze Road. Mr. Sheldon replied that we were not.

Chair Simson asked about a comment in the open house notes (Exhibit E) concerning the City double dipping in regards to street lights because the charge was on the utility bill. She acknowledged that the utility bill was not part of the Comprehensive Plan, but felt as a City representative, she needed to ask about the additional fees and taxes on the utility bill. Mr. Sheldon answered that the individual at the open house felt that the City was double dipping because PGE charged a franchise and street light fee on their bill. Mr. Sheldon remarked that everybody wants to talk about how high our water rates are and reminded that the utility bill covers a variety of utilities. He said the residential monthly bill for water averaged a little over \$40 and the sewer charge is about \$39. He explained that the city issues billing for Clean Water Services and they have indicated that they expect a 5% increase every year. Mr. Sheldon described the bill as including utilities, street fees and the street lights; a common practice on a number of agencies' utility bills.

Commissioner Copfer referred to the comment from the open house letter that stated that Clean Water Services had not increased the City's fees in years. Mr. Sheldon clarified that rates have been raised between 3-5% annually and said their storm rate increases annually as well; from about forty to fifty

cents last year. He said that the City does the billing for Clean Water Services on accounts outside of the city as well and they have been raising their rates.

Commissioner Copfer asked if there was a public record that shows how the funds collected are spent to verify that the funds are not being used for special projects outside what is approved. Mr. Sheldon responded that the Finance Department tracks the revenue, contingencies, and debt service. Commissioner Copfer wanted to know if there was an easy way of showing what the funds are being used for. Mr. Sheldon recommended making inquiries to the Finance Department.

Chair Simson expressed appreciation for the letter from Mr. Sheldon (Exhibit C), because of the concerns she had expressed about how much the projects were and how much customers were paying. She commented that the 2015 Water Master Plan called for saturation development, meaning that development for the Sherwood West was accounted for in the 20 year horizon.

Heidi Springer, MSA, responded that they looked at saturation development in the Sherwood West area as a means of sizing facilities for the area, but were not anticipating development to occur within the twenty years. She said assumptions were made for the purposes of the Water Master Plan in the Sherwood West area with awareness that a concept plan is in process. She said assumptions help inform adequate sizing, but we are not projecting a saturation development within twenty years in that area.

For clarification, Chair Simson recited that the plan indicated that *if* Sherwood West were to develop completely it needed a certain size pipe and the City will plan for that size of pipe from the beginning so the entire development can occur over the next twenty to fifty years and be sized appropriately from the beginning. She mentioned that the capital improvements do not account for 100% growth in the Sherwood West area, but a smaller percent within the ten to twenty year plan. The Capital Improvement Projects that are listed in the Sherwood West area within the next ten to twenty years are projects that may not occur at all, because development in Sherwood West may not start. She said the information was for City Council to prioritize projects in the Capital Improvements Plan when they go through the budgeting process. Ms. Springer confirmed.

Commissioner Pearson commented about the snow pack and said he was told the City's water was not dependent on Mt. hood runoff, but upon spring rains. So the fact that the snow pack is not high does not impact our water. He commented on a conservation note, that when he washes his hands he washes them over an empty coffee can and uses that water to flush the toilet. Commissioner Pearson added that he read the 2015 Water Master Plan and commended the consultant for making it understandable.

With no other questions from the Commission, chair Simson closed the public testimony portion of the hearing. She asked if there were any further question for staff from the commission. None were received.

With no other discussion, the following motion was received.

Motion: From Vice Chair Russell Griffin to forward a recommendation of approval to the City Council for the Water System Master Plan Update, PA 15-01 code update, based on the applicant's testimony, public testimony received, and the analysis, finding and addition to the Staff Report. Seconded by Commissioner Alan Pearson.

Chair Simson clarified that the addition in the staff report was to the introduction paragraph of the code.

All present Planning Commissioners voted in favor (Commissioners Walker was absent).

7. Planning Commissioner Announcements

Chair Simson announced the Sherwood West Preliminary Concept Plan Community Advisory Committee meeting at 6:30 pm on April 2, 2015 at the Sherwood Police Facility.

Vice Chair Griffins commented that being part of the first community musical at the new cultural arts center was a total blast. He said it is a great facility and he felt it was in good hands. He remarked that it was a pleasure having the show there and literally thousands of people came to see the show.

Commissioner Copfer added that it also helped identify some items that need to be addressed.

8. Adjourn

Chair Simson adjourned the meeting at 8:00 pm.

Submitted by:

Kirsten Allen

Kirsten Allen

Planning Department Program Coordinator

Approval Date: April 14, 2015